

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Low-voltage switchgear and controlgear –
Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination
units**

**Appareillage à basse tension –
Partie 3: Interrupteurs, sectionneurs, interrupteurs-sectionneurs et combinés-
fusibles**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2012 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente. un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Low-voltage switchgear and controlgear –
Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination
units**

**Appareillage à basse tension –
Partie 3: Interrupteurs, sectionneurs, interrupteurs-sectionneurs et combinés-
fusibles**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.120.40; 29.130.20

ISBN 978-2-88912-017-8

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	4
1 General	6
1.1 Scope and object.....	6
1.2 Normative references	7
2 Terms and definitions	8
2.1 General	11
2.2 Alphabetical index of terms	11
2.3 Terms and definitions	12
2.4 Summary of the equipment types	14
3 Classification	14
3.1 According to the utilization category	14
3.2 According to the method of operation of manually operated equipment.....	15
3.3 According to suitability for isolation	15
3.4 According to the degree of protection provided.....	15
4 Characteristics.....	15
4.1 Summary of characteristics.....	15
4.2 Type of equipment.....	15
4.3 Rated and limiting values for the main circuit.....	15
4.4 Utilization category	17
4.5 Control circuits	18
4.6 Auxiliary circuits	18
4.7 Relays and releases	19
4.8 Co-ordination with short circuit protective devices (SCPD).....	19
5 Product information.....	19
5.1 Nature of information.....	19
5.2 Marking.....	19
5.3 Instructions for installation, operation and maintenance.....	20
6 Normal service, mounting and transport conditions.....	20
7 Constructional and performance requirements	20
7.1 Constructional requirements	20
7.2 Performance requirements.....	22
7.3 Electromagnetic compatibility.....	26
8 Tests.....	29
8.1 Kind of tests	29
8.2 Type tests for constructional requirements	30
8.3 Performance.....	34
8.4 Electromagnetic compatibility tests	51
8.5 Special tests.....	52
Annex A (normative) Equipment for direct switching of a single motor.....	53
Annex B (informative) Items subject to agreement between manufacturer and user.....	59
Annex C (normative) Single pole operated three pole switches	60
Bibliography	63

Figure 1 – Actuator applied force F	33
Figure C.1 – Typical arrangements.....	61
Table 1 – Summary of equipment definitions	11
Table 2 – Utilization categories.....	18
Table 3 – Verification of rated making and breaking capacities (see 8.3.3.3) – Conditions for making and breaking corresponding to the various utilization categories.....	24
Table 4 – Verification of operational performance – Number of operating cycles corresponding to the rated operational current.....	25
Table 5 – Test circuit parameters for Table 4.....	25
Table 6 – Immunity tests	27
Table 7 – Emission limits.....	29
Table 8 – Actuator test forces	33
Table 9 – List of type tests applicable to a given equipment	34
Table 10 – Overall scheme of test sequences.....	35
Table 11 – Test sequence I: general performance characteristics	39
Table 12 – Temperature-rise limits for terminals and accessible parts.....	42
Table 13 – Test sequence II: operational performance capability	42
Table 14 – Test sequence III: short-circuit performance capability.....	44
Table 15 – Test sequence IV: conditional short-circuit current.....	49
Table 16 – Test sequence V: overload performance capability	51
Table A.1 – Utilization categories	54
Table A.2 – Rated making and breaking capacity conditions corresponding to several utilization categories	54
Table A.3 – Relationship between current broken I_C and off-time for the verification of the rated making and breaking capacities.....	55
Table A.4 – Operational performance – Conditions for making and breaking corresponding to several utilization categories.....	55
Table A.5 – Verification of the number of on-load operating cycles – Conditions for making and breaking corresponding to several utilization categories.....	58

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

**Part 3: Switches, disconnectors, switch-disconnectors
and fuse-combination units**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of IEC 60947-3 consists of the third edition (2008) [documents 17B/1601/FDIS and 17B/1608/RVD] and its amendment 1 (2012) [documents 17B/1758/FDIS and 17B/1763/RVD]. It bears the edition number 3.1.

The technical content is therefore identical to the base edition and its amendment and has been prepared for user convenience. A vertical line in the margin shows where the base publication has been modified by amendment 1. Additions and deletions are displayed in red, with deletions being struck through.

International Standard IEC 60947-3 has been prepared by subcommittee 17B: Low-voltage switchgear and controlgear, of IEC technical committee 17: Switchgear and controlgear.

The document 17B/1601/FDIS, circulated to the National Committees as amendment 3, led to the publication of the new edition.

This edition includes the following significant technical changes with respect to the previous edition:

- alignment with the fifth edition of IEC 60947-1;
- a switching operation without current allowed between making and breaking operation (Table 3);
- increased number of operations for AC-23 allowed with agreement of the manufacturer (Table 3);
- simplified test procedure amended, f) added to 8.3.2.1.3;
- temperature rise test shall be made at the rated operational current I_e instead of the conventional enclosed thermal current I_{the} (8.3.3.1).

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60947 series can be found, under the general title *Low-voltage switchgear and controlgear*, on the IEC website.

This part is to be used in conjunction with IEC 60947-1. The numbering of the subclauses is sometimes not continuous because it is based on IEC 60947-1.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

The contents of the corrigenda of September 2012 and November 2013 have been included in this copy.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units

1 General

The provisions of the general rules dealt with in IEC 60947-1 are applicable to this part, where specifically called for. Clauses and subclauses, tables, figures and appendices of the general rules thus applicable are identified by reference IEC 60947-1, e.g., 4.3.4.1 of IEC 60947-1, Table 4 of IEC 60947-1, or Annex A of IEC 60947-1.

1.1 Scope and object

This part of IEC 60947 applies to switches, disconnectors, switch-disconnectors and fuse-combination units to be used in distribution circuits and motor circuits of which the rated voltage does not exceed 1 000 V a.c. or 1 500 V d.c.

The manufacturer shall specify the type, ratings and characteristics according to the relevant standard of any incorporated fuses.

This part does not apply to equipment coming within the scope of IEC 60947-2, IEC 60947-4-1 and IEC 60947-5-1; however, when switches and fuse combination units coming into the scope of this part are normally used to start, accelerate and/or stop an individual motor they shall also comply with the additional requirements given in Annex A.

The requirements for single pole operated three pole switches are included in Annex C.

Auxiliary switches fitted to equipment within the scope of this part shall comply with the requirements of IEC 60947-5-1.

This part does not include the additional requirements necessary for electrical apparatus for explosive gas atmospheres.

NOTE 1 Depending on its design, a switch (or disconnector) can be referred to as "a rotary switch (disconnector)", "cam-operated switch (disconnector)", "knife-switch (disconnector)", etc.

NOTE 2 In this part, the word "switch" also applies to the apparatus referred to in French as "commutateurs", intended to modify the connections between several circuits and *inter alia* to substitute a part of a circuit for another.

NOTE 3 In general, throughout this part switches, disconnectors, switch-disconnectors and fuse-combination units will be referred to as "equipment".

The object of this part is to state

- a) the characteristics of the equipment;
- b) the conditions with which the equipment shall comply with reference to
 - 1) operation and behaviour in normal service;
 - 2) operation and behaviour in case of specified abnormal conditions, e.g. short circuit;
 - 3) dielectric properties;

- c) the tests for confirming that these conditions have been met and the methods to be adopted for these tests;
- d) the information to be marked on the equipment or made available by the manufacturer, e.g. in the catalogue.

1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-441:1984, *International Electrotechnical Vocabulary (IEV) – Chapter 441: Switchgear, controlgear and fuses*
Amendment 1 (2000)

IEC 60269 (all parts), *Low-voltage fuses*

IEC 60410:1973, *Sampling plans and procedures for inspection by attributes*

IEC 60417-DB:2000 ¹, *Graphical symbols for use on equipment*

IEC 60947-1:2007, *Low-voltage switchgear and controlgear – Part 1: General rules*
Amendment 1: 2010 ²

IEC 60947-2:2006, *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*

IEC 60947-4-1:2000, *Low-voltage switchgear and controlgear – Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters*
Amendment 1 (2002)
Amendment 2 (2005)

IEC 60947-5-1:2003, *Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

IEC 61000-4-2:1995, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*
Amendment 1 (1998)
Amendment 2 (20E00)

IEC 61000-4-3:2006, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*
Amendment 1 (2007)

IEC 61000-4-4:2004, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5:2005, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-6:2003, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*
Amendment 1 (2004)
Amendment 2 (2006)

¹ "DB" refers to the IEC on-line database.

² A consolidated edition 3.1 exists, including IEC 60947-1: 2007 and its Amendment 1: 2010.

CISPR 11:2003, *Industrial, scientific and medical (ISM) radio-frequency equipment – Electromagnetic disturbance characteristics – Limits and methods of measurement*
Amendment 1 (2004)
Amendment 2 (2006)

CISPR 22:2005, *Information technology equipment – Radio disturbance characteristics – Limits and methods of measurement*
Amendment 1 (2005)
Amendment 2 (2006)

2 Terms and definitions

~~For the purposes of this part of IEC 60947, the terms and definitions given in IEC 60050-441, IEC 60947-1 and the following apply.~~

	Reference
D	
Dependent manual operation (of a mechanical switching device)	2.13
Disconnecter	2.2
Disconnecter-fuse	2.7
F	
Fuse-combination unit	2.4
Fuse-disconnector	2.8
Fuse-switch	2.6
Fuse-switch-disconnector	2.10
I	
Independent manual operation (of a mechanical switching device)	2.14
M	
Multiple tip contact system	2.12
S	
Semi-independent manual operation	2.15
Single pole operated three pole switch	2.11
Stored energy operation (of a mechanical switching device)	2.16
Switch (mechanical)	2.1
Switch-disconnector	2.3
Switch-disconnector-fuse	2.9
Switch-fuse	2.5

~~2.1—~~

~~(mechanical) switch~~

~~mechanical switching device capable of making, carrying and breaking currents under normal circuit conditions which may include specified operating overload conditions and also carrying for a specified time currents under specified abnormal circuit conditions such as those of short-circuit~~

~~NOTE—A switch may be capable of making, but not breaking, short-circuit currents.~~

~~[IEV 441-14-10]~~

~~2.2—~~

~~disconnecter~~

~~mechanical switching device which, in the open position, complies with the requirements specified for the isolating function~~

~~[IEV 441-14-05, modified]~~

NOTE 1—This definition differs from IEC 441-14-05 by referring to isolating function instead of isolating distance.

NOTE 2—A disconnecter is capable of opening and closing a circuit when either a negligible current is broken or made, or when no significant change in the voltage across the terminals of each of the poles of the disconnecter occurs. It is also capable of carrying currents under normal circuit conditions and carrying for a specified time currents under abnormal conditions such as those of short circuit.

~~2.3—~~

~~switch-disconnector~~

~~switch which, in the open position, satisfies the isolating requirements specified for a disconnecter~~

~~[IEV 441-14-12]~~

~~2.4—~~

~~fuse-combination unit~~

~~combination of a mechanical switching device and one or more fuses in a composite unit, assembled by the manufacturer or in accordance with his instructions~~

~~[IEV 441-14-04]~~

NOTE—(Not included in IEC 441-14-04.) This is a general term for fuse switching devices (see also from 2.5 to 2.10 and Table 1).

~~2.5—~~

~~switch-fuse~~

~~switch in which one or more poles have a fuse in series in a composite unit~~

~~[IEV 441-14-14]~~

~~2.6—~~

~~fuse-switch~~

~~switch in which a fuse-link or a fuse-carrier with fuse-link forms the moving contact~~

~~[IEV 441-14-17]~~

~~2.7—~~

~~disconnecter-fuse~~

~~disconnecter in which one or more poles have a fuse in series in a composite unit~~

~~[IEV 441-14-15]~~

~~2.8—~~

~~fuse-disconnector~~

~~disconnecter in which a fuse-link or fuse-carrier with fuse-link forms the moving contact~~

~~[IEV 441-14-18]~~

~~2.9—~~

~~switch-disconnector-fuse~~

~~switch-disconnector in which one or more poles have a fuse in series in a composite unit~~

~~[IEV 441-14-16]~~

~~2.10—~~

~~fuse-switch-disconnector~~

~~switch-disconnector in which a fuse-link or a fuse-carrier with fuse-link forms the moving contact~~

~~[IEV 441-14-19]~~

2.11—

single pole operated three pole switch

device consisting of three individually operable single pole switch disconnecting devices according to this part, rated as a complete unit for use in a three phase system

NOTE These devices are intended for power distribution systems where switching and/or isolation of an individual phase may be necessary and they should not be used for the switching of the primary circuit of three-phase equipment.

2.12—

multiple tip contact system

system that consists of more than one contact gap per pole, which can be switched, in series and/or in parallel

2.13—

dependent manual operation (of a mechanical switching device)

operation solely by means of directly applied manual energy such that the speed and force of the operation are dependent upon the action of the operator

[IEV 441-16-13]

2.14—

independent manual operation (of a mechanical switching device)

stored energy operation where the energy originates from manual power, stored and released in one continuous operation, such that the speed and force of the operation are independent of the action of the operator

[IEV 441-16-16]

2.15—

semi-independent manual operation

operation solely by means of directly applied manual energy such that the manual force is increased up to a threshold value beyond which the independent switching operation is achieved unless deliberately delayed by the operator

2.16—

stored energy operation (of a mechanical switching device)

operation by means of energy stored in the mechanism itself prior to the completion of the operation and sufficient to complete it under predetermined conditions








NOTE This kind of operation may be subdivided according to

- a) the manner of storing the energy (spring, weight, etc.);
- b) the origin of the energy (manual, electric, etc.);
- c) the manner of releasing the energy (manual, electric, etc.).

[IEV 441-16-15]

A summary of equipment definitions is given in Table 1.

Table 1 – Summary of equipment definitions

Functions		
Making and breaking current	Isolating	Making, breaking and isolating
Switch 2.1 	Disconnecter 2.2 	Switch-disconnector 2.3 
Fuse-combination units 2.4		
Switch-fuse 2.5 	Disconnecter-fuse 2.7 	Switch-disconnector-fuse 2.9 
Fuse-switch 2.6 	Fuse-disconnector 2.8 	Fuse-switch-disconnector 2.10 
NOTE 1 – All equipment may be single-break or multi-break. NOTE 2 – Numbers are subclause references of the relevant definitions. NOTE 3 – Symbols are based on IEC 60617-7.		
a – The fuse may be on either side of or in a stationary position between the contacts of the equipment.		

2.1 General

For the purposes of this document, the terms and definitions given in IEC 60050-441, IEC 60947-1 and the following apply.

2.2 Alphabetical index of terms

	Reference
D	
Disconnecter	2.3.1
Disconnecter-fuse	2.3.5
F	
Fuse-combination unit	2.3.2
Fuse-disconnector	2.3.6
Fuse-switch	2.3.4
Fuse-switch-disconnector	2.3.8
S	
Semi-independent manual operation	2.3.10
Single pole operated three pole switch	2.3.9
Switch-disconnector-fuse	2.3.7
Switch-fuse	2.3.3

2.3 Terms and definitions

2.3.1

disconnecter

mechanical switching device which, in the open position, complies with the requirements specified for the isolating function

[IEC 60050-441:1984, 441-14-05, modified]

NOTE 1 This definition differs from IEC 60050-441:1984, 441-14-05 by referring to isolating function instead of isolating distance.

NOTE 2 A disconnector is capable of opening and closing a circuit when either a negligible current is broken or made, or when no significant change in the voltage across the terminals of each of the poles of the disconnector occurs. It is also capable of carrying currents under normal circuit conditions and carrying, for a specified time, currents under abnormal conditions such as those of short circuit.

2.3.2

fuse-combination unit

combination of a mechanical switching device and one or more fuses in a composite unit, assembled by the manufacturer or in accordance with his instructions

[IEC 60050-441:1984, 441-14-04]

2.3.3

switch-fuse

switch in which one or more poles have a fuse in series in a composite unit

[IEC 60050-441:1984, 441-14-14]

2.3.3.1

switch-fuse single break

switch-fuse which opens the circuit on one side of the fuse-link only

2.3.3.2

switch-fuse double break

switch-fuse which opens the circuit on both sides of the fuse-link

2.3.4

fuse-switch

switch in which a fuse-link or fuse-carrier with fuse-link forms the moving contact

[IEC 60050-441:1984, 441-14-17]

2.3.4.1

fuse-switch single break

fuse-switch which opens the circuit on one side of the fuse link only

2.3.4.2

fuse-switch double break

fuse-switch which opens the circuit on both sides of the fuse link

2.3.5

disconnecter-fuse

disconnecter in which one or more poles have a fuse in series in a composite unit

[IEC 60050-441:1984, 441-14-15]

2.3.5.1**disconnecter-fuse single break**

disconnecter-fuse which opens the circuit on one side of the fuse-link only

2.3.5.2**disconnecter-fuse double break**

disconnecter-fuse which opens the circuit on both sides of the fuse-link

2.3.6**fuse-disconnector**

disconnecter in which a fuse-link or fuse-carrier with fuse-link forms the moving contact

[IEC 60050-441:1984, 441-14-18]

2.3.6.1**fuse-disconnector single break**

fuse-disconnector which opens the circuit on one side of the fuse link only

2.3.6.2**fuse-disconnector double break**

fuse-disconnector which opens the circuit on both sides of the fuse link

2.3.7**switch-disconnector-fuse**

switch-disconnector in which one or more poles have a fuse in series in a composite unit

[IEC 60050-441:1984, 441-14-16]

2.3.7.1**switch-disconnector-fuse single break**

switch-disconnector-fuse which opens the circuit on one side of the fuse-link only

2.3.7.2**switch-disconnector-fuse double break**

switch-disconnector-fuse which opens the circuit on both sides of the fuse-link

2.3.8**fuse-switch-disconnector**

switch-disconnector in which a fuse-link or fuse-carrier with fuse-link forms the moving contact

[IEC 60050-441:1984, 441-14-19]

2.3.8.1**fuse-switch-disconnector single break**

fuse-switch-disconnector which opens the circuit on one side of the fuse link only

2.3.8.2**fuse-switch-disconnector double break**

fuse-switch-disconnector which opens the circuit on both sides of the fuse link

2.3.9**single pole operated three pole switch**

device consisting of three individually operable single pole switch disconnecting devices according to this part, rated as a complete unit for use in a three-phase system

NOTE These devices are intended for power distribution systems where switching and/or isolation of an individual phase may be necessary and they should not be used for the switching of the primary circuit of three-phase equipment.

2.3.10













semi-independent manual operation

operation solely by means of directly applied manual energy such that the manual force is increased up to a threshold value beyond which the independent switching operation is achieved unless deliberately delayed by the operator

2.4 Summary of the equipment types

A summary of equipment definitions and relevant diagrams is given in Table 1.

Table 1 – Summary of equipment definitions

Functions		
Making and breaking current	Isolating	Making, breaking and isolating
Switch 	Disconnecter 	Switch-disconnector 
Fuse-combination units		
Switch-fuse single break 	Disconnecter-fuse single break ^b 	Switch-disconnector-fuse single break ^b 
Switch-fuse double break 	Disconnecter-fuse double break ^b 	Switch-disconnector-fuse double break ^b 
Fuse-switch single break 	Fuse-disconnector single break ^b 	Fuse-switch-disconnector single break ^b 
Fuse-switch double break 	Fuse-disconnector double break ^b 	Fuse-switch-disconnector double break ^b 
NOTE 1 Equipment shown as single break may be double break.		
NOTE 2 Symbols are based on IEC 60617-7.		
^a The fuse may be on either side of the contacts of the equipment or in a stationary position between these contacts. ^b Disconnection between line and load terminals only is verified by test.		

3 Classification

3.1 According to the utilization category

See 4.4.

3.2 According to the method of operation of manually operated equipment

- dependent manual operation (see ~~2.13~~ 2.4.12 of IEC 60947-1);
- independent manual operation (see ~~2.14~~ 2.4.15 of IEC 60947-1);
- semi-independent manual operation (see ~~2.15~~ 2.3.10).

NOTE The method of operation on closing may be different from the method for opening.

3.3 According to suitability for isolation

- suitable for isolation (see 7.1.7 of IEC 60947-1 and 7.1.7.1);
- not suitable for isolation.

3.4 According to the degree of protection provided

See 7.1.12 of IEC 60947-1.

4 Characteristics

4.1 Summary of characteristics

The characteristics of the equipment shall be stated in terms of the following as applicable:

- type of equipment (see 4.2);
- rated and limiting values for the main circuit (see 4.3);
- utilization category (see 4.4);
- control circuits (see 4.5);
- auxiliary circuits (see 4.6);

4.2 Type of equipment

The following information shall be stated.

- number of poles;
- kind of current (a.c. or d.c.);
- in the case of a.c., number of phases and rated frequency;
- number of positions of the main contacts (if more than two);
- breaking arrangement for fused devices (single break or double break).

~~4.2.1 Number of poles~~

~~4.2.2 Kind of current~~

~~Kind of current (a.c. or d.c.) and, in the case of a.c., number of phases and rated frequency.~~

~~4.2.3 Number of positions of the main contacts (if more than two)~~

4.3 Rated and limiting values for the main circuit

Rated values are assigned by the manufacturer. They shall be stated in accordance with 4.3.1 to 4.3.6.4 but it may not be necessary to establish all the rated values listed.

4.3.1 Rated voltages

An equipment is defined by the following rated voltages.

4.3.1.1 Rated operational voltage (U_e)

Subclause 4.3.1.1 of IEC 60947-1 applies.

4.3.1.2 Rated insulation voltage (U_i)

Subclause 4.3.1.2 of IEC 60947-1 applies.

4.3.1.3 Rated impulse withstand voltage (U_{imp})

Subclause 4.3.1.3 of IEC 60947-1 applies.

4.3.2 Currents

An equipment is defined by the following currents.

4.3.2.1 Conventional free air thermal current (I_{th})

Subclause 4.3.2.1 of IEC 60947-1 applies.

4.3.2.2 Conventional enclosed thermal current (I_{the})

Subclause 4.3.2.2 of IEC 60947-1 applies.

4.3.2.3 Rated operational currents (I_e) (or rated operational powers)

Subclause 4.3.2.3 of IEC 60947-1 applies.

4.3.2.4 Rated uninterrupted current (I_u)

Subclause 4.3.2.4 of IEC 60947-1 applies.

4.3.3 Rated frequency

Subclause 4.3.3 of IEC 60947-1 applies.

4.3.4 Rated duty

The rated duties considered as normal are as follows.

4.3.4.1 Eight-hour duty

Subclause 4.3.4.1 of IEC 60947-1 applies.

4.3.4.2 Uninterrupted duty

Subclause 4.3.4.2 of IEC 60947-1 applies.

4.3.5 Normal load and overload characteristics

4.3.5.1 Ability to withstand motor switching overload currents

See Annex A.

4.3.5.2 Rated making capacity

Subclause 4.3.5.2 of IEC 60947-1 applies with the following additions.

The rated making capacity is stated by reference to the rated operational voltage and rated operational current and to the utilization category according to Table 3.

Not applicable to AC-20 or DC-20 equipment.

4.3.5.3 Rated breaking capacity

Subclause 4.3.5.3 of IEC 60947-1 applies with the following additions.

The rated breaking capacity is stated by reference to the rated operational voltage and rated operational current and to the utilization category according to Table 3.

Not applicable to AC-20 or DC-20 equipment.

4.3.6 Short-circuit characteristics

4.3.6.1 Rated short-time withstand current (I_{cw})

The rated short-time withstand current of a switch, a disconnector or a switch-disconnector is the value of short-time withstand current, assigned by the manufacturer, that the equipment can carry without any damage under the test conditions of 8.3.5.1.

The value of the rated short-time withstand current shall be not less than twelve times the maximum rated operational current and, unless otherwise stated by the manufacturer, the duration of the current shall be 1 s.

For a.c., the value of the current is the r.m.s. value of the a.c. component and it is assumed that the highest peak value likely to occur does not exceed n times this r.m.s. value, the factor n being given by Table 16 of IEC 60947-1.

4.3.6.2 Rated short-circuit making capacity (I_{cm})

~~The rated short-circuit making capacity of a switch or a switch-disconnector is the value of short-circuit making capacity assigned to the equipment by the manufacturer for the rated operational voltage, at rated frequency (if any) and at a specified power factor (or time-constant). It is expressed as the maximum prospective peak current.~~

~~For a.c., the relationship between power factor, prospective peak current and r.m.s. current shall be in accordance with Table 16 of IEC 60947-1.~~

~~Not applicable to AC-20 or DC-20 equipment.~~

Subclause 4.3.6.2 of IEC 60947-1 applies with the following addition.

NOTE I_{cm} is not applicable to fused devices.

4.3.6.3 Vacant

4.3.6.4 Rated conditional short-circuit current

Subclause 4.3.6.4 of IEC 60947-1 applies.

4.4 Utilization category

The utilization categories define the intended applications and are given in Table 2.

Each utilization category is characterized by the values of the currents and voltages, expressed as multiples of the rated operational current and the rated operational voltage, as well as the

power-factors or time-constants of the circuit. The conditions for making and breaking given in Table 3 correspond in principle to the applications listed in Table 2.

The designation of utilization categories is completed by the suffix A or B according to whether the intended applications require frequent or infrequent operations (see Table 4).

Utilization categories with suffix B are appropriate for devices which, due to design or application, are only intended for infrequent operation. This could apply, for example, to disconnectors normally only operated to provide isolation for maintenance work or switching devices where the fuse-link blade forms the moving contact.

The distinction between frequent and infrequent operation is based on the manufacturer's rated operation and the number of operating cycles used as a test criterion in Table 4.

For a particular rated operational current I_e , a device will be designated for frequent use (category A) if the manufacturer's rated operating life is more than the number of operating cycles indicated in columns 3, 4 or 5 of Table 4.

Table 2 – Utilization categories

Nature of current	Utilization categories		Typical applications
	Category A	Category B	
Alternating current	AC-20A ^a	AC-20B ^a	– Connecting and disconnecting under no-load conditions
	AC-21A	AC-21B	– Switching of resistive loads including moderate overloads
	AC-22A	AC-22B	– Switching of mixed resistive and inductive loads, including moderate overloads
	AC-23A	AC-23B	– Switching of motor loads or other highly inductive loads
Direct current	DC-20A ^a	DC-20B ^a	– Connecting and disconnecting under no-load conditions
	DC-21A	DC-21B	– Switching of resistive loads including moderate overloads
	DC-22A	DC-22B	– Switching of mixed resistive and inductive loads, including moderate overloads (e.g. shunt motors)
	DC-23A	DC-23B	– Switching of highly inductive loads (e.g. series motors)
^a The use of these utilization categories is not permitted in the USA.			

Category AC-23 includes occasional switching of individual motors. The switching of capacitors or of tungsten filament lamps shall be subject to agreement between manufacturer and user.

The utilization categories referred to in Tables 2 and 3 do not apply to an equipment normally used to start, accelerate and/or stop individual motors. The utilization categories for such an equipment are dealt with in Annex A.

4.5 Control circuits

Subclause 4.5 of IEC 60947-1 applies.

4.6 Auxiliary circuits

Subclause 4.6 of IEC 60947-1 applies.

4.7 Relays and releases

Subclause 4.7 of IEC 60947-1 applies.

4.8 Co-ordination with short circuit protective devices (SCPD)

Subclause 4.8 of IEC 60947-1 applies.

5 Product information

5.1 Nature of information

Subclause 5.1 of IEC 60947-1 applies as appropriate for a particular design.

5.2 Marking

5.2.1 Each equipment shall be marked in a durable and legible manner with the following data.

The markings for a), b) and c) below shall be on the equipment itself or on a name-plate or name-plates attached to the equipment, and shall be located at a place such that they are legible from the front after mounting the equipment in accordance with the manufacturer's instructions.

- a) Indication of the open and closed position. The open and closed position shall be respectively indicated by the graphical symbols 60417-IEC-5007 and 60417-IEC-5008 of IEC 60417-2 (see 7.1.6.1 of IEC 60947-1).
- b) Suitability for isolation.
The appropriate symbols of Table 1 shall be used.
- c) Additional marking for disconnectors.

Devices of utilization category AC-20A, AC-20B, DC-20A and DC-20B shall be marked "Do not operate under load", unless the device is interlocked to prevent such operation.

NOTE Symbols of the various types of equipment are given in Table 1.

5.2.2 The following data shall also be marked on the equipment but need not be visible from the front when the equipment is mounted:

- a) manufacturer's name or trade mark;
- b) type designation or serial number;
- c) rated operational currents (or rated powers) at the rated operational voltage and utilization category (see 4.3.1, 4.3.2 and 4.4);
- d) value (or range) of the rated frequency or the indication "d.c." (or the symbol — — —);
- e) for fuse-combination units, the fuse type and maximum rated current and the power loss of the fuse-link;
- f) IEC 60947-3, if the manufacturer claims compliance with this part;
- g) degree of protection of enclosed equipment (see Annex C of IEC 60947-1).

5.2.3 The following terminals shall be identified:

- a) line and load terminals unless the connection is immaterial (see 8.3.3.3.1);
- b) neutral pole terminal, if applicable, by the letter "N" (see 7.1.8.4 of IEC 60947-1);
- c) protective earth terminal (see 7.1.10.3 of IEC 60947-1).

5.2.4 The following data shall be made available in the manufacturer's published information:

- a) rated insulation voltage;
- b) rated impulse withstand voltage for equipment suitable for isolation or when determined;
- c) pollution degree, if different from 3;
- d) rated duty;
- e) rated short-time withstand current and duration, where applicable;
- f) rated short-circuit making capacity, where applicable;
- g) rated conditional short-circuit current, where applicable.

5.3 Instructions for installation, operation and maintenance

Subclause 5.3 of IEC 60947-1 applies.

6 Normal service, mounting and transport conditions

Clause 6 of IEC 60947-1 applies with the following addition.

Pollution degree (see 6.1.3.2 of IEC 60947-1).

Unless otherwise stated by the manufacturer, the equipment is intended for installation under environmental conditions of pollution degree 3.

7 Constructional and performance requirements

7.1 Constructional requirements

Subclause 7.1 of IEC 60947-1 applies, with the following additions.

7.1.2 Materials

~~The suitability of materials used shall be verified with respect to resistance to abnormal heat and fire by conducting tests~~

- ~~a) on the equipment; or~~
- ~~b) on sections taken from the equipment; or~~
- ~~c) on samples of identical material having a representative cross-section.~~

~~If an identical material having a representative cross-section has already satisfied the requirements, then those tests need not be repeated.~~

(Void)

7.1.2.2 Glow wire testing

Subclause 7.1.2.2 of IEC 60947-1 applies with the following additions.

Parts of insulating material necessary to retain current-carrying parts in position shall conform to the glow-wire tests of 8.2.1.1.1 of IEC 60947-1 at a test temperature of 960 °C.

7.1.4 Clearances and creepage distances

~~Subclause 7.1.4 of IEC 60947-1 applies with the following addition.~~

~~Guidance on the measurement of clearances and creepage distances is given in Annex G of IEC 60947-1.~~

(Void)

7.1.7 Additional requirements for equipment suitable for isolation

Subclause 7.1.7 of IEC 60947-1 applies with the following additions.

7.1.7.1 Additional constructional requirements

The equipment shall be marked according to 5.2.1 b).

When no indication of the position of the contacts is provided, for example by the actuator or a separate indicator, all the main contacts shall be clearly visible in the open position.

The strength of the actuating mechanism and the reliability of the indication of the open position shall be checked according to 8.2.5. Moreover, when means are provided by the manufacturer to lock the equipment in the open position, locking shall only be possible when the main contacts are in the open position (see 8.2.5).

This requirement does not apply to equipment where the main contact position is visible in the open position and/or the open position is indicated by other means than the actuator.

NOTE Locking in the closed position is permitted for particular applications.

The clearance across the open contacts of the same pole when in the open position shall not be less than the minimum clearance given in Table 13 of IEC 60947-1 and shall also comply with the requirements of 7.2.3.1 b) of IEC 60947-1.

7.1.7.2 Supplementary requirements for equipment with provision for electrical interlocking with contactors or circuit-breakers

~~If an equipment suitable for isolation is provided with an auxiliary switch for the purpose of electrical interlocking with contactor(s) or circuit-breaker(s) and intended to be used in motor circuits, the following requirements shall apply unless the equipment is rated for AC 23 utilization category.~~

~~An auxiliary switch shall be rated according to IEC 60947-5-1 as stated by the manufacturer.~~

~~The time interval between the opening of the contacts of the auxiliary switch and the contacts of the main poles shall be sufficient to ensure that the associated contactor or circuit-breaker interrupts the current before the main poles of the equipment open.~~

~~Unless otherwise stated in the manufacturer's technical literature, the time interval shall be not less than 20 ms when the equipment is operated according to the manufacturer's instructions.~~

~~Compliance shall be verified by measuring the time interval between the instant of opening of the auxiliary switch and the instant of opening of the main poles under no-load conditions when the equipment is operated according to the manufacturer's instructions.~~

~~During the closing operation, the contacts of the auxiliary switch shall close after or simultaneously with the contacts of the main poles.~~

~~A suitable opening time interval may also be provided by an intermediate position (between the ON and OFF positions) at which the interlocking contact(s) is (are) open and the main poles remain closed.~~

(Void)

7.1.7.3 Supplementary requirements for equipment provided with means for padlocking the open position

~~The locking means shall be designed in such a way that it cannot be removed with the appropriate padlock(s) installed. When the equipment is locked by even a single padlock, it shall not be possible by operating the actuator, to reduce the clearance between open contacts to the extent that it no longer complies with the requirements of 7.2.3.1 b) of IEC 60947-1.~~

~~Alternatively, the design may provide padlockable means to prevent access to the actuator.~~

~~Compliance with the requirements to padlock the actuator shall be verified using a padlock specified by the manufacturer or an equivalent gauge, giving the most adverse conditions, to simulate locking. The force F , specified in 8.2.5.2 shall be applied to the actuator in an attempt to operate the equipment from the open position to the closed position. Whilst the force F is applied, the equipment shall be subjected to a test voltage across open contacts. The equipment shall be capable of withstanding the test voltage required according to Table 14 of IEC 60947-1 appropriate to the rated impulse withstand voltage.~~

(Void)

7.1.9 Additional requirements for equipment provided with a neutral pole

Subclause 7.1.9 of IEC 60947-1 applies except for the note referring to an over-current release.

7.1.12 Degrees of protection of enclosed equipment

~~Degrees of protection of enclosed equipment and relevant tests are given in Annex C of IEC 60947-1.~~

(Void)

7.2 Performance requirements

7.2.1 Operating conditions

7.2.1.1 General

Subclause 7.2.1.1 of IEC 60947-1 applies with the following additions.

The following requirements apply to fuse-switches, fuse-disconnectors and fuse-switch-disconnectors with a rated short-circuit making capacity exceeding 10 kA and for which the closing operation is by direct manual operation without an interposing mechanism (dependent and semi-independent manual operation see 2.13 and 2.15 2.4.12 of IEC 60947-1 and 2.3.10).

The test speed for the making operations specified in 8.3.6.2 shall be determined as follows.

- a) The equipment shall be operated 15 times manually under no-load conditions in accordance with the manufacturer's instructions, 5 times by each of three persons. The velocity of the hand actuator at the instant of contact closure of the last closing contact shall be determined by oscillographic or other appropriate means at any convenient part of the device.

The point at which the measurement is made and the velocity at the measurement point shall be stated in the test report. The mean velocity shall be determined after deleting the highest and lowest values.

- b) The test apparatus shall ensure that the equipment under test fully closes and that there is no impediment to the free closing movement of the device. The actual test speed shall not exceed the mean velocity determined according to a).

The mass of the moving parts of the test apparatus (without the equipment under test) shall be $2 \text{ kg} \pm 10 \%$.

7.2.1.2 Limits of operation of power operated equipment

Subclause 7.2.1.2 of IEC 60947-1 applies.

7.2.1.3 Limits of operation of under-voltage relays and releases.

Subclause 7.2.1.3 of IEC 60947-1 applies.

7.2.1.4 Limits of operation of shunt releases

Subclause 7.2.1.4 of IEC 60947-1 applies.

7.2.2 Temperature rise

Subclause 7.2.2 of IEC 60947-1 applies with the following addition.

For fuse-combination units, the temperature rise of the fuse-link contacts during the test according to 8.3.3.1 shall not cause any damage of a nature which impairs the subsequent performance of the equipment in test sequence I.

7.2.3 Dielectric properties

Subclause 7.2.3 of IEC 60947-1 applies with the following additions.

7.2.3.1 Impulse withstand voltage

Subclause 7.2.3.1 of IEC 60947-1 applies with the following addition.

Clearances across the open contacts of a device not suitable for isolation shall withstand the test voltage given in Table 12 of IEC 60947-1 appropriate to the rated impulse withstand voltage.

7.2.3.2 Power-frequency withstand voltage of the main, auxiliary and control circuits

Subclause 7.2.3.2 c) of IEC 60947-1 applies with the following addition.

For equipment suitable for isolation, maximum values of leakage current are specified for all the test sequences in 8.3.3.5, 8.3.4.3, 8.3.5.4, 8.3.6.4 and 8.3.7.3 respectively.

7.2.4 Ability to make and break under no-load, normal load and overload conditions

7.2.4.1 Making and breaking capacities

The rated making and breaking capacities are stated by reference to the rated operational voltage and rated operational current and to the utilization category according to Table 3.

The test conditions are specified in 8.3.3.3.1.

**Table 3 – Verification of rated making and breaking capacities (see 8.3.3.3) –
Conditions for making and breaking corresponding to the various utilization categories**

Utilization categories	Rated operational current	Making ^a			Breaking			Number of operating cycles ^c
		I/I_e	U/U_e	$\cos \phi$	I_c/I_e	U_r/U_e	$\cos \phi$	
AC-20A ^b – AC-20B ^b	All values	–	–	–	–	–	–	5 5 5 3 ^d
AC-21A – AC-21B	All values	1,5	1,05	0,95	1,5	1,05	0,95	
AC-22A – AC-22B	All values	3	1,05	0,65	3	1,05	0,65	
AC-23A – AC-23B	$0 < I_e \leq 100 \text{ A}$	10	1,05	0,45	8	1,05	0,45	
	$100 \text{ A} < I_e$	10	1,05	0,35	8	1,05	0,35	
Utilization categories	Rated operational categories	I/I_e	U/U_e	L/R ms	I_c/I_e	U_r/U_e	L/R ms	Number of operating cycles
DC-20A ^b – DC-20B ^b	All values	–	–	–	–	–	–	5 5 5 5
DC-21A – DC-21B	All values	1,5	1,05	1	1,5	1,05	1	
DC-22A – DC-22B	All values	4	1,05	2,5	4	1,05	2,5	
DC-23A – DC-23B	All values	4	1,05	15	4	1,05	15	
I = making current I_c = breaking current I_e = rated operational current U = applied voltage U_e = rated operational voltage U_r = operational frequency or d.c. recovery voltage								
^a For a.c. the making current is expressed by the r.m.s. value of the periodic component of the current. ^b The use of these utilization categories is not permitted in the USA. ^c One switching operation without current between each making and breaking operation is allowed, providing it does not alter the time interval between the prescribed operations as defined in 8.3.3.3.1. ^d In order to cover both AC-21 and AC-22 categories, an increase in the number of operations for AC-23 from 3 to 5 is allowed with the agreement of the manufacturer.								

7.2.4.2 Operational performance

Tests concerning the verification of the operational performance of an equipment are intended to verify that the equipment is capable of making and breaking without failure the currents flowing in its main circuit for the intended use.

The number of operating cycles and the test circuit parameters for the operational performance test for the various utilization categories are given in Tables 4 and 5.

The test conditions are specified in 8.3.4.1.

**Table 4 – Verification of operational performance –
Number of operating cycles corresponding to the rated operational current**

1	2	3	4	5	6	7	8
Rated operational current I_e	Number of operating cycles per hour	Number of operating cycles					
		AC and DC A categories			AC and DC B categories		
		Without current	With current	Total	Without current	With current	Total
$0 < I_e \leq 100$	120	8 500	1 500	10 000	1 700	300	2 000
$100 < I_e \leq 315$	120	7 000	1 000	8 000	1 400	200	1 600
$315 < I_e \leq 630$	60	4 000	1 000	5 000	800	200	1 000
$630 < I_e \leq 2 500$	20	2 500	500	3 000	500	100	600
$2 500 < I_e$	10	1 500	500	2 000	300	100	400
The values in the table apply to all utilization categories except AC-20A, AC-20B, DC-20A and DC-20B. These categories shall comply with the total number of operating cycles in columns 5 or 8 without current. Column 2 gives the minimum operating rate. The operating rate for any utilization category may be increased with the consent of the manufacturer.							

Table 5 – Test circuit parameters for Table 4

Utilization categories	Values of the rated operational current I_e	Making ^a			Breaking		
		I/I_e	U/U_e	$\cos \phi$	I_c/I_e	U_r/U_e	$\cos \phi$
AC-21A AC-21B	All values	1	1	0,95	1	1	0,95
AC-22A AC-22B	All values	1	1	0,8	1	1	0,8
AC-23A AC-23B	All values	1	1	0,65	1	1	0,65
		I/I_e	U/U_e	L/R ms	I_c/I_e	U_r/U_e	L/R ms
DC-21A DC-21B	All values	1	1	1	1	1	1
DC-22A DC-22B	All values	1	1	2	1	1	2
DC-23A DC-23B	All values	1	1	7,5	1	1	7,5
I = making current I_c = breaking current I_e = rated operational current U = voltage before make (applied voltage) U_e = rated operational voltage U_r = operational frequency or d.c. recovery voltage							
^a For a.c., the making current is expressed by the r.m.s. value of the periodic component of the current.							

7.2.4.3 Mechanical durability

Subclause 7.2.4.3.1 of IEC 60947-1 applies. Test conditions are specified in 8.5.1.

7.2.4.4 Electrical durability

Subclause 7.2.4.3.2 of IEC 60947-1 applies. Test conditions are specified in 8.5.2.

7.2.5 Ability to make, break or withstand short-circuit currents

The equipment shall be so constructed as to be capable of withstanding, under the conditions specified in this part, the thermal, dynamic and electrical stresses resulting from short-circuit currents.

Short-circuit currents may be encountered during current making, current carrying in the closed position and current interruption.

The ability of the equipment to make, carry and break short-circuit currents is stated in terms of one or more of the following ratings.

- a) Rated short-time withstand current (see 4.3.6.1).
- b) Rated short-circuit making capacity (see 4.3.6.2).
- c) Rated conditional short-circuit current (see 4.3.6.4).

7.2.6 Vacant

7.2.7 Additional performance requirements for equipment suitable for isolation

These requirements only apply to equipment with rated operational voltage greater than 50 V.

With the equipment in new condition and the contacts in the open position the equipment shall withstand the dielectric test of 8.3.3.2.

If tests according to 8.3.3.3 and 8.3.4.1 have been made, the equipment in the condition after the tests shall meet the leakage current requirements of 8.3.3.5.

7.2.8 Vacant

7.2.9 Overload requirements for equipment incorporating fuses

The main circuit of an equipment shall be capable of carrying an overload current according to 8.3.7.1 and shall not cause any damage of a nature which impairs the subsequent performance of the equipment in test sequence V.

7.3 Electromagnetic compatibility

7.3.1 Vacant

7.3.2 Immunity

~~7.3.2.1 Equipment not incorporating electronic circuits~~

~~Equipment within the scope of this part standard not incorporating electronic circuits are not sensitive to electromagnetic disturbances in normal service conditions and therefore no immunity tests are required.~~

~~7.3.2.2 Equipment incorporating electronic circuits~~

~~Equipment incorporating electronic circuits (e.g. an electronic fuse-blowing indicator) shall have a satisfactory immunity to electromagnetic disturbances (see 8.4.1.2).~~

Table 6 — Immunity tests

Types of immunity test	Applicable basic standards	Severity levels required
Electrostatic discharge	IEC 61000-4-2	Air discharge 8 kV or contact discharge 4 kV
Electromagnetic field	IEC 61000-4-3	10 V/m
Fast transient/burst	IEC 61000-4-4	2 kV
Surge	IEC 61000-4-5	2 kV (common mode) 1 kV (differential mode)
Conducted disturbances induced by RF fields	IEC 61000-4-6	10 V
NOTE — A simple rectifier is not sensitive to electromagnetic disturbances in normal service conditions and does not therefore require immunity tests.		

Subclause 7.3.2 of IEC 60947-1 applies with the following change and addition.

7.3.2.1 Equipment not incorporating electronic circuits

Subclause 7.3.2.1 of IEC 60947-1 applies.

7.3.2.2 Equipment incorporating electronic circuits

Equipment incorporating electronic circuits (for example fuse-blowing indicator) shall have satisfactory immunity to electromagnetic disturbances (see 8.4.1.2).

For the appropriate tests to verify the compliance with these requirements, see 8.4 of IEC 60947-1.

Specific performance criteria shall be given in the relevant product standard based on the acceptance criteria given in Table 24 of IEC 60947-1.

Table 6 provides the specific immunity performance criteria to be considered.

Table 6 – Immunity tests

Types of test	Test level required	Acceptance criteria (as defined in Table 24 of IEC 60947-1)
Electrostatic discharge immunity test IEC 61000-4-2	8 kV / air discharge or 4 kV / contact discharge	B
Radiated radio-frequency electromagnetic field immunity test IEC 61000-4-3	10 V/m	A
Electrical fast transient/burst immunity test IEC 61000-4-4	2 kV / 5 kHz on power ports 1 kV / 5 kHz on signal ports	B
Surge immunity test IEC 61000-4-5	2 kV (common mode) 1 kV (differential mode)	B
Conducted disturbances induced by radio- frequency fields immunity test IEC 61000-4-6	10 V	A
NOTE 1 A simple rectifier is not sensitive to electromagnetic disturbances in normal service conditions and does not therefore require immunity tests.		
NOTE 2 Where an acceptance criteria B is specified there shall be no change of the status of the main contacts as a result of the disturbance.		

7.3.3 Emission

7.3.3.1 Equipment not incorporating electronic circuits

~~For equipment not incorporating electronic circuits, electromagnetic disturbances can only be generated during occasional switching operations. The duration of disturbances is in the order of milliseconds.~~

~~The frequency, level and consequences of these emissions are considered as a part of the normal electromagnetic environment of low voltage installations.~~

~~As a result, the requirements for electromagnetic emissions are deemed to be satisfied and no verification is necessary.~~

Subclause 7.3.3.1 of IEC 60947-1 applies.

7.3.3.2 Equipment incorporating electronic circuits

Equipment incorporating electronic circuits (e.g. an electronic fuse-blowing indicator) may generate continuous electromagnetic disturbances.

Emission shall fulfil the requirements of class A, group 1 of CISPR 11 or those of class A of CISPR 22 (see 8.4.2.2).

Table 7 – Emission limits

Ports	Frequency ranges MHz	Limits ^d	Standards
Enclosure ^b	30 to 230 ^a	30 dB (μV/m) quasi peak measured at 30 m distance ^c	CISPR 11
	230 to 1 000 ^a	37 dB (μV/m) quasi peak measured at 30 m distance ^c	Class A - Group 1
AC power	0,15 to 0,5 ^a	79 dB (μV) quasi peak 66 dB (μV) average	or
	0,5 to 5 ^a	73 dB (μV) quasi peak 60 dB (μV) average	CISPR 22
	5 to 30 ^a	73 dB (μV) quasi peak 60 dB (μV) average	Class A
^a The lower limit should apply at the transition frequency. ^b Applicable only to mechanical switching devices containing parts which operate at frequencies higher than 9 kHz, e.g. microprocessors. ^c May also be measured at a 10 m distance using the limits increased by 10 dB, or at a 3 m distance using the limits increased by 20 dB. ^d These limits have been copied, without alteration, from CISPR 11 and CISPR 22.			

These limits are given for mechanical switching devices which are used exclusively in an industrial environment. When there exists a likelihood of use outside the industrial environment, the following notice shall be included in the manufacturer's published information.

Caution

This is a class A product. In a domestic environment, this product may cause radio interference in which case the user may be required to take adequate measures.

However, this notice is not necessary when the emission limits given in CISPR 22, class B are fulfilled.

8 Tests

8.1 Kind of tests

8.1.1 General

Subclause 8.1.1 of IEC 60947-1 applies.

8.1.2 Type tests

Subclause 8.1.2 of IEC 60947-1 applies. Type tests are given in Table 9 of this part.

8.1.3 Routine tests

Subclause 8.1.3 of IEC 60947-1 applies with the following additions.

8.1.3.1 General

The following tests apply:

- mechanical operation test (see 8.1.3.2)
operation of the switch, disconnector, switch-disconnector or fuse-combination unit during manufacture and/or other routine test may take the place of the tests listed above, provided the same conditions apply and the number of operations is not less than that specified;
- dielectric test (see 8.1.3.3)
if, by the control of materials and manufacturing processes, the integrity of the dielectric properties has been proven, these tests may be replaced by sampling tests according to a recognized sampling plan (see IEC 60410).

8.1.3.2 Mechanical operation test

A test shall be made to verify the correct mechanical operation of the equipment by 5 closing and opening operations.

8.1.3.3 Dielectric test

The test conditions shall be in accordance with 8.3.3.4.2 of IEC 60947-1. As an alternative, the combined test according to 8.3.3.4.2, item 3), of IEC 60947-1 is allowed. The value of the test voltage shall be in accordance with that given in Table 12A of IEC 60947-1. The duration of the test shall not be less than 1 s and the test voltage shall be applied as follows:

- with the equipment in the open position, between each pair of terminals which are electrically connected together when the equipment is closed;
- with the equipment in the closed position, between each pole and the adjacent pole(s) and between each pole and the frame;
- for equipment incorporating electronic circuits connected to the main poles, with the equipment in the open position, between each pole and the adjacent pole(s) and between each pole and the frame, either on the incoming side or the outgoing side depending on the position of the electronic components.

Alternatively, disconnection of the electronic circuit(s) is permitted during dielectric tests.

8.1.4 Sampling tests

Sampling tests for verification of clearances shall be made according to 8.3.3.4.3 of IEC 60947-1 in accordance with a recognized sampling plan (see IEC 60410).

8.1.5 Special tests

Special tests (see 2.6.4 of IEC 60947-1) are specified in 8.5.

8.2 Type tests for constructional requirements

Subclause 8.2 of IEC 60947-1 applies with the following additions.

8.2.4 Mechanical properties of terminals

Subclause 8.2.4 of IEC 60947-1 applies with the following addition.

Where equipment is designed to be provided with different designs of terminals, the tests shall be conducted on every design.

8.2.5 Verification of the effectiveness of indication of the main contacts position of equipment suitable for isolation

Subclause 8.2.5 of IEC 60947-1 applies with the following additions.

8.2.5.1 Condition of equipment for tests

The test of the actuator mechanism and position indicating device shall be conducted as part of test sequence I (see 8.3.3 and Table 11).

If different types of actuators exist, either additional or integral, only one design shall be tested during sequence I. Moreover, the sample representative of the more critical case shall be tested according to 8.3.3.7.

8.2.5.2 Method of test

~~8.2.5.2.1 Dependent and independent manual operation~~

~~The force necessary to operate the device to the open position shall be measured at the extremity of the actuator. The measured force F shall be equal to the average value of maximum force obtained from 3 consecutive operations, with the device in a clean and new condition. This force F shall then be used for the establishment of the test force in Table 8.~~

~~With the equipment in the closed position, fixed and moving contacts of the pole for which the test is deemed to be the most severe shall be kept closed by appropriate means. The actuator shall be submitted to the test force as defined in Table 8 according to its type. Where the device has more than one contact system in series, each contact system shall be held in the closed position.~~

~~In the case of multiple tip contact systems, the least number of parallel contact tips shall be fixed together as necessary to hold the contact system closed in order to allow the test force to be applied without the contacts separating.~~

~~The appropriate means to keep the contact(s) closed and the number of contacts shall be specified by the manufacturer. The number of contacts and the method shall be stated in the report.~~

~~This force shall be applied without shock to the actuator in a direction to open the contacts for a period of 10 s.~~

~~The direction of the force, as shown in Figure 1, shall be maintained throughout the test.~~

~~If locking means are provided to lock the actuator in the open position it shall not be possible to lock the actuator in this position while the test force is applied.~~

~~8.2.5.2.2 Dependent power operation~~

~~With the equipment in the closed position, the fixed and moving contacts of the pole for which the test is deemed to be the most severe shall be fixed together, for example by welding. Where the device has more than one contact system in series, each contact system shall be held in the closed position.~~

~~In the case of multiple tip contact systems, the least number of parallel contact tips shall be fixed together as necessary to hold the contact system closed in order to allow the test force to be applied without the contacts separating.~~

~~The appropriate means to keep the contact(s) closed and the number of contacts shall be specified by the manufacturer. The number of contacts and the method shall be stated in the report.~~

~~The supply voltage to the power operator shall be applied at 110 % of its normal rated value to attempt to open the contact system of the equipment.~~

~~Three attempts to operate the equipment at 5 min intervals by the power operator shall be made, each for a period of 5 s, unless an associated protective device of the power operator limits the time to a shorter period.~~

~~Verification shall be made according to 8.2.5.3.2.~~

~~NOTE In the USA, devices meeting these additional requirements are not accepted as assuring isolation by themselves. Isolation requirements and procedures are covered in the relevant Federal regulations and maintenance standards.~~

8.2.5.2.3 Independent power operation

~~With the equipment in the closed position, the fixed and moving contacts of the pole for which the test is deemed to be the most severe shall be fixed together, for example by welding. Where the device has more than one contact system in series, each contact system shall be held in the closed position.~~

~~In the case of multiple tip contact systems, the least number of parallel contact tips shall be fixed together as necessary to hold the contact system closed in order to allow the test force to be applied without the contacts separating.~~

~~The appropriate means to keep the contact(s) closed and the number of contacts shall be specified by the manufacturer. The number of contacts and the method shall be stated in the report.~~

~~The stored energy of the power operator shall be released to attempt to open the contact system of the equipment.~~

~~Three attempts to operate the equipment by releasing the stored energy shall be made.~~

~~Verification shall be made according to 8.2.5.3.2.~~

~~NOTE In the USA, devices meeting these additional requirements are not accepted as assuring isolation by themselves. Isolation requirements and procedures are covered in the relevant Federal regulations and maintenance standards.~~

(Void)

8.2.5.3 Condition of equipment during and after test

8.2.5.3.1 Dependent and independent manual operation

~~After the test and when the test force is no longer applied to the actuator with the actuator being left free, the indication of the open position shall not be wrongly given.~~

Table 8—Actuator test forces








Types of actuator	Test force	Minimum test force N	Maximum test force N
Pushbutton (see Figure 1a)	$3 F$	50	150
One-finger operated (see Figure 1b)	$3 F$	50	150
Two-finger operated (see Figure 1c)	$3 F$	100	200
One-hand operated (see Figure 1d and 1e)	$3 F$	150	400
Two-hand operated (see Figure 1f)	$3 F$	200	600
Two-hand operated (see Figure 1g)	$3 F$	200	600

F is the normal operating force in new condition. The test force shall be $3 F$ with the stated minimum and maximum values and be applied as shown in Figure 1.

8.2.5.3.2 Dependent and independent power operation

During and after the test, the open position shall not be indicated by any of the means provided and the equipment shall not show any damage such as to impair its normal operation.

When the equipment is provided with means for padlocking in the open position, it shall not be possible to lock the equipment during the test.

**Figure 1a****Figure 1b****Figure 1c****Figure 1d****Figure 1e****Figure 1f****Figure 1g**

IEC 1399/08

Figure 1—Actuator applied force F

(Void)

Table 9 – List of type tests applicable to a given equipment

Tests	Switch	Fuse-switch	Switch-fuse	Disconnector	Disconnector-fuse	Fuse disconnector	Switch disconnector	Switch disconnector-fuse	Fuse-switch disconnector
Temperature-rise ^a	0	0	0	0	0	0	0	0	0
Temperature-rise verification	0	0	0	0	0	0	0	0	0
Dielectric properties	0	0	0	0	0	0	0	0	0
Dielectric verification	0	0	0	0	0	0	0	0	0
Leakage current	–	–	–	0	0	0	0	0	0
Rated making and breaking capacities (overload)	0	0	0	–	–	–	0	0	0
Operational performance	0	0	0	0	0	0	0	0	0
Rated short-time withstand current	0	–	–	0	–	–	0	–	–
Rated short-circuit making capacity	0	–	–	–	–	–	0	–	–
Rated conditional short-circuit current	0	0	0	0	0	0	0	0	0
Strength of actuator mechanism	–	–	–	0	0	0	0	0	0
Overload test	–	0	0	–	0	0	–	0	0
0 = test – = no test required									
NOTE This list of type tests is for information only, see also footnote “a” in Tables 14 and 15.									
^a Applies to 8.3.2.1.3 only.									

8.3 Performance

Performance type tests to which equipment may be submitted according to its kind are listed in Table 9.

8.3.1 Test sequences

Type tests are grouped together in a number of sequences as shown in Table 10.

For each sequence, tests shall be made in the order listed in accordance with the requirements of the appropriate subclause, apart from the temperature-rise test (simplified testing only) and dielectric properties test of test sequence I, which may be conducted on a separate sample.

Table 10 – Overall scheme of test sequences

Sequences	Tests
General performance characteristics (see 8.3.3 and Table 11)	Temperature-rise ^{e, f} Dielectric properties ^e Making and breaking capacities ^a Dielectric verification ^a Leakage current ^b Temperature-rise verification Strength of actuator mechanism
Operational performance capability (see 8.3.4 and Table 13)	Operational performance Dielectric verification Leakage current ^b Temperature-rise verification
Short-circuit performance capability ^c (see 8.3.5 and Table 14)	Short-time withstand current Short-circuit making capacity ^a Dielectric verification Leakage current ^b Temperature-rise verification
Conditional short-circuit current ^c (see 8.3.6 and Table 15)	Fuse protected short-circuit withstand Fuse protected short-circuit making ^a Dielectric verification Leakage current ^b Temperature-rise verification
Overload performance capability ^d (see 8.3.7 and Table 16)	Overload test Dielectric verification Leakage current ^b Temperature-rise verification
^a Not applicable to AC-20 or DC-20 equipment. See 4.3.5.2 and 4.3.5.3. ^b Only required for equipment suitable for isolation of rated voltage greater than 50 V. ^c Either test sequence III or test sequence IV to be made according to the ratings stated by the manufacturer. ^d Not required for switches, disconnectors and switch-disconnectors. ^e May be conducted outside of the sequence, see 8.3.1. ^f Applies to 8.3.2.1.3 only.	

8.3.2 General test conditions

8.3.2.1 General requirements

Subclause 8.3.2.1 of IEC 60947-1 applies to all type tests as applicable. The equipment at the start of any test sequence shall be in new and clean condition.

The force applied for any opening operation shall not be greater than the test force determined in 8.2.5.2 of IEC 60947-1 and shall be applied in the same manner without shock.

Where doubt exists as to the correct opening operation, no more than 3 attempts to operate the equipment to the open position are allowed.

In order to reduce multiple testing for the same fundamental design of equipment, the following test requirements may be used.

8.3.2.1.1 Simplified test for equipment having the same fundamental design

When submitting simultaneously a range of switches, disconnectors, switch-disconnectors or fuse combination units of the same fundamental design, the following variations are permitted provided the equipment complies in all other respects.

8.3.2.1.2 Requirements for equipment having the same fundamental design

Switches, disconnectors, switch-disconnectors or fuse combination units shall be evaluated with respect to the following criteria during the determination of acceptance as the same fundamental design:

- a) the material, finish and dimensions of the current-carrying parts are identical, except for variation in design of terminals and means of fuse attachment;
- b) the contact size, material, configuration and method of attachment are identical;
- c) the operating mechanism is of the same fundamental design, materials and physical characteristics are identical;
- d) the closing and opening speeds of contacts are substantially the same;
- e) moulding and insulating materials are identical;
- f) method, materials and construction of any arc extinction device are identical.

The following variations are also permitted, provided the simplified test procedure given in 8.3.2.1.3 is used:

- g) utilization category and operational voltage;
- h) application for 50 Hz or 60 Hz;
- i) three or four pole equipment (switched or non-switched neutral), provided the requirements of 7.1.9 are applicable;
- j) design of terminal provided that clearances and creepage distance are not reduced (see 7.1.4, 8.2.4 and 8.3.3.2 of this part standard and also see 7.1.4 and 8.3.3.1 of IEC 60947-1);
- k) different types of actuators, either additional or integral, provided the requirements for strength of actuator are verified (see 8.2.5) on each type of actuator, one of which during test sequence I;
- l) fuse-base contacts of switch-fuses, disconnector-fuses and switch-disconnector-fuse with different types of fuse-links (fuse-link removed only under no-load conditions).

8.3.2.1.3 Simplified test procedure

The following simplified test procedure shall be used.

- a) If equipment having the same fundamental design is marked claiming more than one utilization category and/or more than one operational voltage, the number of test samples may be reduced, providing the tests are conducted under the most severe conditions.

For short-circuit, making and breaking, and operational performance tests, the conditions are deemed more severe if the following conditions are simultaneously fulfilled:

- operational rated voltage equal or higher;
- test current equal or higher;
- power factor equal or lower;
- number of operations equal or higher.

- b) Tests performed at 50 Hz are deemed to cover 60 Hz applications and vice versa with the following exceptions:

- temperature-rise test according to 8.3.3.1 for devices having a current greater than 800 A;

NOTE By agreement between manufacturer and user, tests at 50 Hz may be accepted for operation at 60 Hz and vice versa for currents greater than 800 A.

- temperature-rise and operational performance of relays and releases (see 7.2.2 and 7.2.2.6 of IEC 60947-1). Temperature-rise tests of coils shall be performed for each frequency, but only one included in the relevant test sequence, and if separate supplying of coils and other circuits is possible, it is accepted that other circuits remain supplied at 50 Hz.

- c) Tests performed on three pole devices are deemed to cover also four pole devices with a non-switched neutral pole, provided a single-phase test on the neutral pole is performed according to 8.3.3.3.4 of IEC 60947-1.

Tests performed on four switched pole devices are deemed to cover also three switched pole devices provided that all poles are identical and the closing and opening speeds of contacts are substantially the same (only the requirements of 7.1.9 are applicable concerning closing and opening of the neutral pole). However, the four switched pole devices shall always be connected in a three-phase arrangement (see Figure 11 of IEC 60947-1).

- d) Tests performed with different types of fuse-base contacts.

Where switch-fuse, disconnecter-fuse or switch-disconnector-fuse are designed to be provided with different types of fuse-base contacts, temperature-rise tests according to 8.3.3.1 shall be conducted on each type at the corresponding highest fuse rated current.

The type having the maximum temperature-rise among those of the maximum test current shall be used for tests to sequences I, II and V.

Sequence IV shall be conducted on each type of fuse-base contacts whose fuse connecting means are other than bolted connection, at the highest rated conditional short circuit corresponding current, and, if different, with the type of fuse having the maximum let-through energy at the highest test voltage.

- e) Tests performed with different terminal designs.

Where equipment is designed to be provided with different designs of terminal, the requirements and tests according to 8.3.3.1 and 8.2.4 of IEC 60947-1 shall be conducted on each design.

Where equipment has terminals to be used on plug-on busbars, tests according to 8.3.3.1, 8.3.5.1 or 8.3.6.2.1 a), as applicable, shall be performed. Verification of the plugging operation shall be made. The number of operating cycles shall be 50, the cycle being from the connected position to the disconnected position and back to the connected position.

The test is considered to be satisfactory if the operating conditions of the apparatus have not been impaired.

- f) By tests to 8.3.2.1.3, items d) and e), it is possible to test the temperature-rise at terminals and accessible parts.

If the temperature-rise limits of accessible parts are tested in 8.3.2.1.3 and comply with Table 3 of IEC 60947-1 no further tests of these parts at 8.3.3.6 are necessary.

Since the intention of the tests to 8.3.2.1.3, items d) and e), is to establish the worst case, the values of Table 2 of IEC 60947-1 do not apply.

8.3.2.2 Test quantities

Subclause 8.3.2.2 of IEC 60947-1 applies.

8.3.2.3 Evaluation of test results

The behaviour of the equipment during the tests and its condition after the tests are specified in the appropriate test clause.

8.3.2.4 Test report

Subclause 8.3.2.4 of IEC 60947-1 applies.

8.3.3 Test sequence I: general performance characteristics

This test sequence applies to the types of equipment listed in Table 11 and comprises the tests according to the table.

8.3.3.1 Temperature-rise

Subclause 8.3.3.3 of IEC 60947-1 applies with the following additions.

~~The test shall be made at the rated operational current I_e .~~

The test shall be carried out at the rated operational current I_e ; except in the case of an AC-20 or DC-20 rating when the temperature rise test is carried out at I_{th} . In the case where a test has been made at I_e then the manufacturer may declare an AC-20 or DC-20 rating equal to I_e without further testing.

Fuse-combination units shall be fitted with fuse-links having a rated current equal to the conventional thermal current of the combination unit.

The fuse-link shall have a power loss not exceeding the maximum value specified by the equipment manufacturer.

NOTE 1 The test may be made with a "dummy" fuse-link of essentially similar design to the standardized fuse-link and having the specified power loss.

In the case of tests carried out on a fuse-switch, a fuse-disconnector or a fuse-switch-disconnector where the blades of the fuse-links are part of the make-breaking contacts, fuse-links shall be used.

NOTE 2 For a fuse-switch or a fuse-switch-disconnector where the blades of the fuse-links are part of the make-breaking contacts, dummies or copper links may not replace the fuse-links due to the fact that the blades of the fuse-links in these devices wear. The wear of the fuse-blades influences the thermal verification according to 8.3.3.6.

Details of the fuse-links used for the test, i.e. the manufacturer's name and reference, the rated current, the power loss of the fuse-link, and the breaking capacity, shall be given in the test report. The type test with the specified fuse-links shall be deemed to cover the use of any other fuse-link having a power loss, at the conventional thermal current of the combination unit, not exceeding the power loss of the fuse-link used for the test.

~~In the case of tests carried out on a switch-fuse or a switch-disconnector-fuse, fuse-links may be replaced by suitable copper links of dimensions and mass electrically equivalent to those of the fuse-links recommended by the manufacturer.~~

Table 11 – Test sequence I: general performance characteristics

Tests	Sub-clause No.	Samples ^c	Types of equipment and order of tests					
			Switch	Fuse-switch and switch-fuse	Disconnector	Disconnector-fuse and fuse-disconnector	Switch-disconnector	Switch-disconnector-fuse and fuse-switch-disconnector
Temperature-rise ^{d, e}	8.3.3.1	A,B,C,F	1	1	1	1	1	1
Dielectric properties ^d	8.3.3.2	A,C,F	2	2	2	2	2	2
Making and breaking capacities	8.3.3.3	A,D	3	3	a	a	3	3
Dielectric verification	8.3.3.4	A,D	4	4	a	a	4	4
Leakage current ^b	8.3.3.5	A,D	-	-	3	3	5	5
Temperature-rise verification	8.3.3.6	A,D	5	5	4	4	6	6
Strength of actuator mechanism	8.3.3.7	A,E	-	-	5	5	7	7

^a This test is not required for disconnectors (AC-20 or DC-20). See 4.3.5.2 and 4.3.5.3.

^b Test required only for U_e greater than 50 V.

^c Only tests marked by the same letter shall be applied in sequence to a given sample: "A" is a sample from each fundamental design, chosen from the highest rated current I_e and if applicable, having the maximum temperature-rise according to 8.3.2.1.3, item d).

Other samples if applicable:

"B" is a different sample for 60 Hz test, if applicable, according to 8.3.2.1.3, item b);

"C" are samples of each other terminal design tested at correspondent maximum rated current;

"D" are samples to verify as many combinations of U_e , I_e , AC or DC voltage ratings, to be tested (see 8.3.2.1.3);

"E" is the extra sample as specified in 8.2.5.1 and can be one of sample B, C or D;

"F" are samples of every type of fuse-carrier of fuse-combination unit according to 8.3.2.1.3, item d).

^d May be conducted outside of the sequence, see 8.3.1.

^e Applies only to 8.3.2.1.3.

8.3.3.2 Test of dielectric properties

Subclause 8.3.3.4.1, items 1), 2), 3), 7) and, if applicable, 8) of IEC 60947-1 applies with the following addition.

When, in agreement with the manufacturer, devices are disconnected for the test according to 8.3.3.4.1, item 3) c) of IEC 60947-1, the test report shall state these devices.

For equipment suitable for isolation (see 3.3) having an operational voltage U_e greater than 50 V, the leakage current shall be measured through each pole with the contacts in the open position, at a test voltage of $1,1 U_e$ and shall not exceed 0,5 mA.

8.3.3.3 Making and breaking capacities

8.3.3.3.1 Test values and conditions

Subclause 8.3.3.5 of IEC 60947-1 applies regarding equipment provided with a neutral pole.

The test values are stated in 7.2.4.1, Table 3, according to the utilization category.

The stated number of make-break operating cycles shall be made with a time interval between close-open cycles of $30\text{ s} \pm 10\text{ s}$ except that for equipment of conventional thermal current of 400 A or more, the time interval may be increased by agreement between manufacturer and user and the interval shall be stated in the test report.

During each make-break operating cycle, equipment need only stay in the closed position for a period long enough to allow the switching operation to be completed and to enable the current value to be established and the moving parts of the equipment to come to rest. After each operating cycle, the recovery voltage shall be maintained for at least 0,05 s.

For convenience of testing, equipment of utilization categories AC-23A and AC-23B, make-break operating cycles may be replaced, with the agreement of the manufacturer, by the stated number of $10 I_e$ make cycles followed by the same number of $8 I_e$ break cycles.

For a.c. the power-factor of the test circuit shall be determined in accordance with 8.3.4.1.3 of IEC 60947-1. The values shall be in accordance with Table 3.

For d.c. the time-constant of the test circuit shall be determined in accordance with 8.3.4.1.4 of IEC 60947-1. The values shall be in accordance with Table 3.

The test voltage and the load shall be applied to the appropriate terminals of the equipment. For equipment in which a moving contact remains connected to one of the terminals when the equipment is in the open position, this test shall be repeated with the supply and load connections interchanged, unless the terminals are specifically and clearly marked for load and supply.

In the case of tests carried out on a fuse-switch or a fuse-switch-disconnector where the blades of the fuse-links are part of the make-breaking contacts, fuse-links shall be used.

NOTE For a fuse-switch or a fuse-switch-disconnector where the blades of the fuse-links are part of the make-breaking contacts, dummies or copper links may not replace the fuse-links due to the fact that the blades of the fuse-links in these devices wear. The wear of the fuse-blades influences the thermal verification according to 8.3.3.6.

Details of the fuse-links used for the test, i.e. the manufacturer's name and reference, the rated current, the power loss of the fuse-link and the breaking capacity, shall be given in the test report.

In the case of tests carried out on a switch-fuse or a switch-disconnector-fuse, fuse-links may be replaced by suitable copper links of dimensions and mass electrically equivalent to those of the fuse-links recommended by the manufacturer.

8.3.3.3.2 Test circuit

Subclause 8.3.3.5.2 of IEC 60947-1 applies.

8.3.3.3.3 Transient recovery voltage

Subclause 8.3.3.5.3 of IEC 60947-1 applies only to utilization categories AC-22 and AC-23. For tests for utilization categories DC-22 and DC-23 the test circuit load may be replaced by a motor producing the specified current and time constant value if agreed between manufacturer and user.

8.3.3.3.4 Vacant

8.3.3.3.5 Behaviour of equipment during making and breaking capacity tests

The equipment shall perform during the above tests in such a manner as not to endanger an operator or cause damage to adjacent equipment.

There shall be no permanent arcing or flash-over between poles or between poles and frame and no melting of the fuse in the detection circuit.

The equipment shall remain mechanically operable. Contact welding, such as to prevent an opening operation using normal operating means, is not permitted.

8.3.3.3.6 Condition of equipment after the making and breaking capacity tests

It shall be demonstrated immediately after the test that the equipment will close and open satisfactorily during a no-load close/open operation.

The force required for opening shall not be greater than the test force of 8.2.5.2 and Table 8 17 of IEC 60947-1.

A closing operation is considered satisfactory when normal operation of the handle through its full stroke will close the contacts sufficiently for the equipment to be able to carry its rated operational current.

After the test and without maintenance the equipment shall comply with the requirements of 8.3.3.4.

The contacts shall be in a suitable condition to carry the rated operational current without maintenance and shall comply with the temperature-rise verification of 8.3.3.6.

If the equipment is suitable for isolation, it shall comply with 8.3.3.5 and 8.3.3.7.

8.3.3.4 Dielectric verification

After the test according to 8.3.3.3, a test shall be made according to 8.3.3.4.1 4) of IEC 60947-1.

8.3.3.5 Leakage current

This test is made only on equipment suitable for isolation of rated operational voltage U_e greater than 50 V. The leakage current shall be checked across each contact gap and from each terminal to the frame.

The value of leakage current, with a test voltage equal to 1,1 times the rated operational voltage of equipment shall not exceed

- 0,5 mA per pole for equipment of utilization category AC-20A, AC-20B, DC-20A or DC-20B;
- 2 mA per pole for equipment of all other utilization categories.

8.3.3.6 Temperature-rise verification

After the tests according to 8.3.3.3, the temperature-rise of the terminals and accessible parts shall be checked according to 8.3.3.1 except that where a utilization category is assigned the tests are made at the rated operational current I_e of the equipment tested.

The terminals and accessible parts shall not exceed the limiting values stated in Table 12.

Table 12 – Temperature-rise limits for terminals and accessible parts

Description of part ^a	Temperature-rise limits K
Terminals for external connections	80
Manual operating means: – metallic – non-metallic	25 35
Parts intended to be touched but not hand-held: – metallic – non-metallic	40 50
Parts which need not be touched for normal operation: – metallic – non-metallic	50 60

^a No value is specified for parts other than those listed but no damage shall be caused to adjacent parts of insulating materials.

8.3.3.7 Strength of actuator mechanism

Subclause 8.2.5 applies to equipment suitable for isolation.

8.3.4 Test sequence II: operational performance capability

This test sequence applies to the types of equipment listed in Table 13 and comprises the tests according to this table.

They are made to verify compliance with 7.2.4.2.

Table 13 – Test sequence II: operational performance capability

Tests	Sub-clause No.	Samples	Types of equipment and order of tests					
			Switch	Fuse-switch and switch-fuse	Disconnector	Disconnector-fuse and fuse-disconnector	Switch-disconnector	Switch-disconnector-fuse and fuse-switch-disconnector
Operational performance	8.3.4.1	A, B	1	1	1	1	1	1
Dielectric verification	8.3.4.2	A, B	2	2	2	2	2	2
Leakage current ^a	8.3.4.3	A, B	—	—	3	3	3	3
Temperature-rise verification	8.3.4.4	A, B	3	3	4	4	4	4

^a Test required only for U_e greater than 50 V.

^b "A" is a sample from each fundamental design, chosen from the highest rated current I_e , and if applicable, having the maximum temperature-rise according to 8.3.2.1.3 d).
 "B", if applicable, are samples to verify as many combinations of U_e , I_e , a.c. or d.c. voltage ratings, to be tested.

8.3.4.1 Operational performance test

8.3.4.1.1 Test values and conditions

The test values are stated in Tables 4 and 5, according to the utilization category.

The time interval between Table 4 operating cycles with current and without current and the sequential order of the tests shall be stated in the test report.

During each make-break operating cycle, the equipment need only stay in the closed position for a period long enough to allow the switching operation to be completed and to enable the current value to be established and the moving parts of the equipment to come to rest. After each operating cycle, the recovery voltage shall be maintained for at least 0,05 s.

For a.c. the power-factor of the test circuit shall be determined in accordance with 8.3.4.1.3 of IEC 60947-1. The values shall be in accordance with Table 5.

For d.c. the time-constant of the test circuit shall be determined in accordance with 8.3.4.1.4 of IEC 60947-1. The values shall be in accordance with Table 5.

8.3.4.1.2 Test circuit

Subclause 8.3.3.5.2 of IEC 60947-1 applies.

8.3.4.1.3 Transient recovery voltage

It is not necessary to adjust the transient recovery voltage.

8.3.4.1.4 Switching overvoltages

Under consideration.

8.3.4.1.5 Behaviour of the equipment during the operational performance test

The equipment shall perform during the above tests in such a manner as not to endanger an operator or cause damage to adjacent equipment.

There shall be no permanent arcing or flash-over between poles or between poles and frame and no melting of the fuse in the detection circuit.

The equipment shall remain mechanically operable. Contact welding, such as to prevent an opening operation using normal operating means, is not permitted.

Some wear on the mechanism and contacts is allowed provided that the equipment functions correctly.

8.3.4.1.6 Condition of the equipment after the operational performance test

It shall be demonstrated immediately after the test that the equipment will close and open satisfactorily during a no-load close/open operation.

The force required for opening shall not be greater than the test force of 8.2.5.2 and Table 8 17 of IEC 60947-1.

A closing operation is considered satisfactory when normal operation of the handle through its full stroke will close the contacts sufficiently for the equipment to be able to carry its rated operational current.

After the tests and without maintenance the equipment shall comply with the requirements of 8.3.4.2.

The contacts shall be in a suitable condition to carry the rated operational current without maintenance and shall comply with the temperature-rise verification of 8.3.4.4.

If the equipment is suitable for isolation, it shall comply with 8.3.4.3.

8.3.4.2 Dielectric verification

Subclause 8.3.3.4 applies.

8.3.4.3 Leakage current

Subclause 8.3.3.5 applies.

8.3.4.4 Temperature-rise verification

Subclause 8.3.3.6 applies.

8.3.5 Test sequence III: short-circuit performance capability

This test sequence applies to the types of equipment listed in Table 14 and comprises the tests according to this table.

This test sequence is not mandatory if a value of rated short-circuit making capacity is not stated by the manufacturer (see 8.3.5.2.1) and test sequence IV (see 8.3.6) is carried out.

The tests are made to verify compliance with 7.2.5.

Table 14 – Test sequence III: short-circuit performance capability

Tests	Sub-clause No.	Samples ^a	Types of equipment and order of tests					
			Switch	Fuse-switch and switch-fuse	Disconnector	Disconnector-fuse and fuse-disconnector	Switch-disconnector	Switch-disconnector-fuse and fuse-switch-disconnector
Short-time withstand current	8.3.5.1	A	1		1		1	
Short-circuit making capacity ^{a,b}	8.3.5.2	A, B	2	Not applicable	–	Not applicable	2	Not applicable
Dielectric verification	8.3.5.3	A, B	3		2		3	
Leakage current ^c	8.3.5.4	A, B	–		3		4	
Temperature-rise verification	8.3.5.5	A, B	4		4		5	

^a Test sequence III is not mandatory if test sequence IV is carried out.

^b Switches and switch-disconnectors not having a rated short-circuit making capacity (see 2.1) shall meet the requirements of test sequence IV (see Table 15).

^c Test required only for U_e greater than 50 V.

^d "A" is a sample from each fundamental design, chosen from the highest I_{cw} current.

"B", if applicable, are samples to verify as many combinations of U_e , I_{cw} or I_{cm} , AC or DC voltage ratings, to be tested.

8.3.5.1 Short-time withstand current test

8.3.5.1.1 Test values and conditions

The test conditions of 8.3.4.3 of IEC 60947-1 apply.

The test current shall be the rated short-time withstand current stated according to 4.3.6.1.

8.3.5.1.2 Test circuit

Subclause 8.3.4.1.2 of IEC 60947-1 applies.

For a.c., the power-factor of the test circuit shall be in accordance with 8.3.4.1.3 of IEC 60947-1.

For d.c., the time-constant of the test circuit shall be in accordance with 8.3.4.1.4 of IEC 60947-1.

8.3.5.1.3 Test circuit calibration

The calibration of the test circuit is carried out by placing temporary connections *B* of negligible impedance as close as reasonably possible to the terminals provided for connecting the equipment under test.

For a.c., resistors R_1 and reactors X are adjusted so as to obtain, at the applied voltage, a current equal to the rated short-time withstand current as well as the power-factor as indicated in 8.3.4.1.3 of IEC 60947-1.

For d.c., resistors R_1 and reactors X are adjusted so as to obtain, at the applied voltage, a current the maximum value of which is equal to the rated short-time withstand current as well as the time-constant as indicated in 8.3.4.1.4 of IEC 60947-1.

8.3.5.1.4 Test procedure

The temporary connections *B* are replaced by the equipment under test and the test current is applied for the specified time with the equipment in the closed position.

8.3.5.1.5 Behaviour of the equipment during the test

The equipment shall perform during the test in such a manner as not to endanger an operator or cause damage to adjacent equipment.

There shall be no permanent arcing or flash-over between poles or between poles and frame and no melting of the fuse in the detection circuit.

The equipment shall remain mechanically operable. Contact welding, such as to prevent an opening operation using normal operating means, is not permitted.

8.3.5.1.6 Conditions of the equipment after the test

It shall be demonstrated immediately after the test that the equipment will close and open satisfactorily during a no-load close/open operation.

The force required for opening shall not be greater than the test force of 8.2.5.2 and Table 8 17 of IEC 60947-1.

A closing operation is considered satisfactory when normal operation of the handle through its full stroke will close the contacts sufficiently for the equipment to be able to carry its rated operational current.

After the test and without maintenance if the equipment is a switch or a switch-disconnector, it shall be subjected to the short-circuit making capacity test, 8.3.5.2, as listed in Table 14.

If the equipment is suitable for isolation, it shall comply without maintenance with the dielectric verification of 8.3.5.3.

The contacts of a disconnector shall be in a suitable condition without maintenance to carry the rated operational current and shall comply with the temperature-rise of 8.3.5.5.

8.3.5.2 Short-circuit making capacity test

8.3.5.2.1 Test values and conditions

The test shall be made on the same equipment as for the test of 8.3.5.1 without any maintenance.

The test current shall be that assigned by the manufacturer as stated in 4.3.6.2.

8.3.5.2.2 Test circuit

Subclause 8.3.5.1.2 applies.

8.3.5.2.3 Test circuit calibration

The calibration of the test circuit is carried out by placing temporary connections *B* of negligible impedance as close as reasonably possible to the terminals provided for connecting the equipment under test.

Depending upon whether the equipment is rated a.c. or d.c. the calibration is made as follows.

a) For a.c.:

The tests shall be made at the rated frequency of the equipment.

The prospective current shall be applied for at least 0,05 s and its value is the r.m.s. value determined from the calibration record. This value shall be equal to or higher than the specified value in at least one pole.

The average value of all phases shall comply with the tolerances in 8.3.2.2 of IEC 60947-1.

The highest peak value of the prospective current during its first cycle shall be not less than *n* times the rated short-circuit current, the value of *n* being as stated in the fourth column of Table 16, of IEC 60947-1.

b) For d.c.:

The current shall be applied for the specified time and its mean value, determined from the record, shall be at least equal to the specified value.

If the testing station is unable to make these tests on d.c., they may, if agreed between manufacturer and user, be made on a.c., provided suitable precautions are taken, for instance, the peak value of current shall not exceed the permissible current.

For an equipment having the same rated current for a.c. and d.c. the a.c. test shall be taken as valid for the d.c. rating.

8.3.5.2.4 Test procedure

The temporary connections *B* are replaced by the equipment under test and the equipment shall be closed twice with an interval of approximately 3 min between these operations on a prospective peak current not less than the rated short-circuit making capacity of the equipment. The current shall be maintained for at least 0,05 s.

The closing mechanism shall be operated so as to simulate service conditions as closely as possible.

8.3.5.2.5 Behaviour of the equipment during the test

The equipment shall perform during the above tests in such a manner as not to endanger an operator or cause damage to adjacent equipment.

There shall not be permanent arcing or flash-over between poles or between poles and frame and no melting of the fuse in the detection circuit.

The equipment shall remain mechanically operable. Contact welding, such as to prevent an opening operation using normal operating means, is not permitted.

8.3.5.2.6 Condition of the equipment after the test

It shall be demonstrated immediately after the test that the equipment will open and close satisfactorily during a no-load open/close operation.

The force required for opening shall not be greater than the test force of 8.2.5.2 and Table 8 17 of IEC 60947-1.

A closing operation is considered satisfactory when normal operation of the handle through its full stroke will close the contacts sufficiently for the equipment to be able to carry its rated operational current.

After the test and without maintenance the equipment shall comply with the dielectric verification of 8.3.5.3.

The contacts shall be in a suitable condition without maintenance to carry the highest rated operational current and shall comply with the temperature-rise verification of 8.3.5.5.

8.3.5.3 Dielectric verification

Subclause 8.3.3.4 applies.

8.3.5.4 Leakage current

Subclause 8.3.3.5 applies, except that the maximum value of leakage current shall not exceed 2 mA per pole for all utilization categories.

8.3.5.5 Temperature-rise verification

Subclause 8.3.3.6 applies.

8.3.6 Test sequence IV: conditional short-circuit current

This test sequence applies to the types of equipment listed in Table 15 and comprises the tests according to the table.

This test sequence is not mandatory if a value of rated conditional short-circuit current is not stated by the manufacturer and test sequence III (see 8.3.5) is carried out.

For switches, disconnectors and switch-disconnectors the short-circuit protective device of the equipment may be a circuit-breaker or a fuse and shall be arranged on the load side of the equipment under test.

The type of circuit breaker or fuse shall be that stated by the manufacturer as suitable for the equipment.

Details of the protective device used for the test i.e. manufacturer's name, type designation, rated voltage, current and short-circuit breaking capacity shall be given in the test report.

The type test with the specified protective device shall be deemed to cover the use of any other protective device having a Joule integral (I^2t) and cut-off current at the rated voltage, prospective current and power-factor not exceeding the specified values for the type of protective device used for the test.

The tests are made to verify compliance with 7.2.5.

8.3.6.1 Circuit-breaker protected short-circuit withstand

Under consideration.

8.3.6.2 Fuse protected short-circuit withstand

8.3.6.2.1 Test values and conditions

The fuse-links shall be of the rated maximum current and rated breaking capacity deemed suitable by the manufacturer for use with the equipment.

The equipment manufacturer shall supply the fuse-links (see IEC 60269 series) to be used for the test. Details of the fuse-links used shall be recorded in the test report.

The test voltage to be used shall be equal to $1,05 U_e$, where U_e corresponds to the operational voltage of the device under test.

The test shall be made as follows.

a) Withstand test

A prospective current corresponding to the rated conditional short-circuit current stated by the manufacturer shall be applied with the equipment in the closed position.

b) Making test

After the withstand test of item a), all equipment according to Table 15 shall be fitted with new fuse-links and closed on to the rated conditional short-circuit current.

Table 15 – Test sequence IV: conditional short-circuit current

Tests	Sub-clause No.	Samples ^c	Types of equipment and order of tests					
			Switch ^a	Fuse-switch and switch-fuse	Disconnector ^a	Disconnector-fuse and fuse-disconnector	Switch-disconnector ^a	Switch-disconnector-fuse and fuse-switch-disconnector
Fuse protected short-circuit withstand	8.3.6.2.1a)	A, B	1	1	1	1	1	1
Fuse protected short-circuit making	8.3.6.2.1b)	A, B	2	2	–	–	2	2
Dielectric verification	8.3.6.3	A, B	3	3	2	2	3	3
Leakage current ^b	8.3.6.4	A, B	–	–	3	3	4	4
Temperature-rise verification	8.3.6.5	A, B	4	4	4	4	5	5
^a Test sequence IV is not mandatory if test sequence III is carried out (see Table 14). ^b Test required only for U_e greater than 50 V. ^c "A" is a sample from each fundamental design, chosen from the highest rated conditional short-circuit current, or if applicable, "A" are samples of each type according to 8.3.2.1.3d). "B" if applicable, are samples to verify as many combinations of U_e , I_n , AC or DC voltage ratings, to be tested.								

8.3.6.2.2 Test circuit

Subclause 8.3.5.1.2 applies.

8.3.6.2.3 Test circuit calibration

Subclause 8.3.5.2.3 applies.

8.3.6.2.4 Test procedure

For fuse-switches, fuse-disconnectors and fuse-switch-disconnectors, the closing mechanism shall be operated according to 7.2.1.1.

The temporary connections are replaced by the equipment under test and the test current applied according to 8.3.6.2.1.

The recovery voltage shall be maintained for at least 0,05 s after interruption of the test current by the fuse.

8.3.6.2.5 Behaviour of the equipment during the test

Subclause 8.3.5.2.5 applies.

8.3.6.2.6 Condition of the equipment after the test

Subclause 8.3.5.2.6 applies.

8.3.6.3 Dielectric verification

Subclause 8.3.3.4 applies.

8.3.6.4 Leakage current

Subclause 8.3.5.4 applies.

8.3.6.5 Temperature-rise verification

Subclause 8.3.3.6 applies.

8.3.7 Test sequence V: overload performance capability

This test sequence applies to the types of equipment listed in Table 16 and comprises the tests according to the table.

8.3.7.1 Overload test

The equipment shall first be temperature conditioned at room temperature. The test current is $1,6 I_{the}$ or $1,6 I_{th}$ for a period of 1 h, or until one or more of the fuses blow. If the time is less than 1 h, the time shall be recorded in the test report.

The equipment manufacturer shall supply the fuse-links (see IEC 60269 series) to be used for the test. Details of the fuse-links used shall be recorded in the test report.

Subclause 8.3.3.1 applies with the exception that no temperatures have to be measured.

Within 3 min to 5 min after the fuse(s) has (have) operated or the period of 1 h is over, the equipment shall be operated once, i.e. opened and closed. The equipment shall not have undergone any impairment hindering such operation. The force to open the equipment shall not be greater than the actuator test force of 8.2.5.2 and Table 8 17 of IEC 60947-1.

The time duration of the overload test shall be measured and given in the test report.

8.3.7.2 Dielectric verification

Subclause 8.3.3.4 applies.

8.3.7.3 Leakage current

Subclause 8.3.3.5 applies.

8.3.7.4 Temperature-rise verification

Subclause 8.3.3.6 applies with the addition of the following.

Fuse-links aged during the overload test according to 8.3.7.1 shall be replaced by new fuse-links of the same type and rating.

Table 16 – Test sequence V: overload performance capability

Tests	Sub-clause No.	Samples ^b	Types of equipment and order of tests		
			Fuse-switch and switch-fuse	Disconnector-fuse and fuse-disconnector	Switch-disconnector-fuse and fuse-switch-disconnector
Overload test	8.3.7.1	A	1	1	1
Dielectric verification	8.3.7.2	A	2	2	2
Leakage current ^a	8.3.7.3	A	–	3	3
Temperature-rise verification ^c	8.3.7.4	A	3	4	4
^a Test required only for U _e greater than 50 V. ^b "A" is a sample from each fundamental design, chosen from the highest rated current I _e , and if applicable, having the maximum temperature-rise according to 8.3.2.1.3 d). ^c By agreement with the manufacturer, the test sequence may be changed so that the temperature-rise verification test follows directly after the overload test, followed by dielectric verification and the leakage current tests, as applicable.					

8.4 Electromagnetic compatibility tests

Subclause 8.4 of IEC 60947-1 applies with the following addition.

During tests, the following performance criterion applies:

- unintentional separation or closing of contacts shall not occur.

8.4.1 Immunity

8.4.1.1 Equipment not incorporating electronic circuits

No tests are necessary (see 7.3.2.1).

8.4.1.2 Equipment incorporating electronic circuits

The requirements of 7.3.2.2 of IEC 60947-1 apply. To verify compliance with these requirements, the tests contained in Table 6 shall be conducted.

8.4.2 Emission

8.4.2.1 Equipment not incorporating electronic circuits

No tests are necessary (see 7.3.3.1).

8.4.2.2 Equipment incorporating electronic circuits

The requirements of 7.3.3.2 apply. The limits contained in Table 7 shall be verified by tests.

Measurements shall be made in the operating mode, including grounding conditions, producing the highest emission in the frequency band being investigated which is consistent with normal service conditions (see Clause 6).

Each measurement shall be performed in defined and reproducible conditions.

8.5 Special tests

Resistance to mechanical and/or electrical wear is demonstrated by the operational performance test detailed in 8.3.4.1.

Where abnormal service conditions are expected (see also note to 7.2.4.3 of IEC 60947-1), the following tests may be necessary.

8.5.1 Mechanical durability

The mechanical durability test (see 7.2.4.3 and 8.1.5), where required, is made in accordance with the appropriate requirements of 8.3.4.1, except that for equipment suitable for isolation, the maximum value of leakage current shall not exceed 6 mA per pole for all utilization categories.

The total number of operating cycles shall be as declared by the manufacturer.

8.5.2 Electrical durability

The electrical durability test (see 7.2.4.4 and 8.1.5), where required, is made in accordance with the appropriate requirements of 8.3.4.1, except that for equipment suitable for isolation, the maximum value of leakage current shall not exceed 6 mA per pole for utilization categories AC-21, AC-22, AC-23, DC-21, DC-22 and DC-23.

Equipment of utilization categories AC-20A, AC-20B, DC-20A and DC-20B is not submitted to this test.

The total number of operating cycles shall be as declared by the manufacturer.

Annex A (normative)

Equipment for direct switching of a single motor

A.1 General

Switches, switch-disconnectors and fuse-combination units normally intended for direct switching of individual motors shall comply with the additional requirements of this annex. These requirements are essentially the same as the appropriate subclauses of IEC 60947-4-1 and equipment complying with this annex may state on the nameplate the appropriate utilization category according to Table A.1.

A.2 Rated duty

Additional rated duties considered as standard are as follows.

A.2.1 Intermittent periodic duty or intermittent duty

Subclause 4.3.4.3 of IEC 60947-1 applies with the following additions.

According to the number of operating cycles which they shall be capable of carrying out per hour, equipment is divided into the following classes:

- class 1: up to 1 operating cycle per hour;
- class 3: up to 3 operating cycles per hour;
- class 12: up to 12 operating cycles per hour;
- class 30: up to 30 operating cycles per hour;
- class 120: up to 120 operating cycles per hour.

A.2.2 Temporary duty

Subclause 4.3.4.4 of IEC 60947-1 applies.

A.3 Making and breaking capacities

An equipment is defined by its making and breaking capacities, in accordance with utilization categories as specified in Table A.2 (see A.4).

A.4 Utilization category

The utilization categories as given in A.2 are considered standard in this annex. Any other type of utilization category shall be based on agreement between manufacturer and user but information given in the manufacturer's catalogue or tender may take the place of such an agreement.

Each utilization category is characterized by the values of the currents and voltages, expressed as multiples of the rated operational current and of the rated operational voltage, and by the power-factors or time-constants as shown in Table A.2 and other test conditions used in the definitions of the rated making and breaking capacities.

The utilization categories of Table A.2 correspond in principle to the applications listed in Table A.1.

Table A.1 – Utilization categories

Utilization categories		Typical applications
AC	AC-2	Slip-ring motors: starting, plugging ^a , switching off
	AC-3	Squirrel-cage motors: starting, switching off of motors during running
	AC-4	Squirrel-cage motors: starting, plugging ^a , inching ^b
DC	DC-3	Shunt motors: starting, plugging ^a , inching ^b , dynamic breaking of d.c. motors
	DC-5	Series-motors: starting, plugging ^a , inching ^b , dynamic breaking of d.c. motors
NOTE The switching of rotor circuits, capacitors or tungsten filament lamps shall be subject to special agreement between manufacturer and user.		
^a Plugging is understood to mean stopping or reversing the motor rapidly by reversing motor primary connections while the motor is running.		
^b Inching (jogging) is understood to mean energizing a motor once or repeatedly for short periods to obtain small movements of the driven mechanism.		

Table A.2 – Rated making and breaking capacity conditions corresponding to several utilization categories

Utilization categories	Make and break conditions					
	I_c/I_e	U_r/U_e	$\cos \phi$	On-time s^b	Off-time s	Number of operating cycles
AC-2	4,0	1,05	0,65	0,05	c	50
AC-3 ^e	8,0	1,05	a	0,05	c	50
AC-4 ^e	10,0	1,05	a	0,05	c	50
			L/R ms			
DC-3	4,0	1,05	2,5	0,05	c	50 ^f
DC-5	4,0	1,05	15,0	0,05	c	50 ^f
Make conditions						
Utilization category	I/I_e	U/U_e	$\cos \phi$	On-time s^b	Off-time s	Number of operating cycles
AC-3	10	1,05 ^d	a	0,05	10	50
AC-4	12	1,05 ^d	a	0,05	10	50

¹ I = current made. The making current is expressed in d.c. or a.c. r.m.s. symmetrical values but it is understood that for a.c. the peak value of the asymmetrical current corresponding to the power-factor of that circuit may assume a higher value.
 I_c = current made and broken, expressed in d.c. or a.c. r.m.s. symmetrical values.
 I_e = rated operational current.
 U = applied voltage.
 U_r = power frequency or d.c. recovery voltage.
 U_e = rated operational voltage.
 $\cos \phi$ = power-factor of test circuit.
 L/R = time-constant of test circuit.

^a $\cos \phi = 0,45$ for $I_e \leq 100$ A, $0,35$ for $I_e > 100$ A.
^b Time may be less than 0,05 s provided that contacts are allowed to become properly seated before re-opening.
^c See Table A.3.
^d For U/U_e a tolerance of ± 20 % is accepted.
^e The make conditions shall also be verified but may be combined with the make and break test if agreed by the manufacturer. The making current multiples are to be as shown for I/I_e and the breaking current as shown for I_c/I_e . The off-time is to be taken from Table A.3.
^f 25 operating cycles with one polarity and 25 operating cycles with reverse polarity.

Table A.3 – Relationship between current broken I_c and off-time for the verification of the rated making and breaking capacities

Current broken I_c A	Off-time s
$I_c \leq 100$	10
$100 < I_c \leq 200$	20
$200 < I_c \leq 300$	30
$300 < I_c \leq 400$	40
$400 < I_c \leq 600$	60
$600 < I_c \leq 800$	80
$800 < I_c \leq 1\,000$	100
$1\,000 < I_c \leq 1\,300$	140
$1\,300 < I_c \leq 1\,600$	180
$1\,600 < I_c$	240

The values of off-time may be reduced if agreed by the manufacturer.

A.5 Operational performance

Subclause 7.2.4.2 of IEC 60947-1 applies with the following additions.

Equipment shall be capable of making and breaking currents without failure under the conventional conditions stated in Table A.4 for the required utilization categories and the number of operations indicated therein.

Table A.4 – Operational performance – Conditions for making and breaking corresponding to several utilization categories

Utilization categories	Make and break conditions					
	I_c/I_e	U_r/U_e	$\cos \phi$	On-time s ^b	Off-time s	Number of operating cycles
AC-2	2,0	1,05	0,65 ^a	0,05	^c	6 000
AC-3	2,0	1,05	^a	0,05	^c	6 000
AC-4	6,0	1,05	^a	0,05	^c	6 000
			L/R ms			
DC-3	2,5	1,05	2,0	0,05	^c	6 000 ^d
DC-5	2,5	1,05	7,5	0,05	^c	6 000 ^d

I_c = current made or broken. The making current is expressed in d.c. or a.c. r.m.s. symmetrical values but it is understood that the actual value will be the peak value corresponding to the power-factor of the circuit.
 I_e = rated operational current.
 U_r = power frequency or d.c. recovery voltage.
 U_e = rated operational voltage.

^a $\cos \phi = 0,45$ for $I_e \leq 100$ A, 0,35 for $I_e > 100$ A.
^b Time may be less than 0,05 s provided that contacts are allowed to become properly seated before re-opening.
^c These off-times shall be not greater than the values specified in Table A.3.
^d 3 000 operating cycles with one polarity and 3 000 operating cycles with reverse polarity.

A.6 Mechanical durability

Subclause 7.2.4.3.1 of IEC 60947-1 applies with the following addition.

The preferred numbers of no-load operating cycles expressed in millions are

0,001 – 0,003 – 0,01 – 0,03 – 0,1 – 0,3 and 1.

If no mechanical endurance is stated by the manufacturer, a class of intermittent duty implies a minimum mechanical endurance corresponding to 8 000 h of operation at the highest corresponding frequency of operating cycles.

A.7 Electrical durability

Subclause 7.2.4.3.2 of IEC 60947-1 applies with the following addition.

The total number of on-load operating cycles shall be as declared by the manufacturer.

A.8 Verification of making and breaking capacities

See 8.3.3.3 except that the test values shall be in accordance with Tables A.2 and A.3.

With the agreement of the manufacturer, the tests of A.8 and A.9 may be conducted on the same sample.

A.9 Operational performance test

See 8.3.4.1 except that the test conditions shall be in accordance with Table A.4.

With the agreement of the manufacturer, the tests of A.8 and A.9 may be conducted on the same sample.

A.10 Special tests

Resistance to mechanical and/or electrical wear is demonstrated by the operational performance test detailed in A.9.

Where abnormal service conditions are expected (see also note to 7.2.4.3 of IEC 60947-1) the following tests may be necessary.

A.10.1 Mechanical durability test

A.10.1.1 Condition of the equipment for tests

The equipment shall be installed as for normal service; in particular, the conductors shall be connected in the same manner as for normal use.

During the test there shall be no voltage or current in the main circuit. The equipment may be lubricated before the test if lubrication is prescribed in normal service.

A.10.1.2 Operating conditions

The equipment shall be operated as in normal service.

A.10.1.3 Test procedure

- a) The tests are carried out at the frequency of operations corresponding to the class of intermittent duty. However, if the manufacturer considers that the equipment can satisfy the required conditions when using a higher frequency of operations, he may do so.
- b) The number of operating cycles to be carried out shall be not less than the number of no-load operating cycles stated by the manufacturer.
- c) After each tenth of the total number of operations has been carried out, it is permissible before carrying on with the test
 - to clean the whole equipment without dismantling;
 - to lubricate parts for which lubrication is prescribed by the manufacturer for normal service;
 - to adjust the travel and the pressure of the contacts if the design of the equipment enables this to be done.
- d) This maintenance work shall not include any replacement of parts.

A.10.1.4 Results to be obtained

Following the tests of mechanical durability, the equipment shall still be capable of complying with the normal operating conditions at room temperature. There shall be no loosening of the parts used for connecting the conductors.

A.10.2 Electrical durability test

With respect to its resistance to electrical wear, an equipment is, by convention, characterized by the number of on-load operating cycles, corresponding to the different utilization categories given in Table A.5 which can be made without repair or replacement.

In all cases, the speed and number of operating cycles shall be chosen by the manufacturer.

The tests shall be taken as valid if the values recorded in the test report differ from the values specified only within the tolerances stated in 8.3.2.2.2 of IEC 60947-1.

Tests shall be carried out with the equipment under the appropriate conditions of A.10.1.1 and A.10.1.2 using the test procedure, where applicable, of A.10.1.3, except that replacement of contacts is not permitted.

After the test, the equipment shall fulfil the normal operating conditions specified in 8.3.3.2 and withstand a dielectric test voltage of twice the rated operational voltage U_e , but not less than 1 000 V, applied only as specified in 8.3.3.4.1, item 4) b), of IEC 60947-1.

Table A.5 – Verification of the number of on-load operating cycles – Conditions for making and breaking corresponding to several utilization categories

Utilization categories	Values of the rated operational current	Make			Break		
		I/I_e	U/U_e	$\cos \phi^a$	I_c/I_e	U_r/U_e	$\cos \phi^a$
AC-2	All values	2,5	1	0,65	2,5	1	0,65
AC-3	$I_e \leq 17A$	6	1	0,65	1	0,17	0,65
	$I_e > 17A$	6	1	0,35	1	0,17	0,35
AC-4	$I_e \leq 17A$	6	1	0,65	6	1	0,65
	$I_e > 17A$	6	1	0,35	6	1	0,35
		I/I_e	U/U_e	L/R^b ms	I_c/I_e	U_r/U_e	L/R^b ms
DC-3	All values	2,5	1	2	2,5	1	2
DC-5	All values	2,5	1	7,5	2,5	1	7,5

I_e = rated operational current.
 U_e = rated operational voltage.
 I = current made. In a.c. the conditions for making are expressed in r.m.s. symmetrical values but it is understood that the peak value of asymmetrical current, corresponding the power-factor of the circuit, may assume a higher value.
 U = applied voltage.
 U_r = power frequency and d.c. recovery voltage.
 I_c = current broken.

^a Tolerance for $\cos \phi$: $\pm 0,05$.
^b Tolerance for L/R : ± 15 %.

Annex B (informative)

Items subject to agreement between manufacturer and user

NOTE For the purpose of this annex

- "agreement" is used in a very wide sense;
- "user" includes testing stations.

Annex J of IEC 60947-1 applies with regard to clauses and subclauses of this part, with the following additions.

Clause or subclause numbers of this part	Items
4.4	Switching of capacitors or of tungsten filament lamps
7.1.7.1 note	Locking in the closed position for particular applications
7.1.7.2	Operating time of auxiliary contacts provided for interlocking
7.2.4.2 and Table 4	Increase of the operating rate for the verification of the operational performance
8.3.3.3.1	Time interval greater than 30 s $\pm$ 10 s between close-open cycles for making and breaking capacity test of equipment of $I_{th} > 400$ A For categories AC-23A and AC-23B testing of making and breaking capacities by make cycles at 10 I_e followed by the same number of make-break cycles at 8 I_e
8.3.3.3.3	Verification of making and breaking capacities for utilization categories DC-22 and DC-23: replacement of the load of the test circuit by a motor
8.3.5.2.3	AC test circuit calibration for the short-circuit making capacity test in the case of d.c. equipment
Annex A A.4	Utilization categories other than those listed in Table A.2
Table A.1	Switching of rotor circuits, capacitors or tungsten filament lamps
A.8	Verification of making and breaking capacities
A.9	Operational performance test

Annex C (normative)

Single pole operated three pole switches

C.1 General

All requirements of this part apply except where modified by the following.

The test requirements according to this part for verification of making and breaking capacities, operational performance and conditional short-circuit withstand, apply to devices with poles operated simultaneously. They are therefore not suitable for three-phase switches operated pole by pole.

~~If a three pole operated switch of fundamentally the same design has been successfully tested, it is deemed to satisfy the requirements of this annex for an individually operated three pole device.~~

Important characteristics of three-phase switches operated pole by pole and relevant for the above mentioned tests are as follows.

- The three poles are operated individually and are positioned adjacent to each other.
The three phases can typically be situated beside each other (horizontal version, see Figure C.1 b)) or below each other (vertical version, see Figure C.1 a)).
- The sequence of operation of the poles is at the discretion of a skilled operator.
- The design of the individual poles shall be fundamentally the same.

The position of the device under test shall be defined by the manufacturer and stated in the test report.




Figure C.1 – Typical arrangements

C.2 Tests

When testing single pole operated three pole switches, the relevant test sequences of Table 10 shall be applied with the following identified tests, modified in accordance with Clause C.3:

- 8.3.3.3 Making and breaking capacities of test sequence I;
- 8.3.4.1 Operational performance of test sequence II;
- 8.3.6.2 Fuse protected short-circuit withstand. b) Making of test sequence IV.

C.3 Test set-up and sequence

C.3.1 Making and breaking capacities (8.3.3.3) and operational performance (8.3.4.1)

Test 1: With L1 and L2 closed, L3 is subjected to the required make-break operation cycle.

Test 2: With L2 closed and L3 open, L1 is subjected to the required make-break operation cycle.

All tests shall be performed in a three-phase test circuit according to Figure 5 of IEC 60947-1.

C.3.2 Fuse protected short-circuit test (8.3.6.2)

For the making test of the fuse-switch, the following test shall be applied.

With L1 open and L2 closed, L3 is subjected to the required make operation cycle. The test shall be performed in a three-phase test circuit according to Figure 11 of IEC 60947-1.

C.4 Condition of equipment after tests

The equipment shall comply with the relevant clauses of 8.3.3.3.6, 8.3.4.1.6 and 8.3.5.2.6.

C.5 Instructions for use

The manufacturer shall include within the product literature the following statement.

These devices are intended for power distribution systems where switching and/or isolation of an individual phase may be necessary and shall not be used for the switching of the primary circuit of three-phase equipment.

Bibliography

IEC 60447:2004, *Basic and safety principles for man-machine interface, marking and identification – Actuating principles*

IEC 60617-DB³, *Graphical symbols for diagrams*

³ "DB" refers to the IEC on-line database.

SOMMAIRE

AVANT-PROPOS	66
1 Généralités	68
1.1 Domaine d'application et objet	68
1.2 Références normatives	69
2 Termes et définitions	70
2.1 Généralités	73
2.2 Index alphabétique des termes	73
2.3 Termes et définitions	74
2.4 Résumé des types d'équipements	76
3 Classification	77
3.1 Suivant la catégorie d'emploi	77
3.2 Suivant le mode de manœuvre du matériel manœuvré manuellement	77
3.3 Suivant l'aptitude au sectionnement	78
3.4 Suivant le degré de protection assuré	78
4 Caractéristiques	78
4.1 Enumération des caractéristiques	78
4.2 Type du matériel	78
4.3 Valeurs assignées et valeurs limites pour le circuit principal	78
4.4 Catégorie d'emploi	80
4.5 Circuits de commande	81
4.6 Circuits auxiliaires	81
4.7 Relais et déclencheurs	82
4.8 Coordination avec les dispositifs de protection contre les courts-circuits (DPCC)	82
5 Informations sur le matériel	82
5.1 Nature des informations	82
5.2 Marquage	82
5.3 Instructions d'installation, de fonctionnement et d'entretien	83
6 Conditions normales de service, de montage et de transport	83
7 Dispositions relatives à la construction et au fonctionnement	83
7.1 Dispositions constructives	83
7.2 Dispositions relatives au fonctionnement	86
7.3 Compatibilité électromagnétique	89
8 Essais	92
8.1 Nature des essais	92
8.2 Essais de type pour les dispositions constructives	93
8.3 Fonctionnement	97
8.4 Essais de compatibilité électromagnétique	115
8.5 Essais spéciaux	116
Annexe A (normative) Matériel pour la commande directe d'un seul moteur	117
Annexe B (informative) Points faisant l'objet d'un accord entre le constructeur et l'utilisateur	123
Annexe C (normative) Interrupteurs tripolaires à commande unipolaire	124
Bibliographie	127

Figure 1 – Force F appliquée à l'organe de commande	96
---	----

Figure C.1 – Dispositions typiques	125
--	-----

Tableau 1 – Résumé des définitions des matériels	73
--	----

Tableau 2 – Catégories d'emploi	81
---------------------------------------	----

Tableau 3 – Vérification des pouvoirs assignés de fermeture et de coupure (voir 8.3.3.3) – Conditions d'établissement et de coupure correspondant aux diverses catégories d'emploi	87
--	----

Tableau 4 – Vérification du fonctionnement en service – Nombre de cycles de manœuvres suivant le courant assigné d'emploi	88
---	----

Tableau 5 – Paramètres du circuit d'essai pour le Tableau 4	88
---	----

Tableau 6 – Essais d'immunité	90
-------------------------------------	----

Tableau 7 – Limites d'émission	92
--------------------------------------	----

Tableau 8 – Force d'essai sur l'organe de commande	96
---	----

Tableau 9 – Liste des essais de type applicables à un matériel donné	97
--	----

Tableau 10 – Schéma d'ensemble des séquences d'essais	98
---	----

Tableau 11 – Séquence d'essais I: caractéristiques générales de fonctionnement	102
--	-----

Tableau 12 – Limites d'échauffement des bornes et des parties accessibles	105
---	-----

Tableau 13 – Séquence d'essais II: aptitude au fonctionnement en service	106
--	-----

Tableau 14 – Séquence d'essais III: aptitude au fonctionnement en court-circuit	108
---	-----

Tableau 15 – Séquence d'essais IV: courant de court-circuit conditionnel	113
--	-----

Tableau 16 – Séquence d'essais V: aptitude au fonctionnement en surcharge	115
---	-----

Tableau A.1 – Catégories d'emploi	118
---	-----

Tableau A.2 – Pouvoirs assignés de fermeture et de coupure correspondant aux diverses catégories d'emploi	118
---	-----

Tableau A.3 – Relation entre le courant coupé I_C et la durée de repos pour la vérification des pouvoirs assignés de fermeture et de coupure	119
--	-----

Tableau A.4 – Fonctionnement en service – Conditions d'établissement et de coupure correspondant aux diverses catégories d'emploi	120
---	-----

Tableau A.5 – Vérification du nombre de cycles de manœuvres en charge – Conditions d'établissement et de coupure correspondant aux diverses catégories d'emploi	122
---	-----

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

APPAREILLAGE À BASSE TENSION –

**Partie 3: Interrupteurs, sectionneurs, interrupteurs-sectionneurs
et combinés-fusibles**

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (CEI) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de la CEI). La CEI a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, la CEI – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de la CEI"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec la CEI, participent également aux travaux. La CEI collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de la CEI concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de la CEI intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de la CEI se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de la CEI. Tous les efforts raisonnables sont entrepris afin que la CEI s'assure de l'exactitude du contenu technique de ses publications; la CEI ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de la CEI s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de la CEI dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de la CEI et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) La CEI elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de la CEI. La CEI n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à la CEI, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de la CEI, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de la CEI ou de toute autre Publication de la CEI, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de la CEI peuvent faire l'objet de droits de brevet. La CEI ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets et de ne pas avoir signalé leur existence.

Cette version consolidée de la CEI 60947-3 comprend la troisième édition (2008) [documents 17B/1601/FDIS et 17B/1608/RVD] et son amendement 1 (2012) [documents 17B/1758/FDIS et 17B/1763/RVD]. Elle porte le numéro d'édition 3.1.

Le contenu technique de cette version consolidée est donc identique à celui de l'édition de base et à son amendement; cette version a été préparée par commodité pour l'utilisateur. Une ligne verticale dans la marge indique où la publication de base a été modifiée par l'amendement 1. Les ajouts et les suppressions apparaissent en rouge, les suppressions sont barrées.

La Norme internationale CEI 60947-3 a été établie par le sous-comité 17B: Appareillage à basse tension, du comité d'études 17 de la CEI: Appareillage.

Le document 17B/1601/FDIS, circulé comme amendement 3 auprès des Comités nationaux, a conduit à la publication de cette nouvelle édition.

Cette édition inclut les modifications techniques majeures suivantes par rapport à l'édition précédente:

- alignement avec la cinquième édition de la CEI 60947-1;
- une manœuvre de commutation sans courant est admise entre une manœuvre d'établissement et de coupure (Tableau 3);
- un nombre accru de manœuvres pour AC-23 est admis avec l'accord du fabricant (Tableau 3);
- la procédure d'essai simplifiée est corrigée, le point f) a été ajouté en 8.3.2.1.3;
- l'essai d'échauffement doit être réalisé au courant assigné d'emploi I_g au lieu du courant thermique conventionnel sous enveloppe I_{the} (8.3.3.1).

Cette publication a été rédigée selon les Directives ISO/CEI, Partie 2.

Une liste de toutes les parties de la série CEI 60947, présentées sous le titre général *Appareillage à basse tension*, peut être consultée sur le site web de la CEI.

La présente partie doit être utilisée conjointement avec la CEI 60947-1. La numérotation des paragraphes est parfois discontinue car elle se base sur la CEI 60947-1.

Le comité a décidé que le contenu de la publication de base et de ses amendements ne sera pas modifié avant la date de stabilité indiquée sur le site web de la CEI sous "<http://webstore.iec.ch>" dans les données relatives à la publication recherchée. A cette date, la publication sera

- reconduite,
- supprimée,
- remplacée par une édition révisée, ou
- amendée.

Le contenu des corrigenda de septembre 2012 et novembre 2013 a été pris en considération dans cet exemplaire.

IMPORTANT – Le logo "colour inside" qui se trouve sur la page de couverture de cette publication indique qu'elle contient des couleurs qui sont considérées comme utiles à une bonne compréhension de son contenu. Les utilisateurs devraient, par conséquent, imprimer cette publication en utilisant une imprimante couleur.

APPAREILLAGE À BASSE TENSION –

Partie 3: Interrupteurs, sectionneurs, interrupteurs-sectionneurs et combinés-fusibles

1 Généralités

Les dispositions des règles générales qui font l'objet de la CEI 60947-1 s'appliquent à la présente partie de la CEI 60947 lorsque celle-ci le précise. Les articles, paragraphes, tableaux, figures et annexes des règles générales qui sont ainsi applicables sont identifiés par référence à la CEI 60947-1, par exemple: 4.3.4.1 de la CEI 60947-1, Tableau 4 de CEI 60947-1, ou Annexe A de la CEI 60947-1.

1.1 Domaine d'application et objet

La présente partie de la CEI 60947 s'applique à l'appareillage suivant: interrupteurs, sectionneurs, interrupteurs-sectionneurs et combinés-fusibles, destinés à être insérés dans des circuits de distribution et des circuits de moteurs dont la tension assignée est inférieure ou égale à 1 000 V en courant alternatif ou à 1 500 V en courant continu.

Le constructeur doit spécifier le type, les grandeurs assignées et les caractéristiques de tous les fusibles incorporés, en conformité avec la norme correspondante.

La présente partie n'est pas applicable au matériel faisant partie du domaine d'application de la CEI 60947-2, de la CEI 60947-4-1 et de la CEI 60947-5-1; cependant, quand les interrupteurs et les combinés-fusibles faisant partie du domaine d'application de la présente partie sont normalement utilisés pour assurer le démarrage, l'accélération et/ou l'arrêt d'un moteur, ils doivent aussi répondre aux exigences supplémentaires figurant à l'Annexe A.

Les exigences pour les interrupteurs tripolaires à commande unipolaire se trouvent à l'Annexe C.

Les interrupteurs auxiliaires montés sur du matériel faisant partie du domaine d'application de la présente partie doivent satisfaire aux exigences de la CEI 60947-5-1.

La présente partie ne contient pas les exigences supplémentaires nécessaires au matériel électrique pour atmosphères explosives.

NOTE 1 Selon sa conception, un interrupteur (ou sectionneur) peut être appelé «interrupteur (sectionneur) rotatif», «interrupteur (sectionneur) à came», «interrupteur (sectionneur) à couteaux», etc.

NOTE 2 Dans la présente partie, la dénomination «interrupteur» s'applique aussi aux appareils appelés en français «commutateurs», destinés à modifier les connexions de plusieurs circuits et, notamment, à substituer une portion de circuit à une autre.

NOTE 3 De façon générale, dans le texte de la présente partie, les interrupteurs, les sectionneurs, les interrupteurs-sectionneurs et les combinés-fusibles seront appelés «matériel».

La présente partie a pour objet de fixer

- a) les caractéristiques du matériel;
- b) les conditions auxquelles doit répondre le matériel relativement
 - 1) au fonctionnement et au comportement en service normal;
 - 2) au fonctionnement et au comportement en cas de conditions anormales spécifiées, par exemple en cas de court-circuit;
 - 3) aux qualités diélectriques;

- c) les essais destinés à vérifier si ces conditions sont remplies et les méthodes à adopter pour ces essais;
- d) les indications à porter sur le matériel, ou celles fournies par le constructeur, par exemple dans le catalogue.

1.2 Références normatives

Les documents de référence suivants sont indispensables pour l'application du présent document. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

CEI 60050-441:1984, *Vocabulaire Electrotechnique International (VEI) – Chapitre 441: Appareillage et fusibles*
Amendement 1 (2000)

CEI 60269 (toutes les parties), *Fusibles basse tension*

CEI 60410:1973, *Plans et règles d'échantillonnage pour les contrôles par attributs*

CEI 60417-DB:2000¹, *Symboles graphiques utilisables sur le matériel*

CEI 60947-1:2007, *Appareillage à basse tension – Partie 1: Règles générales*
Amendement 1: 2010²

CEI 60947-2:2006, *Appareillage à basse tension – Partie 2: Disjoncteurs*

CEI 60947-4-1:2000, *Appareillage à basse tension – Partie 4-1: Contacteurs et démarreurs de moteurs – Contacteurs et démarreurs électromécaniques*
Amendement 1 (2002)
Amendement 2 (2005)

CEI 60947-5-1:2003, *Appareillage à basse tension – Partie 5-1: Appareils et éléments de commutation pour circuits de commande – Appareils électromécaniques pour circuits de commande*

CEI 61000-4-2:1995, *Compatibilité électromagnétique (CEM) – Partie 4-2: Techniques d'essai et de mesure – Essais d'immunité aux décharges électrostatiques*
Amendement 1 (1998)
Amendement 2 (2000)

CEI 61000-4-3:2006, *Compatibilité électromagnétique (CEM) – Partie 4-3: Techniques d'essai et de mesure – Essai d'immunité aux champs électromagnétiques rayonnés aux fréquences radioélectriques*
Amendement 1 (2007)

CEI 61000-4-4:2004, *Compatibilité électromagnétique (CEM) – Partie 4-4: Techniques d'essai et de mesure – Essais d'immunité aux transitoires électriques rapides en salves*

CEI 61000-4-5:2005, *Compatibilité électromagnétique (CEM) – Partie 4-5: Techniques d'essai et de mesure – Essai d'immunité aux ondes de choc*

CEI 61000-4-6:2003, *Compatibilité électromagnétique (CEM) – Partie 4-6: Techniques d'essai et de mesure – Immunité aux perturbations conduites, induites par les champs*

¹ «DB» réfère à la base de données en ligne de la CEI.

² Une édition consolidée existe comprenant la CEI 60947-1: 2007 et son Amendement 1: 2010.

radioélectriques

Amendement 1 (2004)

Amendement 2 (2006)

CISPR 11:2003, *Appareils industriels, scientifiques et médicaux (ISM) à fréquence radioélectrique – Caractéristiques de perturbations électromagnétiques – Limites et méthodes de mesure*

Amendement 1 (2004)

Amendement 2 (2006)

CISPR 22:2005, *Appareils de traitement de l'information – Caractéristiques des perturbations radioélectriques – Limites et méthodes de mesure*

Amendement 1 (2005)

Amendement 2 (2006)

2 Termes et définitions

Pour les besoins de la présente partie de la CEI 60947, les termes et définitions donnés dans la CEI 60050-441, la CEI 60947-1 ainsi que les suivants s'appliquent.

	Référence
G	
Combiné-fusibles.....	2.4
F	
Fusible-interrupteur.....	2.6
Fusible-interrupteur-sectionneur.....	2.10
Fusible-sectionneur.....	2.8
I	
Interrupteur (mécanique).....	2.1
Interrupteur à fusibles.....	2.5
Interrupteur-sectionneur.....	2.3
Interrupteur-sectionneur à fusibles.....	2.9
Interrupteur tripolaire à commande unipolaire.....	2.11
M	
Manœuvre à accumulation d'énergie (d'un appareil mécanique de connexion).....	2.16
Manœuvre dépendante manuelle (d'un appareil mécanique de connexion).....	2.13
Manœuvre indépendante manuelle (d'un appareil mécanique de connexion).....	2.14
Manœuvre semi-indépendante manuelle.....	2.15
S	
Sectionneur.....	2.2
Sectionneur à fusibles.....	2.7
Système à points de contact multiples.....	2.12

2.1

interrupteur (mécanique)

appareil mécanique de connexion capable d'établir, de supporter et d'interrompre des courants dans les conditions normales du circuit, y compris éventuellement les conditions spécifiées de surcharge en service, ainsi que de supporter pendant une durée spécifiée des courants dans des conditions anormales spécifiées du circuit telles que celles du court-circuit

NOTE Un interrupteur peut être capable d'établir des courants de court-circuit mais n'est pas capable de les couper.

[VEI 441-14-10]

2.2—**sectionneur**

~~appareil mécanique de connexion qui satisfait, en position d'ouverture, aux exigences spécifiées pour la fonction de sectionnement~~

~~[VEI 441-14-05, modifié]~~

~~NOTE 1 Cette définition diffère de celle du VEI 441-14-05, car elle fait référence à une fonction de sectionnement plutôt qu'à une distance de sectionnement.~~

~~NOTE 2 Un sectionneur est capable d'ouvrir et de fermer un circuit lorsqu'un courant d'intensité négligeable est interrompu ou établi, ou bien lorsqu'il ne se produit aucun changement notable de la tension aux bornes de chacun des pôles du sectionneur. Il est aussi capable de supporter des courants dans les conditions normales du circuit et de supporter des courants pendant une durée spécifiée dans des conditions anormales telles que celles du court-circuit.~~

2.3—**interrupteur-sectionneur**

~~interrupteur qui, dans sa position d'ouverture, satisfait aux conditions d'isolement spécifiées pour un sectionneur~~

~~[VEI 441-14-12]~~

2.4—**combiné-fusibles**

~~combinaison en un seul appareil, assemblé par le constructeur ou selon ses instructions, d'un appareil mécanique de connexion et d'un ou plusieurs fusibles~~

~~[VEI 441-14-04]~~

~~NOTE (Ne fait pas partie de la définition VEI 441-14-04.) Ce terme est un terme général pour les appareils de connexion à fusibles (voir également de 2.5 à 2.10 et le Tableau 1).~~

2.5—**interrupteur à fusibles**

~~interrupteur dans lequel un ou plusieurs pôles comportent un fusible en série dans un appareil combiné~~

~~[VEI 441-14-14]~~

2.6—**fusible-interrupteur**

~~interrupteur dans lequel un élément de remplacement ou un porte fusible avec son élément de remplacement forme le contact mobile~~

~~[VEI 441-14-17]~~

2.7—**sectionneur à fusibles**

~~sectionneur dans lequel un ou plusieurs pôles comportent un fusible en série dans un appareil combiné~~

~~[VEI 441-14-15]~~

2.8—**fusible-sectionneur**

~~sectionneur dans lequel un élément de remplacement ou un porte fusible avec son élément de remplacement forme le contact mobile~~

~~[VEI 441-14-18]~~

2.9—

interrupteur-sectionneur à fusibles

interrupteur-sectionneur dans lequel un ou plusieurs pôles comportent un fusible en série dans un appareil combiné

[VEI 441-14-16]

2.10—

fusible-interrupteur-sectionneur

interrupteur-sectionneur dans lequel un élément de remplacement ou un porte fusible avec son élément de remplacement forme le contact mobile

[VEI 441-14-19]

2.11—

interrupteur tripolaire à commande unipolaire

appareil comprenant trois interrupteurs unipolaires manœuvrables individuellement selon la présente partie, caractérisé comme une entité complète destinée à être utilisée dans un système triphasé

NOTE— Ces appareils sont destinés aux systèmes de distribution de puissance lorsque la commutation et/ou le sectionnement d'une phase individuelle peut être nécessaire; il convient de ne pas les utiliser pour la commutation du circuit primaire d'un matériel triphasé.

2.12—

système à points de contact multiples

système qui comprend plus d'un intervalle de contact par pôle pouvant être commutés en série et/ou en parallèle

2.13—

manœuvre dépendante manuelle (d'un appareil mécanique de connexion)

manœuvre effectuée exclusivement au moyen d'une énergie manuelle directement appliquée, de telle sorte que la vitesse et la force de la manœuvre dépendent de l'action de l'opérateur

[VEI 441-16-13]

2.14—

manœuvre indépendante manuelle (d'un appareil mécanique de connexion)

manœuvre à accumulation d'énergie dans laquelle l'énergie provient de l'énergie manuelle accumulée et libérée en une seule manœuvre continue, de telle sorte que la vitesse et la force de la manœuvre sont indépendantes de l'action de l'opérateur

[VEI 441-16-16]

2.15—

manœuvre semi-indépendante manuelle

manœuvre effectuée exclusivement au moyen d'une énergie manuelle directement appliquée, de telle sorte que la force manuelle est augmentée jusqu'à une valeur limite au delà de laquelle s'effectue la manœuvre indépendante de commutation, sauf si elle est intentionnellement retardée par l'opérateur

2.16—

manœuvre à accumulation d'énergie (d'un appareil mécanique de connexion)

manœuvre effectuée au moyen d'énergie emmagasinée dans le mécanisme lui-même avant l'achèvement de la manœuvre et suffisante pour achever la manœuvre dans des conditions prédéterminées

NOTE— Ce type de manœuvre peut être subdivisé suivant







- a) le mode d'accumulation de l'énergie (ressort, poids, etc.);
- b) la provenance de l'énergie (manuelle, électrique, etc.);

— c) le mode de libération de l'énergie (manuel, électrique, etc.).

[VEI 441 16 15]

Un résumé des définitions des matériels est donné au Tableau 1.

Tableau 1 — Résumé des définitions des matériels

Fonctions		
Etablissement et coupe du courant	Sectionnement	Etablissement, coupe et sectionnement
Interrupteur 2.1 	Sectionneur 2.2 	Interrupteur sectionneur 2.3 
Combiné fusibles 2.4		
Interrupteur à fusibles 2.5  a	Sectionneur à fusibles 2.7  a	Interrupteur sectionneur à fusibles 2.9  a
Fusible-interrupteur 2.6 	Fusible-sectionneur 2.8 	Fusible-interrupteur-sectionneur 2.10 
NOTE 1 — Tous les matériels peuvent être à simple coupe ou à plusieurs coupures. NOTE 2 — Les chiffres donnent les références des paragraphes des définitions correspondantes. NOTE 3 — Les symboles sont basés sur ceux de la CEI 60617-7.		
^a — Le fusible peut être sur l'un ou l'autre des côtés des contacts du matériel ou en position fixe par rapport à ceux-ci.		

2.1 Généralités

Pour les besoins du présent document, les termes et définitions donnés dans la CEI 60050-441 et dans la CEI 60947-1 s'appliquent conjointement avec les suivants.

2.2 Index alphabétique des termes

	Référence
C	
Combiné-fusibles	2.3.2
F	
Fusible-interrupteur	2.3.4
Fusible-interrupteur-sectionneur	2.3.8
Fusible-sectionneur	2.3.6
I	
Interrupteur à fusibles	2.3.3
Interrupteur-sectionneur à fusibles	2.3.7

Interrupteur tripolaire à commande unipolaire	2.3.9
M	

Manœuvre semi-indépendante manuelle	2.3.10
S	

Sectionneur	2.3.1
Sectionneur à fusibles	2.3.5

2.3 Termes et définitions

2.3.1

sectionneur

appareil mécanique de connexion qui satisfait, en position d'ouverture, aux exigences spécifiées pour la fonction de sectionnement

[CEI 60050-441:1984, 441-14-05, modifié]

NOTE 1 La présente définition diffère de la CEI 60050-441:1984, 441-14-05 en se référant à la fonction sectionnement à la place de la distance de sectionnement.

NOTE 2 Un sectionneur est capable d'ouvrir et de fermer un circuit lorsque, soit un courant négligeable est coupé ou établi, ou soit lorsque aucun changement significatif de la tension aux bornes de chaque pôle du sectionneur ne survient. Il est aussi capable de supporter des courants dans des conditions normales et de supporter, pour une durée spécifiée, des courants dans des conditions anormales telles que celles durant un court-circuit.

2.3.2

combiné-fusibles

combinaison en un seul appareil, assemblée par le constructeur ou selon ses instructions, d'un appareil mécanique de connexion et d'un ou plusieurs fusibles

[CEI 60050-441:1984, 441-14-04]

2.3.3

interrupteur à fusibles

interrupteur dans lequel un ou plusieurs pôles comportent un fusible en série dans un appareil combiné

[CEI 60050-441:1984, 441-14-14]

2.3.3.1

interrupteur à fusibles à coupure unique

interrupteur à fusibles qui ouvre le circuit sur un côté de la liaison fusible uniquement

2.3.3.2

interrupteur à fusibles à coupure double

interrupteur à fusibles qui ouvre le circuit des deux côtés de la liaison fusible

2.3.4

fusible-interrupteur

interrupteur dans lequel un élément de remplacement ou un porte-fusible avec son élément de remplacement forme le contact mobile

[CEI 60050-441:1984, 441-14-17]

2.3.4.1

fusible-interrupteur à coupure unique

fusible-interrupteur qui ouvre le circuit sur un côté de la liaison fusible uniquement

2.3.4.2**fusible-interrupteur à coupure double**

fusible-interrupteur qui ouvre le circuit des deux cotés de la liaison fusible

2.3.5**sectionneur à fusibles**

sectionneur dans lequel un ou plusieurs pôles comportent un fusible en série dans un appareil combiné

[CEI 60050-441:1984, 441-14-15]

2.3.5.1**sectionneur à fusibles à coupure unique**

sectionneur à fusibles qui ouvre le circuit sur un coté de la liaison fusible uniquement

2.3.5.2**sectionneur à fusibles à coupure double**

sectionneur à fusibles qui ouvre le circuit des deux cotés de la liaison fusible

2.3.6**fusible-sectionneur**

sectionneur dans lequel un élément de remplacement ou un porte-fusible avec son élément de remplacement forme le contact mobile

[CEI 60050-441:1984, 441-14-18]

2.3.6.1**fusible-sectionneur à coupure unique**

fusible-sectionneur qui ouvre le circuit sur un coté de la liaison fusible uniquement

2.3.6.2**fusible-sectionneur à coupure double**

fusible-sectionneur qui ouvre le circuit des deux cotés de la liaison fusible

2.3.7**interrupteur-sectionneur à fusibles**

interrupteur-sectionneur dans lequel un ou plusieurs pôles comportent un fusible en série dans un appareil combiné

[CEI 60050-441:1984, 441-14-16]

2.3.7.1**interrupteur-sectionneur à fusibles à coupure unique**

interrupteur-sectionneur à fusibles qui ouvre le circuit sur un coté de la liaison fusible uniquement

2.3.7.2**interrupteur-sectionneur à fusibles à coupure double**

interrupteur-sectionneur à fusibles qui ouvre le circuit des deux cotés de la liaison fusible

2.3.8**fusible-interrupteur-sectionneur**

Interrupteur-sectionneur dans lequel un élément de remplacement ou un porte-fusible avec son élément de remplacement forme le contact mobile

[CEI 60050-441:1984, 441-14-19]

2.3.8.1

fusible-interrupteur-sectionneur à coupure unique

fusible-interrupteur-sectionneur qui ouvre le circuit sur un côté de la liaison fusible uniquement

2.3.8.2

fusible-interrupteur-sectionneur à coupure double

fusible-interrupteur-sectionneur qui ouvre le circuit des deux côtés de la liaison fusible

2.3.9

interrupteur tripolaire à commande unipolaire

appareil comprenant trois interrupteurs unipolaires manœuvrables individuellement selon la présente partie, caractérisé comme entité complète destinée à être utilisée dans un système triphasé

NOTE Ces appareils sont destinés aux systèmes de distribution de puissance lorsque la commutation et/ou le sectionnement d'une phase individuelle peut être nécessaire; il convient de ne pas les utiliser pour la commutation du circuit primaire d'un matériel triphasé.

2.3.10















manœuvre semi-indépendante manuelle

manœuvre effectuée exclusivement au moyen d'une énergie manuelle directement appliquée, de telle sorte que la force manuelle est augmentée jusqu'à une valeur limite au-delà de laquelle s'effectue la manœuvre indépendante de commutation, sauf si elle est intentionnellement retardée par l'opérateur

2.4 Résumé des types d'équipements

Un résumé des définitions d'équipement et des diagrammes correspondants est donné dans le Tableau 1.

Tableau 1 – Résumé des définitions des matériels

Fonctions		
Etablissement et coupure du courant	Sectionnement	Etablissement, coupure et sectionnement
Interrupteur 	Sectionneur 	Interrupteur-sectionneur 
Combinés fusibles		
Interrupteur à fusibles à coupure unique  a	Sectionneur à fusibles à coupure unique ^b  a	Interrupteur-sectionneur à fusibles à coupure unique ^b  a
Interrupteur à fusibles à coupure double 	Sectionneur à fusibles à coupure double ^b 	Interrupteur-sectionneur à fusibles à coupure double ^b 
Fusible-interrupteur à coupure unique 	Fusible-sectionneur à coupure unique ^b 	Fusible-interrupteur-sectionneur à coupure unique ^b 
Fusible-interrupteur à coupure double 	Fusible-sectionneur à coupure double ^b 	Fusible-interrupteur-sectionneur à coupure double ^b 
NOTE 1 Un équipement présenté comme étant à coupure simple peut être à coupure double. NOTE 2 Les symboles sont basés sur ceux de la CEI 60617-7.		
a Le fusible peut être sur l'un ou l'autre des côtés des contacts du matériel ou en position fixe par rapport à ceux-ci. b Seule la coupure entre bornes d'entrée et de sortie est vérifiée par un essai.		

3 Classification

3.1 Suivant la catégorie d'emploi

Voir 4.4.

3.2 Suivant le mode de manœuvre du matériel manœuvré manuellement

- manœuvre dépendante manuelle (voir ~~2.13~~ 2.4.12 de la CEI 60947-1);
- manœuvre indépendante manuelle (voir ~~2.14~~ 2.4.15 de la CEI 60947-1);
- manœuvre semi-indépendante manuelle (voir ~~2.15~~ 2.3.10).

NOTE Le mode de manœuvre de fermeture peut être différent de celui d'ouverture.

3.3 Suivant l'aptitude au sectionnement

- apte au sectionnement (voir 7.1.7 de la CEI 60947-1 et 7.1.7.1);
- inapte au sectionnement.

3.4 Suivant le degré de protection assuré

Voir 7.1.12 de la CEI 60947-1.

4 Caractéristiques

4.1 Énumération des caractéristiques

Les caractéristiques du matériel doivent être indiquées de la façon suivante:

- type du matériel (voir 4.2);
- valeurs assignées et valeurs limites du circuit principal (voir 4.3);
- catégorie d'emploi (voir 4.4);
- circuits de commande (voir 4.5);
- circuits auxiliaires (voir 4.6);

4.2 Type du matériel

Il est nécessaire d'indiquer ~~ce qui suit~~ les informations suivantes:

- le nombre de pôles;
- la nature du courant (courant alternatif ou courant continu);
- dans le cas du courant alternatif, le nombre de phases et la fréquence assignée;
- le nombre de positions des contacts principaux (s'il en existe plus de deux);
- la disposition de coupure pour les dispositifs à fusibles (à coupure simple ou double).

4.2.1 Le nombre de pôles

4.2.2 La nature du courant

~~La nature du courant (courant alternatif ou courant continu) et, dans le cas du courant alternatif, le nombre de phases et la fréquence assignée.~~

4.2.3 Le nombre de positions des contacts principaux (s'il en existe plus de deux)

4.3 Valeurs assignées et valeurs limites pour le circuit principal

Les valeurs assignées sont fixées par le constructeur. Elles doivent être indiquées conformément à 4.3.1 et à 4.3.6.4, mais il n'est pas nécessaire de spécifier toutes les valeurs assignées énumérées.

4.3.1 Tensions assignées

Un matériel est défini par les tensions assignées suivantes.

4.3.1.1 Tension assignée d'emploi (U_e)

Le Paragraphe 4.3.1.1 de la CEI 60947-1 s'applique.

4.3.1.2 Tension assignée d'isolement (U_i)

Le Paragraphe 4.3.1.2 de la CEI 60947-1 s'applique.

4.3.1.3 Tension assignée de tenue aux chocs (U_{imp})

Le Paragraphe 4.3.1.3 de la CEI 60947-1 s'applique.

4.3.2 Courants

Le matériel est défini par les courants suivants.

4.3.2.1 Courant thermique conventionnel à l'air libre (I_{th})

Le Paragraphe 4.3.2.1 de la CEI 60947-1 s'applique.

4.3.2.2 Courant thermique conventionnel sous enveloppe (I_{the})

Le Paragraphe 4.3.2.2 de la CEI 60947-1 s'applique.

4.3.2.3 Courants assignés d'emploi (I_e) (ou puissances assignées d'emploi)

Le Paragraphe 4.3.2.3 de la CEI 60947-1 s'applique.

4.3.2.4 Courant assigné ininterrompu (I_u)

Le Paragraphe 4.3.2.4 de la CEI 60947-1 s'applique.

4.3.3 Fréquence assignée

Le Paragraphe 4.3.3 de la CEI 60947-1 s'applique.

4.3.4 Service assigné

Les services assignés considérés comme normaux sont les suivants.

4.3.4.1 Service continu (service de 8 h)

Le Paragraphe 4.3.4.1 de la CEI 60947-1 s'applique.

4.3.4.2 Service ininterrompu

Le Paragraphe 4.3.4.2 de la CEI 60947-1 s'applique.

4.3.5 Caractéristiques en conditions normales de charge et de surcharge

4.3.5.1 Aptitude à supporter les courants de surcharge occasionnés par le démarrage de moteurs

Voir Annexe A.

4.3.5.2 Pouvoir assigné de fermeture

Le Paragraphe 4.3.5.2 de la CEI 60947-1 s'applique avec les compléments suivants.

Le pouvoir assigné de fermeture est exprimé en fonction de la tension assignée d'emploi et du courant assigné d'emploi ainsi que de la catégorie d'emploi, conformément au Tableau 3.

Ne s'applique pas aux matériels AC-20 ou DC-20.

4.3.5.3 Pouvoir assigné de coupure

Le Paragraphe 4.3.5.3 de la CEI 60947-1 s'applique avec les compléments suivants.

Le pouvoir assigné de coupure est exprimé en fonction de la tension assignée d'emploi et du courant assigné d'emploi ainsi que de la catégorie d'emploi, conformément au Tableau 3.

Ne s'applique pas aux matériels AC-20 ou DC-20.

4.3.6 Caractéristiques de court-circuit

4.3.6.1 Courant assigné de courte durée admissible (I_{cw})

Le courant assigné de courte durée admissible d'un interrupteur, d'un sectionneur ou d'un interrupteur-sectionneur est la valeur du courant de courte durée admissible, fixée par le constructeur que le matériel peut supporter sans aucun dommage dans les conditions d'essai de 8.3.5.1.

La valeur du courant assigné de courte durée admissible ne doit pas être inférieure à douze fois le courant assigné d'emploi maximal et, sauf indication contraire du constructeur, sa durée doit être 1 s.

Dans le cas du courant alternatif, la valeur du courant est la valeur efficace de la composante alternative et il est admis que la valeur de crête maximale susceptible d'être atteinte ne dépasse pas n fois cette valeur efficace, le facteur n étant donné par le Tableau 16 de la CEI 60947-1.

4.3.6.2 Pouvoir assigné de fermeture en court-circuit (I_{cm})

~~Le pouvoir assigné de fermeture en court-circuit d'un interrupteur ou d'un interrupteur-sectionneur est la valeur de pouvoir de fermeture en court-circuit, fixée par le constructeur pour ce matériel pour la tension assignée d'emploi, la fréquence assignée (s'il y a lieu) et pour un facteur de puissance (ou une constante de temps) spécifié. Il s'exprime par la valeur maximale de crête du courant présumé.~~

~~En courant alternatif, la relation entre le facteur de puissance, la valeur de crête du courant présumé et la valeur efficace du courant doit être conforme au Tableau 16 de la CEI 60947-1.~~

~~Ne s'applique pas aux matériels AC-20 ou DC-20.~~

~~Le 4.3.6.2 de la CEI 60947-1 s'applique avec le complément suivant.~~

~~NOTE I_{cm} n'est pas applicable aux dispositifs à fusibles.~~

4.3.6.3 Disponible

4.3.6.4 Courant assigné de court-circuit conditionnel

Le Paragraphe 4.3.6.4 de la CEI 60947-1 s'applique.

4.4 Catégorie d'emploi

Les catégories d'emploi définissent les applications prévues et figurent au Tableau 2.

Chaque catégorie d'emploi est caractérisée par les valeurs des courants et des tensions, exprimées en multiples du courant assigné d'emploi et de la tension assignée d'emploi, ainsi que par les facteurs de puissance ou les constantes de temps du circuit. Les conditions d'établissement et de coupure données au Tableau 3 correspondent en principe aux applications énumérées au Tableau 2.

La désignation des catégories d'emploi est complétée par le suffixe A ou le suffixe B suivant que les applications prévues demandent des manœuvres fréquentes ou des manœuvres non fréquentes (voir Tableau 4).

Les catégories d'emploi comportant le suffixe B conviennent aux appareils qui, en raison de leur conception ou de leur utilisation, ne sont prévus que pour des manœuvres non fréquentes. Cela pourrait, par exemple, être le cas d'un sectionneur qui n'est manœuvré que pour effectuer un sectionnement pour des travaux d'entretien, ou d'appareils de connexion dont la lame de l'élément de remplacement constitue le contact mobile.

La distinction entre manœuvres fréquentes et manœuvres non fréquentes est basée sur la caractéristique assignée de fonctionnement déclarée par le constructeur et le nombre de cycles de manœuvres utilisé comme critère d'essai dans le Tableau 4.

Pour un courant assigné particulier de fonctionnement I_e , un appareil sera désigné pour usage fréquent (catégorie A) si la durée de vie assignée de fonctionnement fixée par le constructeur est supérieure au nombre de cycles de manœuvres indiqué dans les colonnes 3, 4 ou 5 du Tableau 4.

Tableau 2 – Catégories d'emploi

Nature du courant	Catégorie d'emploi		Applications caractéristiques
	Catégorie A	Catégorie B	
Courant alternatif	AC-20A ^a	AC-20B ^a	– Fermeture et ouverture à vide
	AC-21A	AC-21B	– Charges résistives, y compris surcharges modérées
	AC-22A	AC-22B	– Charges mixtes résistives et inductives, y compris surcharges modérées
	AC-23A	AC-23B	– Charges constituées par des moteurs ou autres charges fortement inductives
Courant continu	DC-20A ^a	DC-20B ^a	– Fermeture et ouverture à vide
	DC-21A	DC-21B	– Charges résistives, y compris surcharges modérées
	DC-22A	DC-22B	– Charges mixtes résistives et inductives, y compris surcharges modérées (par exemple: moteurs shunt)
	DC-23A	DC-23B	– Charges fortement inductives (par exemple: moteurs série)
^a Ces catégories d'emploi ne sont pas admises aux USA.			

La catégorie AC-23 comprend la commande occasionnelle d'un seul moteur. La commande de condensateurs ou de lampes à filament de tungstène doit faire l'objet d'un accord entre le constructeur et l'utilisateur.

Les catégories d'emploi mentionnées aux Tableaux 2 et 3 ne s'appliquent pas à un matériel normalement utilisé pour assurer le démarrage, l'accélération et/ou l'arrêt d'un seul moteur. Les catégories d'emploi pour un tel matériel sont traitées dans l'Annexe A.

4.5 Circuits de commande

Le Paragraphe 4.5 de la CEI 60947-1 s'applique.

4.6 Circuits auxiliaires

Le Paragraphe 4.6 de la CEI 60947-1 s'applique.

4.7 Relais et déclencheurs

Le Paragraphe 4.7 de la CEI 60947-1 s'applique.

4.8 Coordination avec les dispositifs de protection contre les courts-circuits (DPCC)

Le paragraphe 4.8 de la CEI 60947-1 s'applique.

5 Informations sur le matériel

5.1 Nature des informations

Le Paragraphe 5.1 de la CEI 60947-1 s'applique de façon appropriée pour un modèle particulier.

5.2 Marquage

5.2.1 Chaque matériel doit porter de façon indélébile et lisible les indications suivantes.

Les marques pour a), b) et c) ci-dessous doivent se trouver sur le matériel lui-même ou sur une ou plusieurs plaques signalétiques fixées au matériel, et ces marques doivent être situées dans un endroit tel qu'elles soient visibles et lisibles de face lorsque le matériel est monté selon les instructions du constructeur.

- a) Indication de la position d'ouverture et de la position de fermeture. La position d'ouverture et la position de fermeture doivent être indiquées respectivement par les symboles graphiques 60417-IEC-5007 et 60417-IEC-5008 de la CEI 60417-2 (voir 7.1.6.1 de la CEI 60947-1).
- b) Aptitude au sectionnement.
Les symboles appropriés du Tableau 1 doivent être utilisés.
- c) Marquage supplémentaire des sectionneurs.

Les appareils de catégorie d'emploi AC-20A, AC-20B, DC-20A et DC-20B doivent porter la mention «Ne pas manœuvrer en charge», à moins que l'appareil ne soit muni d'un verrouillage empêchant une telle manœuvre.

NOTE Les symboles des différents types de matériel sont donnés au Tableau 1.

5.2.2 Les indications suivantes doivent aussi être marquées sur le matériel mais il n'est pas nécessaire qu'elles soient visibles de face lorsque le matériel est monté:

- a) nom du constructeur ou marque de fabrique;
- b) désignation du type ou numéro de série;
- c) courants assignés d'emploi (ou puissances assignées) à la tension assignée d'emploi, et catégorie d'emploi (voir 4.3.1, 4.3.2 et 4.4);
- d) valeur (ou domaine) de la fréquence assignée, ou indication «continu» (ou le symbole $\equiv$);
- e) pour les combinés-fusibles, le type et le courant assigné maximal des fusibles et la puissance dissipée de l'élément de remplacement;
- f) CEI 60947-3, si le constructeur déclare la conformité à la présente partie;
- g) degré de protection du matériel sous enveloppe (voir Annexe C de la CEI 60947-1).

5.2.3 Les bornes suivantes doivent être identifiées:

- a) bornes d'entrée et de sortie, à moins que le raccordement n'ait pas d'importance (voir 8.3.3.3.1);
- b) borne du pôle neutre, s'il y a lieu, par la lettre «N» (voir 7.1.8.4 de la CEI 60947-1);
- c) borne de terre de protection (voir 7.1.10.3 de la CEI 60947-1).

5.2.4 Les indications suivantes doivent figurer dans les informations fournies par le constructeur:

- a) tension assignée d'isolement;
- b) tension assignée de tenue aux chocs pour les matériels aptes au sectionnement, ou lorsqu'elle est déterminée;
- c) degré de pollution, s'il est différent de 3;
- d) service assigné;
- e) courant assigné de courte durée admissible et sa durée, le cas échéant;
- f) pouvoir assigné de fermeture en court-circuit, le cas échéant;
- g) courant assigné de court-circuit conditionnel, le cas échéant.

5.3 Instructions d'installation, de fonctionnement et d'entretien

Le Paragraphe 5.3 de la CEI 60947-1 s'applique.

6 Conditions normales de service, de montage et de transport

L'Article 6 de la CEI 60947-1 s'applique, avec le complément suivant.

Degré de pollution (voir 6.1.3.2 de la CEI 60947-1).

Sauf spécification contraire du constructeur, le matériel est prévu pour être installé dans les conditions d'environnement du degré de pollution 3.

7 Dispositions relatives à la construction et au fonctionnement

7.1 Dispositions constructives

Le Paragraphe 7.1 de la CEI 60947-1 s'applique avec les compléments suivants.

7.1.2 Matériaux

~~L'aptitude des matériaux utilisés doit être vérifiée par rapport à la résistance à la chaleur anormale et au feu en réalisant les essais~~

- ~~a) sur le matériel; ou~~
- ~~b) sur des parties prises sur le matériel; ou~~
- ~~c) sur des échantillons de matériau identique et de section représentative.~~

~~Lorsqu'un matériau identique ayant une section représentative a déjà satisfait aux exigences, il n'y a pas lieu de répéter ces essais.~~

(Vide)

7.1.2.2 Essai au fil incandescent

Le Paragraphe 7.1.2.2 de la CEI 60947-1 s'applique avec les compléments suivants.

Les pièces en matériau isolant nécessaires au maintien en position des parties conductrices doivent satisfaire à l'essai au fil incandescent de 8.2.1.1.1 de la CEI 60947-1 à une température d'essai de 960 °C.

7.1.4 Distances d'isolement et lignes de fuite

~~Le Paragraphe 7.1.4 de la CEI 60947-1 s'applique avec le complément suivant.~~

~~Des recommandations pour la mesure des distances d'isolement et des lignes de fuite sont données dans l'Annexe G de la CEI 60947-1.~~

(Vide)

7.1.7 Exigences supplémentaires pour les matériels aptes au sectionnement

Le Paragraphe 7.1.7 de la CEI 60947-1 s'applique avec les compléments suivants.

7.1.7.1 Dispositions constructives supplémentaires

Le matériel doit être marqué conformément à 5.2.1 b).

Lorsqu'il n'existe aucune indication de la position des contacts, par exemple au moyen de l'organe de manœuvre ou d'un indicateur séparé, tous les contacts principaux doivent être nettement visibles en position d'ouverture.

La robustesse du mécanisme transmetteur et la fiabilité de l'indication de la position d'ouverture doivent être vérifiées conformément à 8.2.5. En outre, lorsqu'il existe des dispositifs fournis par le constructeur, pour verrouiller le matériel en position d'ouverture, le verrouillage ne doit être possible que si les contacts principaux sont en position d'ouverture (voir 8.2.5).

Cette exigence n'est pas applicable au matériel dont les contacts principaux sont visibles en position d'ouverture et/ou la position d'ouverture est indiquée par des moyens autres que l'organe de commande.

NOTE Le verrouillage en position de fermeture est admis pour des applications particulières.

L'intervalle de coupure entre les contacts ouverts d'un même pôle en position d'ouverture ne doit pas être inférieur aux distances d'isolement minimales figurant au Tableau 13 de la CEI 60947-1 et il doit également répondre aux exigences de 7.2.3.1 b) de la CEI 60947-1.

7.1.7.2 Exigences supplémentaires pour le matériel assurant le verrouillage électrique avec des contacteurs ou des disjoncteurs

~~Lorsqu'un matériel apte au sectionnement est équipé d'un interrupteur auxiliaire pour le verrouillage électrique avec un ou des contacteurs ou un ou des disjoncteurs et est prévu pour être utilisé dans des circuits de moteur, les exigences suivantes doivent s'appliquer, sauf si le matériel est classé pour la catégorie d'emploi AC-23.~~

~~Un interrupteur auxiliaire doit être classé selon la CEI 60947-5-1 comme fixé par le constructeur.~~

~~L'intervalle de temps entre les ouvertures des contacts de l'interrupteur auxiliaire et des contacts des pôles principaux doit être suffisant pour que le contacteur ou le disjoncteur associé coupe le courant avant l'ouverture des pôles principaux du matériel.~~

~~Sauf exigence contraire dans la documentation technique du constructeur, l'intervalle de temps ne doit pas être inférieur à 20 ms lorsque le matériel est manœuvré selon les instructions du constructeur.~~

~~La conformité doit être vérifiée en mesurant l'intervalle de temps entre l'instant de l'ouverture de l'interrupteur auxiliaire et l'instant de l'ouverture à vide des pôles principaux lorsque le matériel est manœuvré selon les instructions du constructeur.~~

~~Pendant la manœuvre de fermeture, les contacts de l'interrupteur auxiliaire doivent se fermer après ou en même temps que les contacts des pôles principaux.~~

~~Un intervalle de temps d'ouverture convenable peut également être assuré par une position intermédiaire (entre les positions MARCHÉ et ARRÊT) pour laquelle le ou les contacts de verrouillage sont ouverts et les pôles principaux restent fermés.~~

(Vide)

7.1.7.3 Exigences supplémentaires pour le matériel équipé de moyens de verrouillage par cadenas de la position d'ouverture

~~Les moyens de verrouillage doivent être conçus de telle façon qu'ils ne puissent pas être retirés lorsque le ou les cadenas appropriés sont installés. Lorsque le matériel est verrouillé même par un seul cadenas, il ne doit pas être possible en manœuvrant l'organe de commande, de réduire la distance d'isolement entre les contacts ouverts de telle façon qu'elle ne satisfasse plus aux exigences de 7.2.3.1 b) de la CEI 60947-1.~~

~~En variante, on peut par conception fournir des moyens de verrouillage par cadenas interdisant l'accès à l'organe de commande.~~

~~La conformité aux exigences concernant le verrouillage de l'organe de commande doit être vérifiée en utilisant un cadenas spécifié par le constructeur ou un calibre équivalent, fournissant les conditions les plus contraignantes pour simuler un verrouillage. La force F , spécifiée en 8.2.5.2, doit être appliquée à l'organe de commande afin d'essayer de manœuvrer le matériel de la position d'ouverture à la position de fermeture. La force F étant maintenue, le matériel doit être soumis à une tension d'essai entre les contacts ouverts. Le matériel doit être capable de supporter la tension d'essai requise conformément au Tableau 14 de la CEI 60947-1 pour la tension assignée de tenue aux chocs.~~

(Vide)

7.1.9 Exigences supplémentaires pour les matériels dotés d'un pôle neutre

~~Le Paragraphe 7.1.9 de la CEI 60947-1 s'applique, sauf en ce qui concerne la note relative à un déclencheur à maximum de courant.~~

7.1.12 Degrés de protection du matériel sous enveloppe

~~Les degrés de protection du matériel sous enveloppe et les essais appropriés sont donnés à l'Annexe C de la CEI 60947-1.~~

(Vide)

7.2 Dispositions relatives au fonctionnement

7.2.1 Conditions de fonctionnement

7.2.1.1 Généralités

Le Paragraphe 7.2.1.1 de la CEI 60947-1 s'applique avec les compléments suivants.

Les exigences suivantes s'appliquent aux fusibles-interrupteurs, fusibles-sectionneurs et aux fusibles-interrupteurs-sectionneurs dont le pouvoir assigné de fermeture en court-circuit excède 10 kA et pour lesquels la manœuvre de fermeture est faite par une commande manuelle directe sans interposition de mécanisme (manœuvre dépendante et semi-dépendante manuelle voir ~~2.13 et 2.15~~ 2.4.12 de la CEI 60947-1 et 2.3.10).

La vitesse d'essai pour les manœuvres de fermeture spécifiée en 8.3.6.2 doit être déterminée comme suit.

- a) Le matériel doit subir 15 manœuvres manuelles à vide selon les instructions du constructeur, 5 manœuvres par chacune des trois personnes. La vitesse de l'organe de commande manuelle au moment de la fermeture des contacts (fermeture du dernier contact) doit être déterminée par un oscillographe ou tout autre moyen approprié à toute partie convenable du système.

Le point de mesure et la vitesse à ce point de mesure doivent être notés dans le rapport d'essais. La vitesse moyenne doit être déterminée après suppression de la valeur la plus haute et de la valeur la plus basse.

- b) Il faut s'assurer qu'avec l'appareillage d'essai le matériel en essai ferme totalement et qu'il n'y a aucune entrave au mouvement de fermeture libre du système. La vitesse réelle d'essai ne doit pas dépasser la vitesse moyenne déterminée selon a).

La masse des parties mobiles de l'appareillage d'essai (sans le matériel en essai) doit être égale à $2 \text{ kg} \pm 10 \%$.

7.2.1.2 Limites de fonctionnement des matériels à manœuvre à source d'énergie extérieure

Le paragraphe 7.2.1.2 de la CEI 60947-1 s'applique.

7.2.1.3 Limites de fonctionnement des relais et déclencheurs à minimum de tension

Le paragraphe 7.2.1.3 de la CEI 60947-1 s'applique.

7.2.1.4 Limites de fonctionnement des déclencheurs shunts

Le paragraphe 7.2.1.4 de la CEI 60947-1 s'applique.

7.2.2 Echauffement

Le Paragraphe 7.2.2 de la CEI 60947-1 s'applique avec le complément suivant.

Dans le cas des combinés-fusibles, l'échauffement des contacts de l'élément de remplacement au cours de l'essai de 8.3.3.1 ne doit provoquer aucun dommage susceptible de nuire au fonctionnement ultérieur du matériel au cours de la séquence d'essais I.

7.2.3 Propriétés diélectriques

Le Paragraphe 7.2.3 de la CEI 60947-1 s'applique avec les compléments suivants.

7.2.4.2 Fonctionnement en service

Les essais concernant la vérification du fonctionnement en service d'un matériel sont destinés à vérifier que ce matériel peut établir et couper sans défaillance les courants traversant son circuit principal pour l'emploi prévu.

Le nombre de cycles de manœuvres et les paramètres de circuit d'essai pour l'essai de fonctionnement en service suivant les diverses catégories d'emploi sont donnés dans les Tableaux 4 et 5.

Les modalités d'essai sont spécifiées en 8.3.4.1.

**Tableau 4 – Vérification du fonctionnement en service –
Nombre de cycles de manœuvres suivant le courant assigné d'emploi**

1	2	3	4	5	6	7	8
Courant assigné d'emploi I_e	Nombre de cycles de manœuvres par heure	Nombre de cycles de manœuvres					
		Catégorie A: courant alternatif et continu			Catégorie B: courant alternatif et continu		
		Sans courant	Avec courant	Total	Sans courant	Avec courant	Total
$0 < I_e \leq 100$	120	8 500	1 500	10 000	1 700	300	2 000
$100 < I_e \leq 315$	120	7 000	1 000	8 000	1 400	200	1 600
$315 < I_e \leq 630$	60	4 000	1 000	5 000	800	200	1 000
$630 < I_e \leq 2 500$	20	2 500	500	3 000	500	100	600
$2 500 < I_e$	10	1 500	500	2 000	300	100	400

Les valeurs de ce tableau s'appliquent à toutes les catégories d'emploi, sauf AC-20A, AC-20B, DC-20A et DC-20B. Ces catégories doivent satisfaire au nombre total de cycles de manœuvres des colonnes 5 ou 8, sans courant. La colonne 2 donne la cadence minimale de fonctionnement. La cadence de manœuvres pour toute catégorie d'emploi peut être augmentée avec l'accord du constructeur.

Tableau 5 – Paramètres du circuit d'essai pour le Tableau 4

Catégorie d'emploi	Valeur du courant assigné d'emploi I_e	Etablissement ^a			Coupure		
		I/I_e	U/U_e	$\cos \phi$	I_c/I_e	U_r/U_e	$\cos \phi$
AC-21A AC-21B	Toutes valeurs	1	1	0,95	1	1	0,95
AC-22A AC-22B	Toutes valeurs	1	1	0,8	1	1	0,8
AC-23A AC-23B	Toutes valeurs	1	1	0,65	1	1	0,65
		I/I_e	U/U_e	L/R ms	I_c/I_e	U_r/U_e	L/R ms
DC-21A DC-21B	Toutes valeurs	1	1	1	1	1	1
DC-22A DC-22B	Toutes valeurs	1	1	2	1	1	2
DC-23A DC-23B	Toutes valeurs	1	1	7,5	1	1	7,5

I = courant établi
 I_c = courant coupé
 I_e = courant assigné d'emploi
 U = tension avant établissement (tension appliquée)
 U_e = tension assignée d'emploi
 U_r = tension de rétablissement à fréquence industrielle ou en courant continu

^a En courant alternatif, le courant établi est exprimé par la valeur efficace de la composante périodique du courant.

7.2.4.3 Durabilité mécanique

Le Paragraphe 7.2.4.3.1 de la CEI 60947-1 s'applique. Les conditions d'essai sont spécifiées en 8.5.1.

7.2.4.4 Durabilité électrique

Le Paragraphe 7.2.4.3.2 de la CEI 60947-1 s'applique. Les conditions d'essai sont spécifiées en 8.5.2.

7.2.5 Aptitude à l'établissement, à la coupure ou à la tenue des courants de court-circuit

Le matériel doit être construit de manière à pouvoir supporter, dans les conditions spécifiées dans la présente partie, les contraintes thermiques, dynamiques et électriques occasionnées par des courants de court-circuit.

Les courants de court-circuit peuvent se produire durant les manœuvres d'établissement et d'interruption du courant et aussi lorsque le courant circule en position de fermeture.

L'aptitude du matériel à établir, transporter et couper les courants de court-circuit est exprimée en fonction d'une ou plusieurs des caractéristiques assignées suivantes.

- a) Courant assigné de courte durée admissible (voir 4.3.6.1).
- b) Pouvoir assigné de fermeture en court-circuit (voir 4.3.6.2).
- c) Courant assigné de court-circuit conditionnel (voir 4.3.6.4).

7.2.6 Disponible

7.2.7 Exigences supplémentaires de fonctionnement pour les matériels aptes au sectionnement

Ces exigences ne s'appliquent qu'aux matériels dont la tension assignée d'emploi est supérieure à 50 V.

Le matériel à l'état neuf avec ses contacts en position d'ouverture doit supporter l'essai diélectrique de 8.3.3.2.

Si des essais conformes à 8.3.3.3 et à 8.3.4.1 ont été effectués, le matériel doit, dans l'état où il se trouve après ces essais, répondre aux exigences de 8.3.3.5 relatives au courant de fuite.

7.2.8 Disponible

7.2.9 Exigences de surcharge pour un matériel comprenant des fusibles

Le circuit principal d'un matériel doit être capable de transporter un courant de surcharge conformément à 8.3.7.1 et ne doit causer aucun dommage susceptible de nuire au fonctionnement ultérieur du matériel dans la séquence d'essais V.

7.3 Compatibilité électromagnétique

7.3.1 Disponible

7.3.2 Immunité

~~**7.3.2.1 Matériels ne comprenant pas de circuits électroniques**~~

~~Les matériels couverts par la présente partie ne comprenant pas de circuits électroniques ne sont pas sensibles aux perturbations électromagnétiques dans les conditions normales de service et en conséquence aucun essai d'immunité n'est requis.~~

7.3.2.2 Matériels comprenant des circuits électroniques

Les matériels comprenant des circuits électroniques (par exemple indicateur électronique de fusion de fusible) doivent avoir une immunité satisfaisante vis-à-vis des perturbations électromagnétiques (voir 8.4.1.2).

Tableau 6 — Essais d'immunité

Type d'essai d'immunité	Norme fondamentale applicable	Niveau de sévérité requis
Décharge électrostatique	CEI 61000-4-2	Décharge dans l'air 8 kV ou décharge au contact 4 kV
Champ électromagnétique	CEI 61000-4-3	10 V/m
Transitoires rapides en sèves	CEI 61000-4-4	2 kV
Onde de choc	CEI 61000-4-5	2 kV (mode commun) 1 kV (mode différentiel)
Perturbations conduites, induites par des champs à fréquence radioélectrique	CEI 61000-4-6	10 V

NOTE — Un simple redresseur n'est pas sensible aux perturbations électromagnétiques en conditions normales de service et ne nécessite donc pas d'essai d'immunité.

Le paragraphe 7.3.2 de la CEI 60947-1 s'applique avec le complément suivant.

7.3.2.1 Matériel ne comprenant pas de circuits électroniques

Le paragraphe 7.3.2.1 de la CEI 60947-1 s'applique.

7.3.2.2 Matériel comprenant des circuits électroniques

Les matériels qui comprennent des circuits électroniques (par exemple un indicateur de fusion de fusible) doivent posséder une immunité satisfaisante aux perturbations électromagnétiques (voir 8.4.1.2).

Pour les essais appropriés pour vérifier la conformité à ces exigences, voir 8.4 de la CEI 60947-1.

Des critères spécifiques de performances doivent être donnés dans la norme produit applicable sur la base des critères d'acceptation donnés dans le Tableau 24 de la CEI 60947-1.

Le Tableau 6 fournit les critères spécifiques de performances en immunité à prendre en compte.

Tableau 6 – Essais d'immunité

Type d'essai	Niveau d'essai requis	Critère d'acceptation (tel que défini dans le Tableau 24 de la CEI 60947-1)
Essai d'immunité aux décharges électrostatiques CEI 61000-4-2	8 kV/ décharge dans l'air soit 4 kV/ décharge au contact	B
Essai d'immunité aux champs électromagnétiques rayonnés aux fréquences radioélectriques CEI 61000-4-3	10 V/m	A
Essai d'immunité aux transitoires électriques rapides en salve CEI 61000-4-4	2 kV / 5 kHz sur les accès de puissance 1 kV / 5 kHz sur les accès de signaux	B
Essai d'immunité aux ondes de choc CEI 61000-4-5	2 kV (mode commun) 1 kV (mode différentiel)	B
Perturbations conduites, induites par les champs radioélectriques CEI 61000-4-6	10 V	A
NOTE 1 Un simple redresseur n'est pas sensible aux perturbations électromagnétiques en service normal et par conséquent ne nécessite pas d'essai d'immunité.		
NOTE 2 Lorsque le critère d'acceptation B est spécifié, il ne doit pas y avoir de changement du statut des contacts principaux comme résultat de la perturbation.		

7.3.3 Emission

7.3.3.1 Matériels ne comprenant pas de circuits électroniques

~~Pour les matériels ne comprenant pas de circuits électroniques, les perturbations électromagnétiques peuvent seulement être produites pendant des manœuvres occasionnelles de commutation. La durée des perturbations est de l'ordre des millisecondes.~~

~~La fréquence, le niveau et les conséquences de ces émissions sont considérées comme faisant partie de l'environnement électromagnétique normal des installations à basse tension.~~

~~En conséquence, les exigences pour les émissions électromagnétiques sont considérées comme satisfaites et aucune vérification n'est nécessaire.~~

Le Paragraphe 7.3.3.1 de la CEI 60947-1 s'applique.

7.3.3.2 Matériels comprenant des circuits électroniques

Les matériels comprenant des circuits électroniques (par exemple un indicateur électronique de fusion de fusible) peuvent générer des perturbations électromagnétiques continues.

L'émission doit satisfaire aux exigences du groupe 1, classe A du CISPR 11 ou à celles de la classe A du CISPR 22 (voir 8.4.2.2).

Tableau 7 – Limites d'émission

Accès	Gamme de fréquences MHz	Limites ^d	Norme
Enveloppe ^b	30 à 230 ^a	30 dB (μV/m) valeur quasi-crête mesurée à une distance de 30 m ^c	CISPR 11
	230 à 1 000 ^a	37 dB (μV/m) valeur quasi-crête mesurée à une distance de 30 m ^c	Classe A - Groupe 1
Alimentation à courant alternatif	0,15 à 0,5 ^a	79 dB (μV) valeur quasi-crête 66 dB (μV) valeur moyenne	ou
	0,5 à 5 ^a	73 dB (μV) valeur quasi-crête 60 dB (μV) valeur moyenne	CISPR 22
	5 à 30 ^a	73 dB (μV) valeur quasi-crête 60 dB (μV) valeur moyenne	Classe A
^a La limite inférieure est applicable à la fréquence de transition. ^b Applicable seulement aux appareils de commutation mécaniques contenant des parties fonctionnant à des fréquences supérieures à 9 kHz, par exemple microprocesseurs. ^c Peut aussi être mesurée à une distance de 10 m en utilisant les limites augmentées de 10 dB, ou à une distance de 3 m en utilisant les limites augmentées de 20 dB. ^d Ces limites ont été reprises, sans modification, du CISPR 11 et du CISPR 22.			

Ces limites sont données pour des appareils de commutation mécaniques utilisés exclusivement dans un environnement industriel. Lorsqu'il existe une probabilité d'utilisation en dehors de l'environnement industriel, l'avertissement suivant doit être inclus dans les informations fournies par le constructeur.

Avertissement

Ceci est un produit de classe A. Dans un environnement domestique, ce produit peut provoquer une interférence radio qui, dans ce cas, peut obliger l'utilisateur à prendre les mesures appropriées.

Cependant, cet avertissement n'est pas nécessaire lorsque les limites d'émission données dans le CISPR 22, classe B sont respectées.

8 Essais

8.1 Nature des essais

8.1.1 Généralités

Le Paragraphe 8.1.1 de la CEI 60947-1 s'applique.

8.1.2 Essais de type

Le Paragraphe 8.1.2 de la CEI 60947-1 s'applique. Le Tableau 9 de la présente partie donne la liste des essais de type.

8.1.3 Essais individuels

Le Paragraphe 8.1.3 de la CEI 60947-1 s'applique avec les compléments suivants.

8.1.3.1 Généralités

Les essais suivants s'appliquent:

- essai de fonctionnement mécanique (voir 8.1.3.2)
le fonctionnement de l'interrupteur, du sectionneur, de l'interrupteur-sectionneur ou du combiné-fusibles durant la fabrication et/ou un autre essai individuel peuvent remplacer les essais énumérés ci-dessus, si les conditions restent les mêmes et si le nombre de manœuvres n'est pas inférieur à celui spécifié;
- essai diélectrique (voir 8.1.3.3)
si, par le contrôle des matériaux et des procédés de fabrication, l'intégrité des propriétés diélectriques a été prouvée, ces essais peuvent être remplacés par des essais sur des échantillons conformément à un plan d'échantillonnage reconnu (voir CEI 60410);

8.1.3.2 Essai de fonctionnement mécanique

Un essai doit être fait pour vérifier le fonctionnement mécanique correct du matériel en effectuant 5 manœuvres de fermeture et d'ouverture.

8.1.3.3 Essai diélectrique

Les conditions d'essai doivent être conformes à 8.3.3.4.2 de la CEI 60947-1. En variante, l'essai combiné selon 8.3.3.4.2, point 3), de la CEI 60947-1 est autorisé. La valeur de la tension d'essai doit être conforme à celle du Tableau 12A de la CEI 60947-1. La durée de l'essai ne doit pas être inférieure à 1 s et la tension d'essai doit être appliquée comme suit:

- le matériel étant en position d'ouverture, entre chaque paire de bornes qui sont connectées électriquement lorsque le matériel est en position de fermeture;
- le matériel étant en position de fermeture, entre chaque pôle et le ou les pôles adjacents et entre chaque pôle et le châssis;
- pour le matériel comprenant des circuits électroniques raccordés aux pôles principaux, le matériel étant en position d'ouverture, entre chaque pôle et le ou les pôles adjacents et entre chaque pôle et le châssis soit du côté entrée, soit du côté sortie selon la position des composants électroniques.

En variante, la déconnexion du ou des circuits électroniques est permise pendant les essais diélectriques.

8.1.4 Essais sur prélèvements

Les essais sur prélèvements pour la vérification des distances d'isolement doivent être faits conformément à 8.3.3.4.3 de la CEI 60947-1 conformément à un plan de prélèvement reconnu (voir CEI 60410).

8.1.5 Essais spéciaux

Les essais spéciaux (voir 2.6.4 de la CEI 60947-1) sont spécifiés en 8.5.

8.2 Essais de type pour les dispositions constructives

Le Paragraphe 8.2 de la CEI 60947-1 s'applique avec les compléments suivants.

8.2.4 Propriétés mécaniques des bornes

Le Paragraphe 8.2.4 de la CEI 60947-1 s'applique avec le complément suivant.

Lorsque le matériel est prévu pour être fourni avec différentes conceptions de bornes, les essais doivent être effectués sur chaque conception.

8.2.5 Vérification de l'efficacité de l'indication de position des contacts principaux des matériels aptes au sectionnement

Le Paragraphe 8.2.5 de la CEI 60947-1 s'applique avec les compléments suivants.

8.2.5.1 Etat du matériel pour les essais

L'essai du mécanisme de l'organe de commande et de l'indicateur de position doit être mené comme une partie de la séquence d'essais I (voir 8.3.3 et Tableau 11).

S'il existe différents types d'organes de commande, additionnels ou intégrés, une seule conception doit être soumise aux essais au cours de la séquence I. De plus, l'échantillon représentatif du cas le plus critique doit être essayé conformément à 8.3.3.7.

8.2.5.2 Modalités d'essai

8.2.5.2.1 Manœuvre manuelle dépendante et indépendante

~~La force nécessaire pour manœuvrer l'appareil vers la position d'ouverture doit être mesurée à l'extrémité de l'organe de commande. La force mesurée F doit être égale à la valeur moyenne de la force maximale obtenue à partir de 3 manœuvres consécutives, avec l'appareil à l'état neuf et propre. Cette force F doit ensuite être utilisée pour déterminer la force d'essai définie au Tableau 8.~~

~~Le matériel étant en position de fermeture, les contacts fixes et mobiles du pôle pour lequel l'essai est estimé être le plus sévère doivent être maintenus fermés par des moyens appropriés. L'organe de commande doit être soumis à la force d'essai définie au Tableau 8 suivant la nature de l'organe de commande. Lorsque l'appareil possède plus d'un système de contact en série, chaque système de contact doit être maintenu en position fermée.~~

~~Dans le cas de systèmes à points de contact multiples, le plus petit nombre de points de contact en parallèle, nécessaire pour maintenir le système de contact fermé, doit être fixé ensemble afin de permettre à la force d'essai d'être appliquée sans ouverture des contacts.~~

~~Le moyen approprié pour maintenir le ou les contacts fermés et le nombre de contacts doivent être spécifiés par le constructeur. Le nombre de contacts et la méthode doivent être consignés dans le rapport.~~

~~Cette force doit être appliquée sans secousse, à l'organe de commande dans le sens de l'ouverture des contacts pendant 10 s.~~

~~La direction de cette force, comme indiqué à la Figure 1, doit être conservée tout au long de l'essai.~~

~~Si des dispositifs de verrouillage sont prévus pour bloquer l'organe de commande en position d'ouverture, il ne doit pas être possible de bloquer l'organe de commande dans cette position pendant que la force d'essai est appliquée.~~

8.2.5.2.2 Manœuvre dépendante assurée par une source d'énergie extérieure

~~Le matériel étant en position de fermeture, les contacts fixes et mobiles du pôle pour lequel l'essai est estimé être le plus sévère doivent être fixés ensemble, par exemple par soudage. Lorsque l'appareil possède plus d'un système de contact en série, chaque système de contact doit être maintenu en position fermée.~~

~~Dans le cas de systèmes à points de contact multiples, le plus petit nombre de points de contact en parallèle, nécessaire pour maintenir le système de contact fermé, doit être fixé ensemble afin de permettre à la force d'essai d'être appliquée sans ouverture des contacts.~~

~~Le moyen approprié pour maintenir le ou les contacts fermés et le nombre de contacts doivent être spécifiés par le constructeur. Le nombre de contacts et la méthode doivent être consignés dans le rapport.~~

~~La tension d'alimentation égale à 110 % de sa valeur normale assignée doit être appliquée à la commande assurée par une source d'énergie extérieure afin d'essayer d'ouvrir le système de contact du matériel.~~

~~Trois tentatives pour manœuvrer le matériel à des intervalles de 5 min par la commande assurée par une source d'énergie extérieure doivent être faites, chacune d'elles pendant une durée de 5 s, à moins qu'un dispositif de protection associé à la commande assurée par une source d'énergie extérieure ne limite le temps à une durée plus courte.~~

~~La vérification doit être faite selon 8.2.5.3.2.~~

~~NOTE Aux USA, les appareils satisfaisant à ces exigences supplémentaires ne sont pas acceptés comme assurant le sectionnement par eux-mêmes. Les procédures et exigences de sectionnement sont traitées dans les lois fédérales appropriées et dans les normes d'entretien.~~

8.2.5.2.3 Manœuvre indépendante assurée par une source d'énergie extérieure

~~Le matériel étant en position de fermeture, les contacts fixes et mobiles du pôle pour lequel l'essai est estimé être le plus sévère doivent être fixés ensemble, par exemple par soudage. Lorsque l'appareil possède plus d'un système de contact en série, chaque système de contact doit être maintenu en position fermée.~~

~~Dans le cas de systèmes à points de contact multiples, le plus petit nombre de points de contact en parallèle, nécessaire pour maintenir le système de contact fermé, doit être fixé ensemble afin de permettre à la force d'essai d'être appliquée sans ouverture des contacts.~~

~~Le moyen approprié pour maintenir le ou les contacts fermés et le nombre de contacts doivent être spécifiés par le constructeur. Le nombre de contacts et la méthode doivent être consignés dans le rapport.~~

~~L'énergie emmagasinée de la commande assurée par une source d'énergie extérieure doit être libérée afin d'essayer d'ouvrir le système de contact du matériel.~~

~~Trois tentatives pour manœuvrer le matériel par déblocage de l'énergie emmagasinée doivent être effectuées.~~

~~La vérification doit être faite selon 8.2.5.3.2.~~

~~NOTE Aux USA, les appareils satisfaisant à ces exigences supplémentaires ne sont pas acceptés comme assurant le sectionnement par eux-mêmes. Les procédures et exigences de sectionnement sont traitées dans les lois fédérales appropriées et dans les normes d'entretien.~~

~~(Vide)~~

8.2.5.3 Condition des matériels pendant et après l'essai

8.2.5.3.1 Manœuvre manuelle dépendante et indépendante

~~Après l'essai, lorsque la force d'essai n'est plus appliquée à l'organe de commande, celui-ci étant laissé libre, l'indication de la position d'ouverture ne doit pas être inexacte.~~

Tableau 8 — Force d'essai sur l'organe de commande

Type de l'organe de commande	Force d'essai	Force d'essai minimale N	Force d'essai maximale N
Bouton-poussoir (voir Figure 1a)	$3 F$	50	150
Manœuvre à un doigt (voir Figure 1b)	$3 F$	50	150
Manœuvre à deux doigts (voir Figure 1c)	$3 F$	100	200
Manœuvre à une main (voir Figure 1d et 1e)	$3 F$	150	400
Manœuvre à deux mains (voir Figure 1f)	$3 F$	200	600
Manœuvre à deux mains (voir Figure 1g)	$3 F$	200	600

F est la force normale de manœuvre à l'état neuf. La force d'essai doit être $3 F$ avec les valeurs minimales et maximales fixées et appliquées comme indiqué à la Figure 1.

8.2.5.3.2 — Manœuvre dépendante et indépendante assurée par une source d'énergie extérieure

Pendant et après l'essai, la position d'ouverture ne doit pas être indiquée quel que soit le moyen fourni, et le matériel ne doit pas montrer de dommage nuisant à son fonctionnement normal.

Lorsque le matériel est muni de dispositifs de cadenassage en position d'ouverture, il ne doit pas être possible de verrouiller le matériel pendant l'essai.




Figure 1a




Figure 1b




Figure 1c




Figure 1d




Figure 1e




Figure 1f




Figure 1g

IEC 1399/08

Figure 1 — Force F appliquée à l'organe de commande

(Vide)

Tableau 9 – Liste des essais de type applicables à un matériel donné

Essais	Inter-rupteur	Fusible-inter-rupteur	Inter-rupteur à fusibles	Sec-tionneur	Sec-tionneur à fusibles	Fusible sec-tionneur	Inter-rupteur-sec-tionneur	Inter-rupteur-sec-tionneur à fusibles	Fusible-inter-rupteur-sec-tionneur
Echauffement ^a	0	0	0	0	0	0	0	0	0
Vérification de l'échauffement	0	0	0	0	0	0	0	0	0
Propriétés diélectriques	0	0	0	0	0	0	0	0	0
Vérification diélectrique	0	0	0	0	0	0	0	0	0
Courant de fuite	–	–	–	0	0	0	0	0	0
Pouvoirs assignés de fermeture et de coupure (en surcharge)	0	0	0	–	–	–	0	0	0
Fonctionnement en service	0	0	0	0	0	0	0	0	0
Courant assigné de courte durée admissible	0	–	–	0	–	–	0	–	–
Pouvoir assigné de fermeture en court-circuit	0	–	–	–	–	–	0	–	–
Courant assigné de court-circuit conditionnel	0	0	0	0	0	0	0	0	0
Robustesse du mécanisme de l'organe de commande	–	–	–	0	0	0	0	0	0
Essai de surcharge	–	0	0	–	0	0	–	0	0
0 = essai – = pas d'essai prescrit									
NOTE Cette liste d'essais de type est uniquement pour information, voir aussi les notes de bas de tableau "a" dans les Tableaux 14 et 15.									
^a Applicable à 8.3.2.1.3 seulement.									

8.3 Fonctionnement

Le Tableau 9 donne les essais de type de fonctionnement auxquels peut être soumis le matériel suivant sa nature.

8.3.1 Séquences d'essais

Les essais de type sont groupés par séquences, comme indiqué au Tableau 10.

Pour chaque séquence, les essais doivent être effectués dans l'ordre indiqué, conformément aux exigences du paragraphe correspondant, sauf pour l'essai d'échauffement (essai simplifié seulement) et l'essai des propriétés diélectriques de la séquence d'essais I, qui peuvent être effectués sur un échantillon séparé.

Tableau 10 – Schéma d'ensemble des séquences d'essais

Séquences	Essais
Caractéristiques générales de fonctionnement (voir 8.3.3 et Tableau 11)	Echauffement ^{e, f} Propriétés diélectriques ^e Pouvoirs de fermeture et de coupure ^a Vérification diélectrique ^a Courant de fuite ^b Vérification de l'échauffement Robustesse du mécanisme de l'organe de commande
Aptitude au fonctionnement en service (voir 8.3.4 et Tableau 13)	Fonctionnement en service Vérification diélectrique Courant de fuite ^b Vérification de l'échauffement
Aptitude au fonctionnement en court-circuit ^c (voir 8.3.5 et Tableau 14)	Courant de courte durée admissible Pouvoir de fermeture en court-circuit ^a Vérification diélectrique Courant de fuite ^b Vérification de l'échauffement
Courant de court-circuit conditionnel ^c (voir 8.3.6 et Tableau 15)	Tenue au court-circuit avec protection par fusibles Etablissement en court-circuit avec protection par fusibles ^a Vérification diélectrique Courant de fuite ^b Vérification de l'échauffement
Aptitude au fonctionnement en surcharge ^d (voir 8.3.7 et Tableau 16)	Essai de surcharge Vérification diélectrique Courant de fuite ^b Vérification de l'échauffement
^a Pas exigé pour les sectionneurs (AC-20 ou DC-20). Voir 4.3.5.2 et 4.3.5.3. ^b Exigé seulement pour les matériels aptes au sectionnement de tension assignée supérieure à 50 V. ^c Une seule des séquences d'essais III ou IV est à effectuer, suivant les caractéristiques assignées indiquées par le constructeur. ^d Pas exigé pour les interrupteurs, sectionneurs et interrupteurs-sectionneurs. ^e Peut être réalisé en dehors de la séquence, voir 8.3.1. ^f Applicable à 8.3.2.1.3 seulement.	

8.3.2 Conditions générales pour les essais

8.3.2.1 Exigences générales

Le Paragraphe 8.3.2.1 de la CEI 60947-1 s'applique à tous les essais de type, le cas échéant. Au début de toute séquence d'essais, le matériel doit être à l'état neuf et propre.

La force appliquée pour toute manœuvre d'ouverture ne doit pas être supérieure à la force d'essai déterminée en 8.2.5.2 de CEI 60947-1 et doit être appliquée de la même manière sans secousse.

Lorsqu'il existe un doute sur le fait que la manœuvre d'ouverture est correcte, 3 tentatives au plus sont admises pour amener le matériel en position d'ouverture.

Afin de réduire le nombre d'essais pour les matériels de même conception de base, les exigences d'essai suivantes peuvent être utilisées.

8.3.2.1.1 Essais simplifiés pour des matériels ayant la même conception de base

Lorsqu'une gamme d'interrupteurs, de sectionneurs, d'interrupteurs-sectionneurs ou de combinés-fusibles de même conception de base est examinée simultanément, les variantes suivantes sont admises, à condition que le matériel reste conforme par ailleurs.

8.3.2.1.2 Exigences pour des matériels ayant la même conception de base

Pour que les interrupteurs, les sectionneurs, les interrupteurs-sectionneurs, ou les combinés-fusibles soient considérés comme étant de même conception de base, ils doivent être évalués en considérant les critères suivants:

- a) les matériaux, la finition et les dimensions des parties conductrices sont identiques, sauf pour les variantes dans la conception des bornes et des moyens de fixation des fusibles;
- b) la taille des contacts, le matériau, la configuration et le mode de fixation sont identiques;
- c) le mécanisme de manœuvre est de même conception de base, les matériaux et les caractéristiques physiques sont identiques;
- d) les vitesses d'ouverture et de fermeture des contacts sont substantiellement les mêmes;
- e) les matériaux isolants et moulés sont identiques;
- f) la méthode, les matériaux et la construction des dispositifs d'extinction d'arc sont identiques.

Les variantes suivantes sont également permises, à condition que la procédure d'essai simplifiée donnée en 8.3.2.1.3 soit utilisée:

- g) la catégorie d'emploi et la tension d'emploi;
- h) l'application en 50 Hz ou 60 Hz;
- i) les matériels à trois ou quatre pôles (neutre commuté ou non commuté), à condition que les exigences de 7.1.9 soient appliquées;
- j) la conception des bornes, à condition que les distances d'isolement et les lignes de fuites ne soient pas réduites (voir 7.1.4, 8.2.4 et 8.3.3.2 de la présente partie norme et voir aussi 7.1.4 et 8.3.3.1 de la CEI 60947-1);
- k) les différents types d'organe de commande, additionnels ou intégrés, à condition que les exigences concernant leur robustesse (voir 8.2.5) soient vérifiées sur chaque type d'organe de commande, pour l'un d'entre eux pendant la séquence d'essais I;
- l) les contacts du socle de l'interrupteur à fusibles, du sectionneur à fusibles et de l'interrupteur-sectionneur à fusibles avec différents types d'éléments de remplacement (élément de remplacement retiré uniquement en l'absence de charge).

8.3.2.1.3 Procédure d'essai simplifiée

La procédure d'essai simplifiée suivante doit être utilisée.

- a) Si le marquage d'un matériel ayant la même conception de base présente plus d'une catégorie d'emploi et/ou plus d'une tension d'emploi, le nombre d'échantillons d'essai peut être réduit, à condition que les essais soient effectués dans les conditions les plus sévères.

Pour les essais de court-circuit, d'établissement et de coupure, et de fonctionnement en service, les conditions sont estimées plus sévères si les conditions suivantes sont simultanément remplies:

- tension assignée d'emploi égale ou supérieure;
- courant d'essai égal ou supérieur;
- facteur de puissance égal ou inférieur;
- nombre de manœuvres égal ou supérieur.

- b) Les essais effectués à 50 Hz sont estimés couvrir les applications à 60 Hz et vice versa, avec les exceptions suivantes:

- l'essai d'échauffement selon 8.3.3.1 pour les dispositifs ayant un courant supérieur à 800 A;

NOTE Par accord entre le constructeur et l'utilisateur, les essais à 50 Hz peuvent être acceptés pour le fonctionnement à 60 Hz et vice versa pour les courants supérieurs à 800 A.

- l'échauffement et le fonctionnement en service des relais et des déclencheurs (voir 7.2.2 et 7.2.2.6 de la CEI 60947-1). Les essais d'échauffement des bobines doivent être effectués pour chaque fréquence, mais pour une seule fréquence au cours de la séquence d'essais concernée, et si une alimentation séparée des bobines et des autres circuits est possible, il est permis que les autres circuits restent alimentés à 50 Hz.
- c) Les essais effectués sur des appareils tripolaires sont estimés couvrir aussi les appareils tétrapolaires avec un pôle neutre non commuté, à condition qu'un essai unipolaire sur le pôle neutre soit effectué conformément à 8.3.3.3.4 de la CEI 60947-1.

Les essais effectués sur des appareils ayant quatre pôles commutés sont estimés couvrir aussi les appareils ayant trois pôles commutés, à condition que tous les pôles soient identiques et que les vitesses d'ouverture et de fermeture des contacts soient substantiellement les mêmes (seules les exigences de 7.1.9 concernant l'ouverture et la fermeture du pôle neutre sont applicables). Toutefois, les appareils ayant quatre pôles commutés doivent toujours être raccordés en triphasé (voir Figure 11 de la CEI 60947-1).

- d) Essais effectués avec différents types de contacts de socle.

Lorsque des interrupteurs à fusibles, des sectionneurs à fusibles ou des interrupteurs-sectionneurs à fusibles sont conçus pour être fournis avec différents types de contacts de socle, les essais d'échauffement selon 8.3.3.1 doivent être effectués sur chaque type, au courant assigné maximal du fusible correspondant.

Le type ayant l'échauffement maximal parmi ceux dont le courant d'essai est maximal doit être utilisé pour les essais des séquences I, II et V.

La séquence IV doit être effectuée sur chaque type de contacts de socle dont les moyens de connexion des fusibles sont autres que des connexions boulonnées, au courant conditionnel de court-circuit assigné correspondant le plus élevé, et, s'il est différent, avec le type de fusible ayant l'énergie traversante maximale à la tension d'essai la plus élevée.

- e) Essais réalisés avec différentes conceptions de borne.

Lorsqu'un matériel est conçu pour être fourni avec différentes conceptions de borne, les exigences et les essais selon 8.3.3.1 et 8.2.4 de la CEI 60947-1 doivent être réalisés sur chaque conception.

Lorsque le matériel a des bornes prévues pour être enfichées sur un jeu de barres, les essais conformément à 8.3.3.1, 8.3.5.1 ou 8.3.6.2.1 a), selon le cas, doivent être effectués. Une vérification de l'enfichage doit être faite. Le nombre de cycles de fonctionnement doit être de 50, le cycle allant de la position connectée à la position déconnectée et retour à la position connectée.

L'essai est considéré comme satisfaisant si les conditions de fonctionnement de l'appareil n'ont pas été détériorées.

- f) Les essais de 8.3.2.1.3, points d) et e) permettent de vérifier l'échauffement des bornes et des parties accessibles.

Si les limites d'échauffement des parties accessibles sont essayées selon 8.3.2.1.3 et satisfont au Tableau 3 de la CEI 60947-1, il n'est pas nécessaire d'effectuer des essais supplémentaires sur ces parties selon 8.3.3.6.

Etant donné que l'objectif des essais 8.3.2.1.3, points d) et e) est de se placer dans le cas le plus défavorable, les valeurs du Tableau 2 de la CEI 60947-1 ne s'appliquent pas.

8.3.2.2 Grandeurs d'essai

Le Paragraphe 8.3.2.2 de la CEI 60947-1 s'applique.

8.3.2.3 Interprétation des résultats d'essais

Le comportement du matériel au cours des essais et son état après les essais sont spécifiés dans le paragraphe approprié.

8.3.2.4 Compte rendu d'essai

Le Paragraphe 8.3.2.4 de la CEI 60947-1 s'applique.

8.3.3 Séquence d'essais I: caractéristiques générales de fonctionnement

Cette séquence d'essais s'applique aux types de matériels indiqués au Tableau 11 et comprend les essais figurant dans ce tableau.

8.3.3.1 Echauffement

Le Paragraphe 8.3.3.3 de la CEI 60947-1 s'applique avec les compléments suivants:

~~L'essai doit être effectué au courant assigné d'emploi I_e .~~

L'essai doit être mené au courant assigné d'emploi I_e ; excepté dans le cas d'une valeur AC-20 ou DC-20 pour laquelle l'essai d'échauffement est mené avec I_{th} . Dans le cas où l'essai a été mené à I_e alors le constructeur peut déclarer une valeur AC-20 ou DC-20 égale à I_e sans autre essai.

Les combinés-fusibles doivent être munis d'éléments de remplacement dont le courant assigné est égal au courant thermique conventionnel du combiné.

L'élément de remplacement doit avoir une puissance dissipée ne dépassant pas la valeur maximale spécifiée par le constructeur du matériel.

NOTE 1 L'essai peut être effectué avec un élément de remplacement conventionnel d'essai de conception sensiblement analogue à celle de l'élément de remplacement normalisé et de même puissance dissipée.

Dans le cas d'essais effectués sur un fusible-interrupteur, un fusible-sectionneur ou un fusible-interrupteur-sectionneur, lorsque les lames des éléments de remplacement font partie des contacts de fermeture-coupure, l'élément de remplacement doit être utilisé.

NOTE 2 Pour un fusible-interrupteur ou un fusible-interrupteur-sectionneur, lorsque les lames de l'élément de remplacement font partie des contacts de fermeture-coupure, des éléments factices ou des conducteurs de cuivre ne peuvent pas remplacer les éléments de remplacement parce que les lames des éléments de remplacement s'usent. L'usure des lames des éléments de remplacement influence la vérification thermique conformément à 8.3.3.6.

Le compte rendu d'essai doit mentionner tous les renseignements utiles sur les éléments de remplacement utilisés pour l'essai, c'est-à-dire le nom et la référence du constructeur, le courant assigné, la puissance dissipée par l'élément de remplacement et le pouvoir de coupure. On admettra que l'essai de type effectué avec les éléments de remplacement spécifiés s'applique à l'utilisation de tout autre élément de remplacement ayant, pour le courant thermique conventionnel du combiné, une puissance dissipée inférieure ou égale à celle de l'élément de remplacement utilisé pour l'essai.

~~Dans le cas d'essais effectués sur un fusible-interrupteur ou un interrupteur-sectionneur à fusibles, les éléments de remplacement peuvent être remplacés par des liaisons en cuivre appropriées, de dimensions et de masse électriquement équivalentes à celles des éléments de remplacement recommandés par le constructeur.~~

Tableau 11 – Séquence d'essais I: caractéristiques générales de fonctionnement

Essais	N° de paragraphe	Echantillons ^c	Types de matériel et ordre des essais					
			Inter-rupteur	Fusible-inter-rupteur et inter-rupteur à fusibles	Sectionneur	Sectionneur à fusibles et fusible-sectionneur	Inter-rupteur-sectionneur	Inter-rupteur-sectionneur à fusibles et fusible-inter-rupteur-sectionneur
Echauffement ^{d, e}	8.3.3.1	A,B,C,F	1	1	1	1	1	1
Propriétés diélectriques ^d	8.3.3.2	A,C,F	2	2	2	2	2	2
Pouvoirs de fermeture et de coupure	8.3.3.3	A,D	3	3	a	a	3	3
Vérification diélectrique	8.3.3.4	A,D	4	4	a	a	4	4
Courant de fuite ^b	8.3.3.5	A,D	-	-	3	3	5	5
Vérification de l'échauffement	8.3.3.6	A,D	5	5	4	4	6	6
Robustesse du mécanisme de l'organe de commande	8.3.3.7	A,E	-	-	5	5	7	7

^a Cet essai n'est pas exigé pour les sectionneurs (AC-20 ou DC-20). Voir 4.3.5.2 et 4.3.5.3.

^b Cet essai n'est exigé que si U_e est supérieure à 50 V.

^c Seuls les essais marqués avec la même lettre doivent être effectués en séquence sur un échantillon donné: «A» est un échantillon de chaque conception de base, choisi parmi ceux dont le courant assigné I_e est le plus élevé, et, le cas échéant, ayant l'échauffement le plus élevé selon 8.3.2.1.3, point d).
Autres échantillons selon le cas:
«B» est un échantillon différent pour l'essai à 60 Hz, le cas échéant, conformément à 8.3.2.1.3, point b);
«C» sont des échantillons de chacune des autres conceptions de borne, essayés au courant assigné maximal correspondant;
«D» sont des échantillons pour vérifier toutes les combinaisons de U_e , I_e , caractéristiques en courant alternatif ou en courant continu, à soumettre aux essais (voir 8.3.2.1.3);
«E» est l'échantillon supplémentaire comme spécifié en 8.2.5.1 et qui peut être un des échantillons B, C ou D;
«F» sont des échantillons de chaque type de porte-fusible de combiné-fusibles selon 8.3.2.1.3, point d).

^d Peut être réalisé en dehors de la séquence, voir 8.3.1.

^e Applicable à 8.3.2.1.3 seulement.

8.3.3.2 Essai des propriétés diélectriques

Le Paragraphe 8.3.3.4.1, points 1), 2), 3), 7) et, si applicable, 8) de la CEI 60947-1 s'applique avec le complément suivant.

Lorsque, en accord avec le constructeur, les appareils sont déconnectés pour l'essai conformément à 8.3.3.4.1, point 3) c) de la CEI 60947-1, le rapport d'essai doit mentionner ces appareils.

Pour les matériels aptes au sectionnement (voir 3.3) ayant une tension d'emploi U_e supérieure à 50 V, le courant de fuite doit être mesuré à travers chaque pôle avec les contacts en position d'ouverture, à une tension d'essai égale à $1,1 U_e$ et ne doit pas dépasser 0,5 mA.

8.3.3.3 Pouvoirs de fermeture et de coupure

8.3.3.3.1 Valeurs et conditions d'essai

Le Paragraphe 8.3.3.5 de la CEI 60947-1 s'applique aux matériels dotés d'un pôle neutre.

Le Paragraphe 7.2.4.1, Tableau 3, indique les valeurs d'essai, en fonction de la catégorie d'emploi.

Le nombre indiqué de cycles de manœuvres d'établissement-coupure doit être effectué avec un intervalle de temps de $30 \text{ s} \pm 10 \text{ s}$ entre les cycles de fermeture et d'ouverture, sauf dans le cas des matériels de courant thermique conventionnel égal ou supérieur à 400 A pour lesquels cet intervalle de temps peut être augmenté par accord entre le constructeur et l'utilisateur et doit être précisé dans le compte rendu d'essai.

Pendant chaque cycle de manœuvres d'établissement-coupure, il suffit que le matériel reste dans la position de fermeture pendant une durée suffisamment longue pour permettre à la manœuvre électrique de s'effectuer pour que la valeur de courant à établir soit atteinte et pour que les pièces mobiles du matériel puissent atteindre leurs positions de repos. Après chaque cycle de manœuvres, la tension de rétablissement doit être maintenue pendant au moins 0,05 s.

Pour faciliter les essais des matériels de catégorie d'emploi AC-23A et AC-23B, les cycles de manœuvres d'établissement-coupure peuvent être remplacés, avec l'accord du constructeur par le nombre indiqué de cycles de manœuvres d'établissement à $10 I_e$ suivis du même nombre de cycles de manœuvres de coupure à $8 I_e$.

En courant alternatif, le facteur de puissance du circuit d'essai doit être déterminé comme indiqué en 8.3.4.1.3 de la CEI 60947-1. Les valeurs doivent être conformes à celles du Tableau 3.

En courant continu, la constante de temps du circuit d'essai doit être déterminée comme indiqué en 8.3.4.1.4 de la CEI 60947-1. Les valeurs doivent être conformes à celles du Tableau 3.

La tension d'essai doit être appliquée et la charge doit être reliée aux bornes appropriées du matériel. Pour un matériel dans lequel un contact mobile reste relié à l'une des bornes quand le matériel est dans la position d'ouverture, cet essai doit être répété en permutant les connexions d'alimentation et de charge, à moins que les bornes ne soient réellement marquées de façon distincte pour la charge et l'alimentation.

Dans le cas d'essais effectués sur un fusible-interrupteur ou un fusible-interrupteur-sectionneur, lorsque les lames des éléments de remplacement font partie des contacts de fermeture-coupure, l'élément de remplacement doit être utilisé.

NOTE Pour un fusible-interrupteur ou un fusible-interrupteur-sectionneur, lorsque les lames de l'élément de remplacement font partie des contacts de fermeture-coupure, des éléments factices ou des conducteurs de cuivre ne peuvent pas remplacer les éléments de remplacement parce que les lames des éléments de remplacement de ces appareils s'usent. L'usure des lames des éléments de remplacement influence la vérification thermique conformément à 8.3.3.6.

Les caractéristiques des éléments de remplacement utilisés pour l'essai, c'est à dire le nom du constructeur, la référence, le courant assigné, la puissance dissipée de l'élément de remplacement et le pouvoir de coupure, doivent être précisés dans le rapport d'essai.