

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Low voltage surge protective devices –
Part 21: Surge protective devices connected to telecommunications and
signalling networks – Performance requirements and testing methods**

**Parafoudres basse tension –
Partie 21: Parafoudres connectés aux réseaux de signaux et de
télécommunications – Prescriptions de fonctionnement et méthodes d'essais**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Low voltage surge protective devices –
Part 21: Surge protective devices connected to telecommunications and
signalling networks – Performance requirements and testing methods**

**Parafoudres basse tension –
Partie 21: Parafoudres connectés aux réseaux de signaux et de
télécommunications – Prescriptions de fonctionnement et méthodes d'essais**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 General	8
1.1 Scope.....	8
1.2 SPD configurations.....	8
1.3 Use of this standard	10
2 Normative references	13
3 Definitions	14
4 Service and test conditions.....	17
4.1 Service conditions	17
4.1.1 Normal service conditions.....	17
4.1.2 Abnormal service conditions	18
4.2 Test temperature and humidity	18
4.3 SPD testing	18
4.4 Waveform tolerances.....	19
5 Requirements	19
5.1 General requirements.....	19
5.1.1 Identification and documentation	19
5.1.2 Marking	19
5.2 Electrical requirements.....	20
5.2.1 Voltage-limiting requirements.....	20
5.2.2 Current-limiting requirements	21
5.2.3 Transmission requirements.....	22
5.3 Mechanical requirements.....	22
5.3.1 Terminals and connectors.....	23
5.3.2 Mechanical strength (mounting).....	24
5.3.3 Resistance to ingress of solid objects and to harmful ingress of water	24
5.3.4 Protection against direct contact.....	24
5.3.5 Fire resistance.....	24
5.4 Environmental requirements	24
5.4.1 High temperature and humidity endurance.....	24
5.4.2 Environmental cycling with impulse surges	25
5.4.3 Environmental cycling with a.c. surges	25
6 Type test	25
6.1 General tests.....	25
6.1.1 Identification and documentation	25
6.1.2 Marking	25
6.2 Electrical tests.....	26
6.2.1 Voltage-limiting tests	26
6.2.2 Current-limiting tests	32
6.2.3 Transmission tests	35
6.3 Mechanical tests	37
6.3.1 Terminals and connectors.....	37
6.3.2 Mechanical strength (mounting).....	39
6.3.3 Resistance to ingress of solid objects and to harmful ingress of water	39
6.3.4 Protection against direct contact.....	39

6.3.5	Fire resistance.....	40
6.4	Environmental tests.....	41
6.4.1	High temperature and humidity endurance.....	41
6.4.2	Environmental cycling with impulse surges	41
6.4.3	Environmental cycling with a.c. surges	42
6.5	Acceptance tests.....	42
Annex A (informative)	Devices with current-limiting components only	56
Annex B (Void)		57
Annex C (Void)		58
Annex D (informative)	Measurement accuracy	59
Annex E (informative)	Determination of let-through current (I_p).....	60
Bibliography.....		63
Figure 1 – SPD configurations		9
Figure 16 – Examples of multi-line SPDs with a common protective element.....		28
Figure 2 – Test circuits for impulse reset time.....		43
Figure 3 – Test circuits for a.c. durability and overstressed fault mode		44
Figure 4 – Test circuits for impulse durability and overstressed fault mode		45
Figure 5 – Test circuits for rated current, series resistance, response time, current reset time, maximum interrupting voltage and operating duty test		46
Figure 6 – Test circuits for a.c. durability		47
Figure 7 – Test circuits for impulse durability.....		48
Figure 8 – Test circuits for insertion loss.....		49
Figure 9 – Test circuit for return loss		49
Figure 10 – Test circuits for longitudinal balance		50
Figure 11 – Test circuit for bit error ratio test		51
Figure 12 – Test circuit for near-end crosstalk		52
Figure 13 – Test circuits for high temperature/humidity endurance and environmental cycling.....		53
Figure 14 – Environmental cycling schedule A with RH ≥ 90 %		54
Figure 15 – Environmental cycling B		55
Figure A.1 – Configurations of devices with current-limiting component(s) only.....		56
Figure E.1 – Determination of differential mode let-through current.....		60
Figure E.2 – Determination of common mode let-through current		61
Figure E.3 – Determination of differential mode let-through current.....		61
Figure E.4 – Determination of differential mode let-through current.....		61
Figure E.5 – Determination of common mode max. let-through current		61
Figure E.6 – Determination of common mode max. let-through current at multi-terminal SPDs		62

Table 1 – General SPD requirements.....	11
Table 2 – Waveform tolerances.....	19
Table 3 – Voltage and current waveforms for impulse-limiting voltage.....	27
Table 4 – Source voltages and currents for impulse reset test	29
Table 5 – Preferred values of currents for a.c. durability test	30
Table 6 – Test currents for response time.....	32
Table 7 – Preferred values of current for operating duty tests	34
Table 8 – Preferred values of a.c. test currents.....	34
Table 9 – Preferred values of impulse current.....	35
Table 10 – Standard parameters for figure 8.....	35
Table 11 – Impedance values for longitudinal balance test.....	36
Table 12 – Test times for BER test	37
Table 13 – Connectable cross-sectional areas of copper conductors for screw-type terminals or screwless-type terminals	38
Table 14 – Pulling force (screwless terminals)	38
Table 15 – Preferred values of test-time duration for high temperature and humidity endurance.....	41
Table 16 – Preferred values of temperature and duration for environmental cycling tests.....	42

IECNORM.COM : Click to view the full PDF of IEC 61643-21:2000+AMD1:2008 CSV

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW VOLTAGE SURGE PROTECTIVE DEVICES –

**Part 21: Surge protective devices connected to telecommunications
and signalling networks –
Performance requirements and testing methods**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61643-21 has been prepared by subcommittee 37A: Low-voltage surge protective devices, of IEC technical committee 37: Surge arresters.

This consolidated version of IEC 61643-21 consists of the first edition (2000) [documents 37A/101/FDIS and 37A/104/RVD], its amendment 1 (2008) [documents 37A/200/FDIS and 37A/201/RVD] and its corrigendum of March 2001.

The technical content is therefore identical to the base edition and its amendment and has been prepared for user convenience.

It bears the edition number 1.1.

A vertical line in the margin shows where the base publication has been modified by amendment 1.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IECNORM.COM : Click to view the full PDF of IEC 61643-21:2000+AMD1:2008 CSV

INTRODUCTION

The purpose of this International Standard is to identify the requirements for Surge Protective Devices (SPDs) used in protecting telecommunication and signalling systems, for example, low-voltage data, voice, and alarm circuits. All of these systems may be exposed to the effects of lightning and power line faults, either through direct contact or induction. These effects may subject the system to overvoltages or overcurrents or both, whose levels are sufficiently high to harm the system. SPDs are intended to provide protection against overvoltages and overcurrents caused by lightning and power line faults. This standard describes tests and requirements which establish methods for testing SPDs and determining their performance.

The SPDs addressed in this International Standard may contain overvoltage protection components only, or a combination of overvoltage and overcurrent protection components. Protection devices containing overcurrent protection components only are not within the coverage of this standard. However, devices with only overcurrent protection components are covered in annex A.

An SPD may comprise several overvoltage and overcurrent protection components. All SPDs are tested on a "black box" basis, i.e., the number of terminals of the SPD determines the testing procedure, not the number of components in the SPD. The SPD configurations are described in 1.2. In the case of multiple line SPDs, each line may be tested independently of the others, but there may also be a need to test all lines simultaneously.

This standard covers a wide range of testing conditions and requirements; the use of some of these is at the discretion of the user. How the requirements of this standard relate to the different types of SPD is described in 1.3. Whilst this is a performance standard and certain capabilities are demanded of the SPDs, failure rates and their interpretation are left to the user. Selection and application principles are covered in IEC 61643-22.

If the SPD is known to be a single component device, it has to meet the requirements of the relevant standard as well as those in this standard.

LOW VOLTAGE SURGE PROTECTIVE DEVICES –

Part 21: Surge protective devices connected to telecommunications and signalling networks – Performance requirements and testing methods

1 General

1.1 Scope

This International Standard is applicable to devices for surge protection of telecommunications and signalling networks against indirect and direct effects of lightning or other transient overvoltages.

The purpose of these SPDs is to protect modern electronic equipment connected to telecommunications and signalling networks with nominal system voltages up to 1 000 V (r.m.s.) a.c. and 1 500 V d.c.

1.2 SPD configurations

The SPD configurations described in this standard are shown in figure 1. Each SPD configuration is composed of one or more voltage-limiting components and may include current-limiting components.

IECNORM.COM : Click to view the full PDF of IEC 61643-21:2000+AMD1:2008 CSV




Figure 1a – Two-terminal SPD




Figure 1b – Three-terminal SPD




Figure 1c – Three-terminal SPD




Figure 1d – Four-terminal SPD





Figure 1e – Five-terminal SPD



^a The common terminal C may not be provided.

Figure 1f – Multi-terminal SPD

Key

V	voltage-limiting component
V, I	voltage-limiting components or a combination of voltage-limiting and current-limiting components
X1, X2....Xn	line terminals
Y1, Y2...Yn	protected line terminals
C	common terminal

Figure 1 – SPD configurations

1.3 Use of this standard

This standard considers two basic types of SPD.

The first type of SPD contains at least one voltage-limiting component and no current-limiting component(s) in a housing. All the SPD configurations of figure 1 can be of this type. These SPDs shall satisfy the requirements of 5.1, 5.2.1 and 5.3 (see table 1). The SPDs shown in figures 1b, 1d, 1e and 1f may contain a linear component between the line terminal and the corresponding protected line terminal. These SPDs shall also satisfy the applicable requirements of 5.2.2.

The second type of SPD contains both voltage-limiting and current-limiting components in a housing. SPD configurations shown in figures 1b, 1d, 1e, and 1f are applicable for SPDs with both voltage-limiting and current-limiting components. This type of SPD shall satisfy the requirements of 5.1, 5.2.1, 5.2.2 and 5.3 (see table 1). Configurations of protective devices having only current-limiting components are covered in annex A.

SPDs may need to satisfy additional requirements depending on the application. The additional requirements are described in 5.2.3 and 5.4 (see table 1).

Subclause 5.2.3 provides transmission tests that SPDs may need to conform to, depending on their communication and signalling application. Selection of the applicable transmission tests from 5.2.3 shall be made, based on the intended application of the SPDs. Table 1 provides general guidance on how to select the applicable transmission tests.

Subclause 5.4 provides the environmental requirements when the SPDs are intended only for use in uncontrolled environments as described in 4.1. SPDs shall satisfy these requirements after an agreement between the user and the manufacturer. Table 1 provides examples of what requirements different types of SPD shall satisfy.

IECNORM.COM : Click to view the full PDF of IEC 61643-21:2000+A1:2008 CSV

Table 1 – General SPD requirements

Test series ⁴	Requirement – Test	Sub-clause	Type of SPD					
			SPD with only voltage-limiting function	SPD with both voltage-limiting and current-limiting functions	SPD with voltage-limiting function and linear component between its terminals	SPD having both voltage-limiting and current-limiting functions with enhanced transmission capabilities	SPD having only voltage-limiting function but intended for use in extended range environment	SPD having both voltage-limiting and current-limiting functions but intends for use in extended range environment
1	General test	6.1						
	Identification and documentation	6.1.1	A	A	A	A	A	A
	Marking	6.1.2	A	A	A	A	A	A
	Transmission tests	6.2.3						
	Capacitance	6.2.3.1	A	O	O	O	A	O
	Insertion loss	6.2.3.2	O	A	A	A	O	A
	Return loss	6.2.3.3	O	O	O	A	O	O
	Longitudinal balance	6.2.3.4	O	O	O	A	O	O
	Bit Error Ratio (BER)	6.2.3.5	O	O	O	O	O	O
	Near-end crosstalk (NEXT)	6.2.3.6	O	O	O	A	O	O
	Mechanical tests	6.3						
	Terminals and connectors	6.3.1	A	A	A	A	A	A
	General testing procedure	6.3.1.1	A	A	A	A	A	A
	Terminals with screws	6.3.1.2	A	A	A	A	A	A
	Screwless terminals	6.3.1.3	A	A	A	A	A	A
	Insulating pierced connections	6.3.1.4	A	A	A	A	A	A
	Pull-out-test on SPD terminals designed for single-core conductors	6.3.1.4.1	A	A	A	A	A	A
	Pull-out-test on SPD terminals designed for multi-core cables and cords	6.3.1.4.2	A	A	A	A	A	A
	Mechanical strength (mounting)	6.3.2	A	A	A	A	A	A
	Resistance to ingress of solid objects and to harmful ingress of water	6.3.3	A	A	A	A	A	A
	Protection against direct contact	6.3.4	A	A	A	A	A	A
	Fire resistance	6.3.5	A	A	A	A	A	A

Table 1 (continued)[illegible]

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050(702):1992, *International Electrotechnical Vocabulary – Chapter 702: Oscillations, signals and related devices*

IEC 60050(726):1982, *International Electrotechnical Vocabulary – Chapter 726: Transmission lines and waveguides*

IEC 60060-1:1989, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60068-2-30:1980, *Environmental testing – Part 2: Tests – Test Db and guidance: Damp heat, cyclic (12 + 12-hour cycle)*

IEC 60529, *Degrees of protection provided by enclosures (IP code)*

IEC 60695-2-1/1:1994, *Fire hazard testing – Part 2: Test methods – Section 1/sheet 1: Glow-wire end-product test and guidance*

IEC 60950:1999, *Safety of information technology equipment*

IEC 60999-1:1999, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm² up to 35 mm² (included)*

IEC 61000-4-5, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 5 – Surge immunity test*

IEC 61083-1, *Digital recorders for measurements in high voltage impulse tests – Part 1: Requirements for digital recorders*

IEC 61180-1:1992, *High-voltage test techniques for low-voltage equipment – Part 1: Definitions, test and procedure requirements*

IEC 61643-1, *Surge protective devices connected to low-voltage power distribution systems – Part 1: Performance requirements and testing methods*

IEC 61643-22:2004, *Low-voltage surge protective devices – Part 22: Surge protection devices connected to telecommunications and signalling networks – Selection and application principles*

ITU-T Recommendation K.30:1993, *Positive temperature coefficient (PTC) thermistors*

ITU-T Recommendation K.55:2002, *Overvoltage and overcurrent requirements for insulation displacement connectors (IDC) terminations*

ITU-T Recommendation K.65:2004, *Overvoltage and overcurrent requirements for termination modules with contacts for test ports or SPDs*

ITU-T Recommendation O.9:1999, *Measuring arrangements to assess the degree of unbalance about earth*

3 Definitions

For the purpose of this part of IEC 61643, the following definitions apply.

3.1

model number

code, either applied to the SPD or included in its documentation, that is used to identify the SPD

3.2

preferred values

values for the parameters listed in the tables for the various tests, preferred in the sense that their use promotes uniformity and provides a means of comparison among various protective devices. They also provide a common engineering language beneficial to the user and manufacturer of surge protectors used in telecommunications and signalling networks. However, specific applications may require values other than the preferred values of the tables

3.3

overstressed fault mode

mode 1 condition wherein the voltage-limiting part of the SPD has been disconnected. The voltage-limiting function is no longer present, but the line is still operable

mode 2 condition wherein the voltage-limiting part of the SPD has been short-circuited by a very low impedance within the SPD. The line is inoperable, but the equipment is still protected by a short circuit

mode 3 situation wherein the SPD has undergone an internal open circuit on the network side of the voltage-limiting part of the SPD. The line is inoperable but the equipment is still protected by an open line

3.4

protection

application of methods and means to prevent the propagation of stressful electrical energy beyond a designed interface

3.5

current response time

time required for a current-limiting component to operate at a specified current and a specified temperature

3.6

maximum continuous operating voltage U_c

maximum voltage (d.c. or r.m.s.) which may be continuously applied to SPD terminals without causing any degradation in the transmission characteristics of the SPD

3.7

maximum interrupting voltage

maximum voltage (d.c. or r.m.s.) that can be applied to the current-limiting components of an SPD without degradation of the SPD. This voltage may be equal to the U_c of the SPD or may be a higher value depending on the arrangement of the current-limiting component(s) within the SPD

3.8

surge protective device

SPD

device that restricts the voltage of a designated port or ports, caused by a surge, when it exceeds a predetermined level

NOTE 1 Secondary functions may be incorporated, such as a current-limiting to restrict a terminal current.

NOTE 2 Typically the protective circuit has at least one non-linear voltage-limiting surge protective component.

NOTE 3 An SPD is a complete assembly, having terminals to connect to the circuit conductors.

3.9

voltage limiting

action of the SPD that causes all voltages exceeding a predetermined value to be reduced

3.10

current limiting

action of an SPD, containing at least one non-linear current-limiting component, that causes currents exceeding a predetermined value to be restricted

3.11

non-resettable current limiting

action of an SPD that limits current only one time

3.12

resettable current limiting

action of an SPD that limits current and can be manually reset after operating

3.13

self-resetting current limiting

action of an SPD that limits current and will self-reset after the disturbing current is removed

3.14

voltage clamping type SPD

SPD that has high shunt impedance and will have a continuous reduction in impedance with increasing current in response to a voltage surge exceeding the threshold level of the SPD

NOTE Examples of components used in voltage clamping type SPDs: varistors (e.g. MOV) and avalanche breakdown diodes (ABD).

3.15

voltage switching type SPD

SPD that has a high shunt impedance and will have a sudden and large reduction in impedance in response to a voltage surge exceeding the threshold level of the SPD

NOTE Examples of components used in voltage switching type SPDs: air gaps, gas discharge tubes (GDT) and thyristor surge suppressors (TSS).

3.16

voltage protection level U_p

parameter that characterizes the performance of the SPD in limiting the voltage across its terminals. This value of voltage is greater than the highest measured value of impulse-limiting voltage and is specified by the manufacturer

3.17

multi-stage SPD

SPD which has more than one voltage-limiting component. These voltage-limiting components may or may not be electrically separated by a series component. The voltage-limiting components may be either switching or clamping types

3.18

blind spot

situation where voltages above the maximum continuous operating voltage U_c may cause incomplete operation of the SPD. Incomplete operation of the SPD means not all of the stages in a multi-stage SPD have operated during the impulse test. This may result in overstressing of components in the SPD

3.19

a.c. durability

characteristic of an SPD which allows it to conduct alternating current of a specific magnitude and duration for a specified number of times

3.20

impulse durability

characteristic of an SPD which allows it to conduct impulse current of a specified waveform and peak value for a specified number of times

3.21

current reset time

time required for a self-resettable current limiter to revert to its normal or quiescent state

3.22

rated current

maximum current a current-limiting SPD can conduct continuously with no change in the impedance of the current-limiting components

NOTE This is also applicable to linear series components.

3.23

insulation resistance

resistance between designated terminals of an SPD when U_c is applied to those terminals

3.24

return loss

modulus of the reciprocal of the reflection factor, generally expressed in decibels (dB)

NOTE When impedances can be defined, the return loss in dB is given by the formula:

$$20 \log_{10} \text{MOD} [(Z_1 + Z_2)/(Z_1 - Z_2)]$$

where Z_1 is the characteristic impedance of the transmission line ahead of the discontinuity, or the impedance of the source, and Z_2 is the impedance after the discontinuity or load impedance seen from the junction between the source and the load [IEV 702-07-25, modified]

3.25

bit error ratio (BER)

ratio of the number of bit errors to the total number of bits transmitted in a given time interval

3.26

insertion loss

loss resulting from the insertion of an SPD into a transmission system. It is the ratio of the power delivered to that part of the system following the SPD, before insertion of the SPD, to the power delivered to that same part after insertion of the SPD. The insertion loss is generally expressed in decibels [IEV 726-06-07, modified]

3.27

near-end crosstalk (NEXT)

crosstalk that is propagated in a disturbed channel in the direction opposite to the direction of propagation of the current in the disturbing channel. The terminal of the disturbed channel at which the near-end crosstalk is present is ordinarily near to, or coincides with, the energized terminal of the disturbing channel

3.28**longitudinal balance (analogue voice frequency circuits)**

electrical symmetry of the two wires comprising a pair with respect to ground

3.29**longitudinal balance (data transmission)**

measure of the similarity of impedance to ground (or common) for the two or more conductors of a balanced circuit. This term is used to express the degree of susceptibility to common mode interference

3.30**longitudinal balance (communication and control cables)**

ratio of the disturbing common mode (longitudinal) r.m.s. voltage (V_s) to ground and the resulting differential mode (metallic) r.m.s. voltage (V_m) of the SPD under test, expressed in decibels (dB)

NOTE The longitudinal balance in dB is given by the formula:

$$20 \log_{10} V_s/V_m$$

where V_s and V_m are measured at the same frequency.

3.31**longitudinal balance (telecommunications)**

ratio of the disturbing common mode (longitudinal) voltage V_s and the resulting differential mode (metallic) voltage V_m of the SPD under test, expressed in decibels (dB)

3.32**surge (telecommunications)**

temporary excessive voltage or current, or both, coupled on a telecommunication line, from an external electrical source

NOTE 1 Typical electrical sources are lightning and AC/DC power systems.

NOTE 2 Electrical source coupling can be one or more of the following; electric, magnetic, electromagnetic, conductive.

4 Service and test conditions**4.1 Service conditions****4.1.1 Normal service conditions****4.1.1.1 Air pressure and altitude**

Air pressure is 80 kPa to 106 kPa. These values represent an altitude of +2 000 m to –500 m respectively.

4.1.1.2 Ambient temperature

- normal range: –5 °C to +40 °C

NOTE 1 This range normally addresses SPDs for indoor use. This corresponds to code AB4 in IEC 60364-5-51.

- extended range: –40 °C to +70 °C

NOTE 2 This range normally addresses SPDs for outdoor use in non weather-protected locations, class 3K7 in IEC 60721-3-3.

- storage range: –40 °C to +70 °C

NOTE 3 All values beyond will be specified by the manufacturer.

4.1.1.3 Relative humidity

- normal range: 5 % to 95 %

NOTE 1 This range normally addresses SPDs for indoor use. This corresponds to code AB4 in IEC 60364-5-51.

- extended range: 5 % to 100 %

NOTE 2 This range normally addresses SPDs for outdoor use in non weather-protected locations (e.g. SPD is contained in a weather proofed enclosure).

4.1.2 Abnormal service conditions

Exposure of the SPD to abnormal service conditions may require special consideration in the design or application of the SPD, and shall be called to the attention of the manufacturer.

4.2 Test temperature and humidity

If it is known beforehand that a particular device technology causes an SPD to be insensitive to temperature when testing a particular characteristic, a temperature of $23\text{ °C} \pm 2\text{ °C}$ with relative humidity from 45 % to 55 % may be used for that test. In other cases, testing shall be performed for an SPD, sensitive to temperature, at the extreme temperatures of the temperature range selected for the intended application. The selected temperature range may be narrower than the full range of 4.1 depending on the application.

For particular SPD technologies, it may be known beforehand that only one of the extreme temperatures of the selected temperature range represents the worst-case test condition. In this case, the testing shall be performed only at the extreme temperature representing the worst-case test condition. This extreme temperature may be different for each test described in clause 6 for the same SPD technology.

When testing is required to be performed at extreme temperatures, SPDs shall be gradually heated or cooled to the specified extreme temperature, taking sufficient time to avoid thermal shock. Unless otherwise specified, a minimum of 1 h should be used. SPDs shall be held at the specified temperature for a time sufficient to reach thermal equilibrium before testing. Unless otherwise specified, a minimum of 15 min should be used.

4.3 SPD testing

The SPDs covered by this standard shall be tested using the connections or terminations that are used when the SPDs are installed in the field. Also, the measurements shall be made at the connections or terminations of the SPDs. For those that are intended to be used with a base or connector, that base or connector shall be part of the tests.

For telecommunication applications ITU-T gives requirements in the K-series for protection holders (K.65) and termination modules (K.55).

When a base is used for testing, the measurements shall be made as close as possible to the terminals of the SPD. Oscilloscopes used for measurements shall be in accordance with IEC 61083-1.

NOTE For oscilloscope settings, see Annex D.

SPDs of Figures 1c, 1e and 1f may have a common current path (including protective components or just internal connections) that conducts the total impulse current. The manufacturer shall state the maximum value of impulse current for this current path. This value of impulse current may be less than n times the maximum current capability of each line terminal, where n equals the number of line terminals.

These SPDs shall have all of their line terminals tested simultaneously with respect to the common terminal.

Matters of sample size and permissible failure rates are to be agreed between the customer and manufacturer.

4.4 Waveform tolerances

The definition of the waveform parameters A/B where A is the front time in microseconds and B is the time to half-value in microseconds shall be in accordance with IEC 60060-1 (see also IEC 61000-4-5). Table 2 shows the tolerances for the waveforms used in this standard.

Table 2 – Waveform tolerances

Waveform item	1,2/50 or 10/700 Open-circuit voltage	8/20 or 5/300 Short-circuit current	Other waveforms
Peak	±10 %	±10 %	±10 %
Front time	±30 %	±20 %	±30 %
Time to half-value	±20 %	±20 %	±20 %

5 Requirements

5.1 General requirements

The following requirements apply to all SPDs covered by this standard.

5.1.1 Identification and documentation

The information indicated in items a) through n) shall either be marked on the body of the SPD, as described in 5.1.2, or included in the documentation or on the packaging. Any abbreviations used shall be explained in the data sheet. For each test performed on the SPD from clause 6, the test conditions shall be stated in the documentation.

- a) Manufacturer's name or trade mark
- b) Year and week of manufacture, or serial number
- c) Model number
- d) Service conditions
- e) Maximum continuous operating voltage U_c
- f) Rated current
- g) Voltage protection level U_p
- h) Impulse reset (if applicable)
- i) AC durability
- j) Impulse durability
- k) Overstressed fault mode
- l) Transmission characteristics
- m) Additional information, where applicable, concerning replaceable components and the use of radioisotopes
- n) Series resistance (if applicable)

5.1.2 Marking

The SPDs shall be clearly marked with 5.1.1 items: a) the manufacturer's name or trademark, b) manufacturing traceability, c) model number, and e) the maximum continuous operating voltage. The marking material shall be wipe resistant and resistant to solvents normally used in the SPD application. Any notes for special handling shall be included in the documentation or on the packaging. Compliance is checked in accordance with 6.1.2.

5.2 Electrical requirements

The SPD shall meet the following requirements when tested in accordance with the subclauses of clause 6.

5.2.1 Voltage-limiting requirements

When the SPD contains only voltage-limiting components, the SPD shall conform to all requirements of 5.2.1. An SPD that contains both voltage-limiting and current-limiting components shall conform to all requirements of 5.2.1 and to all applicable requirements of 5.2.2.

An SPD that contains any linear component between its line terminals and protected line terminals shall conform to the applicable requirements of 5.2.2.

5.2.1.1 Maximum continuous operating voltage (U_c)

The manufacturer shall state the maximum continuous operating voltage for the SPD appropriate for the application such as AC rms or DC.

Compliance shall be checked in accordance with 6.2.1.1.

5.2.1.2 Insulation resistance

This characteristic shall be stated by the manufacturer. Compliance shall be checked in accordance with 6.2.1.2.

5.2.1.3 Impulse-limiting voltage

The SPD shall limit a specified impulse voltage when tested at the specified test conditions of table 3. The measured limiting voltage shall not exceed the specified voltage protection level U_p . See IEC 61180-1.

5.2.1.4 Impulse reset

This requirement is applicable only to switching-type SPDs. The SPD, after having an impulse wave selected from table 3 applied, shall extinguish or return to its quiescent state. During the application of this impulse wave, a voltage selected from table 4 shall be applied to the SPD. Unless otherwise specified, the SPD shall return to its high impedance state in 30 ms or less.

5.2.1.5 AC durability

The SPD, after having been tested according to 6.2.1.5 using current selected from table 5, shall meet the relevant requirements of 5.2.1 and 5.2.2, if applicable.

5.2.1.6 Impulse durability

The SPD, after having been tested according to 6.2.1.6 using current and voltage waveforms selected from table 3, shall meet the relevant requirements of 5.2.1 and 5.2.2, if applicable.

5.2.1.7 Overstressed fault mode

The SPD shall not become a fire hazard, explosion hazard or electrical hazard and shall not emit toxic fumes when tested in accordance with 6.2.1.7.

The manufacturer shall provide the value of the impulse current (8/20) and the value of alternating current which will lead to a fault mode as described in 6.2.1.7.

5.2.1.8 Blind spot

If no information regarding blind spots is available from the manufacturer, or verification of the manufacturer's information is desired, the testing of multi-stage SPDs shall be performed as described in 6.2.1.8.

5.2.2 Current-limiting requirements

When the SPD contains a combination of both voltage-limiting and current-limiting components, the current-limiting components shall conform to all applicable requirements of 5.2.2. An SPD that contains a linear component (for example, resistor, inductor) between its line terminals shall conform to the requirements of 5.2.2.1, 5.2.2.2, 5.2.2.7 and 5.2.2.8.

5.2.2.1 Rated current

The manufacturer shall specify the rated current. To confirm this value of rated current, the SPD shall be tested according to 6.2.2.1. Application of this test shall cause no change in the operating characteristics of the current-limiting component of the SPD.

5.2.2.2 Series resistance

The manufacturer shall specify the value and tolerance of any series resistance. To confirm this value of series resistance, the SPD shall be tested according to 6.2.2.2.

5.2.2.3 Current response time

When tested according to 6.2.2.3, the current-limiting component(s) shall operate at or below the value of response time specified by the manufacturer. Preferred values of test current are given in table 6. See ITU-T Recommendation K.30.

5.2.2.4 Current reset time

The SPD containing one or more self-resettable current-limiting components shall be tested in accordance with 6.2.2.4. The reset time, or time required for the current-limiting component(s) to return to their quiescent state, shall be less than 120 s, unless otherwise specified.

This requirement is not applicable to SPDs containing manually resettable current-limiting component(s).

5.2.2.5 Maximum interrupting voltage

This requirement is applicable only to SPDs containing self-resettable or manually resettable current-limiting component(s). The SPD manufacturer shall specify the maximum interrupting voltage of the current-limiting component(s) in the SPD. Confirmation of this value is determined by performing the test in 6.2.2.5. There shall be no degradation in the operating characteristics of the current-limiting components after this test.

5.2.2.6 Operating duty test

This requirement is applicable only to SPDs containing self-resettable or manually resettable current-limiting component(s). The SPD shall be subjected to repeated applications of the maximum interrupting voltage. The current shall be sufficient to operate the current-limiting component(s) and shall be selected from table 7. After exposure to these tests, the current-limiting component(s) shall meet the requirements of 5.2.2.3 and 5.2.2.4.

5.2.2.7 AC durability

The SPD shall be subjected to repeated applications of a specified current. Table 8 shows preferred values of alternating currents. After exposure to these currents, the current-limiting component(s) in the SPD shall meet the requirements of 5.2.2.1, 5.2.2.2 and 5.2.2.3.

5.2.2.8 Impulse durability

The SPD shall be subjected to a specified number of surges of specified peak current. Table 9 shows preferred values. After application of these surges in accordance with 6.2.2.8, the current-limiting component(s) of the SPD shall meet the requirements of 5.2.2.1, 5.2.2.2 and 5.2.2.3.

5.2.3 Transmission requirements

The SPD, in addition to the requirements of 5.2.1 and 5.2.2, may need to conform to specific requirements of 5.2.3 depending on its communication and signalling application (for example, voice, data, and video). Table 1 provides guidance in the selection of applicable transmission tests.

5.2.3.1 Capacitance

The manufacturer shall state the value of capacitance between specified terminals. Confirmation shall be determined by testing in accordance with 6.2.3.1.

5.2.3.2 Insertion loss

The SPD shall be tested in accordance with 6.2.3.2 to determine whether the insertion of the SPD into the test system results in a voltage reduction between the generating and the measuring equipment.

5.2.3.3 Return loss

The SPD shall be tested in accordance with 6.2.3.3. This will determine the amount of signal reflected back to the signal source, over a specified frequency range, caused by the insertion of the SPD into a matched transmission line.

5.2.3.4 Longitudinal balance

The SPD shall be tested in accordance with 6.2.3.4. This test determines the minimum acceptable level of longitudinal balance of an SPD used in balanced circuits. The longitudinal balance shall be measured in the frequency range of interest.

5.2.3.5 Bit error ratio (BER)

The SPD shall be tested in accordance with 6.2.3.5. This test determines whether the insertion of a surge protective device causes bit errors in a digital transmission system.

5.2.3.6 Near-end crosstalk (NEXT)

The SPD shall be tested in accordance with 6.2.3.6. This test determines the amount of signal that is coupled from one circuit to another due to the insertion of the SPD.

5.3 Mechanical requirements

The SPD shall conform to the following mechanical requirements. However, certain mechanical requirements may be superseded by national regulations.

5.3.1 Terminals and connectors

- a) Terminals and connectors shall be fastened to the SPD in such a way that they will not work loose if the clamping screws or the lock-nuts are tightened or loosened. A tool shall be required to loosen the clamping screws or the lock-nuts.

- b) Screws, current-carrying parts and connectors

- 1) Connections, whether electrical or mechanical, shall withstand the mechanical stresses occurring in normal use, and the mechanical stresses generated by high current surges.

Screws operated when mounting the SPD during installation shall not be of the thread-cutting type.

Compliance is checked by inspection and tested in accordance with 6.3.1.2.

- 2) Electrical connections shall be so designed that contact pressure is not transmitted through insulating material other than ceramic, pure mica or other material with characteristics no less suitable, unless there is sufficient resilience in the metallic parts to compensate for any possible shrinkage or yielding of the insulating material.

Compliance is checked by inspection.

The suitability of the material is considered with respect to the dimensions.

- 3) Current-carrying parts and connections including parts intended for grounding conductors, if any, shall be of

- copper, or
- an alloy containing at least 58 % copper for cold-worked parts, or
- an alloy containing at least 50 % copper for non-cold-worked parts, or other metal or suitably coated metal, no less resistant to corrosion than copper and having mechanical properties no less suitable.

Requirements for mechanical connections for specific terminals are covered in IEC 61643-1.

- c) Screwless terminals for external conductors

- 1) Terminals shall be so designed and constructed that

- each conductor is clamped individually and the conductors can be connected or disconnected either at the same time or separately;
- it is possible to clamp securely any number of conductors up to the maximum provided.

- 2) Terminals shall be so designed and constructed that they clamp the conductor without undue damage to the conductor.

Compliance is checked by inspection.

- d) Insulation pierced connections for external conductors

- 1) The insulation pierced connections shall make a reliable mechanical connection.

Compliance is checked by inspection and tested in accordance with 6.3.1.4.

- 2) Screws for making contact pressure shall not serve to fix any other component, although they may hold the SPD itself in place or prevent it from turning.

Compliance is checked by inspection.

- 3) Screws shall not be of metal which is soft or liable to creep.

Compliance is checked by inspection.

- e) Corrosion resistant metals

Clamps (except clamping screws), lock-nuts, binding clips, thrust washers, wire, and similar parts, shall consist of corrosion resistant metal (see IEC 60999-1).

5.3.2 Mechanical strength (mounting)

SPDs shall be provided with appropriate means for mounting that will ensure mechanical stability.

5.3.3 Resistance to ingress of solid objects and to harmful ingress of water

SPDs shall be designed in such a way that they operate satisfactorily under the service conditions described in 4.1. SPDs installed in the outdoor environment shall be contained in a weather shield of glass, glazed ceramic or other acceptable material that is resistant to UV radiation, corrosion, erosion, and tracking.

They shall have sufficient surface creepage distance between any two parts of different potential. In some countries, other national regulations may apply.

5.3.4 Protection against direct contact

For protection against direct contact (inaccessibility of live parts), SPDs shall be designed in such a way that live parts cannot be touched when the SPD is installed for the intended use. This requirement is valid for accessible SPDs where the U_c is above 50 V r.m.s. or 71 V d.c.

SPDs, except SPDs classified as inaccessible, shall be so designed that, when they are wired and mounted as for normal use, live parts are not accessible, even after removal of parts which can be removed without the use of a tool (checked by the isolated parts test of 6.3.4).

The connection between the grounding terminals, and all accessible parts connected thereto, shall be of low resistance (see IEC 60529).

In some countries, other national regulations may apply.

5.3.5 Fire resistance

Insulating parts of the housing shall be either non-flammable or self-extinguishing.

In some countries, other national regulations may apply.

5.4 Environmental requirements

The SPD intended only for the uncontrolled environment of 4.1, shall conform to the following environmental requirements after an agreement between the user and the manufacturer.

5.4.1 High temperature and humidity endurance

The SPD shall be exposed to 80 °C and 90 % RH. The duration of the exposure shall be selected from table 15. This test shall be performed only on those SPDs intended for use in uncontrolled environments, and shall be in accordance with 6.4.1. After exposure, the voltage-limiting component(s) of the SPD shall meet the requirements of 5.2.1.2 and 5.2.1.3. If the SPD under test contains current-limiting component(s), these shall meet the requirements of 5.2.2.2 and 5.2.2.3.

If a manufacturer's series of SPDs are identical, except for the U_c value, and the parts used are identical, except changes in the voltage ratings of voltage-limiting and current-limiting components to match a specific SPD U_c value, then only the SPD with the highest voltage protection level shall be tested.

5.4.2 Environmental cycling with impulse surges

The SPD shall be subjected to temperature cycling at high humidity while conducting impulse currents. The type of temperature cycling shall be selected from table 16.

During and after cycling, the voltage-limiting component(s) of the SPD shall meet the requirements of 5.2.1.2 and 5.2.1.3. If the SPD under test contains current-limiting component(s), these shall meet the requirements of 5.2.2.2 and 5.2.2.3.

This test shall be performed only on those SPDs intended for use in uncontrolled environments, and shall be performed in accordance with 6.4.2.

If a manufacturer's series of SPDs are identical, except for the U_c value, and the parts used are identical, except changes in the voltage ratings of voltage-limiting and current-limiting components to match a specific SPD U_c value, then only the SPD with the highest voltage protection level shall be tested.

5.4.3 Environmental cycling with a.c. surges

The SPD shall be subjected to temperature cycling at high humidity while conducting alternating currents. These currents and their duration shall be selected from table 5. The type of temperature cycling shall be selected from table 16.

During and after cycling, the SPD shall meet the requirements of 5.2.1.2 and 5.2.1.3.

This test shall be performed only on those SPDs intended for use in uncontrolled environments and shall be performed in accordance with 6.4.3.

If a manufacturer's series of SPDs are identical, except for the U_c value, and the parts used are identical, except changes in the voltage ratings of voltage-limiting and current-limiting components to match a specific SPD U_c value, then only the SPD with the highest voltage protection level shall be tested.

6 Type test

6.1 General tests

6.1.1 Identification and documentation

Identification and documentation shall meet the requirements of 5.1.1 by inspection.

6.1.2 Marking

Verification of the markings shall be carried out by inspection. The following indelibility test shall be applied on markings of all types except those made by impressing, moulding and engraving.

The test is made by rubbing the marking by hand for 15 s with a piece of cotton wool soaked with water and again for 15 s with a piece of cotton soaked with hexane solvent with a content of aromatics of maximum 0,1 % volume, a kauributanol value of 29, initial boiling-point approximately 65 °C and specific gravity of 0,68 g/cm³. After this test, the marking shall be easily legible.

6.2 Electrical tests

6.2.1 Voltage-limiting tests

6.2.1.1 Maximum continuous operating voltage (U_c)

U_c shall be verified during the insulation resistance test in 6.2.1.2.

6.2.1.2 Insulation resistance

Insulation resistance shall be measured in both polarities at one pair of terminals at a time. The test voltage shall be equal to U_c . The current conducted between the tested terminals shall be measured. The insulation resistance is the test voltage divided by the measured current and shall be higher than or equal to the value stated by the manufacturer.

6.2.1.3 Impulse-limiting voltage

The SPDs shall be tested using one impulse selected from category C of Table 3 and applied to the appropriate terminals. The current level shall be selected based on the energy capability of the SPD as determined in the impulse durability test (see 6.2.1.6). Both impulse-limiting voltage and impulse durability tests shall be performed with the same impulse. Values listed in Table 3 are minimum requirements, other surge current ratings can be found in standards e.g. ITU-T recommendations.

Additional tests may be performed using waveforms selected from Categories A1, B, C and D as well as those listed in the SPD documentation. However, these tests are optional and should only be used as appropriate to the application of the SPDs. The current level shall be selected based on the energy capability of the SPD as indicated by the manufacturer.

Unless otherwise specified, apply five negative and five positive impulses for each impulse test. The generator used shall have its open-circuit voltage and short-circuit current selected from table 3.

Measure the voltage limitation for each impulse without load. The maximum voltage measured at the appropriate terminals shall not exceed the specified voltage protection level (U_p). Sufficient time shall be allowed between impulses to prevent accumulation of heat. It is understood that different SPDs will have different thermal characteristics, and consequently will require different times between impulses.

For detail impulse recorder settings refer to Annex D.

If it is required, the impulse may be applied to terminals X1 – X2 of SPDs shown in figures 1c) and 1e).

For tests on the SPDs shown in figures 1c) and 1e), each pair of terminals (X1 – C and X2 – C) may be tested at the same time and same polarity, or separately.

For SPDs that have a common shunt element (refer to 4.3), the voltage on the line terminals which do not have the impulse applied shall be measured and it shall not exceed U_p .

Table 3 – Voltage and current waveforms for impulse-limiting voltage

Category	Type of test	Open-circuit voltage ^a	Short-circuit current	Minimum number of applications	Terminals to be tested
A1	Very slow rate of rise	≥ 1 kV Rate of rise from 0,1 kV/ μ s to 100 kV/s	10 A, 0,1 A/ μ s to 2 A/ μ s, $\geq 1\,000$ μ s (duration)	Not applicable (NA)	X1 – C X2 – C X1 – X2 ^b
A2	AC	Select a test from Table 5		Single cycle	
B1	Slow rate of rise	1 kV 10/1000	100 A, 10/1000	300	
B2		1 kV to 4 kV 10/700	25 A to 100 A 5/300	300	
B3		≥ 1 kV 100 V/ μ s	10 A to 100 A 10/1 000	300	
C1	Fast rate of rise	0,5 kV to < 2 kV 1,2/50	0,25 kA to < 1 kA 8/20	300	
C2		2 kV to 10 kV 1,2/50	1 kA to 5 kA 8/20	10	
C3		≥ 1 kV 1 kV/ μ s	10 A to 100 A 10/1 000	300	
D1	High energy	≥ 1 kV	0,5 kA to 2,5 kA 10/350	2	
D2		≥ 1 kV	0,6 kA to 2,0 kA 10/250	5	

^a An open-circuit voltage different from 1 kV may be used. However, it must be sufficient to operate the SPD under test.

^b X1 – X2 terminals shall be tested only if it is required.

NOTE 1 For the verification of U_p , one of the above impulse waveform of category C is mandatory and A, B and D are optional. Unless otherwise specified, apply 5 positive and 5 negative pulses.


NOTE 2 For impulse reset, select test from category B, C and D. Unless otherwise specified, apply 3 positive and 3 negative pulses.

NOTE 3 For impulse durability measurement, one impulse waveform of category C is mandatory and A1, B and D are optional.

NOTE 4 Values listed in Table 3 are minimum requirements; other surge current ratings are possible and can also be found in other standards e.g. ITU-T K series – Recommendations.


Simultaneous surge on all protected conductors

Multi-line SPDs may use a common protective element for the ground return of the total impulse current. Two examples are shown in Figure 16. All the protected lines shall have an impulse current equal to total impulse current divided by number of lines. applied simultaneously to verify that the common protective element had adequate current capability. After this test the SPD shall not be degraded. This test also verifies that the internal connections of the SPD have adequate current capability.



IEC 555/08

Star protection circuit



IEC 556/08

Diode steering bridge

Key

X1, X2, Xn,	line terminals	1	individual protective element
Y1, Y2, Yn,	protected line terminals	2	common protective element
C	common		

Figure 16 – Examples of multi-line SPDs with a common protective element

The requirements of the current distributor (coupling network) shown in Figure 4 are as follows:

- The coupling network shall not influence the test impulse. All parameters of the surge waveform according to 4.4 apply to the output terminals of the coupling network.
- The front time and the pulse duration shall be verified at the output terminals of the coupling network for surge voltages (open circuit) and surge currents (short-circuit).
- The surge waveform of the short-circuit current can be measured with the aid of a toroidal current transformer or a current monitoring resistor.
- Preferably resistors should be used for the coupling network.
- The current sharing in each conductor of the distributor has to be tested individually with the other conductors shorted before connection to the respective test specimen is made. The results of this test does not mean that the currents will be equally shared when the SPD is in the circuit.
- During the simultaneous test it will be verified that the common protective element was exposed to the total impulse current without failure of any surge protective components.

6.2.1.4 Impulse reset

The SPD shall be connected as shown in figure 2. The source voltage and current can be selected from, but not limited to, table 4. These power sources represent commonly used system values. For new applications, the impulse reset shall be done with the source voltage and current that is used for the intended application.

The impulse voltage and current waveforms shall be selected from table 3, Categories B, C, and D. The peak open-circuit voltage shall be sufficiently great to ensure that the voltage-limiting component(s) operate(s). The polarity of the impulse voltage shall be the same as the polarity of the voltage source. The reset time is defined as the time from application of the impulse to the return of the SPD to its high-impedance state.

Three impulses shall be applied at intervals not greater than 1 min, and the reset time shall be measured for each impulse. The test shall be repeated in the opposite polarity.

Table 4 – Source voltages and currents for impulse reset test

Open-circuit source voltage ^b V	Short-circuit source current mA
12	500
24	500
48	260
97	80
135	200 ^a
^a The SPD may be connected in parallel by a series combination of a 135-150 Ω resistor and a 0,08 μ F to 0,1 μ F capacitor. ^b Tolerance (including ripple) + 10% -0%	

6.2.1.5 AC durability for voltage limiting function

The SPD shall be connected as shown in figure 3. The a.c. short-circuit current shall be selected from table 5. Apply the currents for the specified number of applications with time between applications sufficient to prevent accumulation of heat in the device under test. The open-circuit voltage shall be of sufficient magnitude to cause a full conduction of the SPD. Prior to testing and after completion of the required number of a.c. applications, the SPD shall meet the requirements of 5.2.1.2, 5.2.1.3, 5.2.1.4 (if applicable) and 5.2.2.2.

The currents, selected from table 5, shall be applied to the appropriate terminals.

If it is required, the currents may be applied to terminals X1 – X2 of SPDs shown in figures 1c) and 1e).

For tests on the SPDs shown in figures 1c) and 1e), each pair of terminals (X1 – C and X2 – C) may be tested separately.

For SPDs that have a common shunt element, refer to 4.3. Otherwise, for multi-terminal SPDs test each line terminal to common terminal separately.

Table 5 – Preferred values of currents for a.c. durability test

48 Hz-62 Hz Short-circuit currents on each tested terminal ^a A_{rms}	Duration s	Number of applications ^b	Test terminals
0,1	1	5	X1 – C X2 – C X1 – X2 ^c
0,25	1	5	
0,5	1	5	
0,5	30	1	
1	1	5	
1	1	60	
2	1	5	
2,5	1	5	
5	1	5	
10	1	5	
20	1	5	
^a Values listed in Table 5 are minimum requirements. .			
^b Different numbers of applications can be found in other standards e.g. ITU-T K series - Recommendations			
^c X1 – X2 terminals shall be tested only if required			

6.2.1.6 Impulse durability for voltage limiting function

The SPD shall be tested using one impulse selected from Category C of table 3 and applied to the appropriate terminals selected from table 3. The same impulse shall be used to perform the impulse-limiting voltage test in 6.2.1.3. Additional tests may be performed using other impulses selected from Categories A1, B, C and D as well as those listed in the SPD documentation. However, these tests are optional and should only be used as appropriate to the application of the SPDs.

The SPD shall be connected as shown in figure 4. Apply the impulse current for the minimum number of applications specified in table 3 with time between applications sufficient to prevent accumulation of heat in the device under test. Half the specified number of tests shall be carried out with one polarity followed by half with the opposite polarity. Alternatively, half of the samples may be tested with one polarity and the other half with the opposite polarity. Prior to testing and after the completion of the number of applications, the SPD shall meet the requirements of 5.2.1.2, 5.2.1.3 (one impulse each polarity), 5.2.1.4 (if applicable) and 5.2.2.2 (if applicable).

If required, the impulse may be applied to terminals X1 – X2 of SPDs shown in figures 1c) and 1e).

For tests on the SPDs shown in figures 1c) and 1e), each pair of terminals (X1 – C and X2 – C) may be tested separately.

For SPDs that have a common current path refer to 4.3.

6.2.1.7 Overstressed fault mode

The SPD shall be overstressed by impulse overstress and a.c. overstress currents. For tests on the SPDs shown in Figures 1c, 1e and 1f, each pair of terminals (X1 – C and X2 – C) may be tested separately. For SPD 1f select two terminals as a representative sample. Different SPDs shall be tested for impulse and a.c. tests.

Then insulation resistance, voltage-limiting and series resistance (if applicable) tests shall be performed to determine if the SPD has reached an acceptable overstressed fault mode as described in 3.3. The SPD shall reach its overstressed fault mode in a safe manner without causing a fire hazard, an explosion hazard, an electrical hazard or emission of toxic fumes.

Impulse overstress

The SPD shall be connected as shown in figure 4. The 8/20 impulse current, i_n , specified by the manufacturer shall be applied to the SPD in the following manner:

$$i_{\text{test}} = i_n (1 + 0,5 N)$$

The test sequence shall begin with $N = 0$ ($i_{\text{test}} = i_n$). For each subsequent test, N increases by 1. This sequence is limited to $N = 6$. If the SPD does not reach an overstressed fault mode after these applications, the SPD shall be tested for overstressed fault mode with a.c.

AC overstress

The SPD shall be connected as shown in figure 3. The a.c. overstress current test shall be specified by the manufacturer. The current shall be applied for 15 min. The open-circuit voltage, 50 Hz or 60 Hz, shall have sufficient magnitude to cause a full conduction of the SPD. At the conclusion of the test, the mounting support shall be able to receive another SPD.

6.2.1.8 Blind spot test

In order to determine whether blind spots exist in a multi-stage SPD, the following tests using a new sample shall be performed.

- Select the impulse waveform used to determine U_p . During the application of this impulse, measure the impulse-limiting voltage and the voltage-time waveform with an oscilloscope.
- Reduce the open-circuit voltage to 10 % of the value used in a), and apply one positive impulse to the SPD while monitoring the limiting voltage with an oscilloscope. The limiting voltage waveform should be different from that obtained in a). If it is not, select a lower open-circuit voltage. However, this voltage shall be above U_c .
- Apply positive impulse voltages whose values are 20 %, 30 %, 45 %, 60 %, 75 % and 90 % of the value used in a), while continuing to monitor the limiting voltage waveform.
- At the open-circuit voltage percentage when the limiting voltage waveform returns to that as determined in a), stop.
- Reduce the open-circuit voltage by 5 % and retest. Continue reducing the open-circuit voltage in steps of 5 % until the waveform noted in b) is obtained.
- At this value of open-circuit voltage, apply two impulses of positive polarity and two impulses of negative polarity.

After testing a) through f), the SPD shall meet the requirements of 5.2.1.2.

6.2.2 Current-limiting tests

6.2.2.1 Rated current

The SPD shall be connected as shown in figure 5. The test voltage source shall be sufficient to supply the rated current. The frequency shall be 0 (d.c.) or 50 Hz or 60 Hz.

During the rated current tests the current-limiting function, if present, shall not operate. For each SPD configuration, the test current shall be applied by adjusting the R_s , or R_{s1} and R_{s2} resistances. The current-limiting function under test shall conduct the rated current for a 1 h minimum period. During this test the touchable parts shall not reach excessive temperatures (see 4.5.1 of IEC 60950).

6.2.2.2 Series resistance

The SPD shall be connected as shown in figure 5. The test source voltage shall be less than the maximum interrupting voltage as specified by the manufacturer. The frequency shall be 0 (d.c.) or 50 Hz or 60 Hz.

The test current shall be made equal to the rated current by adjusting the R_s , or R_{s1} and R_{s2} resistances. The resistance is determined by $(e - IR_s)/I$ where e is the source voltage and I is the rated current as measured by the ammeter in figure 5.

6.2.2.3 Current response time

The SPD shall be connected as shown in Figure 5. The source voltage shall be less than the maximum interrupting voltage as specified by the manufacturer. The frequency shall be either 0 Hz (d.c.) or 50 Hz or 60 Hz, the choice being selected, according to the intended application.

Devices shall be tested at appropriate temperatures with reference to 4.2. Sufficient time shall be allowed between tests to ensure that devices cool back to testing temperature prior to subsequent testing. Alternatively, separate devices can be used for each test to avoid waiting for the cooling period. R_s or R_{s1} and R_{s2} shall be set to provide the desired prospective test currents of Table 6. The response time of the current-limiting function at each test current shall be recorded. The response time is the time from application of power until the current falls to 10 % of the rated current. If the prospective test current exceeds the maximum current capability of the current-limiting component(s), then the highest test current shall be the maximum current capability of the current-limiting component(s).

Table 6 – Test currents for response time

Test currents A
1,5 × rated current
2,1 × rated current
2,75 × rated current
4,0 × rated current
10,0 × rated current

6.2.2.4 Current reset time

The SPD shall be connected as shown in figure 5. The source voltage shall be less than the maximum interrupting voltage as specified by the manufacturer. The frequency shall be 0 (d.c.), 50 Hz or 60 Hz.

For each SPD configuration, the initial load current shall be the rated current, obtained by adjusting the R_s , or R_{s1} and R_{s2} resistances. The SPD shall be allowed to stabilize at the rated current. After the stabilization, the R_s , or R_{s1} and R_{s2} resistances shall be reduced to values such that the load current increases to a level that causes the current-limiting function of the SPD to operate. This test condition shall be maintained for 15 min after the current is reduced below 10 % of the rated current.

The R_s , or R_{s1} and R_{s2} resistances shall then be increased to their initial values. The time which it takes for the load current to return to at least 90 % of the rated current, shall be recorded and shall be less than 120 s. Depending on the application, testing may be done at currents lower than the rated current for self-resetting current-limiting functions. For resettable current-limiting components, the source current shall be interrupted for a time of less than 120 s. After this, the resettable current-limiting function shall conduct the rated current for a period of 5 min to ensure that the current-limiting function has reverted to its quiescent state.

6.2.2.5 Maximum interrupting voltage

The SPD shall be connected as shown in figure 5. The test voltage shall be the maximum interrupting voltage as specified by the manufacturer. The frequency shall be 0 (d.c.) or 50 Hz or 60 Hz.

The R_s , or R_{s1} and R_{s2} resistances shall be adjusted to a value that causes the operation of the current-limiting component of the SPD. This test condition shall be maintained for 1 h. After 1 h, the current-limiting function of the SPD shall satisfy 5.2.2.2, 5.2.2.3 and 5.2.2.4.

6.2.2.6 Operating duty test

The SPD shall be connected as shown in figure 5. The test voltage shall be the maximum interrupting voltage as specified by the manufacturer. The frequency shall be 0 (d.c.) or 50 Hz or 60 Hz.

For each SPD configuration, the load current shall be adjusted (by means of the R_s , or R_{s1} and R_{s2} resistances) to a value selected from table 7 with the SPD temporarily replaced by a short circuit. The selected value shall be sufficient to cause the current-limiting function to operate. After the insertion of the SPD in the circuit, apply the test current until it is reduced below 10 % of the rated current.

After each SPD operation, remove the power for at least 2 min or until the current-limiting component reverts to its quiescent state. This cycle of applying test current, followed by an unpowered period, shall be repeated for the number of times indicated in table 7.

After the final cycle, the SPD shall meet the requirements of 5.2.2.2, 5.2.2.3 and 5.2.2.4.

Table 7 – Preferred values of current for operating duty tests

Current A (d.c. or r.m.s.)	Applications
0,5	60
1	10
3	5
5	5
10	3

6.2.2.7 AC durability for current limiting function

The SPD shall be connected as shown in figure 6. The a.c. short-circuit currents shall be selected from table 8. Apply currents for the specified number of applications with time between applications sufficient to prevent accumulation of heat in the device under test. The peak value of the a.c. source voltage shall not exceed the maximum interrupting voltage as specified by the manufacturer. Prior to testing and after the completion of the number of applications, the SPD shall meet the requirements of 5.2.2.1, 5.2.2.2 and 5.2.2.3.

The current shall be applied to the appropriate terminals selected from table 8. The currents may be applied to terminals X1 – X2, if it is required for three-terminal and five-terminal SPDs. For tests on three-terminal and five-terminal SPDs, each pair of terminals (X1 – C and X2 – C) on the unprotected side may be tested at the same time and same polarity, or separately.

Table 8 – Preferred values of a.c. test currents

48-62 Hz Short-circuit currents A_{rms}	Duration s	Number of applications	Test terminals
0,25	1	5	X1 – C X2 – C X1 – X2
0,5	1	5	
0,5	30	1	
1	1	5	
1	1	60	
2	1	5	
2,5	1	5	
5	1	5	

6.2.2.8 Impulse durability for current limiting function

The SPD shall be connected as shown in figure 7. The impulse voltages and currents shall be selected from table 9. Apply the impulse current for the specified number of applications with time between applications sufficient to prevent accumulation of heat in the device under test. Half the specified number of tests shall be carried out with one polarity followed by half with the opposite polarity. Alternatively, half of the samples may be tested with one polarity and the other half with the opposite polarity. Prior to testing and after the completion of the number of applications, the SPD shall meet the requirements of 5.2.2.1, 5.2.2.2 and 5.2.2.3.

The impulse current shall be selected from table 9 and applied to the appropriate terminals. The impulse current may be applied to terminals X1 – X2 for three-terminal and five-terminal SPDs. For tests on three-terminal and five-terminal SPDs, each pair of terminals (X1 – C and X2 – C) on the unprotected side may be tested at the same time and same polarity, or separately.

Low-current fuses may require a reduction in test I^2t level to be within the SPD rating. Electronic current limiters may be designed to operate with a minimum protected load impedance or voltage (for example, a gas discharge tube in the arc mode). If required, this shall be added to the test circuit.

Table 9 – Preferred values of impulse current

Open-circuit voltage	Short-circuit current	Number of applications	Test terminals
1 kV	100 A, 10/1 000	30	X1 – C X2 – C X1 – X2
1,5 kV, 10/700	37,5 A, 5/300	10	
Maximum interrupting voltage	25 A, 10/1 000	30	
Maximum interrupting voltage	ITU-T Recommendation K17, Figure 1/K17	10	
4 kV, 1,2/50	2 kA, 8/20	10	

6.2.3 Transmission tests

6.2.3.1 Capacitance

The capacitance of the SPD is measured between specified terminals at a signal generator frequency of 1 MHz and 1 V r.m.s. One pair of terminals is measured at a time; all terminals not involved in the measurement shall be connected together and grounded at the generator. No d.c. bias shall be applied. It should be noted that the capacitance of some SPDs is bias voltage dependent. In some applications this bias voltage may appear only on one line of a communications pair resulting in significant capacitance unbalance.

6.2.3.2 Insertion loss

The insertion loss in decibels is measured using leads of a maximum of 1 m in length and having the appropriate characteristic impedance. A measurement is made using the circuit of figure 8 with a short circuit replacing the SPD. The SPD is then inserted and a decibels measurement in decibels is made. The insertion loss is the vector difference between the two measurements. Table 10 lists the characteristic impedances, the frequency ranges and the cable types. The recommended test level is –10 dBm.

The measured loss of the combined baluns and test leads in figure 8 shall not exceed 3 dB within the frequency band of the transmission. The insertion loss shall be measured and recorded within the frequency band of the transmission application that the SPD is intended for use.

Table 10 – Standard parameters for figure 8

Frequency range	Characteristic impedance Z_0 Ω	Cable types
300 Hz to 4 kHz	600	Twisted-pair
4 kHz to 250 MHz	100, 120 or 150	Twisted-pair
≤ 1 GHz	50 or 75	Coaxial
> 1 GHz	50	Coaxial

6.2.3.3 Return loss

The return loss in decibels is measured using leads of a maximum of 1 m in length and having the appropriate characteristic impedance. A measurement is made using the circuit of figure 9 with a short circuit replacing the SPD. The SPD is then inserted and a measurement in decibels is made. Table 10 lists the characteristic impedances, the frequency ranges and the cable types. The recommended test level is –10 dBm.

A signal is applied to the SPD. Signals reflected back, due to impedance discontinuities, are measured at the same terminals to which the signal is applied. The return loss shall be measured and recorded within the frequency band of the transmission application that the SPD is intended for use.

6.2.3.4 Longitudinal balance / Longitudinal conversion loss (LCL)

Longitudinal balance as calculated in the equation below is equivalent to longitudinal conversion loss (LCL) as described in ITU-T O.9 (03.1999).

Figure 10 shows the connections for longitudinal balance testing of three- four- and five-terminal SPDs. For four- and five-terminal SPDs, the test shall be carried out with switch S1 both open and closed. The longitudinal balance is the ratio of the applied longitudinal voltage V_s and the resulting voltage V_m of the SPD under test expressed in dB, as follows:

$$\text{Longitudinal balance (dB)} = 20 \log (V_s / V_m)$$

where the V_s and V_m signals have the same frequency.

Due to more precision at higher frequencies, a balun transformer to implement the SPD may be used instead of the shown ohmic resistances in the test set-up of Figure 10. The test bridge configuration, with transversal impedance Z_1 and longitudinal impedance Z_2 does not represent all conditions found in practice. Values and limits for the intended transmission characteristics, such as frequency range and voltage, special considerations for terminating impedances and measurement frequencies to be used are given in the relevant ITU-T recommendations. An example of values and impedances for different frequency ranges up to 190 kHz is shown in Table 11. Unless otherwise specified, The test may be performed with increasing frequencies, for example at 200 Hz, 500 Hz, 1 000 Hz and 4 000 Hz for analogue applications, or at 5 kHz, 60 kHz, 160 kHz and 190 kHz for digital ISDN applications. The inherent longitudinal balance of the measuring arrangements should be 20 dB greater than the limit set for the SPD. If the longitudinal balance of the SPD is affected by the d.c. bias voltage, then the test should be carried out whilst applying the appropriate d.c. bias voltage at each SPD terminal. Requirements for the measuring arrangements are given in ITU-T Recommendation O.9.

Table 11 – Impedance values for longitudinal balance test

f kHz	Service	Z_1^a Ω	Z_2^b Ω
≤ 4	Analogue	300	150
≤ 190	ISDN	55 or 67.5	20-40
Up to 30 MHz	ADSL2+; VDSL	67,5	20-40
^a The real difference between the test set-up and the actual longitudinal balance is somewhat independent of the terminal input impedance and therefore this analysis applies to virtually all reasonable input impedances. For details to specify Z_1 and Z_2 , see the relevant product standard.			
^b Z_2 should be equal to half of Z_1 .			

Where the longitudinal conversion loss is dependent on the SPD series resistance matching, the balance may be specified as the maximum ohmic or percentage difference between the series resistances.

6.2.3.5 Bit Error Ratio (BER)

Bit error ratio (BER, see Figure 11), the result of dividing the number of bit errors by the total number of bits in a stream, can be used to identify the performance of a communications or data storage product. For example, 2,5 erroneous bits out of 100 000 bits transmitted would be 2,5 out of 10^5 or $2,5 \times 10^{-5}$. An example of test times for different transmission rates is shown in Table 12

BER tests are conducted to measure the change, if any, caused by insertion of an SPD. BER tests are described in ITU-T G series (e.g. for ISDN ITU-T G.821, ADSL2 ITU-T G.992.3, VDSL ITU-T G.993.1, etc.)

Table 12 – Test times for BER test

Pseudo-random bit pattern, (R)	Duration
$R < 64 \text{ kbits/s}$	1 h
$64 \text{ kbits/s} \leq R < 1\,554 \text{ kbits/s}$	30 min
$R \geq 1\,554 \text{ kbits/s}$	10 min

6.2.3.6 Near-end crosstalk (NEXT)

The crosstalk is measured on short lengths of balanced test leads terminated to the SPD according to figure 12. A balanced input signal is applied to a disturbing line of the SPD while the induced signal on the disturbed line is measured at the near end of the test leads. The recommended test signal is –10 dBm.

The measured loss of the combined baluns and test leads shall not exceed 3 dB within the frequency band of the transmission. The near-end crosstalk shall be measured and recorded within the frequency band of the transmission application that the SPD is intended for use.

6.3 Mechanical tests

6.3.1 Terminals and connectors

It shall be verified that the incorporated terminals meet the requirements of 5.3.1.

6.3.1.1 General testing procedure

The SPD is mounted according to the manufacturer's recommendation and is protected against undue external heating or cooling.

Unless otherwise specified, the SPD terminals shall be wired with conductors using the most severe configuration (i.e., the maximum or minimum cross-sectional areas) according to

- table 13 for SPDs that have both line terminals and protected line terminals;
- the manufacturer's instructions for other SPDs.

The SPD under test shall be fixed on a dull, black-painted wood board of about 20 mm thickness. The method of fixing shall comply with any requirements relating to the means of mounting recommended by the manufacturer. During the test, no maintenance or dismantling of the sample is allowed.

6.3.1.2 Terminals with screws

Compliance is checked by inspection and, for screws which are operated when connecting up the SPD, by the following test:

The screws are tightened and loosened

- ten times for screws in engagement with a thread of insulating material;
- five times in all other cases.

Screws or nuts in engagement with a thread of insulating material are completely removed and reinserted each time. The test is made by means of a suitable test screwdriver or spanner applying a torque as suggested by the manufacturer. The screws shall not be tightened in jerks. The conductor is removed each time the screw is loosened.

During the test, the screwed connections shall not work loose and there shall be no damage, such as breakage of screws or damage to the head slots, threads, washers or stirrups, that will impair the further use of the SPD.

Moreover, enclosures and covers shall not be damaged.

Table 13 – Connectable cross-sectional areas of copper conductors for screw-type terminals or screwless-type terminals

Maximum rated current for SPDs A	Range of nominal cross-sectional areas to be clamped	
	ISO – mm ²	AWG – Terminal
Up to and including 1	0,1 to 1	26 to 18
Above 1 up to and including 13	1 to 2,5	18 to 14
Above 13 up to and including 16	1 to 4	18 to 12

6.3.1.3 Screwless terminals

Compliance is checked by the following tests.

The terminals are fitted with new conductors of the type and of the minimum and maximum cross-sectional areas according to table 13 for two-port SPDs or according to the manufacturer's declaration for one-port SPDs.

Each conductor is then subjected to a pull of the value shown in table 14. The pull is applied without jerks for 1 min in the direction of the axis of the conductor.

During the test, there shall be no movement of the conductor in the terminal or any indication of damage.

Table 14 – Pulling force (screwless terminals)

Cross-sectional area mm ²	0,5	0,75	1,0	1,5	2,5	4
Pull force N	30	30	35	40	50	60

6.3.1.4 Insulating pierced connections

6.3.1.4.1 Pull-out test on SPD terminals designed for single-core conductors

Compliance is checked by the following tests.

The terminals are fitted with new copper conductors of the smallest or largest cross-sectional area specified in 6.3.1.1, solid or stranded, whichever is most unfavourable. Screws, if any, are tightened as suggested by the manufacturer.

The conductors are connected and disconnected five times, new conductors being used each time. After each connection, the conductors are subjected to a pull, without jerks, for 1 min in the axis of the conductor according to the value given in table 14.

During the test, there shall be no movement of the conductor in the terminal or any sign of damage.

6.3.1.4.2 Pull-out test on SPD terminals designed for multi-core cables or cords

The pull-out test on the SPD terminals designed for multi-core cables or cords is carried out according to 6.3.1.4.1 except that the pull force is applied to the entire multi-core cable or cord instead of the individual core.

The pull force is calculated according to the following formula:

$$F = F(x) \sqrt{n}$$

where

F is the total force to be applied;

n is the number of cores;

$F(x)$ is the force for one core according to the cross-sectional area of one conductor (see table 14).

During the test the cable or cord shall not slip out of the terminals.

6.3.2 Mechanical strength (mounting)

It shall be verified by inspection that SPDs have adequate mechanical strength to withstand the stresses imposed during installation and use.

6.3.3 Resistance to ingress of solid objects and to harmful ingress of water

Test in accordance with IEC 60529 to check the IP code.

6.3.4 Protection against direct contact

Insulating parts

The sample is mounted as for normal use and fitted with conductors of the smallest cross-sectional areas and the test is repeated using conductors of the largest cross-sectional areas (see table 13). The standard test finger (in accordance with IEC 60529) is applied in every possible position.

For plug-in SPDs (which can be changed without a tool), the test finger is applied in every possible position, when the plug is partially engaged or completely engaged with a socket outlet. An electrical indicator with a voltage of not less than 40 V and not more than 50 V, is used to show contact with the relevant part.

Metal parts

Metal parts which are accessible when the SPD is wired and mounted as for normal use shall be connected to ground through a low-resistance connection, except for small screws and the like, insulated from live parts, for fixing bases and covers or cover plates of socket-outlets.

A current (derived from an a.c. source having a no-load voltage not exceeding 12 V) equal to 1,5 times the rated current or to 25 A, whichever is the greater, is passed between the grounding terminal and each of the accessible metal parts in turn.

The voltage drop between the grounding terminal and the accessible metal part is measured and the resistance is calculated from the current and this voltage drop. The resistance shall not exceed 0,05 Ω .

NOTE Care should be taken that the contact resistance between the tip of the measuring probe and the metal part under test does not influence the test results.

6.3.5 Fire resistance

The glow-wire test is performed in accordance with clauses 4 to 10 of IEC 60695-2-1/1 under the following conditions:

- for external parts of SPD made of insulating material necessary to retain in position current-carrying parts and parts of the protective circuit, by the test made at a temperature of $850\text{ }^{\circ}\text{C} \pm 15\text{ }^{\circ}\text{C}$;
- for all other external parts made of insulating material, by the test made at a temperature of $650\text{ }^{\circ}\text{C} \pm 10\text{ }^{\circ}\text{C}$.

For the purposes of this test, bases of surface-type SPDs are considered as external parts. The test is not made on parts of ceramic material. If the insulating parts are made of the same material, the test is carried out only on one of these parts, at the appropriate glow-wire test temperature.

The glow-wire test is applied to ensure that an electrically heated test wire under defined test conditions does not cause ignition of insulating parts, or to ensure that a part of insulating material, which might be ignited by the heated test wire under defined conditions, has a limited time to burn without spreading fire by flame or burning parts or droplets falling from the tested part.

The test is made on one sample. In case of doubt, the test is repeated on two further samples. The test is made by applying the glow-wire once. The sample shall be positioned during the test in the most unfavourable position of its intended use (with the surface tested in a vertical position).

The tip of the glow-wire shall be applied to the specified surface of the test sample taking into account the conditions of intended use under which a heated or glowing element may come into contact with the sample.

The sample is regarded as having passed the glow-wire test if

- there is no visible flame and no sustained glowing, or if
- flames and glowing on the sample extinguish themselves with 30 s after the removal of the glow-wire.

There shall be no ignition of the tissue paper or scorching of the pinewood board.

6.4 Environmental tests

6.4.1 High temperature and humidity endurance

The SPD shall be exposed to high temperature and relative humidity conditions for a duration selected from table 15. The temperature shall be 80 °C. The relative humidity shall be 90 %.

The SPD shall be tested using the appropriate test circuit of figure 13. The SPD shall be powered with a d.c. or a.c. supply throughout the exposure. The power supply voltage shall be equal to the maximum continuous operating voltage specified in 5.2.1.1. This power supply shall have sufficient current capability to supply the current drawn by the SPD under test. After the exposure, the SPD shall be cooled to an ambient temperature of 23 °C ± 2 °C.

Table 15 – Preferred values of test-time duration for high temperature and humidity endurance

Test-time duration Days
10
21
30
56

6.4.2 Environmental cycling with impulse surges

The SPD shall be exposed to the non-condensing environmental cycle for the duration corresponding to the cycle selected from table 16. During the exposure, a generator of impulses having the characteristics specified in table 3 shall be used to apply sufficient open-circuit voltage selected from Category C of table 3.

When cycle A is selected, two impulse currents shall be applied each cycling day for five consecutive days, followed by two days without application. Alternatively, when cycle B is selected, two impulse currents shall be applied at the first day and the last day of the temperature cycling. On each surge day, one impulse current is applied at high extreme temperature T_1 , given in Table 16, and the other at low extreme temperature T_2 , given in Table 16. The surges shall be applied within 1 h of the centre of the dwell time at low and high extreme temperatures. The impulse currents on a given day shall be of the same polarity, but shall alternate polarity on the next test day. This procedure shall be repeated until the completion of the environmental cycling.

The SPD shall be tested using the appropriate test circuit of figure 13 and shall be powered with a d.c. supply throughout the environmental cycling. The negative or positive level of the d.c. power supply shall not exceed the rated voltage specified in 5.2.1.1. The SPD shall not be powered with the d.c. power supply during the application of the impulse current.

**Table 16 – Preferred values of temperature and duration
for environmental cycling tests**

Cycle	High extreme temperature (T_1) °C	Low extreme temperature (T_2) °C	Duration cycles
Cycle A – Figure 14	32 ± 2	4 ± 2	30
Cycle B – Figure 15 (based on IEC 60068-2-30; 6.3.3, variant 2)	40 or 55 ± 2	25 ± 3	5

The impulse-limiting voltage shall be measured during the application of each impulse current. The insulation resistance shall be measured within 1 h after each surge application. If the SPD is known to be sensitive to the polarity of the d.c. power supply, it shall be tested for insulation resistance with positive and negative polarities.

Within 1 h after the end of the environmental cycling, the SPD shall satisfy the requirements of 5.2.1.2 and 5.2.1.3.

6.4.3 Environmental cycling with a.c. surges

The SPD shall be exposed to the non-condensing environmental cycle for the duration corresponding to the cycle selected from table 16. During the exposure, using a generator, apply sufficient open-circuit a.c. voltage with short-circuit current selected from table 5.

When cycle A is selected, two impulse currents shall be applied each cycling day for five consecutive days followed by two days without application. Alternatively, when cycle B is selected, two impulse currents shall be applied at the first day and the last day of the temperature cycling. On each surge day, one impulse current is applied at high extreme temperature T_1 , given in Table 16, and the other at low extreme temperature T_2 given in Table 16. The surges shall be applied within 1 h of the centre of the dwell time at low and high extreme temperatures. The a.c. surges shall be applied within 1 h of the centre of the dwell time at low and high extreme temperatures. This procedure shall be repeated until the completion of the environmental cycling.


The SPD shall be tested using the appropriate test circuit of figure 13 and shall be powered with a d.c. supply throughout the environmental cycling. The negative or positive level of the d.c. power supply shall not exceed the rated voltage determined in 5.2.1.1. The SPD shall not be powered with the d.c. power supply during the application of the a.c. current.

The a.c. limiting voltage shall be measured during the application of each current. The insulation resistance shall be measured within 1 h after each a.c. surge application. If the SPD is known to be sensitive to the polarity of the d.c. power supply, it shall be tested for insulation resistance with positive and negative polarities.

Within 1 h after the end of the environmental cycling, the voltage-limiting function shall satisfy the impulse-limiting voltage and the insulation resistance requirements.

6.5 Acceptance tests

Acceptance tests are made by agreement between the manufacturer and user.




IEC 1303/2000

Key

O, O ₁ , O ₂	oscilloscopes	V	voltage-limiting component
E, E ₁ , E ₂	d.c. voltage sources	V, I	voltage-limiting components or combination of voltage-limiting and current-limiting components
G	impulse generator	X1, X2	line terminals
IE	isolation element	Y1, Y2	protected line terminals
R _S , R _{S1} , R _{S2}	non-inductive source resistors	C	common terminal

Figure 2 – Test circuits for impulse reset time








Key

A, A₁, A₂ ammeters
 E a.c. voltage source
 R_s, R_{s1}, R_{s2} non-inductive source resistors

V voltage-limiting component
 V, I voltage-limiting components or combination of
 voltage-limiting and current-limiting components
 X1, X2 line terminals
 Y1, Y2 protected line terminals
 C common terminal

IEC 1304/2000

Figure 3 – Test circuits for a.c. durability and overstressed fault mode



IEC 557/08

Key

O, O₁, O₂ oscilloscopes, used to monitor U_p during impulse durability testing

G impulse generator

CD current distributor

C common terminal


V voltage-limiting component

V, I voltage-limiting components or combination of voltage-limiting and current-limiting components

X1, X2 line terminals

Y1, Y2 protected line terminals

Figure 4 – Test circuits for impulse durability and overstressed fault mode




IEC 1306/2000

Key

A, A ₁ , A ₂	ammeters	V	voltage-limiting component
E, E ₁ , E ₂	d.c. or a.c. voltage sources	V, I	voltage-limiting components or combination of voltage-limiting and current-limiting components
R _s , R _{s1} , R _{s2}	non-inductive source resistors	X1, X2	line terminals
		Y1, Y2	protected line terminals
		C	common terminal

Figure 5 – Test circuits for rated current, series resistance, response time, current reset time, maximum interrupting voltage and operating duty test




IEC 1307/2000

Key

A, A₁, A₂ ammeters
 E a.c. voltage source
 R_S, R_{S1}, R_{S2} non-inductive source resistors

V voltage-limiting component
 V, I voltage-limiting components or combination of
 voltage-limiting and current-limiting components
 X1, X2 line terminals
 Y1, Y2 protected line terminals
 C common terminal

Figure 6 – Test circuits for a.c. durability




IEC 1308/2000

Key

O, O₁, O₂ oscilloscopes
G impulse generator

V voltage-limiting component
V, I voltage-limiting components or combination of voltage-limiting and current-limiting components
X1, X2 line terminals
Y1, Y2 protected line terminals
C common terminal

Figure 7 – Test circuits for impulse durability




IEC 1309/2000

N network analyser

B balun

Figure 8 – Test circuits for insertion loss



IEC 1310/2000

Key


N network analyser

R reflecting bridge

B balun

Z1 terminating impedance 100 Ω or 120 Ω or 150 Ω

Figure 9 – Test circuit for return loss




IEC 1311/2000

Key

V_s disturbing common mode (longitudinal) voltage
 V_m resulting differential mode (metallic) voltage
 Z_1, Z_2 terminating impedance

V voltage-limiting component
 V, I voltage-limiting components or combination of voltage-limiting and current-limiting components
 X_1, X_2 line terminals
 Y_1, Y_2 protected line terminals
 C common terminal

Figure 10 – Test circuits for longitudinal balance




IEC 1312/2000

Key

T	BER tester
V	voltage-limiting component
V, I	voltage-limiting components or combination of voltage-limiting and current-limiting components
X1, X2	line terminals
Y1, Y2	protected line terminals
C	common terminal

Figure 11 – Test circuit for bit error ratio test




IEC 1313/2000

Key

- N network analyser
- B balun
- Z1, Z2 terminating impedances

Figure 12 – Test circuit for near-end crosstalk

IECNORM.COM : Click to view the full PDF of IEC 61643-21:2000+AMD1:2008 CSV



IEC 1314/2000

Key

E, E_1, E_2 d.c. or a.c. voltage sources
 R_s, R_{s1}, R_{s2} non-inductive source resistors

V voltage-limiting component
 V, I voltage-limiting components or combination of voltage-limiting and current-limiting components
 $X1, X2$ line terminals
 $Y1, Y2$ protected line terminals
 C common terminal

Figure 13 – Test circuits for high temperature/humidity endurance and environmental cycling





Figure 14 – Environmental cycling schedule A with RH ≥ 90 %

**Key** T_1 upper temperature, +40 °C or +55 °C t_1 end of the temperature rise t_2 start of the temperature fall


IEC 1316/2000

Figure 15 – Environmental cycling B

Annex A (informative)


Devices with current-limiting components only

Configurations of devices with current-limiting components only are shown in figure A.1. Such a device should be tested to the applicable requirements of 5.2.2. The voltage source used in the tests of 6.2.2 shall have a value that is less than or equal to the maximum interrupting voltage as specified by the manufacturer. The current protective device shall also be subjected to the tests of 6.3 and selected tests in 6.2.3, depending on its application.




IEC 1317/2000

Figure A.1a – Two-terminal current-limiter




IEC 1318/2000

Figure A.1b – Three-terminal current-limiter



IEC 1319/2000

Figure A.1c – Four-terminal current-limiter



IEC 1320/2000

Figure A.1d – Five-terminal current-limiter

Key

- I current-limiting-component(s)
- X1, X2 line terminals
- Y1, Y2 protected line terminals
- C common terminal

Figure A.1 – Configurations of devices with current-limiting component(s) only

Annex B

(Void)

IECNORM.COM : Click to view the full PDF of IEC 61643-21:2000+AMD1:2008 CSV

Annex C

(Void)

IECNORM.COM : Click to view the full PDF of IEC 61643-21:2000+AMD1:2008 CSV

Annex D (informative)

Measurement accuracy

IEC 61083-1 defines the measurement accuracy for analogue type and digital type impulse recorders, such as a digital oscilloscope with probes. Analogue recorders shall have rise times five times faster than the signal rise time. This ensures less than 2 % error in the displayed rise time. Digital recorders shall have sample times at least $30/TX$ where TX is the time interval to be measured. A rated resolution of 0,4 % of full-scale deviation (2^{-8} full-scale deviation) or better is recommended for tests where only the impulse parameters are to be evaluated. For reference tests, which require comparison of records, a rated resolution of 0,2 % of full-scale deviation (2^{-9} full-scale deviation) or better shall be used. IEC 61083-1 also covers additional accuracy parameters for specific waveshapes.

IECNORM.COM : Click to view the full PDF of IEC 61643-21:2000+AMD1:2008 CSV

Annex E (informative)


Determination of let-through current (I_p)

To determine the maximum let-through current I_p at the output terminals of an SPD, the input terminals should be exposed to a specified test impulse selected from Table 3. The output current waveform into a short-circuit (Figures E.1 to E.6) should be measured. If the measured waveform is equal to the waveform given by Table 3, then the value I_p is given by the peak value of the measured current. Where the measured waveform deviates from the specified waveform according to Table 3, it can be assumed that at Figures 1b to 1f, the measured maximum current corresponds to I_p . At Figure 1a, I_p is equal to the short-circuit current of the generator. To get an exact calculation of coordination, it is necessary to use the let-through energy (LTE) method (see Clause F.5 of IEC 61643-12 or Clause C.4 of IEC 62305-4).

This determination of the let-through current (I_p) is used to calculate a coordination of SPDs (see Figure E.1 in IEC 61643-22).

If several test impulses are specified, the maximum values of U_p and I_p should be indicated for each test impulse. Depending on the type of SPD (see 1.2), the test a), b) or c) should be chosen.

- a) Asymmetrical application of test impulses to determine the differential mode I_p (see Figure E.1). The test impulse is applied to the input side of the SPD.
- b) Non-symmetrical application of test impulses to determine the common mode I_p (see Figure E.2). The test impulse is applied to the input side of the SPD.
- c) Symmetrical application of test impulses to determine the differential mode I_p (see Figure E.3). The test impulse is applied by a current distributor (1:2) to the input side of the SPD.
- d) Asymmetrical application of test impulses to determine the differential mode I_p (see Figure E.4). The test impulse is applied to the input side of the SPD.
- e) Symmetrical application of test impulses to determine the common mode I_p (see Figure E.5). The test impulse is applied by a current distributor (1:2) to the input side of the SPD.
- f) Symmetrical application of test impulses to determine the common mode I_p (see Figure E.6). The test impulse is applied by a current distributor (1:n) to the input side of the SPD.



NOTE The value of I_p is equal to the surge current of the generator.

Figure E.1 – Determination of differential mode let-through current




Figure E.2 – Determination of common mode let-through current




Figure E.3 – Determination of differential mode let-through current




Figure E.4 – Determination of differential mode let-through current




Figure E.5 – Determination of common mode max. let-through current




Figure E.6 – Determination of common mode max. let-through current at multi-terminal SPDs

IECNORM.COM : Click to view the full PDF of IEC 61643-21:2000+AMD1:2008 CSV

Bibliography

IEC 60060-2:1994, *High-voltage test techniques – Part 2: Measuring systems*

IEC 60068-1:1988, *Environmental testing – Part 1: General and guidance*

IEC 60068-2-38:1974, *Environmental testing – Part 2: Tests – Test Z/AD: Composite temperature/humidity cyclic test*

IEC 60364-5-51:2005, *Electrical installations of buildings – Part 5-51: Selection and erection of electrical equipment – Common rules*

IEC 60721-3-3:1994, *Classification of environmental conditions – Part 3: Classification of groups of environmental parameters and their severities – Section 3: Stationary use at weatherprotected locations*

IEC 61180-1, *High-voltage test techniques for low-voltage equipment – Part 1: Definitions, test and procedure requirements*

IEC 61643-12, *Low-voltage surge protective devices – Part 12: Surge protective devices connected to low-voltage power distribution systems – Selection and application principles*

IEC 62305-4, *Protection against lightning – Part 4: Electrical and electronic systems within structures*

ISO/IEC 11801:1995, *Information technology – Generic cabling for customer premises*

IEEE C62.36:1994, *IEEE Standard Test Methods for Surge Protectors Used in Low-Voltage Data, Communications, and Signaling Circuits (ANSI)*

IEEE C62.64:1997, *IEEE Standard Specifications for Surge Protectors Used in Low-Voltage Data, Communications, and Signaling*

ITU-T Recommendation K.12:1995, *Characteristics of gas discharge tubes for the protection of telecommunications installations*

ITU-T Recommendation K.20:1996, *Resistibility of telecommunication switching equipment to overvoltages and overcurrents*

ITU-T Recommendation K.21:1996, *Resistibility of subscriber's terminals to overvoltages and overcurrents*

ITU-T Recommendation K.28:1993, *Characteristics of semi-conductor arrester assemblies for the protection of telecommunications installations*

ITU-T K.44:2003, *Resistibility tests for telecommunication equipment exposed to overvoltages and overcurrents – Basic recommendation*

SOMMAIRE

AVANT-PROPOS	67
INTRODUCTION	69
1 Généralités	70
1.1 Domaine d'application	70
1.2 Configuration des parafoudres	70
1.3 Utilisation de cette norme	72
2 Références normatives	75
3 Définitions	76
4 Conditions d'utilisation et d'essais	80
4.1 Conditions d'utilisation	80
4.1.1 Conditions normales	80
4.1.2 Conditions anormales	81
4.2 Conditions d'essais (température et humidité)	81
4.3 Conditions d'essai des parafoudres	81
4.4 Tolérances des formes d'ondes	82
5 Prescriptions	82
5.1 Prescriptions générales	82
5.1.1 Identification et documentation	82
5.1.2 Marquage	83
5.2 Prescriptions électriques	83
5.2.1 Prescription de limitation de tension	83
5.2.2 Prescriptions de limitation en courant	84
5.2.3 Prescriptions de transmission	85
5.3 Prescriptions mécaniques	86
5.3.1 Bornes et connecteurs	86
5.3.2 Contraintes mécaniques	87
5.3.3 Résistance à l'introduction de corps solides et d'eau	87
5.3.4 Protection contre les contacts directs	87
5.3.5 Résistance au feu	87
5.4 Prescriptions d'environnement	88
5.4.1 Hautes températures et résistance à l'humidité	88
5.4.2 Conditions d'ambiances cyclées avec impulsions	88
5.4.3 Conditions d'ambiance cyclées en courant alternatif	88
6 Essais de type	89
6.1 Essais généraux	89
6.1.1 Renseignements documentaires et identification	89
6.1.2 Marquage	89
6.2 Essais électriques	89
6.2.1 Essais de limitation de tension	89
6.2.2 Essais de limitation en courant	96
6.2.3 Essais de transmission	99
6.3 Essais mécaniques	102
6.3.1 Bornes et connecteurs	102
6.3.2 Contrainte mécanique (montage)	104
6.3.3 Résistance à l'introduction de corps solides et d'eau	104

6.3.4	Protection contre les contacts directs	104
6.3.5	Résistance au feu	104
6.4	Essais d'environnement	105
6.4.1	Hautes températures et résistance à l'humidité	105
6.4.2	Conditions d'ambiance cyclées avec impulsions transitoires	106
6.4.3	Conditions d'ambiance cyclées avec chocs en courant alternatif	106
6.5	Essais de réception	107
Annexe A (informative) Appareils n'ayant qu'une fonction de limitation en courant		121
Annexe B (Vacant)		122
Annexe C (Vacant)		123
Annexe D (informative) Exactitude de mesure		124
Annexe E (informative) Détermination du courant conventionnel de non-fonctionnement (I_p)		125
Bibliographie		128
Figure 1 – Configurations des parafoudres		71
Figure 16 – Exemples de parafoudres à lignes multiples à élément de protection commun		92
Figure 2 – Circuit d'essai pour le temps de réamorçage en impulsion		108
Figure 3 – Circuits d'essais pour l'endurance en courant alternatif et le mode de défaut par surcharge		109
Figure 4 – Circuit d'essai pour l'endurance aux impulsions et le mode de défaut par surcharge		110
Figure 5 – Circuit d'essai pour le courant assigné, résistance série, temps de réponse, temps de réamorçage en courant, tension de coupure maximale et essai de fonctionnement		111
Figure 6 – Circuits d'essai pour l'endurance en courant alternatif		112
Figure 7 – Circuit d'essai pour l'endurance en impulsionnel		113
Figure 8 – Circuit d'essai pour la perte d'insertion		114
Figure 9 – Circuit d'essai pour le facteur d'adaptation (en réflexion)		114
Figure 10 – Circuit d'essai pour l'affaiblissement de conversion longitudinal		115
Figure 11 – Circuit d'essai pour le taux d'erreur binaire		116
Figure 12 – Circuit d'essai pour la paradiaphonie		117
Figure 13 – Circuit d'essai pour l'endurance aux hautes températures/humidités et l'ambiance cyclée		118
Figure 14 – Cycles A pour les essais de conditions d'ambiance avec un RH $\geq$ 90 %		119
Figure 15 – Cycle B pour les essais de conditions d'ambiance		120
Figure A.1 – Configurations des parafoudres n'ayant que des composants de limitation de courant		121
Figure E.1 – Détermination du courant conventionnel de non-fonctionnement en mode différentiel		125
Figure E.2 – Détermination du courant conventionnel de non-fonctionnement en mode commun		126
Figure E.3 – Détermination du courant conventionnel de non-fonctionnement en mode différentiel		126
Figure E.4 – Détermination du courant conventionnel de non-fonctionnement en mode différentiel		126

Figure E.5 – Détermination du courant conventionnel de non-fonctionnement maximal en mode commun	126
Figure E.6 – Détermination du courant conventionnel de non-fonctionnement maximal en mode commun avec des parafoudres multibornes.....	127
Tableau 1 – Exigences générales des parafoudres	73
Tableau 2 – Tolérances pour les formes d'ondes A/B	82
Tableau 3 – Formes d'ondes de courant et de tension pour la tension de limitation impulsionnelle	91
Tableau 4 – Sources de tension et de courant, pour les essais de réamorçage sur impulsion	93
Tableau 5 – Valeurs préférentielles du courant pour l'essai d'endurance en courant alternatif	94
Tableau 6 – Courants d'essai pour le temps de réponse	96
Tableau 7 – Valeurs préférentielles, pour le courant d'essai de fonctionnement	98
Tableau 8 – Valeurs préférentielles pour courants alternatifs	98
Tableau 9 – Valeurs préférentielles de courants impulsionnels	99
Tableau 10 – Paramètres normalisés pour la Figure 8	99
Tableau 11 – Valeurs d'impédances pour l'essai d'affaiblissement de conversion longitudinale	101
Tableau 12 – Durée pour l'essai de TEB.....	101
Tableau 13 – Sections connectables de conducteurs en cuivre, pour des bornes à vis ou sans vis.....	102
Tableau 14 – Forces de traction (bornes sans vis).....	103
Tableau 15 – Valeurs préférentielles de périodes pour l'essai de hautes températures et de résistance à l'humidité.....	105
Tableau 16 – Valeurs préférentielles des temps et températures pour les essais de conditions d'ambiance cyclées.....	106

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

PARAFOUDRES BASSE TENSION –

**Partie 21: Parafoudres connectés aux réseaux de signaux
et de télécommunications –
Prescriptions de fonctionnement et méthodes d'essais**

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (CEI) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de la CEI). La CEI a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, la CEI – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de la CEI"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec la CEI, participent également aux travaux. La CEI collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de la CEI concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de la CEI intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de la CEI se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de la CEI. Tous les efforts raisonnables sont entrepris afin que la CEI s'assure de l'exactitude du contenu technique de ses publications; la CEI ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de la CEI s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de la CEI dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de la CEI et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) La CEI n'a prévu aucune procédure de marquage valant indication d'approbation et n'engage pas sa responsabilité pour les équipements déclarés conformes à une de ses Publications.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à la CEI, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de la CEI, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de la CEI ou de toute autre Publication de la CEI, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de la CEI peuvent faire l'objet de droits de propriété intellectuelle ou de droits analogues. La CEI ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de propriété et de ne pas avoir signalé leur existence.

La Norme internationale CEI 61643-21 a été établie par le sous-comité 37A: Dispositifs de protection basse tension contre les surtensions, du comité d'études 37 de la CEI: Parafoudres.

Cette version consolidée de la CEI 61643-21 comprend la première édition (2000) [documents 37A/101/FDIS et 37A/104/RVD], son amendement 1 (2008) [documents 37A/200/FDIS et 37A/201/RVD] et son corrigendum de mars 2001.

Le contenu technique de cette version consolidée est donc identique à celui de l'édition de base et à son amendement; cette version a été préparée par commodité pour l'utilisateur.

Elle porte le numéro d'édition 1.1.

Une ligne verticale dans la marge indique où la publication de base a été modifiée par l'amendement 1.

Le comité a décidé que le contenu de la publication de base et de ses amendements ne sera pas modifié avant la date de maintenance indiquée sur le site web de la CEI sous "<http://webstore.iec.ch>" dans les données relatives à la publication recherchée. A cette date, la publication sera

- reconduite,
- supprimée,
- remplacée par une édition révisée, ou
- amendée.

IECNORM.COM : Click to view the full PDF of IEC 61643-21:2000+AMD1:2008 CSV

INTRODUCTION

La présente Norme internationale se propose de répertorier les exigences relatives aux dispositifs de protection contre les surtensions, appelés parafoudres et utilisés dans la protection des systèmes de télécommunications et de transmission de signaux, par exemple données, voix et circuits d'alarme en basse tension. Tous ces systèmes peuvent être exposés aux effets de la foudre et aux défauts des réseaux de distribution d'énergie électrique, soit par contact direct, soit par induction. Ces effets peuvent soumettre le système à des surtensions et/ou des surintensités, dont les niveaux sont suffisamment hauts pour l'endommager. Les parafoudres sont construits pour procurer une protection contre les surtensions et éventuellement les surintensités dues à la foudre et aux défauts des lignes de distribution d'énergie. Cette norme décrit les essais et les exigences définissant des méthodes pour tester les parafoudres et déterminer leurs performances.

Les parafoudres, concernés par cette norme internationale, peuvent comporter des composants de protection contre les surtensions seulement ou une combinaison de composants de protection contre les surtensions et contre les surintensités. Les protections, contenant seulement des composants contre les surintensités, ne sont pas concernées par la présente norme. Cependant, des dispositifs, n'ayant que des composants de protection contre les surintensités, sont couverts par l'annexe A.

Un parafoudre peut contenir plusieurs composants de protection contre les surtensions et contre les surintensités. Tous les parafoudres sont essayés, comme une «boîte noire», à savoir que c'est le nombre de bornes du parafoudre qui détermine la procédure d'essai et non pas le nombre de composants du parafoudre. Les configurations des parafoudres sont décrites en 1.2. Pour les parafoudres à lignes multiples, chaque ligne peut être essayée indépendamment des autres, mais il peut apparaître aussi le besoin d'essayer toutes les lignes simultanément.

Cette norme concerne une large gamme de conditions d'essais et d'exigences ; l'utilisation de certaines d'entre elles est à la discrétion de l'utilisateur. La façon d'utiliser cette norme en fonction des différents modèles de parafoudres est décrite en 1.3. Bien qu'il s'agisse d'une norme de performances et que certaines qualités soient exigées des parafoudres, les taux d'échec et leur interprétation sont du ressort de l'utilisateur. La sélection et les principes d'application sont traités dans la CEI 61643-22.

S'il est admis que le parafoudre n'a qu'un seul composant, il faut qu'il respecte les prescriptions de la norme correspondante ainsi que celles de la présente norme.

PARAFOUDRES BASSE TENSION –

Partie 21: Parafoudres connectés aux réseaux de signaux et de télécommunications – Prescriptions de fonctionnement et méthodes d'essais

1 Généralités

1.1 Domaine d'application

La présente Norme internationale est applicable aux dispositifs de protection (parafoudres) contre les effets directs et indirects de la foudre ou des autres surtensions transitoires, pour les réseaux de télécommunications et de transmission de signaux.

Ces parafoudres sont destinés à protéger les équipements électroniques modernes, connectés aux réseaux de télécommunications et de transmission de signaux, ayant une tension nominale de fonctionnement jusqu'à 1 000 V (efficace) en courant alternatif et 1 500 V en courant continu.

1.2 Configuration des parafoudres

Les configurations des parafoudres décrites dans cette norme sont représentées à la figure 1. Chaque configuration de parafoudre est composée d'un ou de plusieurs composants limiteurs de tension et peut inclure des composants limiteurs de courant.




Figure 1a – Parafoudre à 2 bornes




Figure 1b – Parafoudre à 3 bornes




Figure 1c – Parafoudre à 3 bornes




Figure 1d – Parafoudre à 4 bornes





Figure 1e – Parafoudre à 5 bornes



^a La borne commune C peut ne pas exister.

Figure 1f – Parafoudre multibornes

Légende

V	composant limiteur de tension
V, I	composants limiteurs de tension ou combinaison de composants limiteurs de tension et limiteurs de courant
X1, X2...Xn	bornes de lignes
Y1, Y2...Yn	bornes de lignes protégées
C	borne commune

Figure 1 – Configurations des parafoudres

1.3 Utilisation de cette norme

Cette norme traite de 2 types fondamentaux de parafoudres.

Le premier type contient au moins un composant limiteur de tension et ne contient aucun composant limiteur de courant à l'intérieur du parafoudre. Toutes les configurations de parafoudres de la figure 1 lui sont applicables. Ce type de parafoudre doit satisfaire aux exigences de 5.1, 5.2.1 et 5.3 (voir tableau 1). Cependant, si un parafoudre contient un composant linéaire entre les bornes de lignes et les bornes de lignes protégées – comme aux figures 1b, 1d, 1e et 1f, il doit aussi satisfaire aux exigences applicables du 5.2.2.

Le deuxième type contient à la fois des composants limiteurs de tension et des composants limiteurs de courant à l'intérieur du parafoudre. Les configurations de parafoudres des figures 1b, 1d, 1e et 1f lui sont applicables. Ce type de parafoudre doit satisfaire au moins aux exigences de 5.1, 5.2.1, 5.2.2 et 5.3 (voir tableau 1). Les configurations de parafoudres ne contenant que des composants limiteurs de courant sont données à l'annexe A.

Il se peut que les parafoudres aient à satisfaire à d'autres exigences, selon leurs applications. Ces exigences supplémentaires sont décrites en 5.2.3 et en 5.4 (voir tableau 1).

Le Paragraphe 5.2.3 traite de quelques essais de transmission auxquels les parafoudres peuvent avoir à se conformer, selon leurs applications, en télécommunications ou en transmission de signaux. Ainsi, une sélection des essais de transmission applicables doit être faite selon 5.2.3, en fonction des objectifs d'application des parafoudres. Le Tableau 1 donne des lignes directrices pour choisir les essais de transmission applicables.

Le paragraphe 5.4 traite des exigences d'environnement, seulement quand les parafoudres sont destinés à une utilisation dans des conditions ambiantes non déterminées, telles que décrites en 4.1. Les parafoudres doivent satisfaire à ces exigences, après accord entre l'utilisateur et le fabricant. Le tableau 1 indique des exemples d'exigences que chaque type de parafoudre doit satisfaire.

Tableau 1 – Exigences générales des parafoudres

Série d'essai ⁴	Exigence – Essai	Paragraphe	Type de parafoudre					
			Parafoudre limiteur de tension	Parafoudre limiteur de tension et de courant	Parafoudre limiteur de tension et ayant un composant linéaire entre ses bornes	Parafoudre limiteur de tension et limiteur de courant et ayant des bornes à capacités de transmission	Parafoudre limiteur de tension, mais destiné à un environnement à conditions étendues	Parafoudre limiteur de tension et de courant, mais destiné à un environnement à conditions étendues
1	Essais généraux	6.1						
	Identification et documentation	6.1.1	A	A	A	A	A	A
	Marquage	6.1.2	A	A	A	A	A	A
	Essais de transmission	6.2.3						
	Capacité	6.2.3.1	A	O	O	O	A	O
	Perte d'insertion (ou affaiblissement)	6.2.3.2	O	A	A	A	O	A
	Facteur d'adaptation	6.2.3.3	O	O	O	A	O	O
	Affaiblissement de conversion longitudinal (ACL)	6.2.3.4	O	O	O	A	O	O
	Taux d'erreur binaire (TEB)	6.2.3.5	O	O	O	O	O	O
	Paradiaphonie	6.2.3.6	O	O	O	A	O	O
	Essais mécaniques	6.3						
	Bornes et connecteurs	6.3.1	A	A	A	A	A	A
	Procédure générale d'essai	6.3.1.1	A	A	A	A	A	A
	Bornes à vis	6.3.1.2	A	A	A	A	A	A
	Bornes sans vis	6.3.1.3	A	A	A	A	A	A
	Connexions à perçage d'isolant	6.3.1.4	A	A	A	A	A	A
	Essai de traction pour des bornes de parafoudres à monoconducteurs	6.3.1.4.1	A	A	A	A	A	A
	Essai de traction pour des parafoudres conçus pour des câbles multiconducteurs et des cordons	6.3.1.4.2	A	A	A	A	A	A
	Contrainte mécanique (montage)	6.3.2	A	A	A	A	A	A

Tableau 1 (suite)

Série d'essai ⁴	Exigence – Essai	Paragraphe	Type de parafoudre					
			Parafoudre limiteur de tension	Parafoudre limiteur de tension et de courant	Parafoudre limiteur de tension et ayant un composant linéaire entre ses bornes	Parafoudre limiteur de tension et limiteur de courant et ayant des bornes à capacités de transmission	Parafoudre limiteur de tension, mais destiné à un environnement à conditions étendues	Parafoudre limiteur de tension et de courant, mais destiné à un environnement à conditions étendues
	Résistance à l'introduction de corps solides et d'eau	6.3.3	A	A	A	A	A	A
	Protection contre les contacts directs	6.3.4	A	A	A	A	A	A
	Résistance au feu	6.3.5	A	A	A	A	A	A
	Essais d'environnement	6.4						
	Hautes températures et résistance à l'humidité	6.4.1	O	O	O	O	A	A
	Conditions d'ambiance cyclées avec impulsions transitoires	6.4.2	O	O	O	O	A	A
	Conditions d'ambiance cyclées avec chocs en courant alternatif	6.4.3	O	O	O	O	A	A
2	Essais de limitation de tension	6.2.1						
	Tension maximale de service permanent U_c	6.2.1.1	A	A	A	A	A	A
	Résistance d'isolement	6.2.1.2	A	A	A	A	A	A
	Endurance aux impulsions pour la fonction de limitation de tension	6.2.1.6	A	A	A	A	A	A
	Tension de limitation impulsionnelle ²	6.2.1.3	A	A	A	A	A	A
	Réamorçage sur impulsion	6.2.1.4	A	A	A	A	A	A
	Endurance en courant alternatif pour la fonction de limitation de tension	6.2.1.5	O	O	O	O	O	O
	Essai du point aveugle	6.2.1.8	A	A	A	A	A	A
	Mode de défaut par surcharge	6.2.1.7	A	A	A	A	A	A
3	Essais de limitation de courant	6.2.2						
	Courant assigné	6.2.2.1	N.A.	A	A	A	N.A.	A
	Résistance série	6.2.2.2	N.A.	A	A	A	N.A.	A
	Temps de réponse en courant	6.2.2.3	N.A.	A	N.A.	A ³	N.A.	A ³
	Temps de réamorçage en courant	6.2.2.4	N.A.	A	N.A.	A ³	N.A.	A ³
	Tension maximale de coupure	6.2.2.5	N.A.	A	N.A.	A ³	N.A.	A ³
	Essai de fonctionnement	6.2.2.6	N.A.	A	N.A.	A ³	N.A.	A ³

Tableau 1 (suite)

Série d'essai ⁴	Exigence – Essai	Paragraphe	Type de parafoudre					
			Parafoudre limiteur de tension	Parafoudre limiteur de tension et de courant	Parafoudre limiteur de tension et ayant un composant linéaire entre ses bornes	Parafoudre limiteur de tension et limiteur de courant et ayant des bornes à capacités de transmission	Parafoudre limiteur de tension, mais destiné à un environnement à conditions étendues	Parafoudre limiteur de tension et de courant, mais destiné à un environnement à conditions étendues
	Endurance en courant alternatif pour la fonction de limitation de courant ¹	6.2.2.7	N.A.	A	N.A.	A ³	N.A.	A ³
	Endurance impulsionnelle pour la fonction de limitation de courant ¹	6.2.2.8	N.A.	A	N.A.	A ³	N.A.	A ³
4	Essais de réception	6.5	O	O	O	O	O	O
A	S'applique.							
N.A.	Ne s'applique pas.							
O	Optionnel.							
1	Pour chaque catégorie d'impulsion d'essai, on peut utiliser un nouveau lot d'échantillons.							
2	Il est admis de mesurer la tension de limitation impulsionnelle 6.2.1.3 au cours de l'essai d'endurance impulsionnelle 4.2.1.6.							
3	L'essai ne s'applique pas en présence d'un composant linéaire entre ses bornes.							
4	On prend trois échantillons pour chaque série d'essai.							

2 Références normatives

Les documents de référence suivants sont indispensables pour l'application du présent document. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

CEI 60050(702):1992, *Vocabulaire Electrotechnique International – Chapitre 702: Oscillations, signaux et dispositifs associés*

CEI 60050(726):1982, *Vocabulaire Electrotechnique International – Chapitre 726: Lignes de transmission et guides d'ondes*

CEI 60060-1:1989, *Techniques des essais à haute tension – Partie 1: Définitions et prescriptions générales relatives aux essais*

CEI 60068-2-30:1980, *Essais d'environnement – Partie 2: Essais – Essai Db et guide: Essai cyclique de chaleur humide (cycle de 12+12 heures)*

CEI 60529, *Degrés de protection procurés par les enveloppes (code IP)*

CEI 60695-2-1/1:1994, *Essais relatifs aux risques du feu – Partie 2: Méthodes d'essai – Section 1/Feuille 1: Essai au fil incandescent sur produits finis et guide*

CEI 60950:1999, *Sécurité des matériels de traitement de l'information*

CEI 60999-1:1999, *Dispositifs de connexion – Conducteurs électriques en cuivre – Prescriptions de sécurité pour organes de serrage à vis et sans vis – Partie 1: Prescriptions générales et particulières pour les organes de serrage pour les conducteurs de 0,2 mm² à 35 mm² (inclus)*

CEI 61000-4-5, *Compatibilité électromagnétique (CEM) – Partie 4: Techniques d'essai et de mesure – Section 5: Essai d'immunité aux ondes de choc*

CEI 61083-1, *Enregistreurs numériques pour les mesures pendant les essais de choc à haute tension – Partie 1: Prescriptions pour des enregistreurs numériques*

CEI 61180-1:1992, *Techniques des essais à haute tension pour matériels à basse tension – Partie 1: Définitions, prescriptions et modalités relatives aux essais*

CEI 61643-1, *Dispositifs de protection contre les surtensions connectés aux réseaux de distribution basse tension – Partie 1: Prescriptions de fonctionnement et méthodes d'essai*

CEI 61643-22:2004, *Parafoudres basse tension – Partie 22: Parafoudres connectés aux réseaux de signaux et de télécommunications – Principes de choix et d'application*

UIT-T Recommandation K.30:1993, *Thermistances à coefficient de température positif*

UIT-T Recommandation K.55:2002, *Prescriptions de surtension et de surintensité pour les terminaisons par connecteur autodénudant*

UIT-T Recommandation K.65:2004, *Spécifications relatives aux surtensions et aux surintensités pour les modules de terminaison avec des contacts pour les ports d'essai ou les limiteurs de surtension*

UIT-T Recommandation O.9:1999, *Montages pour la mesure du degré de dissymétrie par rapport à la terre*

3 Définitions

Pour les besoins de la présente partie de la CEI 61643, les définitions suivantes s'appliquent:

3.1

numéro de modèle

code inscrit soit sur le parafoudre, soit dans sa documentation, utilisé pour identifier le parafoudre

3.2

valeurs préférentielles

valeurs des paramètres listées dans les tableaux, pour les différents essais, préférentielles, en ce sens que leur utilisation conduit à une uniformité et fournit des moyens de comparaison entre les différents dispositifs de protection. Cela conduit aussi à un langage technique commun, au bénéfice de l'utilisateur et du constructeur de parafoudres utilisés dans les réseaux de télécommunications et de transmission de signaux. Cependant, il se peut que des applications spécifiques exigent d'autres valeurs que celles retenues dans les tableaux

3.3

modes de défauts par surcharges

mode 1 cas où la partie limitatrice de tension du parafoudre est déconnectée. La fonction de limiteur de tension n'est plus opérationnelle, mais la ligne continue de l'être

mode 2 cas où la partie limitatrice de tension du parafoudre est court-circuitée par une très faible impédance à l'intérieur du parafoudre. La ligne n'est plus opérationnelle, mais les équipements sont encore protégés par un court-circuit

mode 3 situation où un déconnecteur interne au parafoudre a ouvert le circuit du côté du réseau de la partie limitatrice de tension. La ligne n'est plus opérationnelle, mais l'équipement est encore protégé par une ligne ouverte

3.4

protection

application des moyens et des méthodes visant à prévenir la propagation d'un choc électrique énergétique au-delà d'une interface définie

3.5

temps de réponse en courant

temps nécessaire au composant limiteur de courant, pour fonctionner à un courant et à une température définis

3.6

tension maximale de service permanent U_c

tension maximale (en courant continu ou valeur efficace) qui peut être appliquée en continu aux bornes du parafoudre, sans modification des caractéristiques de transmission du parafoudre

3.7

tension maximale de coupure

tension maximale (en courant continu ou valeur efficace) qui peut être appliquée au(x) composant(s) limiteur(s) de courant d'un parafoudre, sans dégradation de celui-ci. Cette tension peut être égale à U_c du parafoudre. Elle peut être supérieure en fonction de la disposition du ou des composant(s) limiteurs de courant dans le parafoudre

3.8

parafoudre

SPD

dispositif qui limite la tension d'un ou de plusieurs ports, générée par une impulsion lorsqu'elle dépasse un niveau prédéterminé

NOTE 1 Des fonctions secondaires peuvent y être incorporées, telles que la limitation de courant pour limiter le courant dans les bornes.

NOTE 2 Le circuit de protection dispose habituellement d'au moins un composant de protection contre les surtensions limiteur de tension et non linéaire.

NOTE 3 Un parafoudre est un ensemble complet, disposant de bornes pour le raccordement aux conducteurs du circuit.

3.9

limitation en tension

action d'un parafoudre, déclenchée pour toutes les tensions excédant un seuil prédéterminé, afin de les réduire

3.10

limitation en courant

action d'un parafoudre, contenant au moins un composant non linéaire limiteur de courant, déclenchée pour tous les courants excédant un seuil prédéterminé, afin de les réduire

3.11

limitation en courant non réamorçable

action d'un parafoudre qui ne limite le courant qu'une seule fois

3.12

limitation en courant réamorçable

action d'un parafoudre qui limite le courant et qui peut être réenclenchée manuellement après fonctionnement

3.13

limitation en courant auto-réamorçable

action d'un parafoudre qui limite le courant et qui revient à son état initial après que le courant perturbateur a disparu

3.14

parafoudre de type limitation en tension

parafoudre présentant une impédance élevée qui diminuera de façon continue avec l'accroissement du courant en réponse à un choc de tension dépassant le seuil de tension du parafoudre

NOTE Exemples de composants utilisés dans les parafoudres de type limitation en tension: les varistances (par exemple les MOV) et les diodes à avalanche (ABD).

3.15

parafoudre de type coupure en tension

parafoudre présentant une impédance élevée qui diminuera de façon importante et brutale en réponse à un choc de tension dépassant le seuil de tension du parafoudre

NOTE Exemples de composants utilisés dans les parafoudres de type coupure en tension: les éclateurs à air, les tubes à décharge dans un gaz (TDG) et les parafoudres à thyristor (TSS).

3.16

niveau de protection en tension U_p

paramètre qui caractérise la performance du parafoudre par limitation des tensions entre ses bornes. Cette valeur de tension doit être supérieure à la valeur la plus élevée mesurée lors des essais de limitation de tension et spécifiée par le fabricant

3.17

parafoudres étagés

parafoudre ayant plus d'un composant limiteur de tension. Ces composants limiteurs de tension peuvent ou non être électriquement séparés par un composant en série. Ces composants limiteurs de tension peuvent être du type limitation en tension ou du type coupure en tension

3.18

point aveugle

cas où des tensions au-dessus de la tension maximale de fonctionnement permanent U_c , du parafoudre, peuvent entraîner un fonctionnement partiel du parafoudre. Le fonctionnement partiel du parafoudre signifie que tous les étages d'un parafoudre multi-étages, n'ont pas fonctionné durant l'impulsion d'essai. Il peut en résulter un dépassement des contraintes admissibles des composants dans le parafoudre

3.19

endurance en courant alternatif

caractéristique d'un parafoudre qui lui permet d'écouler un courant alternatif d'une valeur donnée pendant un temps donné pour un nombre de fois déterminé

3.20**endurance en impulsionnel**

caractéristique d'un parafoudre qui lui permet d'écouler une impulsion de courant de valeur crête donnée et de forme d'onde donnée pour un nombre de fois déterminé

3.21**temps de retour à la normale d'un courant**

temps nécessaire pour un limiteur de courant auto-réamorçable pour revenir à son état normal ou stable

3.22**courant assigné**

courant maximal qu'un parafoudre limiteur de courant peut transporter de façon continue sans modification de l'impédance des composants limiteurs de courant

NOTE Ceci s'applique aussi aux composants en série linéaires.

3.23**résistance d'isolement**

résistance entre des bornes déterminées du parafoudre quand U_c est appliquée à ces mêmes bornes

3.24**facteur d'adaptation (en réflexion)**

module de l'inverse du facteur de réflexion généralement exprimé en décibels (dB)

NOTE Quand les impédances peuvent être connues, le facteur d'adaptation en dB est donné par la formule:

$$20 \log_{10} \text{MOD} [(Z_1 + Z_2)/(Z_1 - Z_2)]$$

où Z_1 est l'impédance caractéristique de la ligne de transmission avant la discontinuité, ou l'impédance de source, et Z_2 est l'impédance après la discontinuité ou celle de la charge vue de l'accès commun à la source et à la charge [VEI 702-07-25, modifié].

3.25**taux d'erreur binaire (TEB)**

rapport entre le nombre d'erreurs binaires (bit) et le nombre total de bits transmis pendant un intervalle de temps donné

3.26**perte d'insertion (affaiblissement)**

perte résultant de l'insertion d'un parafoudre dans un système de transmission. C'est le rapport entre la puissance délivrée dans la partie du système après le parafoudre, avant l'insertion du parafoudre, à la puissance délivrée dans la même partie après l'insertion du parafoudre. La perte d'insertion est généralement exprimée en décibels

[VEI 726-06-07, modifié]

3.27**paradiaphonie**

diaphonie propagée dans un canal perturbé dans la direction opposée à la direction de propagation du courant dans ce canal. La borne du canal perturbé, à laquelle la paradiaphonie est présente, est généralement proche, ou la même, que celle où la puissance est appliquée au canal perturbé

3.28**affaiblissement de conversion longitudinale (ACL) (circuits analogiques pour la voix)**

symétrie électrique des deux fils comprenant une paire vis à vis de la terre

3.29

affaiblissement de conversion longitudinale (ACL) (transmission de données)

mesure de la similitude des impédances à la terre (ou au commun) pour les deux (ou plus) fils d'un circuit équilibré. Ce terme est utilisé pour exprimer la susceptibilité aux interférences de mode commun

3.30

affaiblissement de conversion longitudinale (ACL) (câbles de communication et de contrôle)

rapport entre la tension perturbée en mode commun (longitudinal) V_s efficace, mesurée par rapport à la terre, et la tension résultante en mode différentiel (métallique) V_m efficace du parafoudre en essai, exprimée en décibels

NOTE L'affaiblissement de conversion longitudinal est donné en dB par la formule:

$$20 \log_{10} V_s/V_m$$

où V_s et V_m sont mesurés à la même fréquence.

3.31

affaiblissement de conversion longitudinale (ACL) (télécommunications)

rapport entre la tension perturbée en mode commun (longitudinal) V_s et la tension résultante en mode différentiel (métallique) V_m du parafoudre en essai exprimée en décibels

3.32

choc (télécommunications)

tension ou courant temporaire excessif, ou les deux, couplé à une ligne de télécommunications à partir d'une source électrique externe

NOTE 1 Les sources électriques usuelles sont la foudre et les réseaux d'alimentation alternatifs/continus.

NOTE 2 Le couplage d'une source électrique peut avoir le ou les caractères suivants: électrique, magnétique, électromagnétique, conducteur.

4 Conditions d'utilisation et d'essais

4.1 Conditions d'utilisation

4.1.1 Conditions normales

4.1.1.1 Pression de l'air et altitude

Pression de l'air de 80 kPa à 160 kPa. Ces valeurs représentent une altitude de +2 000 m à – 500 m respectivement.

4.1.1.2 Température ambiante

- domaine normal: -5 °C à +40 °C

NOTE 1 Le présent domaine s'applique normalement aux parafoudres à usage en intérieur. Ceci correspond au code AB4 de la CEI 60364-5-51.

- domaine étendu: -40 °C à +70 °C

NOTE 2 Le présent domaine s'applique normalement aux parafoudres à usage en extérieur dans des emplacements non protégés des intempéries, classe 3K7 dans la CEI 60721-3-3.

- domaine de stockage: -40 °C à +70 °C

NOTE 3 Toute autre valeur sera spécifiée par le fabricant.

4.1.1.3 Humidité relative

- domaine normal: 5 % à 95 %

NOTE 1 Le présent domaine s'applique normalement aux parafoudres à usage en intérieur. Ceci correspond au code AB4 de la CEI 60364-5-51.

- domaine étendu: 5 % à 100 %

NOTE 2 Le présent domaine s'applique normalement aux parafoudres à usage en extérieur dans des emplacements non protégés des intempéries (par exemple le parafoudre est contenu dans une enveloppe à l'épreuve des intempéries).

4.1.2 Conditions anormales

L'exposition d'un parafoudre à des conditions d'utilisation anormales peut entraîner des dispositions spéciales, quant à sa conception ou ses applications et doit retenir toute l'attention du fabricant.

4.2 Conditions d'essais (température et humidité)

Si l'on sait d'avance qu'une technologie particulière rend un parafoudre insensible à la température, en essayant une caractéristique déterminée, une température de $23\text{ °C} \pm 2\text{ °C}$ et une humidité relative de 45 % à 55 % peuvent être utilisées. Dans les autres cas, l'essai doit être exécuté sur un parafoudre sensible à la température, aux températures extrêmes de l'échelle sélectionnée pour l'application voulue. L'échelle des températures sélectionnées peut être plus restreinte que l'échelle complète du 4.1, en fonction de l'application.

Pour certaines techniques de parafoudres, il peut être connu par avance que seule une des températures extrêmes de l'échelle des températures sélectionnées représente la pire des conditions d'essai. Dans ce cas, l'essai doit être fait seulement à cette température extrême. On peut noter que cette température extrême peut être différente à chaque essai, décrit à l'article 6, pour une même technique de parafoudre.

Lorsqu'il est demandé de faire un essai aux températures extrêmes, les parafoudres doivent être chauffés ou refroidis petit à petit, jusqu'à la température extrême spécifiée, en un temps suffisant pour éviter le choc thermique. Sauf spécification contraire, un minimum de 1 h serait utile. Le parafoudre doit être maintenu à la température spécifiée pendant un temps suffisant pour atteindre l'équilibre thermique avant l'essai. Sauf spécification contraire, il convient d'utiliser un minimum de 15 min.

4.3 Conditions d'essai des parafoudres

Les parafoudres concernés par cette norme, doivent être essayés avec les connexions et les bornes utilisées lorsque des parafoudres sont installés comme sur le terrain. De plus, les mesures doivent être réalisées aux connexions ou aux bornes des parafoudres. Pour ceux dont l'utilisation est prévue avec une base ou un connecteur, ces derniers doivent faire partie des essais.

Pour les applications des télécommunications, l'UIT-T donne les exigences dans la série K pour les supports de protection (K.65) et les modules de terminaison (K.55).

Quand une base est utilisée pour l'essai, les mesures doivent être réalisées aussi près que possible des bornes du parafoudre. L'oscilloscope doit être conforme à la CEI 61083-1, quand il est utilisé pour les mesures.

NOTE Les réglages de l'oscilloscope sont développés à l'Annexe D.

Les parafoudres des Figures 1c, 1e et 1f peuvent avoir une boucle de courant commune (y compris des composants de protection ou juste des connexions internes) qui conduit la totalité du courant impulsionnel. Le fabricant doit établir la valeur maximale du courant impulsionnel pour cette boucle de courant. Cette valeur de courant impulsionnel peut être inférieure à n fois la capacité maximale du courant de chaque borne de ligne, où n est égal au nombre de bornes de lignes.

Ces parafoudres doivent être soumis simultanément aux essais en réunissant toutes leurs bornes par rapport à la borne commune.

Les considérations concernant les dimensions d'échantillons et le nombre de défauts acceptables, sont à établir d'un commun accord entre le fabricant et l'utilisateur.

4.4 Tolérances des formes d'ondes

La définition des paramètres de formes d'ondes A/B , quand A est le temps de montée en microsecondes et B la durée à mi-valeur de la crête en microsecondes, doit être conforme à la CEI 60060-1 (voir également la CEI 61000-4-5). Le tableau 2 donne les tolérances pour les formes d'onde concernées par la présente norme.

Tableau 2 – Tolérances pour les formes d'ondes A/B

Forme d'onde	1,2/50 ou 10/700 Tension en circuit ouvert	8/20 ou 5/300 Courant de court-circuit	Autres formes d'ondes
Crête	±10 %	±10 %	±10 %
Temps de montée	±30 %	±20 %	±30 %
Durée à mi-valeur de la crête	±20 %	±20 %	±20 %

5 Prescriptions

5.1 Prescriptions générales

Les prescriptions suivantes s'appliquent à tous les parafoudres couverts par cette norme.

5.1.1 Identification et documentation

Les informations données du point a) au point n) doivent être soit marquées sur le corps du parafoudre, comme décrit en 5.1.2, soit notées dans la documentation ou sur l'emballage. Toutes les abréviations utilisées doivent être expliquées dans la fiche technique. Pour chaque essai de l'article 6 pratiqué sur le parafoudre les conditions d'essai doivent être indiquées dans la documentation.

- Nom du fabricant ou de la marque
- Numéro de la semaine et de l'année de fabrication, ou numéro de série
- Numéro du modèle
- Conditions d'utilisation
- Tension maximale de service permanent U_c
- Courant assigné
- Niveau de protection de tension U_p
- Réinitialisation après impulsion (si applicable)
- Endurance en courant alternatif
- Endurance en courant impulsionnel
- Mode de défaut par surcharges
- Caractéristiques de transmissions
- Autres informations, si nécessaire, concernant les éléments de remplacement et l'usage des matériaux radioactifs
- Résistance série (si applicable)

5.1.2 Marquage

Les parafoudres doivent être clairement marqués conformément aux points suivants de 5.1.1: a) nom du fabricant ou de la marque, b) traçabilité de la fabrication, c) du numéro de modèle, e) tension maximale de service permanent. Le marquage doit être résistant aux frottements et aux solvants normalement utilisés dans les applications de parafoudres. Toute note, concernant une manipulation spéciale, doit figurer dans la documentation ou sur l'emballage. La conformité est vérifiée par l'essai de 6.1.2.

5.2 Prescriptions électriques

Le parafoudre doit satisfaire aux prescriptions suivantes, quand il est essayé conformément aux paragraphes de l'article 6.

5.2.1 Prescription de limitation de tension

Si le parafoudre n'est constitué que de composants de limitation de tension, il doit être conforme aux exigences de 5.2.1. Si le parafoudre est constitué, à la fois, de composants de limitation de tension et de composants de limitation de courant, il doit être conforme aux exigences de 5.2.1 et à toutes les exigences applicables de 5.2.2.

Un parafoudre ayant un composant linéaire entre les bornes de ligne et les bornes de la ligne protégée, doit être conforme aux exigences applicables de 5.2.2.

5.2.1.1 Tension maximale de service permanent (U_c)

Le fabricant doit indiquer la tension maximale de service permanent pour le parafoudre approprié à l'application, que ce soit en courant alternatif ou en courant continu.

La conformité est vérifiée par l'essai de 6.2.1.1.

5.2.1.2 Résistance d'isolement

Cette caractéristique doit être indiquée par le fabricant. La conformité est vérifiée par l'essai de 6.2.1.2.

5.2.1.3 Tension de limitation impulsionnelle

Le parafoudre doit limiter une impulsion de tension donnée lors de l'essai aux conditions spécifiées au tableau 3. La tension de limitation mesurée ne doit pas dépasser le niveau de protection U_p déclaré. Voir CEI 61180-1.

5.2.1.4 Réinitialisation sur impulsion (de courant)

Cette prescription ne s'applique qu'aux parafoudres de type coupure ou tension.

Après avoir appliqué au parafoudre une onde impulsionnelle choisie dans le tableau 3, celui-ci doit s'arrêter de fonctionner ou retourner à son état stable. Durant l'application de cette impulsion, une tension choisie dans le tableau 4 doit lui être appliquée. Sauf spécification contraire, le parafoudre doit revenir à son impédance élevée en 30 ms ou moins.

5.2.1.5 Endurance en courant alternatif

Le parafoudre, après avoir subi l'essai de 6.2.1.5, en utilisant un courant choisi dans le tableau 5, doit satisfaire aux exigences de 5.2.1 et 5.2.2, si applicables.

5.2.1.6 Endurance en impulsionnel

Le parafoudre, après avoir subi l'essai de 6.2.1.6, en utilisant un courant et une forme d'onde choisis dans le tableau 3, doit satisfaire aux exigences de 5.2.1 et 5.2.2, si applicables.

5.2.1.7 Mode de défaut par surcharge

Le parafoudre ne doit pas déclencher de feu dangereux, d'explosion dangereuse, provoquer un danger d'électrocution ni émettre des fumées toxiques lors de l'essai 6.2.1.7.

Le fabricant doit indiquer la valeur de l'impulsion de courant (8/20) et la valeur du courant alternatif qui conduit au mode de défaut décrit en 6.2.1.7.

5.2.1.8 Point aveugle

En l'absence d'informations disponibles de la part du fabricant concernant le point aveugle, ou si la vérification des informations données par le fabricant est désirée, les parafoudres étagés doivent subir l'essai de 6.2.1.8.

5.2.2 Prescriptions de limitation en courant

Quand le parafoudre est composé à la fois de composants limiteurs de tension et de courant, les composants limiteurs de courant doivent être conformes à toutes les exigences applicables de 5.2.2. Le parafoudre, contenant un composant linéaire (par exemple une résistance ou une inductance), entre ses bornes de ligne, doit respecter les exigences de 5.2.2.1, 5.2.2.2, 5.2.2.7 et 5.2.2.8.

5.2.2.1 Courant assigné

Le fabricant doit spécifier le courant assigné. Pour confirmer cette valeur, le parafoudre doit subir l'essai de 6.2.2.1. Il ne doit apparaître aucun changement des caractéristiques opérationnelles des composants limiteurs de courant du parafoudre.

5.2.2.2 Résistance série

Le fabricant doit indiquer la valeur et la tolérance de la résistance série. Pour confirmer cette valeur, le parafoudre doit subir l'essai de 6.2.2.2.

5.2.2.3 Temps de réponse en courant

Lors de l'essai de 6.2.2.3, le ou les composants limiteurs de courant doivent agir dans le temps de réponse indiqué par le fabricant ou moins. Les valeurs préférentielles des essais en courant sont données dans le tableau 6. Voir l'UIT-T Recommandation K.30.

5.2.2.4 Temps de réamorçage en courant

Le parafoudre contenant un ou plusieurs composants limiteurs de courant auto-réamorçables doit subir les essais de 6.2.2.4. Le temps de réamorçage, c'est-à-dire le temps nécessaire pour que le ou les composants limiteurs de courant reviennent à leur état stable, doit être inférieur à 120 s sauf spécification contraire.

Pour les parafoudres équipés d'un dispositif manuel de réamorçage cette exigence n'est pas applicable.

5.2.2.5 Tension maximale de coupure

Cette exigence n'est applicable qu'aux parafoudres ayant des composants de limitation de courant réamorçables manuellement ou automatiquement. Le fabricant du parafoudre doit indiquer la tension maximale de coupure du ou des composants limiteurs de courant dans le parafoudre. La confirmation de cette valeur est obtenue en effectuant l'essai de 6.2.2.5. Il ne doit y avoir aucune dégradation des caractéristiques opérationnelles des composants limiteurs de courant après l'essai.

5.2.2.6 Essai de fonctionnement

Cette exigence n'est applicable qu'aux parafoudres ayant un ou des composants de limitation de courant réamorçables manuellement ou automatiquement. Le parafoudre doit pouvoir accepter la répétition des applications de la tension maximale de coupure. Le courant doit être suffisant pour faire fonctionner le ou les composants de limitation de courant et choisi dans le tableau 7. Après les essais, le ou les composants de limitation de courants doivent respecter les exigences du 5.2.2.3 et du 5.2.2.4.

5.2.2.7 Endurance en courant alternatif

Le parafoudre doit pouvoir accepter la répétition de l'application d'un courant donné. Le tableau 8 donne les valeurs préférentielles de courant alternatif. Après avoir subi ce courant, le ou les composants de limitation de courant dans le parafoudre doivent respecter les exigences de 5.2.2.1, 5.2.2.2 et 5.2.2.3.

5.2.2.8 Endurance en impulsionnel

Le parafoudre doit pouvoir accepter un nombre spécifié d'impulsions de courant de crête spécifié. Le tableau 9 donne les valeurs préférentielles. Après l'application des impulsions conformément à 6.2.2.8, le ou les composants de limitation de courant du parafoudre doivent respecter les exigences de 5.2.2.1, 5.2.2.2, et 5.2.2.3.

5.2.3 Prescriptions de transmission

En plus des exigences de 5.2.1 et 5.2.2, les parafoudres peuvent devoir être conformes à certaines exigences de 5.2.3, suivant leurs applications de télécommunications et de transmission de signaux (par exemple: voix, données et vidéo). Le Tableau 1 donne des lignes directrices pour la sélection des essais de transmissions applicables.

5.2.3.1 Capacité

Le fabricant doit faire état de la valeur de la capacité entre des bornes déterminées. La confirmation doit être effectuée par application de l'essai de 6.2.3.1.

5.2.3.2 Perte d'insertion

Le parafoudre doit subir l'essai de 6.2.3.2 pour déterminer si l'insertion du parafoudre dans le système d'essai entraîne une réduction de tension entre celle générée et celle mesurée par l'équipement.

5.2.3.3 Perte par réflexion

Le parafoudre doit subir l'essai de 6.2.3.3 afin de déterminer le rapport de l'amplitude du signal réfléchi au signal de la source, au-delà d'une bande de fréquence déterminée, lors de l'introduction du parafoudre dans la ligne de transmission perturbée.

5.2.3.4 Affaiblissement de conversion longitudinal (ACL)

Le parafoudre doit subir l'essai de 6.2.3.4. L'essai détermine le niveau minimal acceptable de l'ACL pour un parafoudre utilisé dans le circuit. L'ACL doit être mesuré dans la bande de fréquence désirée.

5.2.3.5 Taux d'erreur binaire (TEB)

Le parafoudre doit subir l'essai de 6.2.3.5. L'essai détermine si l'insertion d'un parafoudre dans une ligne de transmission de données numériques produit des erreurs binaires.

5.2.3.6 Paradiaphonie

Le parafoudre doit subir l'essai de 6.2.3.6. L'essai détermine l'amplitude du couplage d'un circuit à un autre, due à l'insertion du parafoudre.

5.3 Prescriptions mécaniques

Le parafoudre doit être conforme aux exigences mécaniques suivantes. Cependant, certaines exigences mécaniques peuvent être remplacées par des règles nationales.

5.3.1 Bornes et connecteurs

a) Les bornes et connecteurs doivent être fixés au parafoudre de telle façon qu'ils ne bougent pas, lorsque les vis ou les écrous sont serrés ou desserrés. Un outil doit être nécessaire pour dévisser les vis ou les écrous.

b) Vis, parties conduisant le courant et connecteurs

- 1) Les connexions, soit électriques, soit mécaniques, doivent résister aux efforts mécaniques survenant en usage normal et aux efforts mécaniques générés par les forts courants impulsionnels. Les vis qui fonctionnent au moment de monter le parafoudre lors de son installation ne doivent pas être auto-taraudeuses.

La conformité est vérifiée par inspection et par les essais de 6.3.1.2.

- 2) Les connexions électriques doivent être conçues de façon que la pression de contact ne soit pas transmise à des matières isolantes autre que la céramique, le mica pur ou d'autres matériaux aux caractéristiques aussi convenables, de plus les parties métalliques doivent avoir une résilience suffisante pour compenser tout rétrécissement ou affaiblissement éventuels des parties isolantes.

La conformité est vérifiée par inspection.

Le choix convenable des matériaux doit être fait au regard des dimensions.

- 3) Les parties conduisant le courant et les connexions incluant des parties destinées aux conducteurs de protection, si nécessaires, doivent être en

– cuivre ou

– un alliage contenant au moins 58 % de cuivre, pour les parties fonctionnant à froid, ou au moins 50 % de cuivre, pour les autres parties, ou

– un autre métal ou un métal avec un revêtement approprié, ayant une résistance à la corrosion non inférieure à celle du cuivre et ayant des propriétés mécaniques aussi convenables.

Les prescriptions pour les connexions mécaniques des bornes spéciales sont décrites dans la CEI 61643-1.

c) Bornes sans vis pour conducteurs externes

- 1) Les bornes doivent être conçues et construites de manière que

– chaque conducteur soit connecté individuellement et que les conducteurs puissent être connectés ou déconnectés en même temps ou séparément;

- il soit possible de connecter sûrement autant de conducteurs que le maximum prévu.
- 2) Les bornes doivent être conçues et construites afin que la connexion se fasse sans trop de dommage sur le conducteur.
La conformité est vérifiée par examen.
- d) Connexion auto-dénudante pour conducteurs externes
 - 1) Les connexions auto-dénudantes doivent réaliser une connexion mécanique fiable. La conformité est vérifiée par examen et par les essais de 6.3.1.4.
 - 2) Les vis devant établir la pression de contact ne doivent pas servir à fixer tout autre composant. Toutefois elles peuvent maintenir le parafoudre en place et l'empêcher de tourner.
La conformité est vérifiée par examen.
 - 3) Les vis ne doivent pas être en métal doux ou susceptible de glisser.
La conformité est vérifiée par examen.
- e) Métaux résistant à la corrosion
Les fixations (sauf les vis de serrage), écrous, clips, rondelles, fils et autres parties similaires, doivent être constitués de métal résistant à la corrosion (voir CEI 60999-1).

5.3.2 Contraintes mécaniques

Les parafoudres doivent être construits avec des moyens appropriés, pour être montés de manière à assurer leur tenue mécanique.

5.3.3 Résistance à l'introduction de corps solides et d'eau

Les parafoudres doivent être construits de façon à ce qu'ils fonctionnent normalement, dans les conditions de service décrites à 4.1. Les parafoudres installés à l'extérieur doivent être protégés par un revêtement en verre, en céramique ou tout autre matériau acceptable, résistant aux rayons ultraviolets, à la corrosion, à l'érosion et au cheminement.

Ils doivent avoir une distance d'isolement suffisante entre n'importe quelles parties de potentiels différents. Dans certains pays, d'autres règles nationales peuvent être appliquées.

5.3.4 Protection contre les contacts directs

En ce qui concerne la protection contre les contacts directs (inaccessibilité des parties actives), le parafoudre doit être conçu de manière à ce que les parties actives ne puissent être touchées, lorsqu'il est installé comme en usage normal. Cette prescription est valable pour les parafoudres accessibles, dont la tension U_c est supérieure à 50 V eff. ou 71 V en continu.

Les parafoudres, à l'exception de ceux classés inaccessibles, doivent être conçus de manière à ce que, lorsqu'ils sont câblés et montés en usage normal, les parties actives ne puissent pas être accessibles, même après retrait des parties amovibles, sans l'aide d'un outil (contrôlé par l'essai des parties isolées de 6.3.4).

La connexion entre les bornes de terre et toutes les parties accessibles qui lui sont reliées, doit présenter une faible résistance (voir CEI 60529).

Dans certains pays, d'autres règles nationales peuvent être appliquées.

5.3.5 Résistance au feu

Les parties isolantes des boîtiers doivent être, soit non inflammables, soit auto-extinguibles.

Dans certains pays, d'autres règles nationales peuvent être appliquées.

5.4 Prescriptions d'environnement

Les parafoudres destinés seulement à un environnement non connu de 4.1, doivent être conformes aux prescriptions d'environnement suivantes, après accord entre le fabricant et l'utilisateur.

5.4.1 Hautes températures et résistance à l'humidité

Le parafoudre doit être exposé à une température de 80 °C et à une humidité relative de 90 %. La durée d'exposition doit être choisie dans le tableau 15. L'essai ne doit être appliqué qu'aux parafoudres destinés à un environnement non connu et effectué suivant 6.4.1. Après l'exposition, les composants limiteurs de tension du parafoudre doivent respecter les exigences de 5.2.1.2 et 5.2.1.3. Si le parafoudre essayé contient des composants limiteurs de courant, ils doivent respecter les exigences de 5.2.2.2 et 5.2.2.3.

Si les éléments d'une série donnée de fabrication d'un parafoudre ont des composants de limitation de tension et des composants de limitation de courant identiques, mais une tension de service permanent U_c différente, seuls les parafoudres ayant le plus haut niveau de protection doivent être essayés.

5.4.2 Conditions d'ambiances cyclées avec impulsions

Le parafoudre doit être exposé au cycle de températures à humidité élevée tout en conduisant les courants impulsionnels. Le type de cycle de températures doit être choisi dans le tableau 16.

Durant et après l'application de cycle, les composants limiteurs de tension du parafoudre doivent respecter les exigences de 5.2.1.2 et de 5.2.1.3. Si le parafoudre en essai contient des composants limiteurs de courant, ils doivent respecter les exigences de 5.2.2.2 et de 5.2.2.3.

Cet essai ne doit être pratiqué que sur les parafoudres destinés à un environnement non connu et doit être réalisé suivant 6.4.2.

Si les éléments d'une série donnée de fabrication d'un parafoudre ont des composants de limitation de tension et des composants de limitation de courant identiques, mais une tension de service permanent U_c différente, seuls les parafoudres ayant le plus haut niveau de protection doivent être essayés.

5.4.3 Conditions d'ambiance cyclées en courant alternatif

Le parafoudre doit être exposé au cycle de température à humidité élevée tout en conduisant le courant alternatif. Ce courant et sa durée doivent être choisis dans le tableau 5. Le type de cycle de température doit être choisi dans le tableau 16.

Durant et après l'application du cycle, le parafoudre doit respecter les prescriptions de 5.2.1.2 et de 5.2.1.3.

L'essai ne doit être effectué que sur les parafoudres destinés à un environnement non connu et doit être réalisé suivant 6.4.3.

Si les éléments d'une série donnée de fabrication d'un parafoudre ont des composants de limitation de tension et des composants de limitation de courant identiques, mais une tension de service permanent U_c différente, seuls les parafoudres ayant le plus haut niveau de protection doivent être essayés.

6 Essais de type

6.1 Essais généraux

6.1.1 Renseignements documentaires et identification

La vérification de l'identification et des renseignements documentaire, doit respecter les exigences du 5.1.1, et s'effectuer par inspection.

6.1.2 Marquage

La vérification du marquage doit être effectuée par inspection. L'essai suivant d'indélébilité doit être appliqué à tous les marquages, sauf ceux par compression, moulage et gravage.

L'essai est effectué en frottant le marquage à la main, pendant 15 s, avec un morceau d'ouate imbibé d'eau et, pendant 15 s encore, avec un morceau d'ouate imbibé d'hexane (avec une teneur maximale en carbures aromatiques de 0,1 % en volume, un indice de kauributanol de 29, une température initiale d'ébullition d'environ 65 °C, et de masse spécifique de 0,68 g/cm³). Après cet essai, le marquage doit être facilement lisible.

6.2 Essais électriques

6.2.1 Essais de limitation de tension

6.2.1.1 Tension maximale de service permanent U_c

La tension maximale de service permanent U_c doit être vérifiée pendant l'essai de la résistance d'isolement en 6.2.1.2.

6.2.1.2 Résistance d'isolement

La résistance d'isolement doit être mesurée dans les deux polarités à une paire de bornes à la fois. La tension d'essai doit être égale à la tension maximale de service permanent U_c . Le courant traversant les bornes en essai doit être mesuré. La résistance d'isolement est la tension d'essai divisée par le courant mesuré et doit être inférieure ou égale à la valeur donnée par le fabricant.

6.2.1.3 Tension de limitation impulsionnelle

Le parafoudre doit être essayé en utilisant une onde impulsionnelle choisie dans la catégorie C du Tableau 3 et appliquée aux bornes appropriées. L'amplitude du courant doit être choisie en fonction de la capacité d'absorption en énergie du parafoudre, comme déterminé par l'essai d'endurance en impulsionnel de 6.2.1.6. Les essais de tension de limitation impulsionnelle et d'endurance aux impulsions doivent être effectués avec la même impulsion. Les valeurs listées dans le Tableau 3 sont des exigences minimales; d'autres caractéristiques de courants de choc sont disponibles dans les normes, par exemple les recommandations de l'UIT-T.

D'autres essais peuvent être effectués en utilisant les autres formes d'onde des catégories A1, B, C et D, comme indiqué dans les documentations. Cependant, ces essais sont facultatifs et ne devraient être utilisés que suivant l'application du parafoudre. L'amplitude du courant doit être choisie en fonction de la possibilité d'absorption d'énergie du parafoudre comme indiqué par le fabricant.

Sauf spécification contraire, il est appliqué cinq impulsions négatives et cinq positives, pour chaque essai impulsionnel. Le générateur utilisé doit avoir sa tension en circuit ouvert et son courant de court-circuit, choisi dans le tableau 3.

La limitation de la tension est mesurée pour chaque impulsion sans charge. La tension maximale mesurée aux bornes appropriées ne doit pas dépasser le niveau de protection (U_p) spécifié. Un temps suffisant doit être accordé entre les impulsions, pour prévenir toute accumulation de chaleur. Il est entendu que des parafoudres différents auront des caractéristiques thermiques différentes et en conséquence nécessiteront des temps différents entre les impulsions.

Les réglages des enregistreurs impulsionnels sont développés à l'Annexe D.

Si nécessaire, l'impulsion de tension peut être appliquée entre les bornes X1 – X2 des parafoudres des figures 1c) et 1e).

Pour les essais sur les parafoudres des figures 1c) et 1e), chaque paire de bornes (X1 – C et X2 – C) peut être essayée en même temps, à la même polarité ou séparément.

Pour les parafoudres, qui ont un même élément shunt commun, comme décrit en 4.3, la tension aux bornes auxquelles l'impulsion n'est pas appliquée doit être mesurée et ne doit pas dépasser U_p .

IECNORM.COM : Click to view the full PDF of IEC 61643-21:2000+AMD1:2008 CSV

**Tableau 3 – Formes d'ondes de courant et de tension
pour la tension de limitation impulsionnelle**

Catégorie	Type d'essai	Tension en circuit ouvert ^a	Courants de court-circuit	Nombre d'impulsions minimal	Bornes à essayer
A1	Très faible vitesse de montée	≥ 1 kV Vitesse de montée de $0,1$ kV/ μ s à 100 kV/s	10 A, $0,1$ A/ μ s à 2 A/ μ s, $\geq 1\ 000$ s (durée)	Non applicable (NA)	X1 – C X2 – C X1 – X2 ^b
A2	AC	Choix d'essai du Tableau 5		Un seul cycle	
B1	Faible vitesse de montée	1 kV 10/1000	100 A, 10/1000	300	
B2		1 kV à 4 kV 10/700	25 A à 100 A 5/300	300	
B3		≥ 1 kV 100 V/ μ s	10 A à 100 A 10/1 000	300	
C1	Forte vitesse de montée	$0,5$ kV à < 2 kV 1,2/50	$0,25$ kA à < 1 kA, 8/20	300	
C2		2 kV à 10 kV 1,2/50	1 kA à 5 kA, 8/20	10	
C3		≥ 1 kV 1 kV/ μ s	10 A à 100 A 10/1 000	300	
D1	Haute énergie	≥ 1 kV	$0,5$ kA à $2,5$ kA, 10/350	2	
D2		≥ 1 kV	$0,6$ kA à $2,0$ kA, 10/250	5	

^a On peut utiliser une tension en circuit ouvert différente de 1 kV. Cependant, il faut qu'elle soit suffisante pour faire fonctionner le parafoudre en essai.

^b L'essai aux bornes X1 – X2 doit être exécuté, seulement si demandé.

NOTE 1 Pour la vérification de U_p , une des formes d'onde d'impulsion de catégorie C ci-dessus est obligatoire et A, B et D sont optionnelles. Sauf spécification contraire, appliquer 5 impulsions positives et 5 impulsions négatives.


NOTE 2 Pour le réamorçage sur impulsion, choisir l'essai à partir des catégories B, C et D. Sauf spécification contraire, appliquer 3 impulsions positives et 3 impulsions négatives.

NOTE 3 Pour la mesure d'endurance en impulsionnel, une forme d'onde d'impulsion de catégorie C est obligatoire et A1, B et D sont optionnelles.

NOTE 4 Les valeurs listées dans le Tableau 3 sont des exigences minimales; d'autres caractéristiques de courants de choc sont disponibles dans d'autres normes, par exemple les recommandations de l'UIT-T – série K.


Choc simultané sur tous les conducteurs protégés

Les parafoudres à lignes multiples peuvent utiliser un élément de protection commun pour le retour à la terre du courant impulsionnel. Deux exemples sont illustrés à la Figure 16. Toutes les lignes protégées doivent avoir un courant impulsionnel égal au courant impulsionnel total divisé par le nombre de lignes, appliqué simultanément afin de vérifier que l'élément de protection commun dispose de la capacité en courant suffisante. A la fin de cet essai, le parafoudre ne doit pas s'être détérioré. Le présent essai vérifie aussi que les connexions internes du parafoudre disposent de la capacité en courant suffisante.



IEC 555/08

Circuit de protection en étoile



IEC 556/08

Pont à diodes pilotes

Légende

X1, X2, Xn,	bornes de lignes	1	élément de protection individuel
Y1, Y2, Yn,	bornes de lignes protégées	2	élément de protection commun
C	commun		

Figure 16 – Exemples de parafoudres à lignes multiples à élément de protection commun

Les exigences du répartiteur de courant (réseau de couplage) illustré à la Figure 4 sont les suivants:

- Le réseau de couplage ne doit pas influencer l'impulsion d'essai. Tous les paramètres de forme d'onde de choc selon 4.4 s'appliquent aux bornes de sortie du réseau de couplage.
- Le temps de montée et la durée de l'impulsion doivent être vérifiés aux bornes de sortie du réseau de couplage pour les tensions de choc (circuit ouvert) et les courants de choc (court-circuit).
- La forme d'onde de choc du courant de court-circuit peut être mesurée à l'aide d'un transformateur de courant toroïdal ou d'une résistance de surveillance du courant.
- Il est préférable d'utiliser des résistances dans les réseaux de couplage.
- Il faut vérifier individuellement le partage du courant dans chaque conducteur du répartiteur avec les autres conducteurs court-circuités avant que le raccordement à l'échantillon d'essai respectif soit réalisé. Les résultats de cet essai ne signifient pas que les courants seront également partagés lorsque le parafoudre est présent dans le circuit.
- Durant l'essai simultané, il sera vérifié que l'élément de protection commun a été exposé au courant impulsionnel total sans défaillance d'un quelconque composant de protection contre les surtensions.

6.2.1.4 Réamorçage sur impulsion

Le parafoudre doit être connecté, comme indiqué à la figure 2. La source de courant et la source de tension peuvent être choisies parmi les valeurs non limitatives du tableau 4. Ces sources de puissance représentent les valeurs usuelles des systèmes. Pour de nouvelles utilisations, le réamorçage sur impulsion doit être effectué avec les sources de courant et de tension utilisées pour la dite utilisation.

Les formes d'impulsion de tension et de courant doivent être choisies dans le tableau 3, catégories B, C et D. La tension crête en circuit ouvert doit être suffisamment grande, pour que les composants de limitation en tension fonctionnent. La polarité de l'impulsion doit être la même que la polarité de la source de tension. Le temps de réamorçage est défini comme le temps, depuis l'application de l'impulsion, jusqu'au retour du parafoudre à son état à haute impédance.

Trois impulsions doivent être appliquées à pas plus de 1 min d'intervalle. Le temps de réamorçage doit être mesuré à chacune des impulsions. L'essai doit être répété à la polarité inverse.

Tableau 4 – Sources de tension et de courant, pour les essais de réamorçage sur impulsion

Tension en circuit ouvert de la source ^b	Courant de court-circuit de la source
V	mA
12	500
24	500
48	260
97	80
135	200 ^a
^a Le parafoudre peut être connecté en parallèle, par une combinaison de résistances séries de 135-150 Ω et un condensateur de 0,08 μ F à 0,1 μ F. ^b Tolérance (y compris le lissage) + 10% -0%	

6.2.1.5 Endurance en courant alternatif pour la fonction limitation de tension

Le parafoudre doit être connecté, comme indiqué à la figure 3. Les courants de court-circuit en alternatif doivent être choisis dans le tableau 5. Effectuer le nombre spécifié d'applications en courant alternatif, avec un temps entre chaque application suffisant, pour éviter une accumulation de chaleur dans l'appareil en essai. La tension en circuit ouvert doit être de valeur suffisante pour réaliser une pleine conduction du parafoudre. Avant l'essai et après avoir effectué toutes les applications en courant alternatif requises, le parafoudre doit satisfaire aux exigences de 5.2.1.2, 5.2.1.3, 5.2.1.4 (si applicable) et 5.2.2.2.

Les courants choisis dans le tableau 5 doivent être appliqués aux bornes appropriées.

Si demandé, les courants peuvent être appliqués entre les bornes X1 – X2 des parafoudres des figures 1c) et 1e).

Pour les essais sur les parafoudres des figures 1c) et 1e), chaque paire de bornes (X1 – C et X2 – C) peut être essayée séparément.

Pour les parafoudres, qui ont un élément shunt commun, se référer au 4.3. Dans les autres cas, pour les parafoudres multibornes, faire l'essai de chaque borne de ligne à la borne commune séparément.

Tableau 5 – Valeurs préférentielles du courant pour l'essai d'endurance en courant alternatif

48 Hz -62 Hz Courants de court-circuit sur chaque borne à l'essai ^a A_{eff}	Durée s	Nombre d'applications ^b	Bornes à essayer
0,1	1	5	X1 – C X2 – C X1 – X2 ^c
0,25	1	5	
0,5	1	5	
0,5	30	1	
1	1	5	
1	1	60	
2	1	5	
2,5	1	5	
5	1	5	
10	1	5	
20	1	5	
^a Les valeurs indiquées au Tableau 5 sont des exigences minimales.			
^b Des nombres d'applications différents peuvent être trouvés dans d'autres normes, par exemple Série UIT-T K - Recommandations			
^c L'essai aux bornes X1 – X2 doit être exécuté, seulement si demandé.			

6.2.1.6 Endurance impulsionnelle pour la fonction limitation de tension

Le parafoudre doit être essayé en utilisant une impulsion choisie dans la Catégorie C du tableau 3 et appliquée aux bornes appropriées, choisies dans le tableau 3. Cette impulsion doit être la même que celle de l'essai de limitation impulsionnel en 6.2.1.3. D'autres essais peuvent être effectués en plus, en choisissant les autres impulsions du tableau des Catégories A1, B, C et D, comme celles mentionnées dans la documentation du parafoudre. Cependant, ces essais sont facultatifs et ne devraient être utilisés que pour l'application du parafoudre.

Le parafoudre doit être connecté comme indiqué à la figure 4. Appliquer le nombre minimal d'impulsions, définies au tableau 3, avec un temps suffisant entre chacune d'elles, pour éviter toute accumulation de chaleur dans le parafoudre en essai. La moitié du nombre défini d'impulsions de l'essai doit être réalisée dans l'une des polarités et l'autre moitié dans la polarité opposée. Ou bien, la moitié des échantillons peut être essayée avec une polarité et l'autre moitié avec la polarité opposée. Avant l'essai et après avoir effectué toutes les applications requises, le parafoudre doit satisfaire aux exigences de 5.2.1.2, 5.2.1.3 (une impulsion par polarité), 5.2.1.4 (si applicable), 5.2.2.2 (si applicable).

Si demandé, les impulsions pourront être appliquées aux bornes X1 – X2 des parafoudres des figures 1c) et 1e).

Pour les essais sur les parafoudres des figures 1c) et 1e), chaque paire de bornes (X1 – C et X2 – C) peut être essayée séparément.

Pour les parafoudres qui ont une boucle de courant commune, se référer à 4.3.

6.2.1.7 Mode de défaut par surcharge

Le parafoudre ne doit pas être en surcharge par des courants de surcharge impulsions ou alternatifs. Pour les essais sur les parafoudres illustrés aux Figures 1c, 1e et 1f, chaque paire de bornes (X1 – C et X2 – C) peut être essayée séparément. Pour le parafoudre 1f, choisir deux bornes comme un échantillon représentatif. Différents parafoudres doivent être pris pour les essais d'impulsion et pour ceux de courant alternatif.

Les essais de résistance d'isolement, de limitation de tension et de résistance série (s'il y a lieu) doivent être ensuite réalisés pour déterminer si le parafoudre a atteint un mode de défaut par surcharge acceptable, comme décrit en 3.3. Le parafoudre doit atteindre son mode de défaut par surcharge en toute sécurité, sans prendre feu dangereusement, sans explosion dangereuse, sans risque d'électrocution ni d'émission de fumées toxiques.

Surcharge par courants impulsions

Connecter le parafoudre, comme indiqué à la figure 4. Une onde de courant 8/20, i_n , spécifiée par le fabricant, doit être appliquée au parafoudre de la façon suivante:

$$i_{\text{test}} = i_n (1 + 0,5 N)$$

La séquence d'essai commence à $N = 0$ ($i_{\text{test}} = i_n$). Pour chaque essai suivant, accroître N de 1. La séquence est limitée à $N = 6$. Si le parafoudre n'atteint pas un état de défaut par surcharge après ces applications, le parafoudre doit subir l'essai de défaut par surcharge en courant alternatif.

Surcharge par courant alternatif

Le parafoudre doit être connecté, comme indiqué à la figure 3. Le courant alternatif d'essai doit être indiqué par le fabricant. Le courant alternatif doit être appliqué pendant 15 min. La tension en circuit ouvert, 50 Hz ou 60 Hz, doit avoir une valeur suffisante, pour obtenir une conduction complète du parafoudre. Après l'essai, le support du parafoudre doit pouvoir recevoir un autre parafoudre.

6.2.1.8 Essai du point aveugle

Afin de déterminer si le point aveugle existe dans un parafoudre étagé, les essais suivants sont effectués en utilisant un nouvel échantillon:

- Choisir la forme d'onde utilisée pour déterminer U_p . Durant l'application de cette impulsion, enregistrer la tension de limitation et la courbe tension-temps avec un oscilloscope.
- Réduire la tension en circuit ouvert de 10 % de celle utilisée en a), et appliquer une impulsion positive au parafoudre tout en enregistrant la tension de limitation avec un oscilloscope. Il convient que la forme d'onde de la tension de limitation soit différente de celle obtenue en a). Si ce n'est pas le cas, choisir une tension en circuit ouvert inférieure. Cependant cette tension doit être supérieure à U_c .
- Appliquer des tensions impulsives positives dont les valeurs sont de 20 %, 30 %, 45 %, 60 %, 75 %, 90 % de la tension utilisée en a), tout en continuant d'enregistrer la forme d'onde de la tension de limitation.
- Arrêter au pourcentage de tension en circuit ouvert pour lequel la forme d'onde de la tension de limitation revient à celle déterminée en a).
- Réduire la tension en circuit ouvert de 5 % et recommencer l'essai. Continuer de réduire la tension en circuit ouvert par paliers de 5 % jusqu'à ce que la forme d'onde notée en b) soit obtenue.
- A cette valeur de tension en court-circuit appliquer deux impulsions positives et deux impulsions négatives.

Après les essais de a) à f), le parafoudre doit respecter les exigences de 5.2.1.2.

6.2.2 Essais de limitation en courant

6.2.2.1 Courant assigné

Le parafoudre doit être connecté, comme indiqué à la figure 5. La source de tension d'essai doit être suffisante pour fournir le courant assigné. La fréquence doit être de 0 (courant continu), 50 Hz ou 60 Hz.

Durant les essais au courant assigné, la fonction de limitation en courant, si elle existe, ne doit pas fonctionner. Pour chaque configuration de parafoudre, l'essai en courant est effectué par ajustement des résistances R_s ou R_{s1} et R_{s2} . La fonction de limitation en courant en essai doit conduire le courant assigné pendant au minimum 1 h. Durant cet essai les parties accessibles ne doivent pas atteindre des températures excessives (voir 4.5.1 de la CEI 60950).

6.2.2.2 Résistance série

Le parafoudre doit être connecté, comme indiqué à la figure 5. La source de tension d'essai doit être inférieure à la tension maximale de coupure précisée par le constructeur. La fréquence doit être de 0 (courant continu), 50 Hz ou 60 Hz.

Le courant d'essai doit être établi égal au courant assigné par ajustement des résistances R_s ou R_{s1} et R_{s2} . La résistance est obtenue par $(e - IR_s)/I$ où e est la tension de source et I le courant assigné, comme mesuré par l'ampèremètre à la figure 5.

6.2.2.3 Temps de réponse en courant

Le parafoudre doit être connecté, comme indiqué à la Figure 5. La tension de la source doit être inférieure à la tension maximale de coupure, spécifiée par le fabricant. La fréquence doit être de 0 Hz (courant continu), 50 Hz ou 60 Hz, le choix s'effectuant selon l'application de destination.

Les dispositifs doivent être essayés aux températures appropriées en référence à 4.2. Un temps suffisant doit être accordé entre les essais pour que les dispositifs refroidissent jusqu'à la température d'essai avant de procéder aux essais suivants. Autrement, des dispositifs séparés peuvent être utilisés pour chaque essai afin d'éviter l'attente due à la durée de refroidissement. Les résistances R_s ou R_{s1} et R_{s2} doivent être réglées pour fournir les courants d'essai présumés désirés du Tableau 6. Le temps de réponse de la fonction de limitation de courant doit être enregistré à chaque courant d'essai. Le temps de réponse est le temps entre l'application de la puissance et le moment où le courant d'essai tombe à 10 % en dessous du courant assigné. Dans le cas où le courant d'essai présumé excède la capacité maximale en courant du ou des composants de limitation de courant, alors, le courant d'essai le plus élevé doit être égal à la capacité en courant maximale du ou des composants de limitation de courant.

Tableau 6 – Courants d'essai pour le temps de réponse

Courants d'essai A
1,5 × courant assigné
2,1 × courant assigné
2,75 × courant assigné
4,0 × courant assigné
10,0 × courant assigné

6.2.2.4 Temps de réamorçage en courant

Le parafoudre doit être connecté, comme indiqué à la figure 5. La tension de la source doit être inférieure à la tension maximale de coupure, spécifiée par le fabricant. La fréquence doit être de 0 (courant continu), 50 Hz ou 60 Hz.

Pour chaque configuration de parafoudre, le courant de charge initial doit être le courant assigné par ajustement des résistances R_s ou R_{s1} et R_{s2} . Le parafoudre doit être stabilisé au courant assigné. Après stabilisation, les résistances R_s , R_{s1} et R_{s2} doivent être réduites, de façon à ce que le courant de charge augmente jusqu'au niveau où la fonction de limitation en courant du parafoudre fonctionne. Cet état de courant d'essai doit être maintenu pendant 15 min, après que le courant a été réduit en dessous de 10 % du courant assigné.

Après cela, les résistances R_s ou R_{s1} et R_{s2} doivent être augmentées jusqu'à leur valeur initiale. Le temps qu'il faut pour que le courant de charge revienne à au moins 90 % du courant assigné doit être enregistré et doit être inférieur à 120 s. En fonction des applications, l'essai peut être fait à un courant inférieur au courant assigné, pour la fonction de limitation de courant auto-réamorçable. Pour les composants de limitation de courant réamorçables, le courant de la source doit être interrompu pour une durée inférieure à 120 s. Ensuite, la fonction de limitation de courant réamorçable doit conduire au courant assigné, pendant une période de 5 min, pour s'assurer que la fonction de limitation de courant est bien revenue à son état non activé.

6.2.2.5 Tension maximale de coupure

Le parafoudre doit être connecté comme indiqué à la figure 5. La tension d'essai doit être égale à la tension maximale de coupure, spécifiée par le fabricant. La fréquence doit être de 0 (courant continu), 50 Hz ou 60 Hz.

Les résistances R_s , R_{s1} et R_{s2} doivent être ajustées à une valeur qui donne un courant permettant au composant de limitation de courant d'agir. Cet état d'essai doit être maintenu pendant 1 h. Après 1 h, la fonction de limitation de courant du parafoudre doit satisfaire à 5.2.2.2, 5.2.2.3 et 5.2.2.4.

6.2.2.6 Essai de fonctionnement

Le parafoudre doit être connecté comme indiqué à la figure 5. La tension d'essai doit être égale à la tension maximale de coupure spécifiée par le fabricant. La fréquence doit être de 0 (courant continu), 50 Hz ou 60 Hz.

Pour chaque configuration de parafoudre, le courant de charge doit être établi (par ajustement des résistances R_s , R_{s1} et R_{s2}) à la valeur sélectionnée dans le tableau 7, en remplaçant provisoirement le parafoudre par un court-circuit. La valeur sélectionnée doit être suffisante pour que la fonction de limitation de courant agisse. Après l'insertion du parafoudre dans le circuit, appliquer le courant d'essai, jusqu'à ce qu'il soit réduit en dessous de 10 % du courant assigné.

Après chaque application, supprimer la puissance pendant au moins 2 min ou jusqu'à ce que la fonction de limitation de courant revienne à son état non activé. Ce cycle d'application de courant d'essai, suivi d'une période sans puissance, doit être répété le nombre de fois prévu au tableau 7.

Après le dernier cycle, le parafoudre doit satisfaire à 5.2.2.2, 5.2.2.3 et 5.2.2.4.

Tableau 7 – Valeurs préférentielles, pour le courant d'essai de fonctionnement

Courant A (c.c. ou eff.)	Nombre d'applications
0,5	60
1	10
3	5
5	5
10	5

6.2.2.7 Endurance en courant alternatif pour la fonction de limitation de courant

Le parafoudre doit être connecté, comme indiqué à la figure 6. Le courant de court-circuit alternatif doit être choisi parmi les valeurs du tableau 8. Appliquer le courant le nombre de fois spécifié, avec un temps suffisant entre les applications, pour éviter l'accumulation thermique dans le parafoudre en essai. La tension crête de la source alternative ne doit pas dépasser la tension maximale de coupure spécifiée par le fabricant. Avant l'essai et après la totalité des applications, le parafoudre doit satisfaire les exigences de 5.2.2.1, 5.2.2.2, 5.2.2.3.

Le courant doit être appliqué aux bornes appropriées, choisies dans le tableau 8. Le courant peut être appliqué entre les bornes X1 et X2, si demandé pour les parafoudres à trois ou à cinq bornes. Pour les essais sur les parafoudres à trois ou cinq bornes, chaque paire de bornes (X1 – C et X2 – C), du côté non protégé, peut être essayée en même temps ou séparément.

Tableau 8 – Valeurs préférentielles pour courants alternatifs

48-62 Hz Courants de court-circuit A_{eff}	Durée s	Nombres d'applications	Bornes à essayer
0,25	1	5	X1 – C X2 – C X1 – X2
0,5	1	5	
0,5	30	1	
1	1	5	
1	1	60	
2	1	5	
2,5	1	5	
5	1	5	

6.2.2.8 Endurance impulsionnelle pour la fonction de limitation de courant

Le parafoudre doit être connecté comme indiqué à la figure 7. Les tensions et courant impulsionnels sont choisis dans le tableau 9. Appliquer le courant impulsionnel le nombre de fois spécifié, avec un temps suffisant entre les impulsions, pour éviter un effet d'accumulation thermique dans l'appareil en essai. La moitié du nombre spécifié d'impulsions doit être appliqué avec une polarité, suivi par l'autre moitié, avec la polarité opposée. Ou bien, la moitié des échantillons peut être essayée avec une polarité et l'autre moitié avec la polarité opposée. Avant l'essai et après la totalité des applications, le parafoudre doit satisfaire les exigences de 5.2.2.1, 5.2.2.2 et 5.2.2.3.

Le courant impulsionnel doit être choisi dans le tableau 9 et appliqué aux bornes appropriées. Il peut être appliqué entre les bornes X1 et X2 pour les parafoudres à trois et cinq bornes. Pour les essais sur les parafoudres à trois et cinq bornes, chaque paire de bornes (X1 – C et X2 – C), du côté non protégé, peut être essayée en même temps, à la même polarité ou séparément.

Les fusibles de courant faible peuvent demander un niveau d'essai en I^2t en accord avec les valeurs du parafoudre. Les limiteurs de courant électroniques peuvent avoir besoin pour fonctionner d'un dispositif minimal de conduction à la sortie protégée (par exemple l'arc d'un éclateur à gaz). Si demandé, cela doit être ajouté au circuit d'essai.

Tableau 9 – Valeurs préférentielles de courants impulsionnels

Tensions en circuit ouvert	Courants de court-circuit	Nombre d'applications	Bornes à essayer
1 kV	100 A, 10/1 000	30	X1 – C X2 – C X1 – X2
1,5 kV, 10/700	37,5 A, 5/300	10	
Tension maximale d'interruption	25 A, 10/1 000	30	
Tension maximale d'interruption	Figure 1/K17 de UIT-T K17	10	
4 kV, 1,2/50	2 kA, 8/20	10	

6.2.3 Essais de transmission

6.2.3.1 Capacité

La capacité d'un parafoudre est mesurée entre les bornes spécifiées avec un générateur de 1 V eff. à 1 MHz. Une paire de bornes est mesurée à la fois; toutes les bornes non impliquées dans la mesure doivent être connectées entre elles et à la masse du générateur. Aucun courant continu de polarisation ne doit être appliqué. Il doit être noté que la capacité de certains parafoudres dépend de la tension de polarisation. Dans certaines applications cette tension peut apparaître seulement sur un fil de la paire de communication engendrant un déséquilibre des capacités significatif.

6.2.3.2 Perte d'insertion (ou affaiblissement)

La perte d'insertion est mesurée en décibels en utilisant des fils de 1 m de long maximum, avec l'impédance caractéristique appropriée. La mesure est effectuée en utilisant le circuit de la figure 8 avec un court-circuit à la place du parafoudre. Celui-ci est ensuite introduit et la mesure en décibels est effectuée. La perte d'insertion est la différence vectorielle entre les deux mesures. Le tableau 10 donne les impédances caractéristiques, les plages de fréquences et les types de câbles. Le niveau d'essai recommandé est de –10 dBm.

La perte de mesure de l'ensemble des symétriseurs et fils d'essai de la figure 8 ne doit pas dépasser 3 dB, dans la plage de fréquences de transmission. La perte d'insertion doit être mesurée et enregistrée dans la plage de fréquences de transmission, pour laquelle le parafoudre est prévu d'être utilisé.

Tableau 10 – Paramètres normalisés pour la Figure 8

Domaine de fréquences	Impédances caractéristiques Z_0 Ω	Types de câbles
300 Hz à 4 kHz	600	Paire torsadée
4 kHz à 250 MHz	100, 120 ou 150	Paire torsadée
≤ 1 GHz	50 ou 75	Coaxial
> 1 GHz	50	Coaxial

6.2.3.3 Facteur d'adaptation

Le facteur d'adaptation est mesuré en décibels en utilisant des fils de 1 m de long maximum, avec l'impédance caractéristique appropriée. La mesure est effectuée en utilisant le circuit de la figure 9 avec un court-circuit à la place du parafoudre. Celui-ci est ensuite introduit et la mesure en décibels est effectuée. Le tableau 10 donne les impédances caractéristiques, les plages de fréquences et les types de câbles. Le niveau d'essai recommandé est de –10 dBm.

Un signal est appliqué au parafoudre et les signaux réfléchis, dus aux discontinuités d'impédance, sont mesurés à la même borne que celle où est appliqué le signal. Le facteur d'adaptation doit être mesuré et enregistré dans la plage de fréquences de transmission, pour laquelle le parafoudre est prévu d'être utilisé.

6.2.3.4 Affaiblissement de conversion longitudinal / Perte de conversion longitudinale (LCL)

L'affaiblissement de conversion longitudinal tel que calculé dans l'équation ci-dessous est équivalent à la perte de conversion longitudinale (LCL) telle que décrite dans l'UIT-T O.9 (03.1999).

La Figure 10 montre les connexions pour l'essai d'affaiblissement de conversion longitudinal, pour les parafoudres à trois, quatre et cinq bornes. Pour les parafoudres à quatre et cinq bornes, l'essai doit être effectué deux fois: interrupteur S1 fermé et ouvert. L'affaiblissement de conversion longitudinal est le rapport de la tension longitudinale appliquée V_s à la tension résultante V_m du parafoudre en essai exprimée en décibels, comme suit:

$$\text{Affaiblissement de conversion longitudinal (ACL) (dB)} = 20 \log (V_s / V_m)$$

où les signaux V_s et V_m ont la même fréquence.

En raison de la plus grande précision aux fréquences plus élevées, on peut utiliser un transformateur symétriseur pour améliorer le parafoudre au lieu des résistances ohmiques montrées dans le réglage d'essai de la Figure 10. La configuration du pont d'essai, avec une impédance transversale Z_1 et une impédance longitudinale Z_2 , ne représente pas la totalité des conditions observées dans la pratique. Les valeurs et les limites des caractéristiques de transmission prévues telles que le domaine de fréquences et les tensions, les considérations particulières pour les impédances de terminaison et les fréquences de mesure à utiliser sont indiquées dans les recommandations de l'UIT-T appropriée. Un exemple des valeurs et des impédances pour les différents domaines de fréquence jusqu'à 190 kHz est indiqué dans le Tableau 11. Sauf spécification contraire, l'essai peut être réalisé avec des fréquences croissantes, par exemple à 200 Hz, 500 Hz, 1 000 Hz et 4 000 Hz pour les applications analogiques, ou à 5 kHz, 60 kHz, 160 kHz et 190 kHz pour les applications IDSN numériques. Il convient que l'affaiblissement de conversion longitudinale inhérent aux dispositifs de mesure soit de 20 dB supérieur au réglage limite du parafoudre. Si l'ACL du parafoudre est affecté par la tension continue de polarisation, alors, il convient que l'essai soit effectué en appliquant la tension continue de polarisation appropriée à chaque borne du parafoudre. Les exigences pour les dispositifs de mesure sont données dans la Recommandation UIT-T O.9.

Tableau 11 – Valeurs d'impédances pour l'essai d'affaiblissement de conversion longitudinale

f kHz	Service	$Z1^a$ Ω	$Z2^b$ Ω
≤ 4	Analogique	300	150
≤ 190	ISDN	55 ou 67,5	20-40
Jusqu'à 30 MHz	ADSL2+; VDSL	67,5	20-40
^a La différence réelle entre le dispositif d'essai et l'ACL réel est assez indépendante de l'impédance d'entrée de la borne et, de ce fait, cette analyse s'applique à toutes les impédances d'entrée virtuelles raisonnables. Concernant les informations pour spécifier $Z1$ et $Z2$, se reporter à la norme de produit appropriée. ^b Il convient que $Z2$ soit égale à la moitié de $Z1$.			

Quand l'ACL est dépendant de la résistance série introduite par le parafoudre, la conversion peut être spécifiée comme la valeur ohmique maximale ou le pourcentage de différence entre les résistances séries.

6.2.3.5 Taux d'erreur binaire (TEB)

Le taux d'erreur binaire (TEB, voir Figure 11), résultat de la division du nombre de bits en erreur par le nombre total de bits est un flux, peut être utilisé pour caractériser le fonctionnement d'un produit de télécommunications ou de stockage de données. Par exemple, 2,5 bits en erreur sur les 100 000 bits transmis correspondent à 2,5 sur 10^5 soit $2,5 \times 10^{-5}$. Un exemple de durées d'essai pour des vitesses de transmission différentes est indiqué au Tableau 12.

Les essais de TEB sont réalisés afin de mesurer les modifications engendrées, le cas échéant, par l'insertion d'un parafoudre dans le circuit. Les essais de TEB sont décrits dans la série UIT-T – série G (par exemple, pour l'ISDN l'UIT-T G.821, pour l'ADSL2 l'UIT-T G.992.3 et le VDSL ITU-T G.993.1, etc.)

Tableau 12 – Durée pour l'essai de TEB

Profil binaire pseudo-aléatoire (R)	Durée
$R < 64$ kbits / s	1 h
64 kbits / s $\leq R < 1\,554$ kbits / s	30 min
$R \geq 1\,554$ kbits / s	10 min

6.2.3.6 Paradiaphonie

La diaphonie est mesurée par de courts fils d'essai équilibrés, aboutissant au parafoudre, conformément à la figure 12. Un signal équilibré d'entrée est appliqué à la ligne perturbée du parafoudre, pendant que le signal induit sur la ligne perturbée est mesuré à l'extrémité la plus proche des fils d'essai. Le signal d'essai recommandé est de -10 dBm.

La perte totale mesurée sur les symétriseurs et les fils d'essai, ne doit pas dépasser 3 dB, dans la plage de fréquences de transmission. La paradiaphonie doit être mesurée et enregistrée, dans la plage de fréquences de transmission, pour laquelle le parafoudre est conçu.

6.3 Essais mécaniques

6.3.1 Bornes et connecteurs

La vérification des bornes incorporées et leur conformité est obtenue par le respect des exigences de 5.3.1.

6.3.1.1 Procédure générale d'essai

Le parafoudre est monté selon les recommandations du fabricant et est protégé contre tout échauffement ou refroidissement extérieur.

Sauf spécification contraire, les bornes du parafoudre doivent être câblées avec des conducteurs dans les conditions les plus sévères (c'est-à-dire avec des sections maximale et minimale) en accord avec

- le tableau 13, pour les parafoudres qui ont à la fois des bornes de ligne et des bornes de ligne protégée,
- les instructions du fabricant, pour les autres parafoudres.

Le parafoudre en essai doit être fixé sur un tableau de bois peint en noir mat d'environ 20 mm d'épaisseur. La méthode de fixation doit se conformer aux prescriptions relatives aux moyens de montage recommandés par le fabricant. Lors de cet essai, l'entretien et le démontage des échantillons ne sont pas autorisés.

6.3.1.2 Bornes à vis

La conformité est vérifiée par inspection et, pour les vis utilisées à la connexion du parafoudre, par l'essai suivant:

Les vis sont serrées et desserrées:

- dix fois pour les vis s'engageant dans un filetage en matière isolante,
- cinq fois, dans tous les autres cas.

Les vis ou écrous s'engageant dans un filetage en matière isolante sont complètement retirés et réinsérés chaque fois. L'essai est réalisé au moyen d'un tournevis ou d'une clef d'essai appropriés, en appliquant un couple, comme indiqué par le fabricant. Les vis ne doivent pas être serrées par à-coups. Le conducteur est enlevé à chaque fois que la vis est desserrée.

Pendant l'essai, les connexions vissées ne doivent pas se desserrer et aucun endommagement, tel que la cassure des vis ou le dommage des fentes de têtes de vis, des filetages, des rondelles ou des étriers, au point d'empêcher l'usage ultérieur du parafoudre, ne doit être observé.

De plus, les couvercles et enveloppes ne doivent pas être endommagés.

Tableau 13 – Sections connectables de conducteurs en cuivre, pour des bornes à vis ou sans vis

Courant assigné maximal des parafoudres A	Domaines de sections nominales à serrer	
	ISO – mm ²	GTJ – Borne
Inférieur ou égal à 1	0,1 à 1	26 à 18
Supérieur à 1 et jusqu'à 13 inclus	1 à 2,5	18 à 14
Supérieur à 13 et jusqu'à 16 inclus	1 à 4	18 à 12

6.3.1.3 Bornes sans vis

La conformité est vérifiée par les essais suivants.

Les bornes sont équipées de nouveaux conducteurs du type et de sections minimale et maximale définies dans le tableau 13 pour les parafoudres à deux ports ou, selon la déclaration du fabricant pour les parafoudres à un port.

Chaque conducteur est ensuite soumis à une valeur de traction indiquée dans le tableau 14. La traction est exercée sans secousses pendant 1 min dans la direction des axes du conducteur.

Lors de cet essai, le conducteur ne doit pas s'échapper de la borne et il ne doit y avoir aucun indice de dommage.

Tableau 14 – Forces de traction (bornes sans vis)

Section mm ²	0,5	0,75	1,0	1,5	2,5	4
Force de traction N	30	30	35	40	50	60

6.3.1.4 Connexions à perçage d'isolant

6.3.1.4.1 Essai de traction pour des bornes de parafoudres à monoconducteurs

La conformité est vérifiée par les essais suivants:

Les bornes sont équipées de nouveaux conducteurs en cuivre de section minimale ou maximale définie en 6.3.1.1, rigides ou câblés, selon le cas le plus défavorable. Les vis éventuelles sont serrées comme indiqué par le fabricant.

Les conducteurs sont connectés et déconnectés cinq fois, de nouveaux conducteurs étant utilisés à chaque fois. Après chaque connexion, les conducteurs sont soumis à une traction sans secousses pendant 1 min dans l'axe du conducteur selon la valeur donnée dans le tableau 14.

Lors de cet essai, le conducteur ne doit pas s'échapper du parafoudre et aucun indice de dommage ne doit être relevé.

6.3.1.4.2 Essai de traction pour des parafoudres conçus pour des câbles multiconducteurs ou des cordons

L'essai de traction sur des bornes de parafoudres conçus pour des câbles multiconducteurs ou des cordons est effectué selon 6.3.1.4.1, sauf que la force de traction est exercée sur l'ensemble du câble multiconducteur ou du cordon plutôt que sur l'âme seule.

La force de traction est calculée selon la formule suivante:

$$F = F(x) \sqrt{n}$$

où

F est la force totale à appliquer;

n est le nombre de brins;

$F(x)$ est la force sur un brin selon la section du conducteur (voir tableau 14).

Lors de l'essai, le câble ou cordon ne doit pas s'échapper du parafoudre.