

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Communication networks and systems for power utility automation –
Part 7-3: Basic communication structure – Common data classes**

**Réseaux et systèmes de communication pour l'automatisation des systèmes
électriques –
Partie 7-3: Structure de communication de base – Classes de données
communes**

IECNORM.COM : Click to view the full PDF of IEC 61850-7-3:2010



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Communication networks and systems for power utility automation –
Part 7-3: Basic communication structure – Common data classes**

**Réseaux et systèmes de communication pour l'automatisation des systèmes
électriques –
Partie 7-3: Structure de communication de base – Classes de données
communes**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

CONTENTS

FOREWORD.....	6
INTRODUCTION	8
1 Scope.....	9
2 Normative references.....	9
3 Terms and definitions.....	10
4 Abbreviated terms	10
5 Conditions for attribute inclusion	10
6 Constructed attribute classes.....	11
6.1 General.....	11
6.2 Quality	11
6.2.1 Overview.....	11
6.2.2 Validity.....	12
6.2.3 Detail quality	13
6.2.4 Source.....	14
6.2.5 Test.....	14
6.2.6 Frozen by operator.....	14
6.2.7 Quality in the client server context	15
6.2.8 Relation between quality identifiers.....	16
6.3 Analogue value.....	18
6.4 Configuration of analogue value	18
6.5 Range configuration	19
6.6 Step position with transient indication.....	19
6.7 Pulse configuration.....	20
6.8 Originator.....	20
6.9 Unit definition	21
6.10 Vector definition.....	21
6.11 Point definition.....	22
6.12 CtlModels definition.....	22
6.13 SboClasses definition.....	22
6.14 Cell.....	22
6.15 CalendarTime definition	23
7 Common data class specifications.....	25
7.1 General.....	25
7.2 Name spaces.....	25
7.3 Common data class specifications for status information	25
7.3.1 Application of services.....	25
7.3.2 Single point status (SPS)	26
7.3.3 Double point status (DPS).....	27
7.3.4 Integer status (INS).....	27
7.3.5 Enumerated status (ENS).....	28
7.3.6 Protection activation information (ACT)	28
7.3.7 Directional protection activation information (ACD)	29
7.3.8 Security violation counting (SEC).....	30
7.3.9 Binary counter reading (BCR).....	30
7.3.10 Histogram (HST)	31

7.3.11	Visible string status (VSS).....	31
7.4	Common data class specifications for measurand information.....	32
7.4.1	Application of services.....	32
7.4.2	Measured value (MV)	33
7.4.3	Complex measured value (CMV).....	34
7.4.4	Sampled value (SAV)	35
7.4.5	Phase to ground/neutral related measured values of a three-phase system (WYE).....	36
7.4.6	Phase to phase related measured values of a three-phase system (DEL).....	37
7.4.7	Sequence (SEQ)	38
7.4.8	Harmonic value (HMV).....	39
7.4.9	Harmonic value for WYE (HWYE)	40
7.4.10	Harmonic value for DEL (HDEL)	41
7.5	Common data class specifications for controls	42
7.5.1	Application of services.....	42
7.5.2	Controllable single point (SPC).....	43
7.5.3	Controllable double point (DPC)	44
7.5.4	Controllable integer status (INC).....	45
7.5.5	Controllable enumerated status (ENC)	46
7.5.6	Binary controlled step position information (BSC)	47
7.5.7	Integer controlled step position information (ISC)	48
7.5.8	Controllable analogue process value (APC)	49
7.5.9	Binary controlled analog process value (BAC).....	50
7.6	Common data class specifications for status settings.....	51
7.6.1	Application of services.....	51
7.6.2	Single point setting (SPG).....	51
7.6.3	Integer status setting (ING)	52
7.6.4	Enumerated status setting (ENG).....	52
7.6.5	Object reference setting (ORG)	53
7.6.6	Time setting group (TSG).....	53
7.6.7	Currency setting group (CUG)	54
7.6.8	Visible string setting (VSG)	54
7.7	Common data class specifications for analogue settings	55
7.7.1	Application of services.....	55
7.7.2	Analogue setting (ASG)	56
7.7.3	Setting curve (CURVE).....	57
7.7.4	Curve shape setting (CSG)	58
7.8	Common data class specifications for description information	59
7.8.1	Application of services.....	59
7.8.2	Device name plate (DPL)	60
7.8.3	Logical node name plate (LPL)	61
7.8.4	Curve shape description (CSD).....	62
8	Data attribute semantic	63
	Annex A (normative) Value range for units and multiplier	78
	Annex B (informative) Functional constraints	81
	Annex C (normative) Tracking of configuration revisions.....	83
	Annex D (normative) SCL enumerations	84

Bibliography.....	90
Figure 1 – Quality identifiers in a single client-server relationship.....	15
Figure 2 – Quality identifiers in a multiple client-server relationship.....	15
Figure 3 – Interaction of substitution and validity.....	17
Figure 4 – Configuration of command output pulse.....	20
Figure 5 – Cell definition.....	23
Figure 6 – Two-dimensional curve represented by CSG.....	58
Figure 7 – Two-dimensional shape created by multiple CSG.....	59
Table 1 – Conditions for presence of attributes.....	10
Table 2 – Quality.....	12
Table 3 – Relation of the detailed quality identifiers with invalid or questionable quality.....	13
Table 4 – Analogue value.....	18
Table 5 – Configuration of analogue value.....	18
Table 6 – Range configuration.....	19
Table 7 – Step position with transient indication.....	19
Table 8 – Pulse configuration.....	20
Table 9 – Originator.....	21
Table 10 – Values for orCat.....	21
Table 11 – Unit.....	21
Table 12 – Vector.....	21
Table 13 – Point.....	22
Table 14 – Cell.....	23
Table 15 – CalendarTime.....	24
Table 16 – Semantic interpretation of calendar time settings.....	24
Table 17 – Name space attributes.....	25
Table 18 – Basic status information template.....	26
Table 19 – Single point status common data class definition.....	26
Table 20 – Double point status common data class specification.....	27
Table 21 – Integer status common data class specification.....	27
Table 22 – Enumerated status common data class specification.....	28
Table 23 – Protection activation information common data class specification.....	28
Table 24 – Directional protection activation information common data class specification.....	29
Table 25 – Security violation counting common data class specification.....	30
Table 26 – Binary counter reading common data class specification.....	30
Table 27 – Histogram common data class specification.....	31
Table 28 – Visible string status common data class definition.....	31
Table 29 – Basic measurand information template.....	32
Table 30 – Measured value.....	33
Table 31 – Complex measured value.....	34
Table 32 – Sampled value.....	35

Table 33 – WYE	36
Table 34 – Delta	37
Table 35 – Sequence	38
Table 36 – Harmonic value	39
Table 37 – Harmonic values for WYE	40
Table 38 – Harmonic values for delta	41
Table 39 – Basic controllable status information template	42
Table 40 – Controllable single point	43
Table 41 – Controllable double point	44
Table 42 – Controllable integer status	45
Table 43 – Controllable enumerated status	46
Table 44 – Binary controlled step position information	47
Table 45 – Integer controlled step position information	48
Table 46 – Controllable analogue process value	49
Table 47 – Binary controlled analog process value	50
Table 48 – Basic status setting template	51
Table 49 – Single point setting	51
Table 50 – Integer status setting	52
Table 51 – Enumerated status setting	52
Table 52 – Object reference setting common data class specification	53
Table 53 – Time setting group common data class specification	53
Table 54 – Currency setting group common data class specification	54
Table 55 – Visible string setting group common data class specification	54
Table 56 – Basic analogue setting template	55
Table 57 – Analogue setting	56
Table 58 – Setting curve	57
Table 59 – Curve shape setting	58
Table 60 – Basic description information template	59
Table 61 – Device name plate common data class specification	60
Table 62 – Logical node name plate common data class specification	61
Table 63 – Curve shape description common data class specification	62
Table 64 – Semantics of data attributes and data	63
Table A.1 – SI units: base units	78
Table A.2 – SI units: derived units	78
Table A.3 – SI units: extended units	79
Table A.4 – SI units: industry specific units	79
Table A.5 – Multiplier	80
Table B.1 – Functional constraints	82

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 7-3: Basic communication structure – Common data classes

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61850-7-3 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

This second edition cancels and replaces the first edition, published in 2003.

Compared to the first edition, this second edition:

- defines new common data classes used for new standards defining object models for other domains based on IEC 61850 and for the representation of statistical and historical data,
- provides clarifications and corrections to the first edition of IEC 61850-7-3.

The text of this standard is based on the following documents:

FDIS	RVD
57/1087/FDIS	57/1095/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61850 series, published under the general title: *Communication networks and systems for power utility automation*, can be found on the IEC website.

The general title of the series was *Communication networks and systems in substations*. To address the extension of the scope of IEC 61850, it has been changed to *Communication networks and systems for power utility automation*.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This document is part of a set of specifications, which details layered substation communication architecture. This architecture has been chosen to provide abstract definitions of classes and services such that the specifications are independent of specific protocol stacks and objects. The mapping of these abstract classes and services to communication stacks is outside the scope of IEC 61850-7-x and may be found in IEC 61850-8-x (station bus) and IEC 61850-9-x (process bus).

IEC 61850-7-1 gives an overview of this communication architecture. This part of IEC 61850 defines constructed attributed classes and common data classes related to applications in the power system using IEC 61850 modeling concepts like substations, hydro power or distributed energy resources. These common data classes are used in IEC 61850-7-4 to define compatible dataObject classes. The SubDataObjects, DataAttributes or SubAttributes of the instances of dataObject are accessed using services defined in IEC 61850-7-2.

This part of IEC 61850 is used to specify the abstract common data class and constructed attribute class definitions. These abstract definitions are mapped into concrete object definitions that are to be used for a particular protocol (for example MMS, ISO 9506 series).

Note that there are common data classes used for service tracking, that are defined in IEC 61850-7-2.

IECNORM.COM : Click to view the full PDF of IEC 61850-7-3:2010

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 7-3: Basic communication structure – Common data classes

1 Scope

This part of IEC 61850 specifies constructed attribute classes and common data classes related to substation applications. In particular, it specifies:

- common data classes for status information,
- common data classes for measured information,
- common data classes for control,
- common data classes for status settings,
- common data classes for analogue settings and
- attribute types used in these common data classes.

This International Standard is applicable to the description of device models and functions of substations and feeder equipment.

This International Standard may also be applied, for example, to describe device models and functions for:

- substation to substation information exchange,
- substation to control centre information exchange,
- power plant to control centre information exchange,
- information exchange for distributed generation, or
- information exchange for metering.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC/TS 61850-2, *Communication networks and systems in substations – Part 2: Glossary*

IEC 61850-7-1, *Communication networks and systems for power utility automation – Part 7-1: Basic communication structure – Principles and models*¹

IEC 61850-7-2, *Communication networks and systems for power utility automation – Part 7-2: Basic information and communication structure – Abstract communication service interface (ACSI)*

IEC 61850-7-4, *Communication networks and systems for power utility automation – Part 7-4: Basic communication structure – Compatible logical node classes and data object classes*

¹ To be published.

IEEE C37.118:2005, *IEEE Standard for Synchrophasors for Power Systems*

ISO 4217, *Codes for the representation of currencies and funds*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC/TS 61850-2 and IEC 61850-7-2 apply.

4 Abbreviated terms

CDC	common data class
dchg	trigger option for data-change
dupd	trigger option for data-update
FC	functional constraint
qchg	trigger option for quality-change
TrgOp	trigger option

NOTE Abbreviations used for the identification of the common data classes and as names of the attributes are specified in the specific clauses of this document and are not repeated here.

5 Conditions for attribute inclusion

This clause lists general conditions that specify the presence of an attribute. Table 1 gives the conditions for presence of attributes.

Table 1 – Conditions for presence of attributes

Abbreviation	Condition
M	Attribute is mandatory. Attribute shall exist on any CDC type instance.
O	Attribute is optional. Attribute may or may not exist on any CDC type instance.
PICS_SUBST	Attribute is mandatory, if substitution is supported (for substitution, see IEC 61850-7-2), otherwise forbidden.
GC_1	At least one of the attributes shall be present for a given instance of DataObject / SubDataObject.
GC_2_n	All or none of the data attributes belonging to the same group (n) shall be present for a given instance of DataObject / SubDataObject.
GC_1_EXCL	At most one of the data objects shall be present for a given instance.
GC_CON_attr	A configuration data attribute shall only be present, if the (optional) specific data attribute (attr) to which this configuration relates is also present.
GC_2_XOR_n	All or none of a group (n) shall be present. Groups are exclusive, but one group shall be present.
AC_LN0_M	The attribute shall be present if the DataObject NamPit belongs to LLN0; otherwise it may be optional.
AC_LN0_EX	The attribute shall be present only if the DataObject NamPit belongs to LLN0 (applies to IdNs in CDC LPL only).
AC_DLD_M	The attribute shall be present, if LN name space of this LN deviates from the LN name space referenced by IdNs of the logical device in which this LN is contained (applies to InNs in CDC LPL only).
AC_DLN_M	The attribute shall be present, if the data name space of this data deviates from the data name space referenced by either InNs of the logical node in which the data is contained or, if there is no InNs, IdNs of the logical device in which the data is contained (applies to dataNs in all CDCs only).
AC_DLNDA_M	The attribute shall be present, if CDC name space of this data deviates from the CDC

Abbreviation	Condition
	name space referenced by either the dataNs of the data, the lnNs of the logical node in which the data is defined or ldNs of the logical device in which the data is contained (applies to cdcNs and cdcName in all CDCs only).
AC_SCAV	The presence of the configuration data attribute depends on the presence of <i>i</i> and <i>f</i> of the Analog Value of the data attribute to which this configuration attribute relates. For a given data object, that attribute 1) shall be present, if both <i>i</i> and <i>f</i> are present, 2) shall be optional if only <i>i</i> is present, and 3) is not required if only <i>f</i> is present. NOTE If only <i>i</i> is present in a device without floating point capabilities, the configuration parameter may be exchanged offline.
AC_ST	The attribute is mandatory, if the controllable status class supports status information.
AC_CO_O	If the controllable status class supports control, this attribute is available and an optional attribute.
AC_CO_SBO	If the controllable status class supports control and if the control model supports the values "sbo-with-normal-security" or "sbo-with-enhanced-security" or both, that attribute shall be mandatory.
AC_SG_M	The attribute is mandatory, if this data shall be member of a setting group.
AC_SG_O	The attribute is optional, if this data shall be member of a setting group.
AC_SG_C1	One of the attributes is mandatory, if this data shall be member of a setting group.
AC_NS_G_M	The attribute is mandatory, if this data shall be a setting outside a setting group.
AC_NS_G_O	The attribute is optional, if this data shall be a setting outside a setting group.
AC_NS_G_C1	One of the attributes is mandatory, if this data shall be a setting outside a setting group.
AC_RMS_M	The attribute is mandatory when the harmonics reference type is rms.
AC_CLC_O	The attribute shall be optional, when the calculation type (according to data ClcMth) for this LN is Peak fundamental or RMS fundamental. The attribute shall not be available, if ClcMth is TRUE RMS.

6 Constructed attribute classes

6.1 General

Constructed attribute classes are defined for the use in common data classes (CDC) in Clause 7.

IEC 61850-7-1 provides an overview of all IEC 61850-7 documents (IEC 61850-7-2, IEC 61850-7-3, and IEC 61850-7-4). IEC 61850-7-1 also describes the basic notation used in IEC 61850-7-3 and the description of the relations between the IEC 61850-7 documents.

NOTE The common ACSI type "TimeStamp" is specified in IEC 61850-7-2.

6.2 Quality

6.2.1 Overview

Quality type shall be as defined in Table 2.

Table 2 – Quality

Quality type definition			
Attribute name	Attribute type	Value/Value range	M/O/C
	PACKED LIST		
validity	CODED ENUM	good invalid reserved questionable	M
detailQual	PACKED LIST		M
overflow	BOOLEAN	DEFAULT FALSE	M
outOfRange	BOOLEAN	DEFAULT FALSE	M
badReference	BOOLEAN	DEFAULT FALSE	M
oscillatory	BOOLEAN	DEFAULT FALSE	M
failure	BOOLEAN	DEFAULT FALSE	M
oldData	BOOLEAN	DEFAULT FALSE	M
inconsistent	BOOLEAN	DEFAULT FALSE	M
inaccurate	BOOLEAN	DEFAULT FALSE	M
source	CODED ENUM	process substituted DEFAULT process	M
test	BOOLEAN	DEFAULT FALSE	M
operatorBlocked	BOOLEAN	DEFAULT FALSE	M

The DEFAULT value shall be applied, if the functionality of the related attribute is not supported. The mapping may specify to exclude the attribute from the message, if it is not supported or if the DEFAULT value applies.

Quality shall be an attribute that contains information on the quality of the information from the server. Quality of the data is also related to the mode of a logical node. Further details can be found in IEC 61850-7-4. The different quality identifiers are not independent. Basically, there are the following quality identifiers:

- validity;
- detail quality;
- source;
- test;
- frozen by operator.

6.2.2 Validity

Validity shall be good, questionable or invalid.

good: The value shall be marked good if no abnormal condition of the acquisition function or the information source is detected.

invalid: The value shall be marked invalid when an abnormal condition of the acquisition function or the information source (missing or non-operating updating devices) is detected. The value shall not be defined under this condition. The mark invalid shall be used to indicate to the client that the value may be incorrect and shall not be used.

EXAMPLE If an input unit detects an oscillation of one input, it will mark the related information as invalid.

questionable: The value shall be marked questionable if a supervision function detects an abnormal behaviour, however the value could still be valid. The client shall be responsible for determining whether or not values marked "questionable" should be used.

6.2.3 Detail quality

The reason for an invalid or questionable value of an attribute may be specified in more detail with further quality identifiers. If one of these identifiers is set then validity shall be set to invalid or questionable. Table 3 shows the relation of the detailed quality identifiers with invalid or questionable quality.

Table 3 – Relation of the detailed quality identifiers with invalid or questionable quality

detailQual	invalid	questionable
overflow	X	
outOfRange	X	X
badReference	X	X
oscillatory	X	X
failure	X	
OldData		X
inconsistent		X
inaccurate		X

overflow: this identifier shall indicate a quality issue that the value of the attribute to which the quality has been associated is beyond the capability of being represented properly (used for measurand information only).

EXAMPLE A measured value may exceed the range that may be represented by the selected data type, for example the data type is a 16-bit unsigned integer and the value exceeds 65 535.

outOfRange: this identifier shall indicate a quality issue that the attribute to which the quality has been associated is beyond a predefined range of values. The server shall decide if validity shall be set to invalid or questionable (used for measurand information only).

EXAMPLE A measured value may exceed a predefined range, however the selected data type can still represent the value, for example the data type is a 16-bit unsigned integer, the predefined range is 0 to 40 000, if the value is between 40 001 and 65 535 it is considered to be out of range.

badReference: this identifier shall indicate that the value may not be a correct value due to a reference being out of calibration. The server shall decide if validity shall be set to invalid or questionable (used for measurand information and binary counter information only).

oscillatory: to prevent overloading of event driven communication channels, it is desirable to detect and suppress oscillating (fast changing) binary inputs. If a signal changes in a defined time (t_{osc}) twice in the same direction (from 0 to 1 or from 1 to 0) then it shall be defined as an oscillation and the detail quality identifier "oscillatory" shall be set. If a configured number of transient changes is detected, they shall be suppressed. In this time, the validity status "questionable" shall be set. If the signal is still in the oscillating state after the defined number of changes, the value shall be left in the state it was in when the oscillatory flag was set. In this case, the validity status "questionable" shall be reset and "invalid" shall be set as long as the signal is oscillating. If the configuration is such that all transient changes should be suppressed, the validity status "invalid" shall be set immediately in addition to the detail quality identifier "oscillatory" (used for status information only).

failure: this identifier shall indicate that a supervision function has detected an internal or external failure.

oldData: a value shall be oldData if an update is not made during a specific time interval. The value may be an old value that may have changed in the meantime. This specific time interval may be defined by an allowed-age attribute.

NOTE "Fail silent" errors, where the equipment stops sending data, will cause an oldData condition. In this case, the last received information was correct.

inconsistent: this identifier shall indicate that an evaluation function has detected an inconsistency.

inaccurate: this identifier shall indicate that the value does not meet the stated accuracy of the source.

EXAMPLE The measured value of power factor may be noisy (inaccurate) when the current is very small.

6.2.4 Source

Source shall give information related to the origin of a value. The value may be acquired from the process or be a substituted value.

process: the value is provided by an input function from the process I/O or is calculated from some application function.

substituted: the value is provided by input of an operator or by an automatic source.

NOTE 1 Substitution may be done locally or via the communication services. In the second case, specific attributes with a FC SV are used.

NOTE 2 There are various means to clear a substitution. As an example, a substitution that was done following an invalid condition may be cleared automatically if the invalid condition is cleared. However, this is a local issue and therefore not within the scope of this standard.

6.2.5 Test

Test shall be an additional identifier that may be used to classify a value being a test value and not to be used for operational purposes. The processing of the test quality in the client shall be as described in IEC 61850-7-4. The bit shall be completely independent from the other bits within the quality descriptor.

6.2.6 Frozen by operator


operatorBlocked: this identifier shall be set if further update of the value has been blocked by an operator. The value shall be the information that was acquired before blocking. If this identifier is set, then the identifier oldData of detailQual shall also be set.

The operator shall use the data attribute blkEna to block the update of the value.

NOTE Both an operator as well as an automatic function may freeze communication updating as well as input updating. In both cases, detailQual.oldData will be set. If the blocking is done by an operator, then the identifier operatorBlocked is set additionally. In that case, an operator activity is required to clear the condition.

EXAMPLE An operator may freeze the update of an input, to save the old value before the auxiliary supply is switched off.

6.2.7 Quality in the client server context




IEC 808/03

Figure 1 – Quality identifiers in a single client-server relationship

The quality identifier shall reflect the quality of the information in the server, as it is supplied to the client. Figure 1 shows potential sources that may influence the quality in a single client-server relationship. "Information source" is the (hardwired) connection of the process information to the system. The information may be invalid or questionable as indicated in Figure 1. Further abnormal behaviour of the information source may be detected by the input unit. In that case, the input unit may keep the old data and flag it accordingly.

In a multiple client-server relationship, as shown in Figure 2, information may be acquired over a communication link (with client B). If that communication link is broken, client B will detect that error situation and qualify the information as questionable/old data.



IEC 809/03

Figure 2 – Quality identifiers in a multiple client-server relationship

In the multiple client-server relationship, the quality of the data received from server A shall reflect both the quality of the server B (acquired with client B) as well as its own quality. Therefore, handling of prioritisation of quality from different levels may require further specification beyond that included in this standard. For the identifier validity, the value invalid shall dominate over the value questionable, since this is the worst case. For the identifier source, the higher level of the multiple client-server relationship shall dominate over the lower level.

EXAMPLE Let A be the higher level and B the lower level. The quality from server B is invalid. If now the communication fails (questionable, oldData) between server B and client B, the quality will remain invalid and not become questionable, since the last information was not correct. Server A therefore will report the information as invalid.

6.2.8 Relation between quality identifiers

Validity and source have a prioritized relation. If source is in the “process” state, then validity shall determine the quality of the origin value. If source is in the “substitute” state, then validity shall be overruled by the definition of the substituted value. This is an important feature, since substitution is used to replace invalid values with substituted values that may be used by the client such as good values.

EXAMPLE 1 If both questionable and substituted are set, this means that the substituted value is questionable. This may happen if, in a hierarchical configuration, a substitution is performed at the lowest level and the communication fails on a higher level.

EXAMPLE 2 If an invalid value is substituted, the invalid field will be cleared and the substituted field will be set to indicate the substitution.

The quality identifier operatorBlocked is independent of the other quality identifiers.

EXAMPLE 3 An oscillating input may cause the invalid field to be set. Due to the continuing changes in the value, many reports are generated, loading the communication network. An operator may block the update of the input. In this case, the field operatorBlocked will also be set.

An example for the interaction between the quality identifiers and the impact of multiple client-server relation is shown in Figure 3. In this example, it is assumed that a bay level device acts as a client of the process level server and as a server to the station level client.


NOTE This is one example of a multiple client-server relationship; other multiple client-server relationships may exist, but the behaviour will not change.

In case A, the input is blocked, the quality of the information is marked as questionable and oldData.

In case B, a substitution is done at process level. Now, the quality of the information to the next higher level (the bay level) is marked as substituted (but good).

In case C, the communication between process and bay level fails. Between bay level and station level, the information is still marked as substituted. In addition, questionable and oldData is set to indicate that the (substituted) information may be old.

In case D, a new substitution is made at bay level. Now the quality of the information to the next higher level is marked as substituted (and good) and is independent from the first substitution.



IEC 2550/10

Key

CL client
Se server

Figure 3 – Interaction of substitution and validity

6.3 Analogue value

Analogue value type shall be as defined in Table 4.

Table 4 – Analogue value

AnalogueValue type definition			
Attribute name	Attribute type	Value/Value range	M/O/C
<i>i</i>	INT32	integer value	GC_1
<i>f</i>	FLOAT32	floating point value	GC_1

Analogue values may be represented as a basic type INTEGER (attribute *i*) or as FLOATING POINT (attribute *f*). At least one of the attributes shall be used. If both *i* and *f* exist, the application in the server shall insure that both values remain consistent. The latest value set by the communication service shall be used to update the other value. As an example, if xxx.*f* is written, the application shall update xxx.*i* accordingly.

The measured values represent primary process values.

i: The value of *i* shall be an integer representation of the measured value. The formula to convert between *i* and the process value (*pVal*) shall be:

$$pVal = (i \times scaleFactor) + offset$$

It shall be true within acceptable error when *i*, scaleFactor, offset and *f* are all present.

f: The value of *f* shall be the floating point representation of the measured value. The formula to convert between *f* and the process value shall be:

$$pVal = f \times 10^{units.multiplier}$$

NOTE The reason for both integer and floating point representation is so that IEDs without FLOATING POINT capabilities are enabled to support analogue values. In this case, the scaleFactor and offset may be exchanged offline between clients and servers.

6.4 Configuration of analogue value

Configuration of analogue value type shall be as defined in Table 5.

Table 5 – Configuration of analogue value

ScaledValueConfig type definition			
Attribute name	Attribute type	Value/value range	M/O/C
scaleFactor	FLOAT32		M
offset	FLOAT32		M

This constructed attribute class shall be used to configure the INTEGER value representation of the analogue value. The formula for conversion between integer and floating point value is given in 6.3.

scaleFactor: the value of scaleFactor shall be the scaling factor.

offset: the value of offset shall be the offset.

NOTE If a server does not support transmission of FLOAT32 values, the client may retrieve these values from the SCL file.

6.5 Range configuration

Range configuration type is used to configure the limits that define the range of a measured value and shall be as defined in Table 6.

Table 6 – Range configuration

RangeConfig type definition			
Attribute name	Attribute type	Value/Value range	M/O/C
hhLim	AnalogueValue		M
hLim	AnalogueValue		M
lLim	AnalogueValue		M
lLim	AnalogueValue		M
min	AnalogueValue		M
max	AnalogueValue		M
limDb	INT32U	0 ... 100 000	O

hhLim, hLim, lLim, lLim: These attributes shall be the configuration parameters used in the context with the range attribute as defined in Clause 8.

min: the min (minimum) attribute shall represent the minimum process measurement for which values of *i* or *f* are considered within process limits. If the value is lower, q shall be set accordingly (validity = questionable, detailQual = outOfRange).

max: the max (maximum) attribute shall represent the maximum process measurement for which values of *i* or *f* are considered within process limits. If the value is higher, q shall be set accordingly (validity = questionable, detailQual = outOfRange).

limDb: The value is used to introduce a hysteresis in the calculation of range. Range is immediately set to the higher value, when a high limit has been crossed (to the lower value, when a low limit has been crossed). However, range is only set back to the lower value, when the value of the high limit minus limDb has been crossed (to the higher value when the value of the low limit plus limDb has been crossed). The value shall represent the percentage between max and min in units of 0,001 %. If limDb is not present, no hysteresis calculation is made.

6.6 Step position with transient indication

Step position with transient indication type is for example used to indicate the position of tap changers and shall be as defined in Table 7.

Table 7 – Step position with transient indication

ValWithTrans type definition			
Attribute name	Attribute type	Value/Value range	M/O/C
posVal	INT8	–64 ... 63	M
transInd	BOOLEAN		O

The posVal shall contain the step position, the transInd shall indicate that the equipment is in a transient state.

6.7 Pulse configuration


Pulse configuration type is used to configure the output pulse generated with a command and shall be as defined in Table 8.

Table 8 – Pulse configuration

PulseConfig type definition			
Attribute name	Attribute type	Value/Value range	M/O/C
cmdQual	ENUMERATED	pulse persistent	M
onDur	INT32U		M
offDur	INT32U		M
numPls	INT32U		M

cmdQual: this identifier shall define if the control output is a pulse output or if it is a persistent output. If it is set to pulse, then the duration of the pulse shall be defined with the identifiers onDur, offDur and numPls. If it is set to persistent, the output stays in the state indicated in the operate service.

onDur, offDur, numPls: as the result of receiving an Operate service, a pulsed output may be generated to the on or off input of a switching device. The shape of this output is defined by onDur, offDur and numPls according to Figure 4. NumPls shall specify the number of pulses that are generated. onDur shall specify the on duration of the pulse, offDur specifies the duration between two pulses. onDur and offDur shall be specified in ms; a value of 0 ms shall specify that the duration is locally defined.



IEC 811/03

Figure 4 – Configuration of command output pulse

6.8 Originator

Originator type shall be as defined in Table 9.

Table 9 – Originator

Originator type definition			
Attribute name	Attribute type	Value/Value range	M/O/C
orCat	ENUMERATED	not-supported bay-control station-control remote-control automatic-bay automatic-station automatic-remote maintenance process	M
orIdent	OCTET STRING64		M

orCat: The originator category shall specify the category of the originator. An explanation of the values for orCat is given in Table 10.

Table 10 – Values for orCat

Value	Explanation
not-supported	That value shall not be used
bay-control	Control operation issued from an operator using a client located at bay level
station-control	Control operation issued from an operator using a client located at station level
remote-control	Control operation from a remote operator outside the substation (for example network control center)
automatic-bay	Control operation issued from an automatic function at bay level
automatic-station	Control operation issued from an automatic function at station level
automatic-remote	Control operation issued from a automatic function outside of the substation
maintenance	Control operation issued from a maintenance/service tool
process	Status change occurred without control action (for example external trip of a circuit breaker or failure inside the breaker)

orIdent: the originator identification shall show the identification of the originator. The value of NULL shall be reserved to indicate that the originator of a particular action is not known.

6.9 Unit definition

Unit type shall be as defined in Table 11.

Table 11 – Unit

Unit type definition			
Attribute name	Attribute type	Value/Value range	M/O/C
SIUnit	ENUMERATED	According to Tables A.1 to A.4 in Annex A	M
multiplier	ENUMERATED	According to Table A.5 in Annex A	O

SIUnit: shall define the SI unit according to Annex A.

multiplier: shall define the multiplier value according to Annex A. The default value is 0 (i.e. multiplier = 1).

6.10 Vector definition

Vector type shall be as defined in Table 12.

Table 12 – Vector

Vector type definition			
Attribute name	Attribute type	Value/Value range	M/O/C

Vector type definition			
Attribute name	Attribute type	Value/Value range	M/O/C
mag	AnalogueValue		M
ang	AnalogueValue	$-180 < n \leq +180$	AC_CLC_O

mag: the magnitude of the complex value.

ang: the angle of the complex value. The SIUnit shall be degrees and the unit multiplier is 1. The angle reference is defined in the context where the Vector type is used.

6.11 Point definition

Point type shall be as defined in Table 13 and is used to represent points in a two- or three-dimensional coordinates system.

Table 13 – Point

Point type definition			
Attribute name	Attribute type	Value/Value range	M/O/C
xVal	FLOAT32		M
yVal	FLOAT32		M
zVal	FLOAT32		O

xVal: the x value of a point.

yVal: the y value of a point.

zVal: the z value of a point.

6.12 CtlModels definition

CtlModels type is defined as follows:

ENUMERATED (status-only | direct-with-normal-security | sbo-with-normal-security | direct-with-enhanced-security | sbo-with-enhanced-security)

Details are provided in Clause 8.

6.13 SboClasses definition

SboClasses type is defined as follows:

ENUMERATED (operate-once | operate-many)

Details are provided in Clause 8.

6.14 Cell

Cell type is used to define a rectangle area in a two-dimensional environment and shall be defined as in Table 14. Cell type can as well be used to describe a range within a one-dimensional environment. For details, see Figure 5.

Table 14 – Cell


Cell type definition			
Attribute name	Attribute type	Value/Value range	M/O/C
xStart	FLOAT32		M
xEnd	FLOAT32		O
yStart	FLOAT32		O
yEnd	FLOAT32		O

xStart: the x value of the lower left corner of the square.

xEnd: the x value of the upper right corner of the square. That component shall not be present to indicate infinity in the direction of the x axis.

yStart: The y value of the lower left corner of the square. That component shall not be present, if only a one-dimensional range needs to be described.

yEnd: The y value of the upper right corner of the square. That component shall not be present, if only a one-dimensional range needs to be described or to indicate infinity in the direction of the y axis.



IEC 2551/10

Figure 5 – Cell definition

6.15 CalendarTime definition

CalendarTime type is used to define a time setting in reference to the calendar and shall be as defined in Table 15. That constructed attribute class allows the specification of times like the last day of the month or the second Sunday in March at 03.00h.

Table 15 – CalendarTime

CalendarTime type definition			
Attribute name	Attribute type	Value/Value range	M/O/C
occ	INT16U		M
occType	ENUMERATED	Time, WeekDay, WeekOfYear, DayOfMonth, DayOfYear	M
occPer	ENUMERATED	Hour, Day, Week, Month, Year	M
weekDay	ENUMERATED	reserved, Monday, Tuesday, ... Sunday	M
month	ENUMERATED	reserved, January, February, ... December	M
day	INT8U	1..31	M
hr	INT8U	0..23	M
mn	INT8U	0..59	M

occ: Occurrence of a calendar element. The value 0 is used to indicate the last. For the identification of week numbers, week number 01 shall always be the first week in January (according to definition of UN / CEFAC).

occType: the kind of calendar element that is used for the occurrence.

occPer: the repetition period of a calendar-based time setting.

weekDay: the weekday.

month: the month.

day: the day.

hr: the hour.

mn: the minute.

The semantic interpretation of the attributes is given in Table 16.

Table 16 – Semantic interpretation of calendar time settings

occPer	occType	
Hour	Time	At <mn> minute every hour
Day	Time	At <hr>, <mn> every day
Week	WeekDay	At <weekDay>, <hr>, <mn> every week
Month	WeekDay	At <occ>, <weekDay>, <hr>, <mn> every month
Month	DayOfMonth	At <occ>, <hr>, <mn> every month
Year	Time	At <month>, <day>, <hr>, <mn> every year
Year	WeekDay	At <occ>, <weekDay>, <month>, <hr>, <mn> every year
Year	WeekOfYear	At week <occ>, <weekDay>, <hr>, <mn>
Year	DayOfYear	At <occ>, <hr>, <mn> every year

7 Common data class specifications

7.1 General

Common data classes are defined for use in IEC 61850-7-4. Common data classes are composed of constructed attribute classes defined in Clause 6 of this document or of types defined in IEC 61850-7-2 or of common data classes defined in this clause. IEC 61850-7-1 provides the basic notation used in this clause.

The common data classes define the relation between their attributes and the functional constraint as well as the possible trigger options. If two trigger options are stated, then a concrete implementation shall select one of them. The selection is based on the purpose of the data object of this common data class and is fix for the data object within a LN class.

The semantic of the SubDataObjects and DataAttributes is defined in Clause 8.

7.2 Name spaces

Name spaces are defined to identify extensions to the present definitions of IEC 61850-7-3 and IEC 61850-7-4. The name space is based on a hierarchical structure from logical node zero LLN0 at the top down to the common data class CDC. See Table 17.

Table 17 – Name space attributes

Attribute	Application	Scope of the standard specified with the attribute
IdNs	The DataAttribute IdNs shall be included in the logical node LLN0 .	LN class definition (CDC definition by reference)
InNs	The DataAttribute InNs shall be included if the name space of the LN deviates from the name space of the logical device in which the LN is defined.	LN Class definition (CDC definition by reference)
cdcNs	The DataAttribute cdcNs shall be included if the definition of at least one SubDataObject, DataAttribute, or SubAttribute of the CDC deviates from the definition in the specification in which the CDC of the DataObject is defined. In that case, the name of the new CDC is provided in the data attribute cdcName.	CDC definition
dataNs	The DataAttribute dataNs shall be included if the name space of the DataObject deviates from the name space of the logical node in which the DataObject is defined.	LN class definition (CDC definition by reference)

7.3 Common data class specifications for status information

7.3.1 Application of services

Table 18 defines the basic status information template. In particular, it defines the inheritance and specialization of services defined in IEC 61850-7-2.

Table 18 – Basic status information template

Basic status information template					
Attribute name	Attribute type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status					
substitution and blocked					
configuration, description and extension					
Services (see IEC 61850-7-2)					
The following services are inherited from IEC 61850-7-2. They are specialized by restricting the service to attributes with a functional constraint as specified below.					
Service model of IEC 61850-7-2	Service	Service applies to Attr with FC		Remark	
GenCommonDataClass model	SetDataValues GetDataValues GetDataDefinition GetDataDirectory	DC, CF, SV, BL ALL ALL ALL			
Data set model	GetDataSetValues SetDataSetValues	ALL DC, CF, SV, BL			
Reporting model GSE model Sampled values model	Report SendGOOSEMessage SendGSSEMessage SendMSVMessage SendUSVMessage	ALL ST ST ST ST		As specified within the data set that is used to define the content of the message	

7.3.2 Single point status (SPS)

Table 19 defines the common data class “single point status”.

Table 19 – Single point status common data class definition

SPS class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status					
stVal	BOOLEAN	ST	dchg	TRUE FALSE	M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	BOOLEAN	SV		TRUE FALSE	PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLND_A_M
Services					
As defined in Table 18.					

7.3.3 Double point status (DPS)

Table 20 defines the common data class “double point status”.

Table 20 – Double point status common data class specification

DPS class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status					
stVal	CODED ENUM	ST	dchg	intermediate-state off on bad-state	M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	CODED ENUM	SV		intermediate-state off on bad-state	PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 18.					

The value bad-state means that the server cannot detect if the position is open, close or in intermediate state.

7.3.4 Integer status (INS)

Table 21 defines the common data class “integer status”.

Table 21 – Integer status common data class specification

INS class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status					
stVal	INT32	ST	dchg, dupd		M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	INT32	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
units	Unit	CF	dchg		O

d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_M
cdcName	VISIBLE STRING255	EX			AC_DLND_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 18.					

7.3.5 Enumerated status (ENS)

Table 22 defines the common data class “enumerated status”.

Table 22 – Enumerated status common data class specification

ENS class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status					
stVal	ENUMERATED	ST	dchg, dupd		M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	ENUMERATED	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_A_M
Services					
As defined in Table 18.					

7.3.6 Protection activation information (ACT)

Table 23 defines the common data class “protection activation information”.

Table 23 – Protection activation information common data class specification

ACT class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status					
general	BOOLEAN	ST	dchg		M
phsA	BOOLEAN	ST	dcha		O

phsB	BOOLEAN	ST	dchg		O
phsC	BOOLEAN	ST	dchg		O
neut	BOOLEAN	ST	dchg		O
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
originSrc	Originator	ST			O
operTmPhsA	TimeStamp	ST			O
operTmPhsB	TimeStamp	ST			O
operTmPhsC	TimeStamp	ST			O
<i>configuration, description and extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 18.					

NOTE The attribute originSrc may be used to identify the originator when a data of the CDC ACT is used to perform an operation. An example would be the data OpOpn of the LN CSWI being used to open a breaker (LN XCBR) through a GOOSE message. The LN XCBR receives the data CSWI.OpOpn including the originator as a GOOSE message. Once operated, the new status information in XCBR.Pos will include the originator information it received as part of the GOOSE message that triggered the operation.

7.3.7 Directional protection activation information (ACD)

Table 24 defines the common data class “directional protection activation information”.

**Table 24 – Directional protection activation information
common data class specification**

ACD class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status					
general	BOOLEAN	ST	dchg		M
dirGeneral	ENUMERATED	ST	dchg	unknown forward backward both	M
phsA	BOOLEAN	ST	dchg		GC_2_1
dirPhsA	ENUMERATED	ST	dchg	unknown forward backward	GC_2_1
phsB	BOOLEAN	ST	dchg		GC_2_2
dirPhsB	ENUMERATED	ST	dchg	unknown forward backward	GC_2_2
phsC	BOOLEAN	ST	dchg		GC_2_3
dirPhsC	ENUMERATED	ST	dchg	unknown forward backward	GC_2_3
neut	BOOLEAN	ST	dchg		GC_2_4
dirNeut	ENUMERATED	ST	dchg	unknown forward backward	GC_2_4
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
configuration, description and extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC DLN M

Services
As defined in Table 18.

7.3.8 Security violation counting (SEC)

Table 25 defines the common data class “security violation counting”.

Table 25 – Security violation counting common data class specification

SEC class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status					
cnt	INT32U	ST	dchg		M
sev	ENUMERATED	ST		unknown critical major minor warning	M
t	TimeStamp	ST			M
addr	OCTET STRING64	ST			O
addInfo	VISIBLE STRING64	ST			O
configuration, description and extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 18.					

7.3.9 Binary counter reading (BCR)

Table 26 defines the common data class “binary counter reading”.

Table 26 – Binary counter reading common data class specification

BCR class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status					
actVal	INT64	ST	dchg		M
frVal	INT64	ST	dupd		GC_2_1
frTm	TimeStamp	ST			GC_2_1
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
configuration, description and extension					
units	Unit	CF	dchg	see Annex A	O
pulsQty	FLOAT32	CF	dchg		M
frEna	BOOLEAN	CF	dchg		GC_2_1
strTm	TimeStamp	CF	dchg		GC_2_1
frPd	INT32	CF	dchg		GC_2_1
frRs	BOOLEAN	CF	dchg		GC_2_1
d	VISIBLE STRING255	DC			O
dU	UNICODE STRING255	DC			O

cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 18.					

7.3.10 Histogram (HST)

Table 27 defines the common data class "Histogram".

Table 27 – Histogram common data class specification

HST class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status					
hstVal	ARRAY 0..maxPts-1 OF INT32	ST	dchg, dupd		M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
configuration, description and extension					
numPts	INT16U	CF		0 < numPts ≤ maxPts	M
hstRangeC	ARRAY 0..maxPts-1 OF Cells	CF	dchg		M
xUnits	Unit	CF	dchg		M
yUnits	Unit	CF	dchg		O
units	Unit	CF	dchg		O
maxPts	INT16U	CF			M
xD	VISIBLE STRING255	DC			M
xDU	UNICODE STRING255	DC			O
yD	VISIBLE STRING255	DC			O
yDU	UNICODE STRING255	DC			O
d	VISIBLE STRING255	DC			O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 18.					

7.3.11 Visible string status (VSS)

Table 28 defines the common data class "visible string status".

Table 28 – Visible string status common data class definition

VSS class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					

VSS class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
<i>status</i>					
stVal	VISIBLE STRING 255	ST	dchg	Text	M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
<i>configuration, description and extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_M
cdcName	VISIBLE STRING255	EX			AC_DLND_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 18.					

7.4 Common data class specifications for measurand information

7.4.1 Application of services

Table 29 defines the basic measurand information template. In particular, it defines the inheritance and specialization of services defined in IEC 61850-7-2.

NOTE Measured values as used in the following clauses may also be applied to calculated values.

Table 29 – Basic measurand information template

Basic measurand information template					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
Data					
DataAttribute					
measured attributes					
substitution					
configuration, description and extension					
Services (see IEC 61850-7-2)					
The following services are inherited from IEC 61850-7-2. They are specialized by restricting the service to attributes with a functional constraint as specified below.					
Service model of IEC 61850-7-2	Service	Service applies to Attr with FC	Remark		
GenCommonDataClass model	SetDataValues GetDataValues GetDataDefinition GetDataDirectory	DC, CF, SV, BL ALL ALL ALL			
Data set model	GetDataSetValues SetDataSetValues	ALL DC, CF, SV, BL			
Reporting model GSE model Sampled values model	Report SendGOOSEMessage SendMSVMessage SendUSVMessage	ALL MX MX MX	As specified within the data set that is used to define the content of the message		

7.4.2 Measured value (MV)

Table 30 defines the common data class “measured value”.

Table 30 – Measured value

MV class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
measured attributes					
instMag	AnalogueValue	MX			O
mag	AnalogueValue	MX	dchg, dupd		M
range	ENUMERATED	MX	dchg	normal high low high-high low-low	O
q	Quality	MX	qchg		M
t	TimeStamp	MX			M
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subMag	AnalogueValue	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
units	Unit	CF	dchg	see Annex A	O
db	INT32U	CF	dchg	0 ... 100 000	O
zeroDb	INT32U	CF	dchg	0 ... 100 000	O
sVC	ScaledValueConfig	CF	dchg		AC_SCAV
rangeC	RangeConfig	CF	dchg		GC_CON_range
smpRate	INT32U	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 29.					

7.4.3 Complex measured value (CMV)

Table 31 defines the common data class “complex measured value”.

Table 31 – Complex measured value

CMV class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
measured attributes					
instCVal	Vector	MX			O
cVal	Vector	MX	dchg, dupd		M
range	ENUMERATED	MX	dchg	normal high low high-high low-low	O
rangeAng	ENUMERATED	MX	dchg	normal high low high-high low-low	O
q	Quality	MX	qchg		M
t	TimeStamp	MX			M
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subCVal	Vector	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
units	Unit	CF	dchg	see Annex A	O
db	INT32U	CF	dchg	0 ... 100 000	O
dbAng	INT32U	CF	dchg	0 ... 100 000	O
zeroDb	INT32U	CF	dchg	0 ... 100 000	O
rangeC	RangeConfig	CF	dchg		GC_CON_range
rangeAngC	RangeConfig	CF	dchg		GC_CON_range Ang
magSVC	ScaledValueConfig	CF	dchg		AC_SCAV
angSVC	ScaledValueConfig	CF	dchg		AC_SCAV
angRef	ENUMERATED	CF	dchg	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother Synchrophasor	O
smpRate	INT32U	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 29.					

7.4.4 Sampled value (SAV)

Table 32 defines the common data class “sampled value”. This common data class is used to represent samples of instantaneous analogue values. The values are usually transmitted using the “transmission of sampled value model” as defined in IEC 61850-7-2.

Table 32 – Sampled value

SAV class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
measured attributes					
instMag	AnalogueValue	MX			M
q	Quality	MX	qchg		M
t	TimeStamp	MX			O
configuration, description and extension					
units	Unit	CF	dchg	see Annex A	O
sVC	ScaledValueConfig	CF	dchg		AC_SCAV
min	AnalogueValue	CF	dchg		O
max	AnalogueValue	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLND_M
Services					
As defined in Table 29.					

7.4.5 Phase to ground/neutral related measured values of a three-phase system (WYE)

Table 33 defines the common data class “WYE”. This class is a collection of simultaneous measurements of values in a three-phase system that represent phase to ground values.

Table 33 – WYE

WYE class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
SubDataObject					
phsA	CMV				GC_1
phsB	CMV				GC_1
phsC	CMV				GC_1
neut	CMV				GC_1
net	CMV				GC_1
res	CMV				GC_1
DataAttribute					
configuration, description and extension					
angRef	ENUMERATED	CF	dchg	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother Synchrophasor	O
phsToNeut	BOOLEAN	CF	dchg	DEFAULT = FALSE	O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 29.					

With regard to data attributes of the CDC CMV, the following additional specifications apply.

- The data attribute angRef of phsA, phsB, phsC, neut, net and res shall not be used. Instead, the attribute angRef defined with the CDC WYE shall be used.
- The values of phsA.t, phsB.t, phsC.t, neut.t, net.t and res.t are identical. They specify the time at which the values for phsA, phsB, phsC and neut have been simultaneously acquired or determined.

7.4.6 Phase to phase related measured values of a three-phase system (DEL)

Table 34 defines the common data class “delta”. This class is a collection of measurements of values in a three-phase system that represent phase to phase values.

Table 34 – Delta

DEL class					
data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
SubDataObject					
phsAB	CMV				GC_1
phsBC	CMV				GC_1
phsCA	CMV				GC_1
DataAttribute					
configuration, description and extension					
angRef	ENUMERATED	CF	dchg	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother Synchronphasor	O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 29.					

With regard to data attributes of the CDC CMV, the following additional specifications apply.

- The data attribute angRef of phsAB, phsBC and phsCA shall not be used. Instead, the attribute angRef defined with the CDC DEL shall be used.
- The values of phsAB.t, phsBC.t and phsCA.t are identical. They specify the time at which the values for phsAB, phsBC and phsCA have been simultaneously acquired or determined.

7.4.7 Sequence (SEQ)

Table 35 defines the common data class “sequence”. This class is a collection of sequence components of a value.

Table 35 – Sequence

SEQ class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
SubDataObject					
c1	CMV				M
c2	CMV				M
c3	CMV				M
DataAttribute					
measured attributes					
seqT	ENUMERATED	MX		pos-neg-zero dir-quad-zero	M
configuration, description and extension					
phsRef	ENUMERATED	CF	dchg	A B C	O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 29.					

With regard to data attributes of the CDC CMV, the following additional specifications apply.

- The values of c1.t, c2.t and c3.t are identical. They specify the time at which the values for c1, c2 and c3 have been calculated.

7.4.8 Harmonic value (HVM)

Table 36 defines the common data class for non-phase-related harmonic values. This class is a collection of values that represent the harmonic or interharmonic content of a process value.

Table 36 – Harmonic value

HMV class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
SubDataObject					
har	ARRAY 0..numHar OF CMV				M
DataAttribute					
configuration, description and extension					
numHar	INT16U	CF	dchg	>0	M
numCyc	INT16U	CF	dchg	>0	M
evalTm	INT16U	CF	dchg		M
smpRate	INT32U	CF	dchg		O
frequency	FLOAT32	CF	dchg	nominal frequency	M
hvRef	ENUMERATED	CF	dchg	fundamental rms absolute	O
rmsCyc	INT16U	CF	dchg		AC_RMS_M
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 29.					

NOTE Harmonics for a single circuit have phase angles (optional) but need no reference for the angle (angRef), since by convention, the reference is always the fundamental frequency (index 1).

7.4.9 Harmonic value for WYE (HWYE)

Table 37 defines the common data class “harmonic value for WYE”. This class is a collection of simultaneous measurements (or evaluations) of values that represent the harmonic or interharmonic content of a process value in a three-phase system with phase to ground values.

Table 37 – Harmonic values for WYE

HWYE class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
SubDataObject					
phsAHar	ARRAY 0..numHar OF CMV				M
phsBHar	ARRAY 0..numHar OF CMV				O
phsCHar	ARRAY 0..numHar OF CMV				O
neutHar	ARRAY 0..numHar OF CMV				O
netHar	ARRAY 0..numHar OF CMV				O
resHar	ARRAY 0..numHar OF CMV				O
DataAttribute					
configuration, description and extension					
numHar	INT16U	CF	dchg	>0	M
numCyc	INT16U	CF	dchg	>0	M
evalTm	INT16U	CF	dchg		M
angRef	ENUMERATED	CF	dchg	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother Synchrophasor	O
smpRate	INT32U	CF	dchg		O
frequency	FLOAT32	CF	dchg	fundamental frequency	M
hvRef	ENUMERATED	CF	dchg	fundamental rms absolute	O
rmsCyc	INT16U	CF	dchg		AC_RMS_M
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 29.					

7.4.10 Harmonic value for DEL (HDEL)

Table 38 defines the common data class “harmonic value for delta”. This class is a collection of simultaneous measurements (or evaluations) of values that represent the harmonic or interharmonic content of a process value in a three-phase system with phase to phase values.

Table 38 – Harmonic values for delta

HDEL class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
SubDataObject					
phsABHar	ARRAY 0..numHar OF CMV				M
phsBCHar	ARRAY 0..numHar OF CMV				O
phsCAHar	ARRAY 0..numHar OF CMV				O
DataAttribute					
configuration, description and extension					
numHar	INT16U	CF	dchg	>0	M
numCyc	INT16U	CF	dchg	>0	M
evalTm	INT16U	CF	dchg		M
angRef	ENUMERATED	CF	dchg	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother Synchrophasor	O
smpRate	INT32U	CF	dchg		O
frequency	FLOAT32	CF	dchg	nominal frequency	M
hvRef	ENUMERATED	CF	dchg	fundamental rms absolute	O
rmsCyc	INT16U	CF	dchg		AC_RMS_M
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 29.					

7.5 Common data class specifications for controls

7.5.1 Application of services

Table 39 defines the basic controllable status information template. In particular, it defines the inheritance and specialization of services defined in IEC 61850-7-2.

Table 39 – Basic controllable status information template

Basic controllable status information template					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status / measured attributes and control mirror					
substitution and blocked					
configuration, description and extension					
parameters for control services					
Services (see IEC 61850-7-2)					
The following services are inherited from IEC 61850-7-2. They are specialized by restricting the service to attributes with a functional constraint as specified below.					
Service model of IEC 61850-7-2	Service	Service applies to Attr with FC	Remark		
GenCommonDataClass model	SetDataValues GetDataValues GetDataDefinition GetDataDirectory	DC, CF, SV, BL ALL ALL ALL			
Data set model	GetDataSetValues SetDataSetValues	ALL DC, CF, SV, BL			
Reporting model GSE model	Report SendGOOSEMessage SendGSSEMessage	ALL ST, MX ST	As specified within the data set that is used to define the content of the message		
Sampled values model	SendMSVMessage SendUSVMessage	ST, MX ST, MX			
Control model	Select SelectWithValue Cancel Operate CommandTermination TimeActivatedOperate				

All common data classes for controllable status information include both the control and the related status information.

NOTE The service parameter of the control, which belongs to the control model defined in IEC 61850-7-2, is included here, since the type is defined by the CDC.

7.5.2 Controllable single point (SPC)

Table 40 defines the common data class “controllable single point”.

Table 40 – Controllable single point

SPC class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status and control mirror					
origin	Originator	ST			AC_CO_O
ctlNum	INT8U	ST		0..255	AC_CO_O
stVal	BOOLEAN	ST	dchg	FALSE TRUE	AC_ST
q	Quality	ST	qchg		AC_ST
t	TimeStamp	ST			AC_ST
stSeld	BOOLEAN	ST	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	BOOLEAN	SV		FALSE TRUE	PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
pulseConfig	PulseConfig	CF	dchg		AC_CO_O
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_M
cdcName	VISIBLE STRING255	EX			AC_DLND_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 39.					
parameters for control services					
Service parameter name		Service parameter type		Value/Value range	
ctlVal		BOOLEAN		off (FALSE) on (TRUE)	

7.5.3 Controllable double point (DPC)

Table 41 defines the common data class “controllable double point”.

Table 41 – Controllable double point

DPC class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataSetName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status and control mirror					
origin	Originator	ST			AC_CO_O
ctlNum	INT8U	ST		0..255	AC_CO_O
stVal	CODED ENUM	ST	dchg	intermediate-state off on bad-state	M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
stSeld	BOOLEAN	ST	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	CODED ENUM	SV		intermediate-state off on bad-state	PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
pulseConfig	PulseConfig	CF	dchg		AC_CO_O
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_M
cdcName	VISIBLE STRING255	EX			AC_DLND_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 39.					
parameters for control services					
Service parameter name		Service parameter type		Value/Value range	
ctlVal		BOOLEAN		off (FALSE) on (TRUE)	

The value bad-state means that the server cannot detect if the position is open, close or in intermediate state.

7.5.4 Controllable integer status (INC)

Table 42 defines the common data class “controllable integer status”.

Table 42 – Controllable integer status

INC class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status and control mirror					
origin	Originator	ST			AC_CO_O
ctlNum	INT8U	ST		0..255	AC_CO_O
stVal	INT32	ST	dchg		M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
stSeld	BOOLEAN	ST	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	INT32	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
minVal	INT32	CF	dchg		O
maxVal	INT32	CF	dchg		O
stepSize	INT32U	CF	dchg	1 ... (maxVal – minVal)	O
operTimeout	INT32U	CF	dchg		AC_CO_O
units	Unit	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_M
cdcName	VISIBLE STRING255	EX			AC_DLND_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 39.					
parameters for control services					
Service parameter name		Service parameter type		Value/Value range	
ctlVal		INT32			

7.5.5 Controllable enumerated status (ENC)

Table 43 defines the common data class “controllable enumerated status”.

Table 43 – Controllable enumerated status

ENC class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status and control mirror					
origin	Originator	ST			AC_CO_O
ctlNum	INT8U	ST		0..255	AC_CO_O
stVal	ENUMERATED	ST	dchg		M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
stSeld	BOOLEAN	ST	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	ENUMERATED	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 39.					
parameters for control services					
Service parameter name		Service parameter type		Value/Value range	
ctlVal		ENUMERATED			

7.5.6 Binary controlled step position information (BSC)

Table 44 defines the common data class “binary controlled step position information”.

Table 44 – Binary controlled step position information

BSC class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status and control mirror					
origin	Originator	ST			AC_CO_O
ctlNum	INT8U	ST		0..255	AC_CO_O
valWTr	ValWithTrans	ST	dchg		AC_ST
q	Quality	ST	qchg		AC_ST
t	TimeStamp	ST			AC_ST
stSeld	BOOLEAN	ST	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	ValWithTrans	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
persistent	BOOLEAN	CF	dchg		M
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
minVal	INT8	CF	dchg		O
maxVal	INT8	CF	dchg		O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_M
cdcName	VISIBLE STRING255	EX			AC_DLND_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 39.					
parameters for control services					
Service parameter name		Service parameter type		Value/Value range	
ctlVal		CODED ENUM		stop lower higher reserved	

7.5.7 Integer controlled step position information (ISC)

Table 45 defines the common data class “integer controlled step position information”.

Table 45 – Integer controlled step position information

ISC class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
status and control mirror					
origin	Originator	ST			AC_CO_O
ctlNum	INT8U	ST		0..255	AC_CO_O
valWTr	ValWithTrans	ST	dchg		AC_ST
q	Quality	ST	qchg		AC_ST
t	TimeStamp	ST			AC_ST
stSeld	BOOLEAN	ST	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	ValWithTrans	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
minVal	INT8	CF	dchg		O
maxVal	INT8	CF	dchg		O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_M
cdcName	VISIBLE STRING255	EX			AC_DLND_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 39.					
parameters for control services					
Service parameter name		Service parameter type		Value/Value range	
ctlVal		INT8		-64 ... 63	

7.5.8 Controllable analogue process value (APC)

Table 46 defines the common data class “controllable analogue process value”.

Table 46 – Controllable analogue process value

APC class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
measured attributes and control mirror					
origin	Originator	MX			AC_CO_O
ctlNum	INT8U	MX		0..255	AC_CO_O
mxVal	AnalogueValue	MX	dchg		AC_ST
q	Quality	MX	qchg		AC_ST
t	TimeStamp	MX			AC_ST
stSeld	BOOLEAN	MX	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	AnalogueValue	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
units	Unit	CF	dchg	see Annex A	O
db	INT32U	CF	dchg	0 ... 100 000	O
sVC	ScaledValueConfig	CF	dchg		AC_SCAV
minVal	AnalogueValue	CF	dchg		O
maxVal	AnalogueValue	CF	dchg		O
stepSize	AnalogueValue	CF	dchg	0 ... (maxVal – minVal)	O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 39.					
parameters for control services					
Service parameter name		Service parameter type		Value/Value range	
ctlVal		AnalogueValue			

7.5.9 Binary controlled analog process value (BAC)

Table 47 defines the common data class “binary controlled analog process value”.

Table 47 – Binary controlled analog process value

BAC class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
Status and control mirror					
origin	Originator	MX			AC_CO_O
ctlNum	INT8U	MX		0..255	AC_CO_O
mxVal	AnalogueValue	MX	dchg		AC_ST
q	Quality	MX	qchg		AC_ST
t	TimeStamp	MX			AC_ST
stSeld	BOOLEAN	MX	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution and blocked					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	AnalogueValue	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description and extension					
persistent	BOOLEAN	CF	dchg		M
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
units	Unit	CF	dchg	see Annex A	O
dB	INT32U	CF	dchg	0 ... 100 000	O
sVC	ScaledValueConfig	CF	dchg		AC_SCAV
minVal	AnalogueValue	CF	dchg		O
maxVal	AnalogueValue	CF	dchg		O
stepSize	AnalogueValue	CF	dchg	1 ... (maxVal – minVal)	O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 39.					
parameters for control services					
Service parameter name		Service parameter type		Value/Value range	
ctlVal		CODED ENUM		stop lower higher reserved	

7.6 Common data class specifications for status settings

7.6.1 Application of services

Table 48 defines the basic controllable status settings template. In particular, it defines the inheritance and specialization of services defined in IEC 61850-7-2.

Table 48 – Basic status setting template

Basic controllable status information template					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataSetName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
setting					
configuration, description and extension					
Services (see IEC 61850-7-2)					
The following services are inherited from IEC 61850-7-2. They are specialized by restricting the service to attributes with a functional constraint as specified below.					
Service model of IEC 61850-7-2	Service		Service applies to Attr with FC	Remark	
GenCommonDataClass model	SetDataValues GetDataValues GetDataDefinition GetDataDirectory		DC, CF, SP ALL except SE ALL ALL		
Data set model	GetDataSetValues SetDataSetValues		ALL except SE DC, CF		
Reporting model GSE model	Report SendGOOSEMessage		ALL except SE SP	As specified within the data set that is used to define the content of the message	
Setting group control model	SetEditSGValues GetEditSGValues		SE SE, SG		

7.6.2 Single point setting (SPG)

Table 49 defines the common data class “single point setting”.

Table 49 – Single point setting

SPG class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataSetName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
setting					
setVal	BOOLEAN	SP	dchg	off (FALSE) on (TRUE)	AC_NS_G_M
setVal	BOOLEAN	SG, SE		off (FALSE) on (TRUE)	AC_SG_M
configuration, description and extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DL_NDA_M
cdcName	VISIBLE STRING255	EX			AC_DL_NDA_M
dataNs	VISIBLE STRING255	EX			AC_DL_N_M
Services					
As defined in Table 48.					

7.6.3 Integer status setting (ING)

Table 50 defines the common data class “integer status setting”.

Table 50 – Integer status setting

ING class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataSetName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
setting					
setVal	INT32	SP	dchg		AC_NSQ_M
setVal	INT32	SG, SE			AC_SQ_M
configuration, description and extension					
minVal	INT32	CF	dchg		O
maxVal	INT32	CF	dchg		O
stepSize	INT32U	CF	dchg	1 ... (maxVal – minVal)	O
units	Unit	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDQ_M
cdcName	VISIBLE STRING255	EX			AC_DLNDQ_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 48.					

7.6.4 Enumerated status setting (ENG)

Table 51 defines the common data class “enumerated status setting”.

Table 51 – Enumerated status setting

ENG class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataSetName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
setting					
setVal	ENUMERATED	SP	dchg		AC_NSQ_M
setVal	ENUMERATED	SG, SE			AC_SQ_M
configuration, description and extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDQ_M
cdcName	VISIBLE STRING255	EX			AC_DLNDQ_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 48.					

7.6.5 Object reference setting (ORG)

Table 52 defines the common data class “object reference setting”.

Table 52 – Object reference setting common data class specification

ORG class					
Data attribute Name	Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
Setting					
setSrcRef	ObjectReference	SP	dchg	Object Reference	M
setTstRef	ObjectReference	SP	dchg	Object Reference	GC_2_1
setSrcCB	ObjectReference	SP	dchg	Object Reference	O
setTstCB	ObjectReference	SP	dchg	Object Reference	GC_CON_setTstRef
intAddr	VISIBLE STRING255	SP	dchg		O
tstEna	BOOLEAN	SP	dchg		GC_2_1
configuration, description and extension					
purpose	VISIBLE STRING255	DC			O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 48.					

7.6.6 Time setting group (TSG)

Table 53 defines the common data class “Time setting group”.

Table 53 – Time setting group common data class specification

TSG class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
Setting					
setTm	TimeStamp	SP	dchg		AC_NS_G_C1
setCal	CalendarTime	SP	dchg		AC_NS_G_C1
setTm	TimeStamp	SG, SE			AC_SG_C1
setCal	CalendarTime	SG, SE			AC_SG_C1
configuration, description and extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DL_NDA_M
cdcName	VISIBLE STRING255	EX			AC_DL_NDA_M

TSG class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 48.					

7.6.7 Currency setting group (CUG)

Table 54 defines the common data class "Currency setting group".

Table 54 – Currency setting group common data class specification

CUG class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
Setting					
cur	Currency	SP	dchg	ISO 4217 3-character currency code	AC_NSQ_M
cur	Currency	SG, SE		ISO 4217 3-character currency code	AC_SG_M
configuration, description and extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 48.					

7.6.8 Visible string setting (VSG)

Table 55 defines the common data class "visible string setting group"

Table 55 – Visible string setting group common data class specification

VSG class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
Setting					
setVal	VISIBLE STRING255	SP	dchg		AC_NSQ_M
setVal	VISIBLE STRING255	SG, SE			AC_SG_M
configuration, description and extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_M

VSG class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 48.					

7.7 Common data class specifications for analogue settings

7.7.1 Application of services

Table 56 defines the basic controllable analogue information template. In particular, it defines the inheritance and specialization of services defined in IEC 61850-7-2.

Table 56 – Basic analogue setting template

Basic controllable analogue information template					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
setting					
configuration, description and extension					
Services (see IEC 61850-7-2)					
The following services are inherited from IEC 61850-7-2. They are specialized by restricting the service to attributes with a functional constraint as specified below.					
Service model of IEC 61850-7-2	Service		Service applies to Attr with FC	Remark	
GenCommonDataClass model	SetDataValues GetDataValues GetDataDefinition GetDataDirectory		DC, CF, SP ALL except SE ALL ALL		
Data set model	GetDataSetValues SetDataSetValues		ALL except SE DC, CF		
Reporting model GSE model	Report SendGOOSEMessage		ALL except SE SP	As specified within the data set that is used to define the content of the message	
Setting group control model	SetEditSGValues GetEditSGValues		SE SE, SG		

7.7.2 Analogue setting (ASG)

Table 57 defines the common data class “analogue setting”.

Table 57 – Analogue setting

ASG class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
setting					
setMag	AnalogueValue	SP	dchg		AC_NS_G_M
setMag	AnalogueValue	SG, SE			AC_SG_M
configuration, description and extension					
units	Unit	CF	dchg	see Annex A	O
sVC	ScaledValueConfig	CF	dchg		AC_SCAV
minVal	AnalogueValue	CF	dchg		O
maxVal	AnalogueValue	CF	dchg		O
stepSize	AnalogueValue	CF	dchg	0 ... (maxVal – minVal)	O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DL_NDA_M
cdcName	VISIBLE STRING255	EX			AC_DL_NDA_M
dataNs	VISIBLE STRING255	EX			AC_DL_N_M
Services					
As defined in Table 56.					

7.7.3 Setting curve (CURVE)

Table 58 defines the common data class “setting curve”.

Table 58 – Setting curve

CURVE class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
Setting					
setCharact	ENUMERATED	SP	dchg		AC_NSG_M
setParA	FLOAT32	SP	dchg		AC_NSG_O
setParB	FLOAT32	SP	dchg		AC_NSG_O
setParC	FLOAT32	SP	dchg		AC_NSG_O
setParD	FLOAT32	SP	dchg		AC_NSG_O
setParE	FLOAT32	SP	dchg		AC_NSG_O
setParF	FLOAT32	SP	dchg		AC_NSG_O
setCharact	ENUMERATED	SG, SE			AC_SG_M
setParA	FLOAT32	SG, SE			AC_SG_O
setParB	FLOAT32	SG, SE			AC_SG_O
setParC	FLOAT32	SG, SE			AC_SG_O
setParD	FLOAT32	SG, SE			AC_SG_O
setParE	FLOAT32	SG, SE			AC_SG_O
setParF	FLOAT32	SG, SE			AC_SG_O
configuration, description and extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 56.					

DataObjects of this common data class shall be used to describe setting curves used in protection equipment. The CDC CURVE is used to select with the attribute setChar one of up to 48 predefined curve shapes. In some cases, in addition, parameters may be changed for the curves. The curve shapes are typically defined with formulas that use up to 6 parameters. Some of these formulas are standardized (value of setCharact between 1 and 16), other formulas may be user-defined (value of setCharact between 17 and 32; the specification of the formula is a local issue). In some cases, the curve may be specified as an array of n (x,y) pairs (value of setChar between 33 and 48; the specification of the array of n (x,y) pairs is a local issue; a data of the CDC CSG may be used to specify each of the characteristics 33 to 48). The resulting curve may be read from the device using a dedicated data of the CDC CSD as defined in 7.8.4.

7.7.4 Curve shape setting (CSG)

Table 59 defines the common data class for curve shape setting.

Table 59 – Curve shape setting

CSG class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					

The curve is created by the connection of crvPts(n) with crvPts(n+1) with $0 < n < \text{numPts}$. See Figure 6.




Figure 6 – Two-dimensional curve represented by CSG

A family of shape settings can be created by multiple instances of a data object with the CDC CSG. In that case, the common data attribute type point used for crvPts shall not support the optional element z and the attribute pointZ is used to represent the value of the curve on the z axis. The three-dimensional shape is created by connecting the curves with each other. See Figure 7.




Figure 7 – Two-dimensional shape created by multiple CSG

7.8 Common data class specifications for description information

7.8.1 Application of services

Table 60 defines the basic description information template. In particular, it defines the inheritance and specialization of services defined in IEC 61850-7-2.

Table 60 – Basic description information template

Basic description information template					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
configuration, description and extension					
Services (see IEC 61850-7-2)					
The following services are inherited from IEC 61850-7-2. They are specialized by restricting the service to attributes with a functional constraint as specified below.					
Service model of IEC 61850-7-2	Service	Service applies to Attr with FC		Remark	
GenCommonDataClass model	SetDataValues GetDataValues GetDataDefinition GetDataDirectory	DC, CF ALL ALL ALL			
Data set model	GetDataSetValues SetDataSetValues	ALL DC, CF			
Reporting model	Report	ALL		As specified within the data set that is used to define the content of the message	
GOOSE, SV model	GOOSE, SV	ST			

7.8.2 Device name plate (DPL)

Table 61 defines the common data class “device name plate”. Data of this common data class are used to identify entities like primary equipment or physical devices.

Table 61 – Device name plate common data class specification

DPL class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
configuration, description and extension					
vendor	VISIBLE STRING255	DC			M
hwRev	VISIBLE STRING255	DC			O
swRev	VISIBLE STRING255	DC			O
serNum	VISIBLE STRING255	DC			O
model	VISIBLE STRING255	DC			O
location	VISIBLE STRING255	DC			O
name	VISIBLE STRING64	DC			O
owner	VISIBLE STRING255	DC			O
ePSName	VISIBLE STRING255	DC			O
primeOper	VISIBLE STRING255	DC			O
secondOper	VISIBLE STRING255	DC			O
latitude	FLOAT32	DC			O
longitude	FLOAT32	DC			O
altitude	FLOAT32	DC			O
mRID	VISIBLE STRING255	DC			O
d	VISIBLE STRING255	DC			O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 60.					

7.8.3 Logical node name plate (LPL)

Table 62 defines the common data class “logical node name plate”. Data of this common data class are used to describe logical nodes.

Table 62 – Logical node name plate common data class specification

LPL class					
Data attribute name	Type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
configuration, description and extension					
vendor	VISIBLE STRING255	DC			M
swRev	VISIBLE STRING255	DC			M
d	VISIBLE STRING255	DC			O
dU	UNICODE STRING255	DC			O
configRev	VISIBLE STRING255	DC			AC_LN0_M
paramRev	INT32	ST	dchg		O
valRev	INT32	ST	dchg		O
IdNs	VISIBLE STRING255	EX		Shall be included in LLN0 only; for example "IEC 61850-7-4:2010"; details of the name space concept are defined in IEC 61850-7-1.	AC_LN0_EX
InNs	VISIBLE STRING255	EX			AC_DLD_M
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 60.					

7.8.4 Curve shape description (CSD)

Table 63 defines the common data class "curve shape description". Data of this common data class are used to read the shape of a curve as for example used with protection settings.

Table 63 – Curve shape description common data class specification

CSD class					
Attribute name	Attribute type	FC	TrgOp	Value/Value range	M/O/C
DataName	Inherited from GenDataObject Class or from GenSubDataObject Class (see IEC 61850-7-2)				
DataAttribute					
configuration, description and extension					
xUnits	Unit	DC			M
xD	VISIBLE STRING255	DC			M
xDU	UNICODE STRING255	DC			O
yUnits	Unit	DC			M
yD	VISIBLE STRING255	DC			M
yDU	UNICODE STRING255	DC			O
zUnits	Unit	DC			O
zD	VISIBLE STRING255	DC			O
zDU	UNICODE STRING255	DC			O
numPts	INT16U	DC		>1	M
crvPts	ARRAY 0..numPts-1 OF Point	DC			M
d	VISIBLE STRING255	DC			O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 60.					

The curve is created by the connection of crvPts(n) with crvPts(n+1) with 0<n<numPts.

8 Data attribute semantic

The data attributes, controllable parameters and in some case data used in Clause 7 shall have semantics as defined in Table 64.

Table 64 – Semantics of data attributes and data


Data attribute name	Semantics												
actVal	Binary counter status represented as an integer value.												
addInfo	Additional information that may give further clarification as to the last detected violation.												
addr	Address of the remote source that last caused the count to be incremented. NOTE 1 The kind of address stored (application address, IP address, link address, ...) is whatever the server can detect. This may depend on the specific mapping.												
altitude	Geographical position of device in WGS84 coordinates – altitude.												
angRef	Angle reference. Indicates the quantity that is used as reference for the phase angle. For the indicated quantity, the fundamental frequency (index = 1) is used as reference by convention. angRef = "Synchrophasor" means that the reference of the angle is as defined in 4.2 of IEEE C37.118.												
angSVC	Scaled value configuration for angles. Shall be used to configure the scaled value representation of the angle of the attributes instCVal and cVal and the limits in rangeAngC of the CDC CMV.												
blkEna	If TRUE, the operator-blocked quality flag is set, and the process value no longer updated.												
c1	Sequence component 1. For the semantic meaning, see seqT.												
c2	Sequence component 2. For the semantic meaning, see seqT.												
c3	Sequence component 3. For the semantic meaning, see seqT.												
cdcName	Name of the common data class. Used together with cdcNs, for details, see IEC 61850-7-1.												
cdcNs	Common data class name space. For details, see IEC 61850-7-1.												
cnt	Counter value of security violations.												
configRev	Uniquely identifies the configuration of a logical device instance. ConfigRev in LLN0 (at LD level) has to be changed at least on any semantic change of the data model of this LD related to the client functionality. How this is detected and performed is left to the user. Also the semantics of configRev concerning other LNs is left to the user. For further details, see as well Annex C.												
crvPts	The array with the points specifying a curve shape.												
ctlModel	Specifies the control model of IEC 61850-7-2 that corresponds to the behaviour of the data. <table border="1"> <thead> <tr> <th>Value</th><th>Explanation</th></tr> </thead> <tbody> <tr> <td>status-only</td><td>The object is not controllable, only the services that apply to a status object are supported. The attribute ctlVal does not exist.</td></tr> <tr> <td>direct-with-normal-security</td><td>Direct control with normal security according to IEC 61850-7-2.</td></tr> <tr> <td>sbo-with-normal-security</td><td>SBO control with normal security according to IEC 61850-7-2.</td></tr> <tr> <td>direct-with-enhanced-security</td><td>Direct control with enhanced security according to IEC 61850-7-2.</td></tr> <tr> <td>sbo-with-enhanced-security</td><td>SBO control with enhanced security according to IEC 61850-7-2.</td></tr> </tbody> </table> NOTE 2 If a data instance of a control class has no status information associated, then the attribute stVal does not exist. In that case, the value range for ctlModel is restricted to direct-with-normal-security and sbo-with-normal-security.	Value	Explanation	status-only	The object is not controllable, only the services that apply to a status object are supported. The attribute ctlVal does not exist.	direct-with-normal-security	Direct control with normal security according to IEC 61850-7-2.	sbo-with-normal-security	SBO control with normal security according to IEC 61850-7-2.	direct-with-enhanced-security	Direct control with enhanced security according to IEC 61850-7-2.	sbo-with-enhanced-security	SBO control with enhanced security according to IEC 61850-7-2.
Value	Explanation												
status-only	The object is not controllable, only the services that apply to a status object are supported. The attribute ctlVal does not exist.												
direct-with-normal-security	Direct control with normal security according to IEC 61850-7-2.												
sbo-with-normal-security	SBO control with normal security according to IEC 61850-7-2.												
direct-with-enhanced-security	Direct control with enhanced security according to IEC 61850-7-2.												
sbo-with-enhanced-security	SBO control with enhanced security according to IEC 61850-7-2.												
ctlNum	The control sequence number of the last control service.												

Data attribute name	Semantics
ctlVal	Service parameter that determines the control activity. For the CDC INC, the integer value 0 shall be transmitted to reset the value. For the CDC BSC, if the data attribute persistent is FALSE, higher and lower refer to one step in the data attribute posVal of the data attribute valWTr. For the CDC ISC, the INTEGER value refers always to a dedicated position in the data attribute posVal of the data attribute valWTr which has to be reached directly. The service parameter is applicable for the following services: SelVal (Request, Response+, Response-) Operate (Request, Response+, Response-) TimOper (Request, Response+, Response-)
cur	3-character currency code according to ISO 4217.
cVal	Deadbanded complex value. Based on a deadband calculation from instCVal. The deadband calculation is done both on instCVal.mag based on the configuration parameter db as well as on instCVal.ang based on the configuration parameter dbAng independently. For details on deadband calculation, see mag.
d	Textual description of the data. In case of the common data class LPL, the description refers to the logical node.
dataNs	Data name space. For details, see IEC 61850-7-1.
db	Deadband. Shall represent a configuration parameter used to calculate all deadbanded attributes (for example mag attribute in the CDC MV). The value shall represent the percentage of difference between max. and min. in units of 0,001 %. If an integral calculation is used to determine the deadbanded value, the value shall be represented as 0,001 % s. A dB value of 0 shall suppress reporting events on the analog value, so that only changes of the range value will lead to events.
dbAng	Deadband for angles. Shall represent a configuration parameter used to calculate deadbanded attributes for the angle in the case the data attribute is of the common data attribute type vector (for example cVal attribute of the CDC CMV). The value shall represent the percentage of difference between max. and min. in units of 0,001 %. If an integral calculation is used to determine the deadbanded value, the value shall be represented as 0,001 % s.
dirGeneral	General direction of the fault. If the faults of individual phases have different directions, this attribute shall be set to both.
dirNeut	Direction of the fault for neut.
dirPhsA	Direction of the fault for phase A.
dirPhsB	Direction of the fault for phase B.
dirPhsC	Direction of the fault for phase C.
dU	Textual description of the data using unicode characters. For further details, see d.
ePSName	Name of electric power system the device is connected to.
evalTm	Time window applied to interharmonic calculations. The value shall be represented in ms. For further details, see har.
frEna	BOOLEAN value, which controls the freezing process. If TRUE, freezing shall occur as specified in strTm, frPd and frRs. If FALSE, no freezing shall occur.
frequency	Nominal frequency of the power system or some other fundamental frequency in Hz.
frPd	Time interval in ms between freeze operations. If frPd is 0, only a single freeze is performed at the time indicated in strTm.
frRs	Indicates that counter is to be automatically reset to zero after each freezing process.
frTm	Time of the last counter freeze.
frVal	Frozen binary counter status represented as an integer value.
general	Logical "or" of the phase values, for example trip or start. The attribute shall also be set if not all phases have a fault condition.


Data attribute name	Semantics
har	This array shall contain the harmonic and subharmonic or the interharmonic values. Harmonic and subharmonic values (evalTm equal to the period of the power frequency) The first array element shall contain the dc components, the further array elements shall contain the values for the harmonics 1 .. numHar. If numCycl is larger than one, then the array shall contain both harmonics and subharmonics and their multiples. In that case, sequence entries with the number $n \times 2^{numCycl-1}$ are harmonics; all other ones are subharmonics or multiple of subharmonics. Interharmonic values (evalTm not equal to the period of the power frequency) The first array element shall contain the dc components, the further array elements shall contain the values for the harmonics 1 .. numHar.

IECNORM.COM : Click to view the full PDF of IEC 61850-7-3:2010

Data attribute name	Semantics																					
hstVal	This array shall contain the values for the histogram entries. A histogram can be calculated based on a one-dimensional or a two-dimensional range. Details of a one-dimensional histogram representation are shown in the drawing below. IEC 2554/10 A histogram evaluates a series of values and evaluates the appearance of a value in a certain range. The evaluation can typically be a count, a measurement of a duration or the calculation of an average. The value range is configured with the configuration attribute hstRangeC. The attribute hstVal[1] shall be the count of the appearance of the evaluated values in the range hstRangeC[1]. For a two-dimensional histogram, the range can be as shown in the following drawing. Each of the rectangles represents one range; there is no rule, how to order the ranges. IEC 2555/10 For that example, the values would be as follows: <table><tr><td>index</td><td>0</td><td>1</td><td>2</td><td>3</td><td>4</td><td>5</td></tr><tr><td>hstVal</td><td>0</td><td>10</td><td>9</td><td>1</td><td>5</td><td>3</td></tr><tr><td>hstRangeC</td><td>0;0 / 4;10</td><td>4;0 / 10;4</td><td>10;0 / 12;4</td><td>4;4 / 12;8</td><td>4;8 / 8;10</td><td>8;8 / 12;10</td></tr></table>	index	0	1	2	3	4	5	hstVal	0	10	9	1	5	3	hstRangeC	0;0 / 4;10	4;0 / 10;4	10;0 / 12;4	4;4 / 12;8	4;8 / 8;10	8;8 / 12;10
index	0	1	2	3	4	5																
hstVal	0	10	9	1	5	3																
hstRangeC	0;0 / 4;10	4;0 / 10;4	10;0 / 12;4	4;4 / 12;8	4;8 / 8;10	8;8 / 12;10																
hstRangeC	This array shall contain the values for the configuration of the ranges for the histogram. For details, see hstVal.																					
hvRef	Specifies the reference type (i.e. ratio of harmonic to fundamental, to RMS or to absolute), which the data attribute mag of the data attribute type Vector contain.																					
hwRev	HW-revision.																					
intAddr	This value represents a manufacturer specific internal address.																					

Data attribute name	Semantics
instCVal	Instant value of a vector type value.
instMag	Magnitude of the instantaneous value of a measured value. NOTE 3 The presence of the attribute instMag is optional, that only affects the visibility of that value to the communication. The instantaneous value may be required for the internal behaviour of the function, e.g. to perform the deadband calculation as explained with the attribute mag.
latitude	Geographical position of device in WGS84 coordinates – latitude.
IdNs	Logical device name space. For details, see IEC 61850-7-1.
InNs	Logical node name space. For details, see IEC 61850-7-1.
location	Location, where the equipment is installed.
longitude	Geographical position of device in WGS84 coordinates – longitude.
mag	Deadbanded value. Shall be based on a dead band calculation from the instantaneous value (modelled as instMag) as illustrated below. The value of mag shall be updated to the current instantaneous value when the value has changed according the configuration parameter db. If db=0, the value of mag is identical to the value of instMag.  NOTE 4 The drawing above is an example. There may be other algorithms providing a comparable result; for example as an alternate solution, the dead band calculation may use the integral of the change of instMag. The algorithm used is a local issue. NOTE 5 This value mag is typically used to create reports for analogue values. Such a report sent "by exception" is not comparable to the transfer of sampled measured values as supported by the CDC SAV. NOTE 6 The data attribute mag explained here is not the same like the data attribute component mag of the common data attribute type vector. Therefore in particular the value instCVal.mag is NOT a deadbanded value.
magSVC	Scaled value configuration for magnitude. Shall be used to configure the scaled value representation of the magnitude of the attributes instCVal, cVal, rangeC of the CDC CMV.
max	Maximum process measurement for which values of <i>i</i> or <i>f</i> are considered within process limits. If the value is higher, q shall be set accordingly (validity = questionable, detailQual = outOfRange).
maxPts	The maximal number of points that is supported to be set as number of points for a given curve setting or as a number of cells for a histogram.
maxVal	Defines together with minVal the setting range for ctiVal (CDC INC, BSC, ISC), setVal (CDC ING) or setMag (CDC APC, ASG).
min	Minimum process measurement for which values of <i>i</i> or <i>f</i> are considered within process limits. If the value is lower, q shall be set accordingly (validity = questionable, detailQual = outOfRange).
minVal	Defines together with maxVal the setting range for ctiVal (CDC INC, BSC, ISC), setVal (CDC ING) or setMag (CDC APC, ASG).
model	Vendor specific product name.
mRID	Master resource ID – unique identification of an asset or device.
mxVal	Measured analogue process value. The return information with the current value of the controllable analogue process value. The value can be dead banded for reporting.
name	The name of the IED (if DPL is used in the context of a LPHD) or of a device like a circuit breaker (if used for the data EENaName).

Data attribute name	Semantics
net	Net current. Net current is the algebraic sum of the instantaneous values of currents flowing through all live conductors (sum over phase currents) <u>and</u> neutral of a circuit at a point of the electrical installation. For further details, see phsA (WYE).
netHar	This array shall contain the harmonic and subharmonics or interharmonic values related to net current. For further details, see Har.
neut (WYE)	Value of the measured phase neutral. If a direct measurement of this value is not available, it is acceptable to substitute an estimate computed by creating the algebraic sum of the instantaneous values of currents flowing through all live conductors. In that case, 'neut' is identical to 'res'. For further details, see phsA (WYE).
neut (ACT, ACD)	Start event with earth current.
neutHar	This array shall contain the harmonic and subharmonics or interharmonic values related to neutral. For further details, see Har.
numCyc	Number of cycles of power frequency, which are used for harmonic, subharmonic and interharmonic calculation. For further details, see har.
numHar	Number of harmonic and subharmonics or interharmonic values that can be accessed. The range of the numHar value shall be 1 or greater. The array element "1" shall represent the first harmonic value. The value 0 shall refer to the dc component. The maximal value for numHar may be calculated as follows: $numHar = \frac{1}{2} \times smpRate \times frequency \times evalTm \times 2^{numCycl-1} + 1$
numPts	Number of points or cells used to define a curve or a histogram.
operTimeout	This attribute specifies the timeout used to supervise an operation according the control model defined in IEC 61850-7-2. When operTimeout expires without an indication of a new valid state, the command action shall be terminated. In the control models with enhanced security, a negative command termination is sent as response. The value shall be in ms.
operTmPhsA	Operation Time for Phase A. Is used for point on wave switching.
operTmPhsB	Operation Time for Phase B. Is used for point on wave switching.
operTmPhsC	Operation Time for Phase C. Is used for point on wave switching.
opRcvd	Indication that a operate command for a controllable data object has been received. Used for testing purposes together with opOk and tOpOk in particular when the LN mode is TEST-BLOCKED. IEC 2557/10 The command is received by the IED as a control service or as a GOOSE message with a data object that is interpreted as a operate request on the controllable object. The command is then processed. If the command is accepted, the wired output would be activated. The data attribute opOk confirms that the command has been accepted and reflects the timing of the wired output; i.e. the duration of that signal is determined by the CF attribute pulseConfig if the output is a pulse. The data attribute tOpOk is a timestamp indicating when the output would be activated.
opOk	Indication that an operate command for a controllable data object has been evaluated and accepted. For details, see opRcvd.

Data attribute name	Semantics
origin	Origin contains information related to the originator of the last change of the process value of the controllable object. If the initiator of a change of the process value is not known, origin.orCat shall be set to process and origin.orIdent shall be set to NULL. Substitution shall not affect the value of origin.
originSrc	originSrc contains the information related to the originator of a control action forwarded by a GOOSE message.
owner	Owner of the device.
paramRev	Uniquely identifies the parameter revision of a logical device or logical node instance. ParamRev has to be changed at least on any change of a parameter (FC=SE or FC=SP) within this logical device or logical node. How this is detected and performed is left to the user. For further details, see as well Annex C. The change of ParamRev shall be done with the following semantic: – if the parameter change is done in the IED only through communication services or through the local HMI, the value shall be increased by one; – if the parameter change is done in the configuration file, the value shall be increased by 10 000.
persistent	Configures the control output. If set to FALSE, the operate service results in the change of exactly one step higher or lower. If set to TRUE, the operate service initiates the persistent activation of the output. The output shall be deactivated by an operate service with the value stop or by a local timeout. A client may repeat sending the operate service in order to retrigger the output. If persistent is set to TRUE, ctlModel shall be set to direct-with-normal-security.
phsA (WYE)	Value of phase A. In the WYE class, values for phsA, phsB, phsC, neut, net and res have been simultaneously acquired or determined. It shall be assumed that any jitter between the acquisition times dedicated for phsA, phsB, phsC, neut, net and res is neglectable. The jitter for simultaneity shall be as indicated in the time quality field. The relation between the phase values and neutral, net and residual is illustrated in the following drawing:  $I_{res} = I_A + I_B + I_C$ $I_{net} = I_A + I_B + I_C + I_{neut}$ $I_{res} = 0$ if not grounded and no fault $I_{res} > 0$ and $I_{net} = 0$ if not grounded and fault (phase asymmetry) $I_{net} > 0$ if grounded and fault (phase asymmetry) IEC 2558/10
phsA (ACT, ACD)	Trip or start event of phase A.
phsAB	Value of phase A to phase B measurement. In the DEL class, values for phsAB, phsBC and phsCA have been simultaneously acquired or determined. It shall be assumed that any jitter between the acquisition times dedicated for phsAB, phsBC and phsCA is neglectable. The jitter for simultaneity shall be as indicated in the time quality field.
phsABHar	This array shall contain the harmonic and subharmonics or interharmonic values related to phase A to phase B. For further details, see Har.
phsAHar	This array shall contain the harmonic and subharmonics or interharmonic values related to phase A. For further details, see Har.

Data attribute name	Semantics																																																
phsB (WYE)	Value of phase B. For further details, see phsA (WYE).																																																
phsB (ACT, ACD)	Trip or start event of phase B.																																																
phsBC	Value of phase B to phase C measurement. For further details, see phsAB.																																																
phsBCHar	This array shall contain the harmonic and subharmonics or interharmonic values related to phase B to phase C. For further details, see Har.																																																
phsBHar	This array shall contain the harmonic and subharmonics or interharmonic values related to phase B. For further details, see Har.																																																
phsC (WYE)	Value of phase C. For further details, see phsA (WYE).																																																
phsC (ACT, ACD)	Trip or start event of phase C.																																																
phsCA	Value of phase C to phase A measurement. For further details, see phsAB.																																																
phsCAHar	This array shall contain the harmonic and subharmonics or interharmonic values related to phase C to phase A. For further details, see Har.																																																
phsCHar	This array shall contain the harmonic and subharmonics or interharmonic values related to phase C. For further details, see Har.																																																
phsRef	Indicates which phase has been used as reference for the transformation of phase values to sequence values.																																																
phsToNeut	This configuration parameter indicates that the WYE class is used for phase to neutral values instead of phase to ground values. The data attribute neut will always indicate the neutral to ground value.																																																
pointZ	Position of the curve on z-axis.																																																
primeOper	Primary operator of device.																																																
pulseConfig	Used to configure the output pulse generated with the command if applicable.																																																
pulsQty	Magnitude of the counted value per count. actVal/frVal and pulsQty are used to calculate the value: $value = actVal \times pulsQty$ $value = frVal \times pulsQty$																																																
purpose	Description of the purpose of the object reference.																																																
q	Quality of the attribute(s) representing the value of the data. For the different CDCs, q applies to the following data attributes: <table border="1"> <thead> <tr> <th>CDC</th><th>data attribute q applies to</th></tr> </thead> <tbody> <tr> <td>SPS</td><td>stVal</td></tr> <tr> <td>DPS</td><td>stVal</td></tr> <tr> <td>INS</td><td>stVal</td></tr> <tr> <td>ENS</td><td>stVal</td></tr> <tr> <td>ACT</td><td>general, phsA, phsB, phsC, neut</td></tr> <tr> <td>ACD</td><td>general, dirGeneral, phsA, dirPhsA, phsB, dirPhsB, phsC, dirPhsC, neut, dirNeut</td></tr> <tr> <td>BCR</td><td>actVal, frVal</td></tr> <tr> <td>HST</td><td>hstCnt</td></tr> <tr> <td>VSS</td><td>stVal</td></tr> <tr> <td>MV</td><td>instMag, Mag, range</td></tr> <tr> <td>CMV</td><td>instCMag, cMag, range</td></tr> <tr> <td>SAV</td><td>instMag</td></tr> <tr> <td>HMV</td><td>Har</td></tr> <tr> <td>HWYE</td><td>phsAHar, phsBHar, phsCHar, neutHar, netHar, resHar</td></tr> <tr> <td>HDEL</td><td>phsABHar, phsBCHar, phsCAHar</td></tr> <tr> <td>SPC</td><td>stVal</td></tr> <tr> <td>DPC</td><td>stVal</td></tr> <tr> <td>INC</td><td>stVal</td></tr> <tr> <td>ENC</td><td>stVal</td></tr> <tr> <td>BSC</td><td>valWTr</td></tr> <tr> <td>ISC</td><td>valWTr</td></tr> <tr> <td>APC</td><td>mxVal</td></tr> <tr> <td>BAC</td><td>mxVal</td></tr> </tbody> </table>	CDC	data attribute q applies to	SPS	stVal	DPS	stVal	INS	stVal	ENS	stVal	ACT	general, phsA, phsB, phsC, neut	ACD	general, dirGeneral, phsA, dirPhsA, phsB, dirPhsB, phsC, dirPhsC, neut, dirNeut	BCR	actVal, frVal	HST	hstCnt	VSS	stVal	MV	instMag, Mag, range	CMV	instCMag, cMag, range	SAV	instMag	HMV	Har	HWYE	phsAHar, phsBHar, phsCHar, neutHar, netHar, resHar	HDEL	phsABHar, phsBCHar, phsCAHar	SPC	stVal	DPC	stVal	INC	stVal	ENC	stVal	BSC	valWTr	ISC	valWTr	APC	mxVal	BAC	mxVal
CDC	data attribute q applies to																																																
SPS	stVal																																																
DPS	stVal																																																
INS	stVal																																																
ENS	stVal																																																
ACT	general, phsA, phsB, phsC, neut																																																
ACD	general, dirGeneral, phsA, dirPhsA, phsB, dirPhsB, phsC, dirPhsC, neut, dirNeut																																																
BCR	actVal, frVal																																																
HST	hstCnt																																																
VSS	stVal																																																
MV	instMag, Mag, range																																																
CMV	instCMag, cMag, range																																																
SAV	instMag																																																
HMV	Har																																																
HWYE	phsAHar, phsBHar, phsCHar, neutHar, netHar, resHar																																																
HDEL	phsABHar, phsBCHar, phsCAHar																																																
SPC	stVal																																																
DPC	stVal																																																
INC	stVal																																																
ENC	stVal																																																
BSC	valWTr																																																
ISC	valWTr																																																
APC	mxVal																																																
BAC	mxVal																																																

Data attribute name	Semantics			
range	Range in which the current value of instMag or instCVal.mag is. It may be used to issue an event if the current value changes and transitions to another range. Range shall be used in the context with configuration attributes like hhLim, hLim, lLim, llLim, min and max as shown below.			
		range	validity	detail-qual
	max	_____	high-high	questionable
	hhLim	_____	high-high	good
	hLim	_____	high	good
	lLim	_____	normal	good
	llLim	_____	low	good
	min	_____	low-low	good
			low-low	questionable
				outOfRange
NOTE 7 The use of algorithms to filter events based on transition from one range to another is a local issue.				
NOTE 8 This value with the trigger option "data-change" as described in 61850-7-2 may be used to report an event to the client.				
rangeAng	Range in which the current value of instCVal.ang is. For further details, see range.			
rangeAngC	Configuration parameters as used in the context with the rangeAng attribute.			
rangeC	Configuration parameters as used in the context with the range attribute.			
res	Residual current. Residual current is the algebraic sum of the instantaneous values of currents flowing through all live conductors (i.e. sum over phase currents) of a circuit at a point of the electrical installation. For further details, see phsA (WYE).			
resHar	This array shall contain the harmonic and subharmonics or interharmonic values related to residual current. For further details, see Har.			
rmsCyc	Number of cycles of power frequency, which are used for the calculation of rms values.			
sboClass	Specifies the SBO-class according to the control model of IEC 61850-7-2 that corresponds to the behaviour of the data. The following values are defined: operate-once: Following an operate request, the control object shall return in the unselected state. operate-many: Following an operate request, the control object shall remain in the ready state, as long as sboTimeout did not expire.			
sboTimeout	Specifies the timeout between a select and an operate command according to the control model of IEC 61850-7-2. The value shall be in ms.			
secondOper	Secondary operator of device.			
seqT	This attribute shall specify the type of the sequence. The following values are used:			
	value	c1	c2	c3
	pos-neg-zero	pos	neg	zero
	dir-quad-zero	dir	quad	zero
serNum	Serial number.			
setCal	The value of a time setting, if the time is set with a calendar time.			

Data attribute name	Semantics																																														
setCharact	This attribute shall describe the curve characteristic. The values are defined below. Each curve is of the form $x = f(y)$. There are three options to describe $f(y)$: - characteristic = 1 ... 16: As a formula based on up to 6 parameters A, B, C, D, E and F. The formula is standardized by ANSI or IEC. ANSI and IEC also specify the values for A, B, C, D, E and F in that case, the corresponding attributes (setParA, ..., setParF) are read-only. - characteristic = 17 ... 32: As a definable formula based on up to 6 parameters A, B, C, D, E and F. In that case, it may be possible that the parameters may be modified. The specification of the formula is a local issue. The actual shape of the curve may be read out using a dedicated data of the CDC CSD. - characteristic = 33 ... 48: As a definable curve specified as an array of $n(x,y)$ pairs. The specification of the array can be performed using data of CDC = CSG where applicable. Otherwise it is a local issue. The actual shape of the curve may be read out using a dedicated data of the CDC CSD. <table> <tr> <th>value</th><th>curve characteristic</th></tr> <tr><td>1</td><td>ANSI Extremely Inverse</td></tr> <tr><td>2</td><td>ANSI Very Inverse</td></tr> <tr><td>3</td><td>ANSI Normal Inverse</td></tr> <tr><td>4</td><td>ANSI Moderately Inverse</td></tr> <tr><td>5</td><td>ANSI Definite Time (Definite Time Over Current = default)</td></tr> <tr><td>6</td><td>Long-Time Extremely Inverse</td></tr> <tr><td>7</td><td>Long-Time Very Inverse</td></tr> <tr><td>8</td><td>Long-Time Inverse</td></tr> <tr><td>9</td><td>IEC Normal Inverse</td></tr> <tr><td>10</td><td>IEC Very Inverse</td></tr> <tr><td>11</td><td>IEC Inverse</td></tr> <tr><td>12</td><td>IEC Extremely Inverse</td></tr> <tr><td>13</td><td>IEC Short-Time Inverse</td></tr> <tr><td>14</td><td>IEC Long-Time Inverse</td></tr> <tr><td>15</td><td>IEC Definite Time</td></tr> <tr><td>16</td><td>Reserved</td></tr> <tr><td>17</td><td>Definable curve 1 based on formula $[x=f(y,A,B,C,D, E, F)]$</td></tr> <tr><td>...</td><td></td></tr> <tr><td>32</td><td>Definable curve 16 based on formula $[x=f(y,A,B,C,D, E, F)]$</td></tr> <tr><td>33</td><td>Vendor specific curve 1 defined by n pairs (x,y)</td></tr> <tr><td>...</td><td></td></tr> <tr><td>48</td><td>Vendor specific curve 16 defined by n pairs (x,y)</td></tr> </table>	value	curve characteristic	1	ANSI Extremely Inverse	2	ANSI Very Inverse	3	ANSI Normal Inverse	4	ANSI Moderately Inverse	5	ANSI Definite Time (Definite Time Over Current = default)	6	Long-Time Extremely Inverse	7	Long-Time Very Inverse	8	Long-Time Inverse	9	IEC Normal Inverse	10	IEC Very Inverse	11	IEC Inverse	12	IEC Extremely Inverse	13	IEC Short-Time Inverse	14	IEC Long-Time Inverse	15	IEC Definite Time	16	Reserved	17	Definable curve 1 based on formula $[x=f(y,A,B,C,D, E, F)]$	...		32	Definable curve 16 based on formula $[x=f(y,A,B,C,D, E, F)]$	33	Vendor specific curve 1 defined by n pairs (x,y)	...		48	Vendor specific curve 16 defined by n pairs (x,y)
value	curve characteristic																																														
1	ANSI Extremely Inverse																																														
2	ANSI Very Inverse																																														
3	ANSI Normal Inverse																																														
4	ANSI Moderately Inverse																																														
5	ANSI Definite Time (Definite Time Over Current = default)																																														
6	Long-Time Extremely Inverse																																														
7	Long-Time Very Inverse																																														
8	Long-Time Inverse																																														
9	IEC Normal Inverse																																														
10	IEC Very Inverse																																														
11	IEC Inverse																																														
12	IEC Extremely Inverse																																														
13	IEC Short-Time Inverse																																														
14	IEC Long-Time Inverse																																														
15	IEC Definite Time																																														
16	Reserved																																														
17	Definable curve 1 based on formula $[x=f(y,A,B,C,D, E, F)]$																																														
...																																															
32	Definable curve 16 based on formula $[x=f(y,A,B,C,D, E, F)]$																																														
33	Vendor specific curve 1 defined by n pairs (x,y)																																														
...																																															
48	Vendor specific curve 16 defined by n pairs (x,y)																																														
setMag	The value of an analogue setting or set point.																																														
setParA	Attribute used to set the parameter A of the setting curve (see detailed description under setCharact).																																														
setParB	Attribute used to set the parameter B of the setting curve (see detailed description under setCharact).																																														
setParC	Attribute used to set the parameter C of the setting curve (see detailed description under setCharact).																																														
setParD	Attribute used to set the parameter D of the setting curve (see detailed description under setCharact).																																														
setParE	Attribute used to set the parameter E of the setting curve (see detailed description under setCharact).																																														
setParF	Attribute used to set the parameter F of the setting curve (see detailed description under setCharact).																																														
setSrcCB	The value of the object reference to the control block indicating from where the object referred to with setSrcRef shall be received.																																														
setSrcRef	The value of the object reference setting. The attribute may be used to reference e.g. a logical node instance or a data object instance.																																														
setTm	The value of a time setting, if the time is set with a time stamp.																																														
setTstCB	The value of the object reference to the control block indicating from where the object referred to with setTstRef shall be received. For details, see tstEna.																																														
setTstRef	The value of the object reference setting used when tstEna is true for testing purpose as an alternate reference to the reference set with setSrcRef. For details, see tstEna.																																														

Data attribute name	Semantics												
setVal	The value of a status setting.												
sev	Severity of the last violation detected. The values are: <table> <tr> <th>value</th><th></th></tr> <tr> <td>unknown</td><td>Severity cannot be determined.</td></tr> <tr> <td>critical</td><td>Severity is critical in terms of safe operation or data considered critical and privileged access was attempted.</td></tr> <tr> <td>major</td><td>Severity is major in terms of safe operation or data considered of major importance and privileged access was attempted.</td></tr> <tr> <td>minor</td><td>Severity is minor in the sense that access control was denied to data considered privileged.</td></tr> <tr> <td>warning</td><td>Is less severe than minor.</td></tr> </table>	value		unknown	Severity cannot be determined.	critical	Severity is critical in terms of safe operation or data considered critical and privileged access was attempted.	major	Severity is major in terms of safe operation or data considered of major importance and privileged access was attempted.	minor	Severity is minor in the sense that access control was denied to data considered privileged.	warning	Is less severe than minor.
value													
unknown	Severity cannot be determined.												
critical	Severity is critical in terms of safe operation or data considered critical and privileged access was attempted.												
major	Severity is major in terms of safe operation or data considered of major importance and privileged access was attempted.												
minor	Severity is minor in the sense that access control was denied to data considered privileged.												
warning	Is less severe than minor.												
smpRate (HVM, HWYE, HDEL)	Determines according to the sampling theorem the highest possible harmonic or interharmonic detectable. The minimum is $2 \times$ frequency. The value shall represent the number of samples per nominal period. In the case of a d.c. system, the value shall represent the number of samples per s.												
smpRate (MV, CMV, WYE, DEL)	Sampling rate that has been used to determine the analogue values. The value shall represent the number of samples per nominal period. In the case of a d.c. system, the value shall represent the number of samples per s.												
stepSize	Defines the step between individual values that ctVal (CDC INC, APC, BAC), setVal (CDC ING) or setMag (CDC ASG) will accept.												
strTm	Starting time of the freeze process. If the current time is later than the start time, the first freeze shall occur at the next freeze interval (frPd) expiration, computed from the start time setting.												
stSeld	The controllable data is in the status "selected".												
stVal	Status value of the data.												
subCVal	Value used to substitute the data attribute instCVal.												

Data attribute name	Semantics																														
subEna	Used to enable substitution. If this attribute is set to true, the attribute(s) representing the value of the data instance shall always be set to the same value as the attribute(s) used to store the substitution value of the data. If this attribute is set to false, the attribute(s) representing the value of the data instance shall be based on the process value. For the different CDCs, subEna applies to the following data attributes: <table border="1"> <thead> <tr> <th>CDC</th><th>data attribute subEna applies to</th></tr> </thead> <tbody> <tr> <td>SPS</td><td>stVal and subVal, q and subQ</td></tr> <tr> <td>DPS</td><td>stVal and subVal, q and subQ</td></tr> <tr> <td>INS</td><td>stVal and subVal, q and subQ</td></tr> <tr> <td>ENS</td><td>stVal and subVal, q and subQ</td></tr> <tr> <td>MV</td><td>instMag and subMag, q and subQ</td></tr> <tr> <td>CMV</td><td>instCVal and subCVal, q and subQ</td></tr> <tr> <td>SPC</td><td>stVal and subVal, q and subQ</td></tr> <tr> <td>DPC</td><td>stVal and subVal, q and subQ</td></tr> <tr> <td>INC</td><td>stVal and subVal, q and subQ</td></tr> <tr> <td>ENC</td><td>stVal and subVal, q and subQ</td></tr> <tr> <td>BSC</td><td>valWTr and subVal, q and subQ</td></tr> <tr> <td>ISC</td><td>valWTr and subVal, q and subQ</td></tr> <tr> <td>APC</td><td>mxVal and subVal; q and subQ</td></tr> <tr> <td>BAC</td><td>mxVal and subVal; q and subQ</td></tr> </tbody> </table> In the typical use case for substitution, an operator on the client side enters manually a value for a DataAttribute located in a specific device. The client sets the DataAttribute to the value entered. If a client accesses the value of that DataAttribute (for example, using a GetDataValue service or subscribing to a report), the client shall receive the manual entered (substituted) value instead of the value determined by the process. The concept of substitution is shown below. Usually, input from the process or the result of the calculation from a function provides the value of a DataAttribute (in that case, the source is called "process"). In case of substitution, the value of a DataAttribute may be provided by an operator making use of a client. This selection of the source of the value (substitution value or process value) shall be controlled by the service SetDataValue ("xy.subEna" <TRUE>) to substitute or SetDataValue ("xy.subEna" <FALSE>) to unsubstute. The service SetDataValue ("xy.subVal" <value for substitution>) shall be used to set the substituted value. There may be cases where a local automatic function disables substitution, for example, if blocking of information exchange is disabled or communication is no longer interrupted. Example: Common data class "SPS" (see IEC 61850-7-3) IEC 2559/10 It is the responsibility of the client application, in particular in the case of multiple attributes to be substituted, to set all relevant substitution values before enabling substitution. While substitution is enabled, changing of all substitution-related attributes is allowed but it is the responsibility of the implementation to avoid inconsistent transient value combination.	CDC	data attribute subEna applies to	SPS	stVal and subVal, q and subQ	DPS	stVal and subVal, q and subQ	INS	stVal and subVal, q and subQ	ENS	stVal and subVal, q and subQ	MV	instMag and subMag, q and subQ	CMV	instCVal and subCVal, q and subQ	SPC	stVal and subVal, q and subQ	DPC	stVal and subVal, q and subQ	INC	stVal and subVal, q and subQ	ENC	stVal and subVal, q and subQ	BSC	valWTr and subVal, q and subQ	ISC	valWTr and subVal, q and subQ	APC	mxVal and subVal; q and subQ	BAC	mxVal and subVal; q and subQ
CDC	data attribute subEna applies to																														
SPS	stVal and subVal, q and subQ																														
DPS	stVal and subVal, q and subQ																														
INS	stVal and subVal, q and subQ																														
ENS	stVal and subVal, q and subQ																														
MV	instMag and subMag, q and subQ																														
CMV	instCVal and subCVal, q and subQ																														
SPC	stVal and subVal, q and subQ																														
DPC	stVal and subVal, q and subQ																														
INC	stVal and subVal, q and subQ																														
ENC	stVal and subVal, q and subQ																														
BSC	valWTr and subVal, q and subQ																														
ISC	valWTr and subVal, q and subQ																														
APC	mxVal and subVal; q and subQ																														
BAC	mxVal and subVal; q and subQ																														
subID	Shows the address of the device that made the substitution. The value of null shall be used if subEna is false or if the device is not known.																														
subMag	Value used to substitute the data attribute instMag.																														
subQ	Value used to substitute the data attribute q.																														

Data attribute name	Semantics																																																		
subVal	Value used to substitute the attribute representing the value of the data instance. For the different CDCs, subVal is used to substitute the following data attributes: <table> <tr> <th>CDC</th><th>data attribute subVal is used to substitute</th></tr> <tr><td>SPS</td><td>stVal</td></tr> <tr><td>DPS</td><td>stVal</td></tr> <tr><td>INS</td><td>stVal</td></tr> <tr><td>ENS</td><td>stVal</td></tr> <tr><td>SPC</td><td>stVal</td></tr> <tr><td>DPC</td><td>stVal</td></tr> <tr><td>INC</td><td>stVal</td></tr> <tr><td>ENC</td><td>stVal</td></tr> <tr><td>BSC</td><td>valWTr</td></tr> <tr><td>ISC</td><td>valWTr</td></tr> <tr><td>APC</td><td>mxVal</td></tr> <tr><td>BAC</td><td>mxVal</td></tr> </table>	CDC	data attribute subVal is used to substitute	SPS	stVal	DPS	stVal	INS	stVal	ENS	stVal	SPC	stVal	DPC	stVal	INC	stVal	ENC	stVal	BSC	valWTr	ISC	valWTr	APC	mxVal	BAC	mxVal																								
CDC	data attribute subVal is used to substitute																																																		
SPS	stVal																																																		
DPS	stVal																																																		
INS	stVal																																																		
ENS	stVal																																																		
SPC	stVal																																																		
DPC	stVal																																																		
INC	stVal																																																		
ENC	stVal																																																		
BSC	valWTr																																																		
ISC	valWTr																																																		
APC	mxVal																																																		
BAC	mxVal																																																		
sVC	Scaled value configuration. Shall be used to configure the scaled value representation. For the different CDCs, sVC applies to the following data attributes and service parameters: <table> <tr> <th>CDC</th><th>data attribute sVC applies to</th></tr> <tr><td>MV</td><td>instMag, mag, subMag, rangeC</td></tr> <tr><td>SAV</td><td>instMag, min, max</td></tr> <tr><td>APC</td><td>mxVal, subVal, minVal, maxVal, stepSize, service parameter ctrlVal</td></tr> <tr><td>BAC</td><td>mxVal, subVal, minVal, maxVal, stepSize</td></tr> <tr><td>ASG</td><td>setMag, minVal, maxVal, stepSize</td></tr> </table>	CDC	data attribute sVC applies to	MV	instMag, mag, subMag, rangeC	SAV	instMag, min, max	APC	mxVal, subVal, minVal, maxVal, stepSize, service parameter ctrlVal	BAC	mxVal, subVal, minVal, maxVal, stepSize	ASG	setMag, minVal, maxVal, stepSize																																						
CDC	data attribute sVC applies to																																																		
MV	instMag, mag, subMag, rangeC																																																		
SAV	instMag, min, max																																																		
APC	mxVal, subVal, minVal, maxVal, stepSize, service parameter ctrlVal																																																		
BAC	mxVal, subVal, minVal, maxVal, stepSize																																																		
ASG	setMag, minVal, maxVal, stepSize																																																		
swRev	SW-revision.																																																		
t	Timestamp of the last change in one of the attribute(s) representing the value of the data or in the q attribute. For the different CDCs, t applies to the following data attributes: <table> <tr> <th>CDC</th><th>data attribute t applies to</th></tr> <tr><td>SPS</td><td>stVal</td></tr> <tr><td>DPS</td><td>stVal</td></tr> <tr><td>INS</td><td>stVal</td></tr> <tr><td>ENS</td><td>stVal</td></tr> <tr><td>ACT</td><td>general, phsA, phsB, phsC, neut</td></tr> <tr><td>ACD</td><td>general, dirGeneral, phsA, dirPhsA, phsB, dirPhsB, phsC, dirPhsC, neut, dirNeut</td></tr> <tr><td>SEC</td><td>cnt</td></tr> <tr><td>BCR</td><td>actVal</td></tr> <tr><td>HST</td><td>hstCnt</td></tr> <tr><td>VSS</td><td>stVal</td></tr> <tr><td>MV</td><td>mag, range</td></tr> <tr><td>CMV</td><td>cVal, range</td></tr> <tr><td>SAV</td><td>instMag</td></tr> <tr><td>HMV</td><td>Har</td></tr> <tr><td>HWYE</td><td>phsAHar, phsBHar, phsCHar, neutHar, netHar, resHar</td></tr> <tr><td>HDEL</td><td>phsABHar, phsBCHar, phsCAHar</td></tr> <tr><td>SPC</td><td>stVal</td></tr> <tr><td>DPC</td><td>stVal</td></tr> <tr><td>INC</td><td>stVal</td></tr> <tr><td>ENC</td><td>stVal</td></tr> <tr><td>BSC</td><td>valWTr</td></tr> <tr><td>ISC</td><td>valWTr</td></tr> <tr><td>APC</td><td>mxVal</td></tr> <tr><td>BAC</td><td>mxVal</td></tr> </table>	CDC	data attribute t applies to	SPS	stVal	DPS	stVal	INS	stVal	ENS	stVal	ACT	general, phsA, phsB, phsC, neut	ACD	general, dirGeneral, phsA, dirPhsA, phsB, dirPhsB, phsC, dirPhsC, neut, dirNeut	SEC	cnt	BCR	actVal	HST	hstCnt	VSS	stVal	MV	mag, range	CMV	cVal, range	SAV	instMag	HMV	Har	HWYE	phsAHar, phsBHar, phsCHar, neutHar, netHar, resHar	HDEL	phsABHar, phsBCHar, phsCAHar	SPC	stVal	DPC	stVal	INC	stVal	ENC	stVal	BSC	valWTr	ISC	valWTr	APC	mxVal	BAC	mxVal
CDC	data attribute t applies to																																																		
SPS	stVal																																																		
DPS	stVal																																																		
INS	stVal																																																		
ENS	stVal																																																		
ACT	general, phsA, phsB, phsC, neut																																																		
ACD	general, dirGeneral, phsA, dirPhsA, phsB, dirPhsB, phsC, dirPhsC, neut, dirNeut																																																		
SEC	cnt																																																		
BCR	actVal																																																		
HST	hstCnt																																																		
VSS	stVal																																																		
MV	mag, range																																																		
CMV	cVal, range																																																		
SAV	instMag																																																		
HMV	Har																																																		
HWYE	phsAHar, phsBHar, phsCHar, neutHar, netHar, resHar																																																		
HDEL	phsABHar, phsBCHar, phsCAHar																																																		
SPC	stVal																																																		
DPC	stVal																																																		
INC	stVal																																																		
ENC	stVal																																																		
BSC	valWTr																																																		
ISC	valWTr																																																		
APC	mxVal																																																		
BAC	mxVal																																																		
tOpOk	The time stamp with the time, when an output of a controllable object is activated following a control command. For details, see opRcvd.																																																		

Data attribute name	Semantics						
zeroDb	Configuration parameter used to calculate the range around zero, where the analogue value will be forced to zero. The value shall represent the percentage of difference between max and min in units of 0,001 %. For the different CDCs, zeroDb applies to the following data attributes: <table><tr><th>CDC</th><th>data attribute zeroDb applies to</th></tr><tr><td>MV</td><td>mag</td></tr><tr><td>CMV</td><td>cVal.mag</td></tr></table>	CDC	data attribute zeroDb applies to	MV	mag	CMV	cVal.mag
CDC	data attribute zeroDb applies to						
MV	mag						
CMV	cVal.mag						
zUnits	Unit of the z-axis of a curve.						

IECNORM.COM : Click to view the full PDF of IEC 61850-7-3:2010

Annex A (normative)

Value range for units and multiplier

The units shall be SI units. The enumeration shall be as defined in Table A.1, Table A.2, Table A.3 and Table A.4. The multiplier shall be represented as an enumeration where the value of the enumeration equals the exponent of the multiplier value in base 10, as defined in Table A.5.

Table A.1 – SI units: base units

Value	Quantity	Unit name	Symbol
1	None	dimensionless	none
2	Length	meter	m
3	Mass	kilogram	kg
4	Time	second	s
5	Current	ampere	A
6	Temperature	Kelvin	K
7	Amount of substance	mole	mol
8	Luminous intensity	candela	cd

Table A.2 – SI units: derived units

Value	Quantity	Unit name	Symbol
9	Plane angle	degrees	deg
10	Plane angle	radian	rad
11	Solid angle	steradian	sr
21	Absorbed dose	Gray (J/kg)	Gy
22	Activity	becquerel (1/s)	Bq
23	Relative temperature	degrees Celsius	°C
24	Dose equivalent	sievert (J/kg)	Sv
25	Electric capacitance	farad (C/V)	F
26	Electric charge	coulomb (As)	C
27	Electric conductance	siemens (A/V)	S
28	Electric inductance	henry (Wb/A)	H
29	Electric potential	volt (W/A)	V
30	Electric resistance	ohm (V/A)	Ω
31	Energy	joule (N m)	J
32	Force	newton (kg m/s ²)	N
33	Frequency	hertz (1/s)	Hz
34	Illuminance	lux (lm/m ²)	lx
35	Luminous flux	lumen (cd sr)	lm
36	Magnetic flux	weber (V s)	Wb
37	Magnetic flux density	tesla (Wb/m ²)	T
38	Power	watt (J/s)	W
39	Pressure	pascal (N/m ²)	Pa

Table A.3 – SI units: extended units

Value	Quantity	Unit name	Symbol
41	Area	square meter (m ²)	m ²
42	Volume	cubic meter (m ³)	m ³
43	Velocity	meters per second (m/s)	ms ⁻¹
44	Acceleration	meters per second ² (m/s ²)	ms ⁻²
45	Volumetric flow rate	cubic meters per second (m ³ /s)	m ³ s ⁻¹
46	Fuel efficiency	meters/cubic meter (m/m ³)	m/m ³
47	Moment of mass	kilogram meter (kg m)	M
48	Density	kilogram/cubic meter (kg/m ³)	kg/m ³
49	Viscosity	meter square/second (m ² /s)	m ² /s
50	Thermal conductivity	watt/meter Kelvin (W/m K)	W/m K
51	Heat capacity	joule/Kelvin (J/K)	J/K
52	Concentration	parts per million	ppm
53	Rotational speed	rotations per second (1/s)	s ⁻¹
54	Angular velocity	radian per second (rad/s)	rads ⁻¹
55	Insolation	watt per square meter	W/m ²
56	Insolation energy	watt seconds per square meter	J/m ²
57	Electric conductivity	siemens per meter	S/m
58	Temperature change rate	kelvin per second	K/s
59	Pressure change rate	pascal per second	Pa/s
60	Specific heat	joule per kilogram per kelvin	J/kg K

Table A.4 – SI units: industry specific units

Value	Quantity	Unit name	Symbol
61	Apparent power	volt ampere (VA)	VA
62	Real power	watts (I ² R)	W
63	Reactive power	volt ampere reactive (VISinθ)	VA _r
64	Phase angle	degrees	θ
65	Power factor	(dimensionless)	Cosθ
66	Volt seconds	volt seconds (Ws/A)	Vs
67	Volts squared	volt square (W ² /A ²)	V ²
68	Amp seconds	amp second (As)	As
69	Amps squared	amp square (A ²)	A ²
70	Amps squared time	amp square second (A ² s)	A ² t
71	Apparent energy	volt ampere hours	VAh
72	Real energy	watt hours	Wh
73	Reactive energy	volt ampere reactive hours	VA _r h
74	Magnetic flux	volts per hertz	V/Hz
75	Rate of change of frequency	hertz per second	Hz/s
76	Number of characters	characters	char
77	Baud	characters per second	char/s

Value	Quantity	Unit name	Symbol
78	Turbine inertia	kg square meter	kgm ²
79	Sound pressure level	decibel	dB
80	Heat rate	joule per watt-hour	J/Wh
81	Ramp rate	watt per second	W/s
82	Flow rate	litres per second	L/s
83	Power level	power measurement relative to 1 mW	dBm

Table A.5 – Multiplier

Value	Multiplier value	Name	Symbol
–24	10 ^{–24}	Yocto	y
–21	10 ^{–21}	Zepto	z
–18	10 ^{–18}	Atto	a
–15	10 ^{–15}	Femto	f
–12	10 ^{–12}	Pico	p
–9	10 ^{–9}	Nano	n
–6	10 ^{–6}	Micro	μ
–3	10 ^{–3}	Milli	m
–2	10 ^{–2}	Centi	c
–1	10 ^{–1}	Deci	d
0	1		
1	10 ¹	Deca	da
2	10 ²	Hecto	h
3	10 ³	Kilo	k
6	10 ⁶	Mega	M
9	10 ⁹	Giga	G
12	10 ¹²	Tera	T
15	10 ¹⁵	Peta	P
18	10 ¹⁸	Exa	E
21	10 ²¹	Zetta	Z
24	10 ²⁴	Yotta	Y

NOTE A value that is representing a percentage can use the unit 1 (dimensionless) and a multiplier –2.

Annex B (informative)

Functional constraints

The functional constraints are defined in IEC 61850-7-2. Those that are relevant for this part of IEC 61850 are repeated here for better reading of the standard. See Table B.1.

IECNORM.COM : Click to view the full PDF of IEC 61850-7-3:2010

Table B.1 – Functional constraints

FunctionalConstraint values			
FC	Semantic	Services allowed	Initial values/storage/ explanation
ST	Status information	DataAttribute shall represent status information whose value may be read, substituted, reported, and logged but shall not be writeable.	Initial value of the DataAttribute shall be taken from the process.
MX	Measurands (analogue values)	DataAttribute shall represent measurand information whose value may be read, substituted, reported, and logged but shall not be writeable.	Initial value of the DataAttribute shall be taken from the process.
SP	Setting (outside setting group)	DataAttribute shall represent setting parameter information whose value is read and may be written. Changes of values shall become effective immediately, and may be reported.	Initial value of the DataAttribute shall be as configured; value shall be non-volatile.
SV	Substitution	DataAttribute shall represent substitution information whose value may be written to substitute the value attribute and read. A value change may be reported.	If the value of the DataAttribute is volatile then the initial value shall be FALSE, else the value should be as set or configured.
CF	Configuration	DataAttribute shall represent configuration information whose value may be written and read. Values written may become effective immediately or deferred by reasons outside the scope of this standard. Value changes may be reported.	Initial value of the DataAttribute shall be as configured; value shall be non-volatile.
DC	Description	DataAttribute shall represent description information whose value may be written and read.	Initial value of the DataAttribute shall be as configured; value shall be non-volatile.
SG	Setting group	Logical devices that implement the SGCB class maintain multiple grouped values of all instances of DataAttributes with functional constraint SG. Each group contains one value for each DataAttribute. DataAttributes with functional constraint SG shall be the current active value (for details, see IEC 61850-7-2). DataAttributes with FC=SG shall not be writeable.	Initial value of the DataAttribute shall be as configured; value shall be non-volatile.
SE	Setting group editable	DataAttribute that can be edited by SGCB services. Defines the edit buffer for the value sets belonging to attributes with FC=SG.	Value of the DataAttribute shall be available after SelectEditSG service has been processed.
SR	Service response	DataAttribute shall represent data from different process objects with the same tracking object whose values can be used to be reported and logged; the values shall not be writeable. These attributes are used for service tracking (see IEC 61850-7-2).	Initial value of the DataAttribute are a private issue, e.g., all zero (except for times stamp).
OR	Operate received	DataAttribute shall represent the result of an Operate request at the data object receiving the Operate request, even if the execution of the Operate is blocked.	Initial value is irrelevant / arbitrary
BL	Blocking	DataAttribute is used for blocking value updates	If the value of the DataAttribute is volatile then the initial value shall be FALSE, else the value should be as set or configured.
EX	Extended definition (application name space)	DataAttribute shall represent an application name space. Application name spaces are used to define the semantic definitions of LNs, data object class, and DataAttributes as specified in 61850-7-3 and IEC 61850-7-4. DataAttributes with FC=EX shall not be writeable, Note that private extensions of control blocks may use the FC EX at SCSM level.	Value of the DataAttribute shall be as configured; value shall be non-volatile.

Annex C (normative)

Tracking of configuration revisions

		Issue	Impact / Comment	Where is the change made?		configRev	paramRev	valRev	confRev
				In config file	In IED only				
Configuration	Data model and semantic	Semantic change within a logical device / logical node	A logical node gets a new semantic use; e.g. a instance of a LN CSWI is now serving a different physical switch or an instance of a logical node PDIS is now used for another zone. A data gets a new semantic use; e.g. the use of GGIO.Alm1 changes from "Door open" to "Fire alarm".			x			
		Change of domain data model (presence of LNs, Data, Data Attributes; Instance names)	Available information. Identification of the information.	Through IED configuration tool		x			
		Content of data sets; presence of data sets and control blocks	Subscribers of GOOSE or sampled value messages may be affected. Preconfigured clients for reporting are affected.	Through system or IED configuration tool	Communication services (where applicable) or local HMI				x
		Enabling and disabling control blocks		Through system or IED configuration tool (pre-configuration)					
Operation / pre-configuration	Communication behaviour	Changing selected values of control blocks (for details, see IEC 61850-7-2)	Message content may not be as expected (reference to data set may change). For sampled values, sample rate may be changed. For sampled values, message structure may be changed.	Through system or IED configuration tool (pre-configuration)	Communication services (where applicable) or local HMI				x
		Editing values of setting groups (SE)		Through IED configuration tool (pre-configuration) or through system configuration tool			x		
		Change of a setting (SP)					x		
	Settings and setting groups	Change of the active setting group (SG)	Preconfigured active setting group. Change online of active SG through specific service.						
		Change of the value of a CF attribute							x

Annex D (normative) SCL enumerations

```

<EnumType id="ControlOutputKind">
  <EnumVal ord="0">pulse</EnumVal>
  <EnumVal ord="1">persistent</EnumVal>
</EnumType>
<EnumType id="CtlModelKind">
  <EnumVal ord="0">status-only</EnumVal>
  <EnumVal ord="1">direct-with-normal-security</EnumVal>
  <EnumVal ord="2">sbo-with-normal-security</EnumVal>
  <EnumVal ord="3">direct-with-enhanced-security</EnumVal>
  <EnumVal ord="4">sbo-with-enhanced-security</EnumVal>
</EnumType>
<EnumType id="SboClassKind">
  <EnumVal ord="0">operate-once</EnumVal>
  <EnumVal ord="1">operate-many</EnumVal>
</EnumType>
<EnumType id="OriginatorCategoryKind">
  <EnumVal ord="0">not-supported</EnumVal>
  <EnumVal ord="1">bay-control</EnumVal>
  <EnumVal ord="2">station-control</EnumVal>
  <EnumVal ord="3">remote-control</EnumVal>
  <EnumVal ord="4">automatic-bay</EnumVal>
  <EnumVal ord="5">automatic-station</EnumVal>
  <EnumVal ord="6">automatic-remote</EnumVal>
  <EnumVal ord="7">maintenance</EnumVal>
  <EnumVal ord="8">process</EnumVal>
</EnumType>
<EnumType id="OccurrenceKind">
  <EnumVal ord="0">Time</EnumVal>
  <EnumVal ord="1">WeekDay</EnumVal>
  <EnumVal ord="2">WeekOfYear</EnumVal>
  <EnumVal ord="3">DayOfMonth</EnumVal>
  <EnumVal ord="4">DayOfYear</EnumVal>
</EnumType>
<EnumType id="MonthKind">
  <EnumVal ord="0">reserved</EnumVal>
  <EnumVal ord="1">January</EnumVal>
  <EnumVal ord="2">February</EnumVal>
  <EnumVal ord="3">March</EnumVal>
  <EnumVal ord="4">April</EnumVal>
  <EnumVal ord="5">May</EnumVal>
  <EnumVal ord="6">June</EnumVal>
  <EnumVal ord="7">July</EnumVal>

```

```
<EnumVal ord="8">August</EnumVal>
<EnumVal ord="9">September</EnumVal>
<EnumVal ord="10">October</EnumVal>
<EnumVal ord="11">November</EnumVal>
<EnumVal ord="12">December</EnumVal>
</EnumType>
<EnumType id="PeriodKind">
  <EnumVal ord="0">Hour</EnumVal>
  <EnumVal ord="1">Day</EnumVal>
  <EnumVal ord="2">Week</EnumVal>
  <EnumVal ord="3">Month</EnumVal>
  <EnumVal ord="4">Year</EnumVal>
</EnumType>
<EnumType id="DaWeekdayKind">
  <EnumVal ord="0">reserved</EnumVal>
  <EnumVal ord="1">Monday</EnumVal>
  <EnumVal ord="2">Tuesday</EnumVal>
  <EnumVal ord="3">Wednesday</EnumVal>
  <EnumVal ord="4">Thursday</EnumVal>
  <EnumVal ord="5">Friday</EnumVal>
  <EnumVal ord="6">Saturday</EnumVal>
  <EnumVal ord="7">Sunday</EnumVal>
</EnumType>
<EnumType id="FaultDirectionKind">
  <EnumVal ord="0">unknown</EnumVal>
  <EnumVal ord="1">forward</EnumVal>
  <EnumVal ord="2">backward</EnumVal>
  <EnumVal ord="3">both</EnumVal>
</EnumType>
<EnumType id="PhaseFaultDirectionKind">
  <EnumVal ord="0">unknown</EnumVal>
  <EnumVal ord="1">forward</EnumVal>
  <EnumVal ord="2">backward</EnumVal>
</EnumType>
<EnumType id="SeverityKind">
  <EnumVal ord="0">unknown</EnumVal>
  <EnumVal ord="1">critical</EnumVal>
  <EnumVal ord="2">major</EnumVal>
  <EnumVal ord="3">minor</EnumVal>
  <EnumVal ord="4">warning</EnumVal>
</EnumType>
<EnumType id="RangeKind">
  <EnumVal ord="0">normal</EnumVal>
  <EnumVal ord="1">high</EnumVal>
  <EnumVal ord="2">low</EnumVal>
  <EnumVal ord="3">high-high</EnumVal>
  <EnumVal ord="4">low-low</EnumVal>
```

```

</EnumType>
<EnumType id="AngleReferenceKind">
  <EnumVal ord="0">V</EnumVal>
  <EnumVal ord="1">A</EnumVal>
  <EnumVal ord="2">other</EnumVal>
  <EnumVal ord="3">Synchrophasor</EnumVal>
</EnumType>
<EnumType id="PhaseAngleReferenceKind">
  <EnumVal ord="0">Va</EnumVal>
  <EnumVal ord="1">Vb</EnumVal>
  <EnumVal ord="2">Vc</EnumVal>
  <EnumVal ord="3">Aa</EnumVal>
  <EnumVal ord="4">Ab</EnumVal>
  <EnumVal ord="5">Ac</EnumVal>
  <EnumVal ord="6">Vab</EnumVal>
  <EnumVal ord="7">Vbc</EnumVal>
  <EnumVal ord="8">Vca</EnumVal>
  <EnumVal ord="9">Vother</EnumVal>
  <EnumVal ord="10">Aother</EnumVal>
  <EnumVal ord="11">Synchrophasor</EnumVal>
</EnumType>
<EnumType id="PhaseReferenceKind">
  <EnumVal ord="0">A</EnumVal>
  <EnumVal ord="1">B</EnumVal>
  <EnumVal ord="2">C</EnumVal>
</EnumType>
<EnumType id="SequenceKind">
  <EnumVal ord="0">pos-neg-zero</EnumVal>
  <EnumVal ord="1">dir-quad-zero</EnumVal>
</EnumType>
<EnumType id="HvReferenceKind">
  <EnumVal ord="0">fundamental</EnumVal>
  <EnumVal ord="1">rms</EnumVal>
  <EnumVal ord="2">absolute</EnumVal>
</EnumType>
<EnumType id="CurveCharKind">
  <EnumVal ord="0">none</EnumVal>
  <EnumVal ord="1">ANSI Extremely Inverse</EnumVal>
  <EnumVal ord="2">ANSI Very Inverse</EnumVal>
  <EnumVal ord="3">ANSI Normal Inverse</EnumVal>
  <EnumVal ord="4">ANSI Moderate Inverse</EnumVal>
  <EnumVal ord="5">ANSI Definite Time</EnumVal>
  <EnumVal ord="6">Long-Time Extremely Inverse</EnumVal>
  <EnumVal ord="7">Long-Time Very Inverse</EnumVal>
  <EnumVal ord="8">Long-Time Inverse</EnumVal>
  <EnumVal ord="9">IEC Normal Inverse</EnumVal>
  <EnumVal ord="10">IEC Very Inverse</EnumVal>

```



```

<EnumVal ord="11">IEC Inverse</EnumVal>
<EnumVal ord="12">IEC Extremely Inverse</EnumVal>
<EnumVal ord="13">IEC Short-Time Inverse</EnumVal>
<EnumVal ord="14">IEC Long-Time Inverse</EnumVal>
<EnumVal ord="15">IEC Definite Time</EnumVal>
<EnumVal ord="16">Reserved</EnumVal>
<EnumVal ord="17">Polynom 1</EnumVal>
<EnumVal ord="18">Polynom 2</EnumVal>
<EnumVal ord="19">Polynom 3</EnumVal>
<EnumVal ord="20">Polynom 4</EnumVal>
<EnumVal ord="21">Polynom 5</EnumVal>
<EnumVal ord="22">Polynom 6</EnumVal>
<EnumVal ord="23">Polynom 7</EnumVal>
<EnumVal ord="24">Polynom 8</EnumVal>
<EnumVal ord="25">Polynom 9</EnumVal>
<EnumVal ord="26">Polynom 10</EnumVal>
<EnumVal ord="27">Polynom 11</EnumVal>
<EnumVal ord="28">Polynom 12</EnumVal>
<EnumVal ord="29">Polynom 13</EnumVal>
<EnumVal ord="30">Polynom 14</EnumVal>
<EnumVal ord="31">Polynom 15</EnumVal>
<EnumVal ord="32">Polynom 16</EnumVal>
<EnumVal ord="33">Multiline 1</EnumVal>
<EnumVal ord="34">Multiline 2</EnumVal>
<EnumVal ord="35">Multiline 3</EnumVal>
<EnumVal ord="36">Multiline 4</EnumVal>
<EnumVal ord="37">Multiline 5</EnumVal>
<EnumVal ord="38">Multiline 6</EnumVal>
<EnumVal ord="39">Multiline 7</EnumVal>
<EnumVal ord="40">Multiline 8</EnumVal>
<EnumVal ord="41">Multiline 9</EnumVal>
<EnumVal ord="42">Multiline 10</EnumVal>
<EnumVal ord="43">Multiline 11</EnumVal>
<EnumVal ord="44">Multiline 12</EnumVal>
<EnumVal ord="45">Multiline 13</EnumVal>
<EnumVal ord="46">Multiline 14</EnumVal>
<EnumVal ord="47">Multiline 15</EnumVal>
<EnumVal ord="48">Multiline 16</EnumVal>
</EnumType>
<EnumType id="MultiplierKind">
  <EnumVal ord="-24">y</EnumVal>
  <EnumVal ord="-21">z</EnumVal>
  <EnumVal ord="-18">a</EnumVal>
  <EnumVal ord="-15">f</EnumVal>
  <EnumVal ord="-12">p</EnumVal>
  <EnumVal ord="-9">n</EnumVal>
  <EnumVal ord="-6">μ</EnumVal>

```

```

<EnumVal ord="-3">m</EnumVal>
<EnumVal ord="-2">c</EnumVal>
<EnumVal ord="-1">d</EnumVal>
<EnumVal ord="0"></EnumVal>
<EnumVal ord="1">da</EnumVal>
<EnumVal ord="2">h</EnumVal>
<EnumVal ord="3">k</EnumVal>
<EnumVal ord="6">M</EnumVal>
<EnumVal ord="9">G</EnumVal>
<EnumVal ord="12">T</EnumVal>
<EnumVal ord="15">P</EnumVal>
<EnumVal ord="18">E</EnumVal>
<EnumVal ord="21">Z</EnumVal>
<EnumVal ord="24">Y</EnumVal>
</EnumType>
<EnumType id="SIUnitKind">
  <EnumVal ord="1"></EnumVal>
  <EnumVal ord="2">m</EnumVal>
  <EnumVal ord="3">kg</EnumVal>
  <EnumVal ord="4">s</EnumVal>
  <EnumVal ord="5">A</EnumVal>
  <EnumVal ord="6">K</EnumVal>
  <EnumVal ord="7">mol</EnumVal>
  <EnumVal ord="8">cd</EnumVal>
  <EnumVal ord="9">deg</EnumVal>
  <EnumVal ord="10">rad</EnumVal>
  <EnumVal ord="11">sr</EnumVal>
  <EnumVal ord="21">Gy</EnumVal>
  <EnumVal ord="22">Bq</EnumVal>
  <EnumVal ord="23">°C</EnumVal>
  <EnumVal ord="24">Sv</EnumVal>
  <EnumVal ord="25">F</EnumVal>
  <EnumVal ord="26">C</EnumVal>
  <EnumVal ord="27">S</EnumVal>
  <EnumVal ord="28">H</EnumVal>
  <EnumVal ord="29">V</EnumVal>
  <EnumVal ord="30">ohm</EnumVal>
  <EnumVal ord="31">J</EnumVal>
  <EnumVal ord="32">N</EnumVal>
  <EnumVal ord="33">Hz</EnumVal>
  <EnumVal ord="34">Ix</EnumVal>
  <EnumVal ord="35">Lm</EnumVal>
  <EnumVal ord="36">Wb</EnumVal>
  <EnumVal ord="37">T</EnumVal>
  <EnumVal ord="38">W</EnumVal>
  <EnumVal ord="39">Pa</EnumVal>
  <EnumVal ord="41">m²</EnumVal>

```

```

<EnumVal ord="42">m³</EnumVal>
<EnumVal ord="43">m/s</EnumVal>
<EnumVal ord="44">m/s²</EnumVal>
<EnumVal ord="45">m³/s</EnumVal>
<EnumVal ord="46">m/m³</EnumVal>
<EnumVal ord="47">M</EnumVal>
<EnumVal ord="48">kg/m³</EnumVal>
<EnumVal ord="49">m²/s</EnumVal>
<EnumVal ord="50">W/m K</EnumVal>
<EnumVal ord="51">J/K</EnumVal>
<EnumVal ord="52">ppm</EnumVal>
<EnumVal ord="53">1/s</EnumVal>
<EnumVal ord="54">rad/s</EnumVal>
<EnumVal ord="55">W/m²</EnumVal>
<EnumVal ord="56">J/m²</EnumVal>
<EnumVal ord="57">S/m</EnumVal>
<EnumVal ord="58">K/s</EnumVal>
<EnumVal ord="59">Pa/s</EnumVal>
<EnumVal ord="60">J/kg K</EnumVal>
<EnumVal ord="61">VA</EnumVal>
<EnumVal ord="62">Watts</EnumVal>
<EnumVal ord="63">VAr</EnumVal>
<EnumVal ord="64">phi</EnumVal>
<EnumVal ord="65">cos(phi)</EnumVal>
<EnumVal ord="66">Vs</EnumVal>
<EnumVal ord="67">V²</EnumVal>
<EnumVal ord="68">As</EnumVal>
<EnumVal ord="69">A²</EnumVal>
<EnumVal ord="70">A²t</EnumVal>
<EnumVal ord="71">VAh</EnumVal>
<EnumVal ord="72">Wh</EnumVal>
<EnumVal ord="73">VArh</EnumVal>
<EnumVal ord="74">V/Hz</EnumVal>
<EnumVal ord="75">Hz/s</EnumVal>
<EnumVal ord="76">char</EnumVal>
<EnumVal ord="77">char/s</EnumVal>
<EnumVal ord="78">kgm²</EnumVal>
<EnumVal ord="79">dB</EnumVal>
<EnumVal ord="80">J/Wh</EnumVal>
<EnumVal ord="81">W/s</EnumVal>
<EnumVal ord="82">I/s</EnumVal>
<EnumVal ord="83">dBm</EnumVal>
</EnumType>

```

Bibliography

IEC 61850-8-x (all parts), *Communication networks and systems for power utility automation – Part 8: Specific Communication Service Mapping (SCSM)*

IEC 61850-9-x (all parts), *Communication networks and systems for power utility automation – Part 9: Specific Communication Service Mapping (SCSM)*

ISO 9506 (all parts), *Industrial automation systems – Manufacturing Message Specification*

IECNORM.COM : Click to view the full PDF of IEC 61850-7-3:2010

IECNORM.COM : Click to view the full PDF of IEC 61850-7-3:2010

SOMMAIRE

AVANT-PROPOS	97
INTRODUCTION	99
1 Domaine d'application	100
2 Références normatives	100
3 Termes et définitions	101
4 Abréviations	101
5 Conditions pour l'inclusion d'attribut	101
6 Classes d'attributs construits	102
6.1 Généralités	102
6.2 Quality	103
6.2.1 Vue générale	103
6.2.2 Validity	103
6.2.3 Detail quality	104
6.2.4 Source	105
6.2.5 Test	105
6.2.6 Gelé par l'opérateur	106
6.2.7 Qualité dans le contexte client-serveur	106
6.2.8 Relation entre identificateurs de qualité	107
6.3 Analogue value	109
6.4 Configuration du type analogue value	109
6.5 Range configuration	110
6.6 Step position with transient indication	110
6.7 Pulse configuration	111
6.8 Originator	111
6.9 Définition de unit	112
6.10 Définition de vector	112
6.11 Définition de Point	113
6.12 Définition de CtModels	113
6.13 Définition de SboClasses	113
6.14 Cell	113
6.15 Définition de CalendarTime	114
7 Spécifications des classe de données communes	115
7.1 Généralités	115
7.2 Espaces de nom	115
7.3 Spécifications de classe de données communes pour les informations relatives au statut	116
7.3.1 Application de services	116
7.3.2 Single point status (SPS)	117
7.3.3 Double point status (DPS)	117
7.3.4 Integer status (INS)	118
7.3.5 Enumerated status (ENS)	118
7.3.6 Protection activation information (ACT)	119
7.3.7 Directional protection activation information (ACD)	120
7.3.8 Security violation counting (SEC)	120
7.3.9 Binary counter reading (BCR)	121
7.3.10 Histogram (HST)	122

7.3.11	Visible string status (VSS).....	122
7.4	Spécifications de classe de données communes pour les informations relatives au mesurande.....	123
7.4.1	Application de services.....	123
7.4.2	Measured value (MV)	124
7.4.3	Complex measured value (CMV).....	125
7.4.4	Sampled value (SAV)	126
7.4.5	Valeurs mesurées liées à phase-terre/neutre pour un système triphasé (WYE)	126
7.4.6	Valeurs mesurées liées à phase-phase pour un système triphasé (DEL).....	127
7.4.7	Sequence (SEQ)	128
7.4.8	Harmonic value (HMV).....	128
7.4.9	Harmonic value for WYE (HWYE)	129
7.4.10	Harmonic value for DEL (HDEL)	130
7.5	Spécifications de classe de données communes pour les commandes.....	131
7.5.1	Application de services.....	131
7.5.2	Controllable single point (SPC).....	132
7.5.3	Controllable double point (DPC)	133
7.5.4	Controllable integer status (INC).....	134
7.5.5	Controllable enumerated status (ENC).....	135
7.5.6	Binary controlled step position information (BSC)	136
7.5.7	Integer controlled step position information (ISC)	137
7.5.8	Controllable analogue process value (APC)	138
7.5.9	Binary controlled analog process value (BAC).....	139
7.6	Spécifications de classe de données communes pour "status settings".....	140
7.6.1	Application de services.....	140
7.6.2	Single point setting (SPG).....	140
7.6.3	Integer status setting (ING)	141
7.6.4	Enumerated status setting (ENG).....	141
7.6.5	Object reference setting (ORG)	142
7.6.6	Time setting group (TSG).....	142
7.6.7	Currency setting group (CUG)	143
7.6.8	Visible String Setting (VSG)	143
7.7	Spécifications de classe de données communes pour "analogue settings" (c'est-à-dire réglages analogiques)	144
7.7.1	Application de services.....	144
7.7.2	Analogue setting (ASG)	145
7.7.3	Setting curve (CURVE).....	146
7.7.4	Curve shape setting (CSG)	147
7.8	Spécifications de classe de données communes pour les informations de description	148
7.8.1	Application de services.....	148
7.8.2	Device name plate (DPL)	149
7.8.3	Logical node name plate (LPL)	150
7.8.4	Curve shape description (CSD).....	151
8	Sémantique des attributs de données	152
	Annexe A (normative) Plage de valeurs pour units et pour multiplier	168
	Annexe B (informative) Contraintes fonctionnelles	171

Annexe C (normative) Suivi des révisions de configuration	174
Annexe D (normative) Énumérations du SCL	176
Bibliographie.....	182
Figure 1– Identificateurs de qualité dans une relation client-serveur simple	106
Figure 2 – Identificateurs de qualité dans une relation client-serveur multiple	107
Figure 3 – Interaction de substitution et validity	108
Figure 4 – Configuration d'impulsion de sortie de commande	111
Figure 5 – Définition de Cell	114
Figure 6 – Courbe à deux dimensions représentée par CSG	147
Figure 7 – Forme à deux dimensions créée par plusieurs CSG.....	148
Tableau 1 – Conditions pour la présence d'attributs	101
Tableau 2 – Quality	103
Tableau 3 – Relation des identificateurs de qualité détaillée avec la qualité "invalid" ou "questionable"	104
Tableau 4 – Analogue value	109
Tableau 5 – Configuration du type analogue value.....	109
Tableau 6 – Range configuration.....	110
Tableau 7 – Step position with transient indication.....	110
Tableau 8 – Pulse configuration.....	111
Tableau 9 – Originator	111
Tableau 10 – Valeurs pour orCat.....	112
Tableau 11 – Unit	112
Tableau 12 – Vector	112
Tableau 13 – Point	113
Tableau 14 – Cell	113
Tableau 15 – CalendarTime.....	114
Tableau 16 – Interprétation sémantique des réglages du temps de calendrier.....	115
Tableau 17 – Attributs d'espace de nom	116
Tableau 18 – Modèle d'informations de statut de base	116
Tableau 19 – Définition de la classe de données communes "Single point status"	117
Tableau 20 – Spécification de la classe de données communes "Double point status"	117
Tableau 21 – Spécification de la classe de données communes "Integer status"	118
Tableau 22 – Spécification de la classe de données communes "Enumerated status"	119
Tableau 23 – Spécification de la classe de données communes "protection activation information"	119
Tableau 24 – Spécification de la classe de données communes "Directional protection activation information"	120
Tableau 25 – Spécification de la classe de données communes "Security violation counting"	121
Tableau 26 – Spécification de la classe de données communes "Binary counter reading".....	121
Tableau 27 – Spécification de la classe de données communes "Histogram"	122

Tableau 28 – Définition de la classe de données communes "Visible string status"	122
Tableau 29 – Modèle d'informations de mesurande de base	123
Tableau 30 – Measured value	124
Tableau 31 – Complex measured value	125
Tableau 32 – Sampled value	126
Tableau 33 – WYE	126
Tableau 34 – Delta	127
Tableau 35 – Sequence	128
Tableau 36 – Harmonic value	128
Tableau 37 – Harmonic values for WYE	129
Tableau 38 – Harmonic values for delta	130
Tableau 39 – Modèle d'informations de statut contrôlable de base	131
Tableau 40 – Controllable single point	132
Tableau 41 – Controllable double point	133
Tableau 42 – Controllable integer status	134
Tableau 43 – Controllable enumerated status	135
Tableau 44 – Binary controlled step position information	136
Tableau 45 – Integer controlled step position information	137
Tableau 46 – Controllable analogue process value	138
Tableau 47 – Binary controlled analog process value	139
Tableau 48 – Modèle de réglages de statut de base	140
Tableau 49 – Single point setting	140
Tableau 50 – Integer status setting	141
Tableau 51 – Enumerated status setting	141
Tableau 52 – Spécification de la classe de données communes "Object reference setting"	142
Tableau 53 – Spécification de la classe de données communes "Time setting group"	142
Tableau 54 – Spécification de la classe de données communes "Currency setting group"	143
Tableau 55 – Spécification de la classe de données communes "Visible string setting group"	143
Tableau 56 – Modèle de réglages analogiques de base	144
Tableau 57 – Analogue setting	145
Tableau 58 – Setting curve	146
Tableau 59 – Curve shape setting	147
Tableau 60 – Modèle d'informations de description de base	148
Tableau 61 – Spécification de la classe de données communes "Device name plate"	149
Tableau 62 – Spécification de la classe de données communes "Logical node name plate"	150
Tableau 63 – Spécification de la classe de données communes "Curve shape description"	151
Tableau 64 – Sémantique des attributs de données et des données	152
Tableau A.1 – Unités SI: unités de base	168
Tableau A.2 – Unités SI: unités dérivées	168

Tableau A.3 – Unités SI: unités étendues.....	169
Tableau A.4 – Unités SI: unités spécifiques à l'industrie	169
Tableau A.5 – Multiplicateur	170
Tableau B.1 – Contraintes fonctionnelles	172

IECNORM.COM : Click to view the full PDF of IEC 61850-7-3:2010

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

**RÉSEAUX ET SYSTÈMES DE COMMUNICATION POUR
L'AUTOMATISATION DES SYSTÈMES ÉLECTRIQUES –****Partie 7-3: Structure de communication de base –
Classes de données communes**

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (CEI) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de la CEI). La CEI a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, la CEI – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de la CEI"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec la CEI, participent également aux travaux. La CEI collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de la CEI concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de la CEI intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de la CEI se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de la CEI. Tous les efforts raisonnables sont entrepris afin que la CEI s'assure de l'exactitude du contenu technique de ses publications; la CEI ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de la CEI s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de la CEI dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de la CEI et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) La CEI elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de la CEI. La CEI n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à la CEI, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de la CEI, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de la CEI ou de toute autre Publication de la CEI, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de la CEI peuvent faire l'objet de droits de propriété intellectuelle ou de droits analogues. La CEI ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de propriété et de ne pas avoir signalé leur existence.

La Norme internationale CEI 61850-7-3 a été établie par le comité d'études 57 de la CEI: Gestion des systèmes de puissance et échanges d'informations associés.

Cette deuxième édition annule et remplace la première édition parue en 2003.

Par rapport à la première édition, cette deuxième édition:

- définit de nouvelles classes de données communes utilisées pour de nouvelles normes définissant des modèles d'objets pour d'autres domaines reposant sur la CEI 61850 et pour la représentation des données statistiques et historiques,
- apporte des clarifications et des corrections à la première édition de la CEI 61850-7-3.

Le texte anglais de cette norme est issu des documents 57/1087/FDIS et 57/1095/RVD. Le rapport de vote 57/1095/RVD donne toute information sur le vote ayant abouti à l'approbation de cette norme.

La version française de cette norme n'a pas été soumise au vote.

Cette publication a été rédigée selon les Directives ISO/CEI, Partie 2.

Une liste de toutes les parties de la série CEI 61850, sous le titre général: *Réseaux et systèmes de communication pour l'automatisation des systèmes électriques*, peut être consultée sur le site web de la CEI.

Le titre général de cette série était *Réseaux et systèmes de communication dans des postes*. Pour correspondre à l'extension du domaine d'application de la CEI 61850, le titre général a été remplacé par *Réseaux et systèmes de communication pour l'automatisation des systèmes électriques*.

Le comité a décidé que le contenu de cette publication ne sera pas modifié avant la date de stabilité indiquée sur le site web de la CEI sous «<http://webstore.iec.ch>» dans les données relatives à la publication recherchée. A cette date, la publication sera

- reconduite,
- supprimée,
- remplacée par une édition révisée, ou
- amendée.

IMPORTANT – Le logo "colour inside" qui se trouve sur la page de couverture de cette publication indique qu'elle contient des couleurs qui sont considérées comme utiles à une bonne compréhension de son contenu. Les utilisateurs devraient, par conséquent, imprimer cette publication en utilisant une imprimante couleur.

INTRODUCTION

Le présent document fait partie d'un ensemble de spécifications qui donne en détail une architecture de communication stratifiée d'un poste. Cette architecture a été choisie pour fournir des définitions abstraites de classes et de services de manière à rendre les spécifications indépendantes de toute pile protocolaire spécifique et de tout objet spécifique. Le mappage de ces classes abstraites et de services à des piles de communication ne relève pas du domaine d'application de la CEI 61850-7-x et peut être consulté dans la CEI 61850-8-x (bus de poste) et dans la CEI 61850-9-x (bus de processus).

La CEI 61850-7-1 donne une vue d'ensemble de cette architecture de communication. La présente partie de la CEI 61850 définit des classes d'attributs construits et des classes de données communes liées à des applications dans les systèmes électriques utilisant les concepts de modélisation selon la CEI 61850 tels que les postes, l'hydroélectricité ou les ressources énergétiques distribuées. Ces classes de données communes sont utilisées dans la CEI 61850-7-4 pour définir des classes dataObject compatibles. Les SubDataObjects, DataAttributes ou SubAttributes des instances de dataObject doivent être accessibles en utilisant des services définis dans la CEI 61850-7-2.

La présente partie est utilisée pour spécifier les définitions de classe de données communes abstraite et de classe d'attributs construits. Ces définitions abstraites sont mappées à des définitions d'objets concrets qui sont à utiliser pour un protocole particulier (par exemple MMS, série ISO 9506).

Remarquer qu'il existe des classes de données communes utilisées pour le suivi de service, qui sont définies dans la CEI 61850-7-2.

RÉSEAUX ET SYSTÈMES DE COMMUNICATION POUR L'AUTOMATISATION DES SYSTÈMES ÉLECTRIQUES –

Partie 7-3: Structure de communication de base – Classes de données communes

1 Domaine d'application

La présente partie de la CEI 61850 spécifie les classes d'attributs construites et les classes de données communes liées à des applications de poste. En particulier, elle spécifie:

- les classes de données communes pour les informations relatives au statut,
- les classes de données communes pour les informations mesurées,
- les classes de données communes pour le contrôle,
- les classes de données communes pour les réglages de statut,
- les classes de données communes pour les réglages analogiques, et
- les types d'attribut utilisés dans ces classes de données communes.

La présente Norme internationale est applicable à la description des modèles et fonctions de dispositifs pour les postes et les lignes d'alimentation.

La présente Norme internationale peut aussi être appliquée, par exemple, pour décrire des modèles et fonctions de dispositifs pour:

- l'échange d'informations de poste à poste,
- l'échange d'informations de poste à centre de conduite,
- l'échange d'informations de centrale électrique à centre de conduite,
- l'échange d'informations pour la production distribuée, ou
- l'échange d'informations pour le comptage.

2 Références normatives

Les documents de référence suivants sont indispensables pour l'application du présent document. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

CEI/TS 61850-2, *Communication networks and systems in substations – Part 2: Glossary* (disponible en anglais seulement)

CEI 61850-7-1, *Communication networks and systems for power utility automation – Part 7-1: Basic communication structure – Principles and models* (disponible en anglais seulement)¹

CEI 61850-7-2, *Communication networks and systems for power utility automation – Part 7-2: Basic information and communication structure – Abstract communication service interface (ACSI)* (disponible en anglais seulement)

¹ A publier.

CEI 61850-7-4, *Communication networks and systems for power utility automation – Part 7-4: Basic communication structure – Compatible logical node classes and data object classes* (disponible en anglais seulement)

IEEE C37.118:2005, *IEEE Standard for Synchrophasors for Power Systems* (disponible en anglais seulement)

ISO 4217, *Codes pour la représentation des monnaies et types de fonds*

3 Termes et définitions

Pour les besoins du présent document, les termes et définitions donnés dans la CEI/TS 61850-2 et dans la CEI 61850-7-2 s'appliquent.

NOTE La CEI/TS 61850-2 et la CEI 61850-7-2 ne sont disponibles qu'en anglais.

4 Abréviations

CDC ²	classe de données communes
dchg ³	option de déclenchement pour changement de données
dupd ⁴	option de déclenchement pour mise à jour de données
FC ⁵	contrainte fonctionnelle
qchg ⁶	option de déclenchement pour changement de qualité
TrgOp ⁷	option de déclenchement

NOTE Les abréviations utilisées pour l'identification des classes de données communes et comme noms des attributs sont spécifiées dans les articles spécifiques du présent document et ne sont pas reprises ici.

5 Conditions pour l'inclusion d'attribut

Le présent article énumère les conditions générales qui spécifient la présence d'un attribut. Le Tableau 1 donne les conditions pour la présence d'attributs.

Tableau 1 – Conditions pour la présence d'attributs

Abréviation	Condition
M	L'attribut est obligatoire. L'attribut doit exister pour toute instance de type CDC.
O	L'attribut est facultatif. L'attribut peut exister ou peut ne pas exister pour toute instance de type CDC.
PICS_SUBST	L'attribut est obligatoire, si la substitution est prise en charge pour cet objet (pour la substitution, voir la CEI 61850-7-2), sinon il est interdit.
GC_1	Au moins l'un des attributs doit être présent pour une instance donnée de DataObject / SubDataObject.
GC_2_n	Tous ou zéro des attributs de données appartenant au même groupe (n) doi(ven)t être présent(s) pour une instance de DataObject / SubDataObject.
GC_1_EXCL	Au maximum un des objets de données doit être présent pour une instance donnée.

² CDC = *common data class*.

³ dchg = *trigger option for data-change*.

⁴ dupd = *trigger option for data-update*.

⁵ FC = *functional constraint*.

⁶ qchg = *trigger option for data-change*.

⁷ TrgOp = *trigger option*.

Abréviation	Condition
GC_CON_attr	Un attribut de données de configuration doit seulement être présent si l'attribut (attr) de donnée spécifique (facultatif) auquel cette configuration se rapporte est présent aussi.
GC_2_XOR_n	Tous ou zéro d'un groupe (n) doit être présent(s). Les groupes sont exclusifs mais un groupe doit être présent.
AC_LN0_M	L'attribut doit être présent si le DataObject NamPit appartient à LLN0; autrement, il peut être facultatif.
AC_LN0_EX	L'attribut doit être présent seulement si le DataObject NamPit appartient au LLN0 (s'applique aux IdNs dans la CDC LPL seulement).
AC_DLD_M	L'attribut doit être présent, si l'espace de nom NL de ce NL (nœud logique) s'écarte de l'espace de nom NL référencé par le IdNs du dispositif logique dans lequel chaque NL est contenu (s'applique aux InNs dans la CDC LPL (logical node name plate) seulement).
AC_DLN_M	L'attribut doit être présent, si l'espace de nom de données pour cette donnée s'écarte de l'espace de nom référencé soit par le InNs du nœud logique dans lequel la donnée est contenue, soit, en l'absence de InNs, le IdNs du dispositif logique dans lequel la donnée est contenue (s'applique à dataNs dans toutes les CDC seulement).
AC_DLND_A_M	L'attribut doit être présent, si l'espace de nom de CDC pour cette donnée s'écarte de l'espace de nom référencé soit par le dataNs de la donnée, le InNs du nœud logique dans lequel la donnée est définie, soit le InNs du dispositif logique dans lequel la donnée est contenue (s'applique à cdcNs et cdcName dans toutes les CDC seulement).
AC_SCAV	La présence de l'attribut de donnée configuration dépend de la présence de <i>i</i> et <i>f</i> de la valeur analogique de l'attribut de donnée auquel cet attribut configuration se rapporte. Pour un objet de donnée donné, cet attribut 1) doit être présent, si <i>i</i> et <i>f</i> sont présents tous les deux, 2) doit être facultatif si seul <i>i</i> est présent, 3) n'est pas requis si seul <i>f</i> est présent. NOTE Si seul <i>i</i> est présent dans un dispositif sans fonctionnalité de virgule flottante, le paramètre de configuration peut être échangé hors ligne.
AC_ST	L'attribut est obligatoire si la classe de statut contrôlable prend en charge l'information relative au statut.
AC_CO_O	Si la classe de statut contrôlable prend en charge le contrôle, cet attribut est disponible et est un attribut facultatif.
AC_CO_SBO	Si la classe de statut contrôlable prend en charge le contrôle et si le modèle de contrôle prend en charge les valeurs "sbo-with-normal-security" et/ou "sbo-with-enhanced-security", cet attribut doit être obligatoire.
AC_SG_M	L'attribut est obligatoire si cette donnée doit être membre d'un groupe de réglages.
AC_SG_O	L'attribut est facultatif si cette donnée doit être membre d'un groupe de réglages.
AC_SG_C1	L'un des attributs est obligatoire si cette donnée doit être membre d'un groupe de réglages.
AC_NS_G_M	L'attribut est obligatoire si cette donnée doit être un réglage à l'extérieur d'un groupe de réglages.
AC_NS_G_O	L'attribut est facultatif si cette donnée doit être un réglage à l'extérieur d'un groupe de réglages.
AC_NS_G_C1	L'un des attributs est obligatoire si cette donnée doit être un réglage à l'extérieur d'un groupe de réglages.
AC_RMS_M	L'attribut est obligatoire lorsque la référence aux harmoniques est du type rms.
AC_CLC_O	L'attribut doit être facultatif lorsque le type de calcul (conformément à la donnée ClcMth) pour ce NL est Peak fundamental (fréquence fondamentale de crête) ou RMS fundamental (fréquence fondamentale quadratique moyenne). L'attribut ne doit pas être disponible, si ClcMth est TRUE RMS.

6 Classes d'attributs construits

6.1 Généralités

Les classes d'attributs construits sont définies pour être utilisées dans des classes de données communes (CDC) dans l'Article 7.

La CEI 61850-7-1 fournit une vue d'ensemble de tous les documents de la CEI 61850-7 (CEI 61850-7-2, CEI 61850-7-3, et CEI 61850-7-4). La CEI 61850-7-1 décrit également la notation de base utilisée dans la CEI 61850-7-3 et la description des relations entre les documents de la CEI 61850-7.

NOTE Le type ACSI commun "TimeStamp" est spécifié dans la CEI 61850-7-2.

6.2 Quality

6.2.1 Vue générale

Le type de qualité doit être tel que défini au Tableau 2.

Tableau 2 – Quality

Définition du type quality			
Nom d'attribut	Type d'attribut	Valeur/Plage de valeurs	M/O/C
	PACKED LIST		
validity	CODED ENUM	good invalid reserved questionable	M
detailQual	PACKED LIST		M
overflow	BOOLEAN	DEFAULT FALSE	M
outOfRange	BOOLEAN	DEFAULT FALSE	M
badReference	BOOLEAN	DEFAULT FALSE	M
oscillatory	BOOLEAN	DEFAULT FALSE	M
Failure	BOOLEAN	DEFAULT FALSE	M
oldData	BOOLEAN	DEFAULT FALSE	M
inconsistent	BOOLEAN	DEFAULT FALSE	M
inaccurate	BOOLEAN	DEFAULT FALSE	M
Source	CODED ENUM	process substituted DEFAULT process	M
test	BOOLEAN	DEFAULT FALSE	M
operatorBlocked	BOOLEAN	DEFAULT FALSE	M

La valeur par défaut (DEFAULT) doit être appliquée, si la fonctionnalité de l'attribut connexe n'est pas prise en charge. Le mappage peut spécifier d'exclure l'attribut du message, s'il n'est pas pris en charge ou si la valeur par défaut DEFAULT s'applique.

Quality (c'est-à-dire la qualité) doit être un attribut qui contient des informations relatives à la qualité des informations provenant du serveur. La qualité de la donnée est également reliée au mode d'un nœud logique. Des détails supplémentaires peuvent être consultés dans la CEI 61850-7-4. Les différents identificateurs de la qualité ne sont pas indépendants. Fondamentalement, les identificateurs de la qualité sont les suivants:

- validity;
- detail quality;
- source;
- test;
- frozen by operator.

6.2.2 Validity

Validity (c'est-à-dire la validité) doit être good (c'est-à-dire bonne), questionable (c'est-à-dire douteuse) ou invalid (c'est-à-dire non valide).

good: La valeur doit être marquée "good" (c'est-à-dire bonne) s'il n'est détecté aucun état anormal de la fonction d'acquisition ou de la source d'informations.

invalid: La valeur doit être marquée comme "invalid" (c'est-à-dire non valide) lorsqu'il est détecté un état anormal de la fonction d'acquisition ou de la source d'informations (dispositifs de mise à jour absents ou non opérationnels). La valeur ne doit pas être définie dans cet état. La marque "invalid" (c'est-à-dire non valide) doit être utilisée pour indiquer au client que la valeur peut être incorrecte et ne doit pas être utilisée.

EXEMPLE Si une unité de saisie d'entrées détecte une oscillation d'une donnée d'entrée, elle marquera les informations correspondantes comme étant "invalid" (c'est-à-dire non valides).

questionable: La valeur doit être marquée "questionable" (c'est-à-dire douteuse) si une fonction de surveillance détecte un comportement anormal, mais la valeur peut néanmoins être "valid" (c'est-à-dire valide). Le client doit avoir la responsabilité de déterminer s'il convient ou non d'utiliser des valeurs marquées "questionable" (c'est-à-dire douteuses).

6.2.3 Detail quality

La raison pour laquelle un attribut a la valeur "invalid" (c'est-à-dire non valide) ou "questionable" (c'est-à-dire douteuse) peut être spécifiée en plus de détails avec des identificateurs de qualité supplémentaires. Si l'un de ces identificateurs est mis, "validity" doit être mis à "invalid" ou "questionable". Le tableau 3 montre la relation des identificateurs de qualité détaillée avec la qualité "invalid" (c'est-à-dire non valide) ou "questionable" (c'est-à-dire douteuse).

Tableau 3 – Relation des identificateurs de qualité détaillée avec la qualité "invalid" ou "questionable"

detailQual	invalid	questionable
overflow	X	
outOfRange	X	X
badReference	X	X
oscillatory	X	X
Failure	X	
OldData		X
inconsistent		X
inaccurate		X

overflow: cet identificateur doit indiquer une question de qualité correspondant à ce que la valeur de l'attribut à laquelle la qualité a été associée se situe au-delà des valeurs pouvant être représentées correctement (applicable aux informations relatives aux mesurandes uniquement).

EXEMPLE Une valeur mesurée peut excéder la plage qui peut être représentée par le type de données sélectionné; par exemple, le type de données est un nombre entier non signé de 16 bits et la valeur dépasse 65 535.

outOfRange: cet identificateur doit indiquer une question de qualité correspondant à la valeur de l'attribut auquel la qualité a été associée et qui se situe au-delà d'une plage prédéfinie de valeurs. Le serveur doit décider si "validity" doit être mis à "invalid" ou à "questionable" (applicable aux informations relatives aux mesurandes uniquement).

EXEMPLE Une valeur mesurée peut excéder une plage prédéfinie; cependant, le type de données sélectionné peut encore représenter la valeur; par exemple: le type de données étant nombre entier non signé de 16 bits et la plage prédéfinie allant de 0 à 40 000, la valeur est considérée être hors plage si elle est comprise entre 40 001 et 65 535.

badReference: cet identificateur doit indiquer que la valeur peut ne pas être une valeur correcte en raison d'une référence hors calibre. Le serveur doit décider si "validity" doit être mis à "invalid" ou à "questionable" (applicable aux informations relatives aux mesurandes et aux informations relatives au compteur binaire uniquement).

oscillatory: pour prévenir une surcharge des voies de communication guidées par les événements, il est souhaitable de détecter et de supprimer les entrées binaires oscillantes (qui changent très vite). Si un signal change dans une durée définie (t_{osc}) deux fois dans le même sens (de 0 à 1 ou de 1 à 0), il doit être défini comme étant une oscillation et l'identificateur de qualité de détail "oscillatory" doit être mis. Si des nombres configurés de changements transitoires sont détectés, ils doivent être supprimés. Pendant cette période, l'état "questionable" (douteux) de "validity" doit être mis. Si le signal est toujours oscillant après le nombre défini de changements, la valeur doit être laissée dans l'état dans lequel elle était lorsque le fanion "oscillatory" a été mis. Dans ce cas, l'état "questionable" de validity doit être remplacé par "invalid" aussi longtemps que le signal reste incertain. Si, du fait de la configuration, il convient de supprimer tous les changements transitoires, "validity" doit immédiatement être mis à "invalid" en plus de l'indicateur de qualité de détail "oscillatory" (applicable à l'information d'état uniquement).

failure: cet identificateur doit indiquer qu'une fonction de surveillance a détecté une défaillance interne ou externe.

oldData: une valeur doit être "oldData" si une mise à jour n'a pas été effectuée pendant une durée spécifique. La valeur peut être une ancienne valeur qui a pu changer entre-temps. La durée spécifique peut être définie par un attribut allowed-age.

NOTE Les erreurs "Fail silent", lorsque le matériel cesse d'envoyer des données, conduiront à un état "oldData". Dans ce cas, la dernière information reçue était correcte.

inconsistent: cet identificateur doit indiquer qu'une fonction d'évaluation a détecté une incohérence.

inaccurate: cet identificateur doit indiquer que la valeur ne satisfait pas à la précision énoncée pour la source.

EXEMPLE La valeur mesurée du facteur de puissance peut être affectée par le bruit (imprécise) lorsque le courant est très faible.

6.2.4 Source

Source doit donner l'information relative à l'origine de la valeur. La valeur peut être acquise du processus ou être une valeur substituée.

process: la valeur est fournie par une fonction d'entrée de l'E/S du processus ou est calculée par une fonction applicative.

substituted: La valeur est fournie par l'entrée d'un opérateur ou par une source automatique.

NOTE 1 La substitution peut être effectuée localement ou via les services de communication. Le second cas utilise des attributs spécifiques avec un FC SV.

NOTE 2 Il existe divers moyens d'annuler une substitution. À titre d'exemple, une substitution qui a été effectuée à la suite d'un état "invalid" peut être annulée automatiquement si la condition non valide est éliminée. Cependant, il s'agit d'une question locale qui ne relève donc pas du domaine d'application de la présente norme.

6.2.5 Test

"Test" doit être un identificateur supplémentaire qui peut être utilisé pour classer une valeur comme étant valeur d'essai et ne devant pas être utilisée pour un objectif opérationnel. Le traitement de la qualité d'essai (test quality) dans le client doit être tel que décrit dans la CEI 61850-7-4. Le bit doit être complètement indépendant des autres bits du descripteur de qualité.

6.2.6 Gelé par l'opérateur


operatorBlocked: cet identificateur doit être mis si une autre mise à jour de la valeur a été bloquée par un opérateur. La valeur doit être l'information qui a été acquise avant le blocage. Si cet identificateur est mis, l'identificateur oldData de detailQual doit aussi être mis.

L'opérateur doit utiliser l'attribut de donnée **blkEna** pour bloquer la mise à jour de la valeur.

NOTE Un opérateur et aussi une fonction automatique peuvent geler la mise à jour des communications et aussi la mise à jour des données d'entrée. Dans les deux cas, detailQual.oldData sera mis. Si le blocage est effectué par un opérateur, l'identificateur operatorBlocked est mis en plus. Dans ce cas, une activité d'opérateur est requise pour éliminer l'état.

EXEMPLE Un opérateur peut geler la mise à jour d'une donnée d'entrée, afin de sauver l'ancienne valeur avant que l'alimentation auxiliaire soit mise hors tension.

6.2.7 Qualité dans le contexte client-serveur



CEI 808/03

Figure 1– Identificateurs de qualité dans une relation client-serveur simple

L'identificateur de qualité doit refléter la qualité de l'information dans le serveur, telle qu'elle est fournie au client. La Figure 1 montre des sources potentielles qui peuvent influencer la qualité dans une relation client-serveur simple. "Information Source" (c'est-à-dire la source d'information) est le raccordement (câblé) de l'information sur le processus au système. L'information peut être "non valide" (invalid) ou "douteuse" (questionable) comme montré dans la Figure 1. Un comportement anormal supplémentaire de la source d'information peut être détecté par l'unité d'entrée. Dans ce cas, l'unité d'entrée peut conserver l'ancienne donnée et la signaler en conséquence.

Dans une relation client-serveur multiple, telle que montrée à la Figure 2, les informations peuvent être acquises sur une liaison de communication (avec le Client B). Si cette liaison de communication est rompue, le client B détectera cette situation d'erreur et qualifiera les informations comme étant douteuses/anciennes.




Figure 2 – Indicateurs de qualité dans une relation client-serveur multiple

Dans une relation client-serveur multiple, la qualité des données reçues du serveur A doit refléter aussi bien la qualité du serveur B (acquise avec le client B) que sa propre qualité. Par conséquent, la gestion des priorités de qualité de différents niveaux peut exiger une spécification supplémentaire au-delà de celle incluse dans la présente norme. Pour l'identificateur validity, la valeur "invalid" doit prévaloir sur la valeur "questionable", car elle représente le cas le plus défavorable. Pour l'identificateur source, le niveau supérieur de la relation client – serveur multiple doit prévaloir sur le niveau inférieur.

EXEMPLE Soient A le niveau supérieur et B le niveau inférieur. La qualité issue du serveur B est "invalid". Si maintenant la communication est en panne (questionable, oldData) entre le serveur B et le client B, la qualité restera "invalid" et ne deviendra pas "questionable", car la dernière information n'était pas correcte. Le Serveur A rapportera donc l'information comme "invalid".

6.2.8 Relation entre indicateurs de qualité

Validity et source ont une relation hiérarchisée par ordre de priorité. Si source est dans l'état "process", validity doit déterminer la qualité de la valeur d'origine. Si "source" est dans l'état "substitute", "validity" doit être annulé par la définition de la valeur substituée. Il s'agit d'une caractéristique importante, car la substitution est utilisée pour remplacer des valeurs non valides par des valeurs substituées qui peuvent être utilisées par le client comme des valeurs correctes.

EXEMPLE 1 Si "questionable" et "substituted" sont mis tous les deux, cela signifie que la valeur substituée est douteuse. Cela peut se produire si, dans une configuration hiérarchique, une substitution est effectuée au niveau le plus bas et la communication échoue sur un niveau supérieur.

EXEMPLE 2 Si une valeur non valide est substituée, le champ "invalid" sera effacé et le champ "substituted" sera mis pour indiquer la substitution.

L'identificateur de qualité operatorBlocked est indépendant des autres indicateurs de qualité.

EXEMPLE 3 Une entrée oscillante peut entraîner l'activation du champ "invalid". En raison des changements continus de la valeur, plusieurs rapports sont générés, ce qui charge le réseau de communication. Un opérateur peut bloquer la mise à jour de l'entrée. Dans ce cas, le champ operatorBlocked sera activé aussi.

Un exemple de l'interaction entre les indicateurs de qualité et l'impact de la relation client-serveur multiple est illustré à la Figure 3. Dans cet exemple, il est supposé qu'un dispositif de niveau baie agit comme client du serveur de niveau processus et comme serveur pour le client de niveau poste.


NOTE Il s'agit d'un exemple de relation client-serveur multiple; d'autres relations client-serveur multiples peuvent exister, mais le comportement ne changera pas.

Dans le cas A, l'entrée est bloquée, la qualité de l'information est marquée comme étant "questionable" (c'est-à-dire douteuse) et oldData.

Dans le cas B, une substitution est effectuée au niveau processus. En l'occurrence, la qualité de l'information au niveau supérieur suivant (le niveau baie) est marquée comme étant "substituted" (mais "good").

Dans le cas C, la communication entre les niveaux processus et baie échoue. Entre le niveau baie et le niveau poste, l'information est encore marquée comme étant "substituted" (c'est-à-dire substituée). En outre, questionable et oldData sont mis pour indiquer que l'information (substituted) peut être old (c'est-à-dire ancienne).

Dans le cas D, une nouvelle substitution est effectuée au niveau baie. En l'occurrence, la qualité de l'information au niveau supérieur suivant est marquée comme étant "substituted" (mais "good") et elle est indépendante de la première substitution.



Légende
CL client
SE serveur

IEC 2550/10

Figure 3 – Interaction de substitution et validity

6.3 Analogue value

Le type "analogue value" (c'est-à-dire valeur analogique) doit être tel que défini au Tableau 4.

Tableau 4 – Analogue value

Définition du type AnalogueValue			
Nom d'attribut	Type d'attribut	Valeur/Plage de valeurs	M/O/C
<i>i</i>	INT32	valeur entière	GC_1
<i>f</i>	FLOAT32	valeur en virgule flottante	GC_1

Les valeurs analogiques peuvent être représentées comme un type INTEGER de base (attribut *i*) ou comme FLOATING POINT (attribut *f*). Au moins l'un des attributs doit être utilisé. Si *i* et aussi *f* existent, l'application dans le serveur doit assurer que les deux valeurs restent cohérentes. La dernière valeur réglée par le service de communication doit être utilisée pour mettre à jour l'autre valeur. Par exemple, si xxx.*f* est inscrit, l'application doit mettre à jour xxx.*i* en conséquence.

Les valeurs mesurées représentent des valeurs de processus primaire.

i: La valeur de *i* doit être une représentation entière de la valeur mesurée. La formule de conversion entre *i* et la valeur de processus (*pVal*) doit être:

$$pVal = (i \times scaleFactor) + offset$$

La valeur doit être vraie (c'est-à-dire vrai) dans la limite de l'erreur tolérée lorsque *i*, *scaleFactor*, *offset* et *f* sont tous présents.

f: La valeur de *f* doit être une représentation en virgule flottante de la valeur mesurée. La formule de conversion entre *f* et la valeur de processus doit être:

$$pVal = f \times 10^{units.mult \text{ iplier}}$$

NOTE La raison de la représentation entière et en virgule flottante est de permettre aux IED dépourvus de fonctionnalités FLOATING POINT de prendre en charge les valeurs analogiques. Dans ce cas, le *scaleFactor* et *offset* peuvent être échangés hors ligne entre clients et serveurs.

6.4 Configuration du type analogue value

La configuration du type "analogue value" (c'est-à-dire valeur analogique) doit être telle que définie au Tableau 5.

Tableau 5 – Configuration du type analogue value

Définition du type ScaledValueConfig			
Nom d'attribut	Type d'attribut	Valeur/plage de valeurs	M/O/C
<i>scaleFactor</i>	FLOAT32		M
<i>offset</i>	FLOAT32		M

Cette classe d'attributs construits doit être utilisée pour configurer la représentation de valeurs INTEGER de la valeur analogique. La formule de conversion entre valeur entière et valeur en virgule flottante est donnée en 6.3.

scaleFactor: la valeur de *scaleFactor* doit être le facteur de mise à l'échelle.

offset: la valeur de "offset" doit être le décalage.

NOTE Si un serveur ne prend pas en charge la transmission de valeurs FLOAT32, le client peut récupérer ces valeurs du fichier SCL.

6.5 Range configuration

Le type range configuration (c'est-à-dire configuration de plage) est utilisé pour configurer les limites qui définissent la plage d'une valeur mesurée et doit être tel que défini au Tableau 6.

Tableau 6 – Range configuration

Définition du type RangeConfig			
Nom d'attribut	Type d'attribut	Valeur/Plage de valeurs	M/O/C
hhLim	AnalogueValue		M
hLim	AnalogueValue		M
lLim	AnalogueValue		M
llLim	AnalogueValue		M
min	AnalogueValue		M
max	AnalogueValue		M
limDb	INT32U	0 ... 100 000	O

hhLim, hLim, lLim, llLim: Ces attributs doivent être les paramètres de configuration utilisés dans le contexte avec l'attribut range tel que défini à l'Article 8.

min: L'attribut min (minimum) doit représenter la mesure minimale de processus pour laquelle les valeurs de *i* ou *f* sont considérées être dans les limites du processus. Si la valeur est inférieure, q doit être mis en conséquence (validity = questionable, detailQual = outOfRange).

max: L'attribut max (maximum) doit représenter la mesure maximale de processus pour laquelle les valeurs de *i* ou *f* sont considérées être dans les limites du processus. Si la valeur est supérieure, q doit être mis en conséquence (validity = questionable, detailQual = outOfRange).

limDb: La valeur est utilisée pour introduire un hystérésis dans le calcul de range (c'est-à-dire la plage). Range est immédiatement mis à la valeur supérieure, lorsqu'une limite haute a été franchie (à la valeur inférieure, lorsqu'une limite basse a été franchie). Cependant, range est seulement ramené à la valeur inférieure si la valeur de la limite haute moins limDb a été franchie (à la valeur supérieure si la valeur de la limite basse plus limDb a été franchie). La valeur doit représenter le pourcentage entre max et min en unités de 0,001 %. Si limDb est absent, aucun calcul d'hystérésis n'est effectué.

6.6 Step position with transient indication

Le type "step position with transient indication" (c'est-à-dire position de phase avec indication d'état transitoire) est par exemple utilisé pour indiquer la position de changeurs de prise et doit être tel que défini au Tableau 7.

Tableau 7 – Step position with transient indication

Définition du type ValWithTrans			
Nom d'attribut	Type d'attribut	Valeur/Plage de valeurs	M/O/C
posVal	INT8	–64 ... 63	M
transInd	BOOLEAN		O

Le posVal doit contenir la position de phase, le transInd doit indiquer que l'équipement est dans un état transitoire.

6.7 Pulse configuration

Le type "pulse configuration" (c'est-à-dire configuration d'impulsion) est utilisé pour configurer l'impulsion de sortie générée avec une commande et doit être tel que défini au Tableau 8.

Tableau 8 – Pulse configuration

Définition du type PulseConfig			
Nom d'attribut	Type d'attribut	Valeur/Plage de valeurs	M/O/C
cmdQual	ENUMERATED	pulse persistent	M
onDur	INT32U		M
offDur	INT32U		M
numPls	INT32U		M

cmdQual: cet identificateur doit définir si la sortie de contrôle est une sortie pulsée ou s'il s'agit d'une sortie persistante. S'il est mis à "pulse", la durée de l'impulsion doit être définie avec les identificateurs onDur, offDur et numPls. S'il est mis à "persistent", la sortie reste dans l'état indiqué dans le service "operate".

onDur, offDur, numPls: à la réception d'un service Operate, une sortie pulsée peut être générée à l'entrée on ou off d'un dispositif de commutation. La forme de cette sortie est définie par onDur, offDur et numPls conformément à la Figure 4. NumPls doit spécifier le nombre d'impulsions qui sont générées. onDur doit spécifier la durée de marche de l'impulsion, offDur spécifie la durée entre deux impulsions. onDur et offDur doivent être spécifiés en ms; une valeur de 0 ms doit spécifier que la durée est définie localement.




Figure 4 – Configuration d'impulsion de sortie de commande

6.8 Originator

Le type "originator" (c'est-à-dire émetteur) doit être tel que défini au Tableau 9.

Tableau 9 – Originator

Définition du type Originator			
Nom d'attribut	Type d'attribut	Valeur/Plage de valeurs	M/O/C
orCat	ENUMERATED	not-supported bay-control station-control remote-control automatic-bay automatic-station automatic-remote maintenance process	M
orIdent	OCTET STRING64		M

orCat: La catégorie d'émetteur doit spécifier la catégorie de l'émetteur. Une explication des valeurs pour orCat est donnée au Tableau 10.

Tableau 10 – Valeurs pour orCat

Valeur	Explication
not-supported	Cette valeur ne doit pas être utilisée
bay-control	Opération de contrôle émise par un opérateur utilisant un client situé au niveau baie
station-control	Opération de contrôle émise par un opérateur utilisant un client situé au niveau poste
remote-control	Opération de contrôle émise par un opérateur distant situé à l'extérieur du poste (un centre de conduite de réseau, par exemple)
automatic-bay	Opération de contrôle émise par une fonction automatique au niveau baie
automatic-station	Opération de contrôle émise par une fonction automatique au niveau poste
automatic-remote	Opération de contrôle émise par une fonction automatique à l'extérieur du poste
maintenance	Opération de contrôle émise par un outil de maintenance/entretien
process	Changement de statut survenu sans action de commande (par exemple déclenchement externe d'un disjoncteur ou défaillance à l'intérieur du disjoncteur)

orIdent: l'identification d'émetteur doit montrer l'identification de l'émetteur. La valeur NULL doit être réservée pour indiquer que l'émetteur d'une action particulière est inconnu.

6.9 Définition de unit

Le type "unit" (c'est-à-dire unité) doit être tel que défini au Tableau 11.

Tableau 11 – Unit

Définition de Unit			
Nom d'attribut	Type d'attribut	Valeur/Plage de valeurs	M/O/C
SIUnit	ENUMERATED	Conformément aux Tableaux A.1 à A.4 dans l'Annexe A	M
multiplier	ENUMERATED	Conformément au Tableau A.5 dans l'Annexe A	O

SIUnit: doit définir l'unité SI conformément à l'Annexe A.

multiplier: doit définir la valeur du multiplicateur conformément à l'Annexe A. La valeur par défaut est 0 (c'est-à-dire multiplier = 1).

6.10 Définition de vector

Le type "Vector" (c'est-à-dire vecteur) doit être tel que défini au Tableau 12.

Tableau 12 – Vector

Définition du type Vector			
Nom d'attribut	Type d'attribut	Valeur/Plage de valeurs	M/O/C
mag	AnalogueValue		M
ang	AnalogueValue	$-180 < n \leq +180$	AC_CLC_O

mag: l'amplitude de la valeur complexe.

ang: l'angle de la valeur complexe. Le SIUnit doit être degrés et le multiplicateur d'unité est 1. La référence angulaire est définie dans le contexte où le type Vector est utilisé.

6.11 Définition de Point

Le type Point doit être tel que défini au Tableau 13 et il est utilisé pour représenter des points dans un système de coordonnées à deux dimensions ou à trois dimensions.

Tableau 13 – Point

Définition du type Point			
Nom d'attribut	Type d'attribut	Valeur/Plage de valeurs	M/O/C
xVal	FLOAT32		M
yVal	FLOAT32		M
zVal	FLOAT32		O

xVal: la valeur x d'un point

yVal: la valeur y d'un point

zVal: la valeur z d'un point

6.12 Définition de CtlModels

Le type CtlModels est défini comme suit:

ENUMERATED (status-only | direct-with-normal-security | sbo-with-normal-security | direct-with-enhanced-security | sbo-with-enhanced-security)

Des détails sont fournis dans l'article 8.

6.13 Définition de SboClasses

Le type SboClasses est défini comme suit:

ENUMERATED (operate-once | operate-many)

Des détails sont fournis dans l'article 8.

6.14 Cell

Le type Cell (c'est-à-dire cellule) est utilisé pour définir une surface rectangulaire dans un environnement à deux dimensions et il doit être défini comme au Tableau 14. Le type Cell peut tout aussi bien servir à décrire une plage dans un environnement monodimensionnel. Pour les détails, voir Figure 5.

Tableau 14 – Cell


Définition du type Cell			
Nom d'attribut	Type d'attribut	Valeur/Plage de valeurs	M/O/C
xStart	FLOAT32		M
xEnd	FLOAT32		O
yStart	FLOAT32		O
yEnd	FLOAT32		O

xStart: la valeur x du coin inférieur gauche du carré.

xEnd: la valeur x du coin supérieur droit du carré. Cette composante ne doit pas être présente pour indiquer l'infini dans la direction de l'axe des x.

yStart: la valeur y du coin inférieur gauche du carré. Cette composante ne doit pas être présente s'il est nécessaire de décrire seulement une plage à une dimension.

yEnd: la valeur y du coin supérieur droit du carré. Cette composante ne doit pas être présente s'il est nécessaire de décrire seulement une plage à une dimension ou pour indiquer l'infini dans la direction de l'axe des y.



IEC 2551/10

Figure 5 – Définition de Cell

6.15 Définition de CalendarTime

Le type CalendarTime est utilisé pour définir un réglage de temps en référence au calendrier et doit être tel que défini au Tableau 15. Cette classe d'attributs construits permet la spécification des temps tels que le dernier jour du mois ou le deuxième samedi de mars à 03.00h.

Tableau 15 – CalendarTime

Définition du type CalendarTime			
Nom d'attribut	Type d'attribut	Valeur/Plage de valeurs	M/O/C
occ	INT16U		M
occType	ENUMERATED	Time, WeekDay, WeekOfYear, DayOfMonth, DayOfYear	M
occPer	ENUMERATED	Hour, Day, Week, Month, Year	M
weekDay	ENUMERATED	reserved, Monday, Tuesday, ... Sunday	M
month	ENUMERATED	reserved, January, February, ... December	M
day	INT8U	1..31	M
hr	INT8U	0..23	M
mn	INT8U	0..59	M

occ: Occurrence d'un élément du calendrier. La valeur 0 est utilisée pour indiquer la dernière. Pour l'identification des numéros de semaine, le numéro de semaine 01 doit toujours être la première semaine de janvier (conformément à la définition de l'ONU / CEFAC).

occType: le type d'élément de calendrier qui est utilisé pour cette occurrence.

occPer: La durée de répétition d'un réglage de temps basé sur le calendrier.

weekDay: le jour de la semaine.

month: le mois.

day: le jour.

hr: l'heure.

mn: la minute.

L'interprétation sémantique des attributs est donnée au Tableau 16.

Tableau 16 – Interprétation sémantique des réglages du temps de calendrier

occPer	occType	
Hour	Time	À <mn> minute toutes les heures
Day	Time	À <hr>, <mn> tous les jours
Week	WeekDay	À <weekDay>, <hr>, <mn> toutes les semaines
Month	WeekDay	À <occ>, <weekDay>, <hr>, <mn> tous les mois
Month	DayOfMonth	À <occ>, <hr>, <mn> tous les mois
Year	Time	À <month>, <day>, <hr>, <mn> tous les ans
Year	WeekDay	À <occ>, <weekDay>, <month>, <hr>, <mn> tous les ans
Year	WeekOfYear	À la semaine <occ>, <weekDay>, <hr>, <mn>
Year	DayOfYear	À <occ>, <hr>, <mn> tous les ans

7 Spécifications des classe de données communes

7.1 Généralités

Les classes de données communes sont définies pour l'utilisation dans la CEI 61850-7-4. Les classes de données communes sont composées de classes d'attributs construits définies à l'Article 6 de la présente partie ou des types définis dans la CEI 61850-7-2 des classes de données communes définies dans le présent article. La CEI 61850-7-1 fournit la notation de base utilisée dans le présent article.

Les classes de données communes définissent la relation entre leurs attributs et la contrainte fonctionnelle ainsi que les possibles options de déclenchement. Si deux options de déclenchement sont énoncées, une implémentation concrète doit sélectionner l'une d'elles. La sélection est basée sur le but de l'objet de donnée de cette classe de données communes et elle est fixe pour l'objet de donnée dans une classe NL (de nœuds logiques).

La sémantique des SubDataObjects et DataAttributes est définie à l'Article 8.

7.2 Espaces de nom

Les espaces de nom sont définis pour identifier des extensions aux présentes définitions de la CEI 61850-7-3 et de la CEI 61850-7-4. L'espace de nom est basé sur une structure hiérarchique descendant du nœud logique zéro LLN0 situé en haut jusqu'à la classe de données communes CDC. Voir Tableau 17.

Tableau 17 – Attributs d'espace de nom

Attribut	Application	Domaine d'application de la norme spécifiée avec l'attribut
IdNs	Le DataAttribute IdNs doit être inclus dans le nœud logique LLN0.	Définition de la classe NL (définition de CDC par référence)
InNs	Le DataAttribute InNs doit être inclus si l'espace de nom du NL s'écarte de l'espace de nom du dispositif logique dans lequel le NL est défini.	Définition de la classe NL (définition de CDC par référence)
cdcNs	Le DataAttribute cdcNs doit être inclus si la définition d'au moins un SubDataObject, DataAttribute ou SubAttribute de la CDC s'écarte de la définition donnée dans la spécification dans laquelle la CDC du DataObject est définie. Dans ce cas, le nom de la nouvelle CDC est fourni dans l'attribut de donnée cdcName.	Définition de CDC
dataNs	Le DataAttribute dataNs doit être inclus si l'espace de nom du DataObject s'écarte de l'espace de nom du nœud logique dans lequel le DataObject est défini.	Définition de la classe NL (définition de CDC par référence)

7.3 Spécifications de classe de données communes pour les informations relatives au statut

7.3.1 Application de services

Le Tableau 18 définit le modèle d'informations de statut de base. Il définit en particulier les relations d'héritage et la spécialisation de services définis dans la CEI 61850-7-2.

Tableau 18 – Modèle d'informations de statut de base

Modèle d'informations de statut de base					
Nom d'attribut	Type d'attribut	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut					
substitution et bloqué					
configuration, description et extension					
Services (voir la CEI 61850-7-2)					
Les services suivants sont hérités de la CEI 61850-7-2. Ils sont spécialisés en limitant le service aux attributs ayant une contrainte fonctionnelle comme spécifié ci-dessous.					
Modèle de services selon la CEI 61850-7-2	Service		Le service s'applique à Attr avec FC	Remarque	
GenCommonDataClass model (modèle de GenCommonDataClass)	SetDataValues GetDataValues GetDataDefinition GetDataDirectory		DC, CF, SV, BL ALL ALL ALL		
Data set model (Modèle de jeux de données)	GetDataSetValues SetDataSetValues		ALL DC, CF, SV, BL		

Modèle de production de rapports Modèle GSE Sampled values mode (Modèle de valeurs échantillonnées)	Report SendGOOSEMessage SendGSSEMessage SendMSVMessage SendUSVMessage	ALL ST ST ST ST	comme spécifié dans le jeu de données qui est utilisé pour définir le contenu du message.
---	---	-----------------------------	---

7.3.2 Single point status (SPS)

Le Tableau 19 définit la classe de données communes "single point status" (c'est-à-dire statut de simple position).

Tableau 19 – Définition de la classe de données communes "Single point status"

Classe SPS					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataSetName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut					
stVal	BOOLEAN	ST	dchg	TRUE FALSE	M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
substitution et bloqué					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	BOOLEAN	SV		TRUE FALSE	PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description et extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_M
cdcName	VISIBLE STRING255	EX			AC_DLND_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 18.					

7.3.3 Double point status (DPS)

Le Tableau 20 définit la classe de données communes "double point status" (c'est-à-dire statut de double position).

Tableau 20 – Spécification de la classe de données communes "Double point status"

Classe DPS					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataSetName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut					
stVal	CODED ENUM	ST	dchg	intermediate-state off on bad-state	M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
substitution et bloqué					

subEna	BOOLEAN	SV			PICS_SUBST
subVal	CODED ENUM	SV		intermediate-state off on bad-state	PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
<i>configuration, description et extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 18.					

La valeur bad-state signifie que le serveur ne peut pas détecter si la position est ouverte, fermée ou dans un état intermédiaire.

7.3.4 Integer status (INS)

Le Tableau 21 définit la classe de données communes "integer status" (c'est-à-dire statut d'entier).

Tableau 21 – Spécification de la classe de données communes "Integer status"

Classe INS					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut					
stVal	INT32	ST	dchg, dupd		M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
substitution et bloqué					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	INT32	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description et extension					
units	Unit	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 18.					

7.3.5 Enumerated status (ENS)

Le Tableau 22 définit la classe de données communes "enumerated status" (c'est-à-dire statut énuméré).

Tableau 22 – Spécification de la classe de données communes "Enumerated status"

Classe ENS					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut					
stVal	ENUMERATED	ST	dchg, dupd		M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
substitution et bloqué					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	ENUMERATED	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description et extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLND_A_M
Services					
Comme défini dans le Tableau 18.					

7.3.6 Protection activation information (ACT)

Le Tableau 23 définit la classe de données communes "protection activation information".

Tableau 23 – Spécification de la classe de données communes "protection activation information"

Classe ACT					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérite de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut					
Généralités	BOOLEAN	ST	dchg		M
phsA	BOOLEAN	ST	dchg		O
phsB	BOOLEAN	ST	dchg		O
phsC	BOOLEAN	ST	dchg		O
neut	BOOLEAN	ST	dchg		O
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
originSrc	Originator	ST			O
operTmPhsA	TimeStamp	ST			O
operTmPhsB	TimeStamp	ST			O
operTmPhsC	TimeStamp	ST			O
configuration, description et extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC DLNDA M

cdcName	VISIBLE STRING255	EX			AC_DLND_M
dataNs	VISIBLE STRING255	EX			AC_DLND_M
Services					
Comme défini dans le Tableau 18.					

NOTE L'attribut originSrc peut être utilisé pour identifier l'émetteur lorsqu'une donnée de la CDC ACT est utilisée pour exécuter une opération. Un exemple serait la donnée OpOpn du NL CSWI utilisée pour ouvrir un disjoncteur (LN XCBR) par un message GOOSE. Le NL XCBR reçoit la donnée CSWI.OpOpn comportant l'émetteur comme un message GOOSE. Une fois actionné, l'information relative au nouveau statut contenue dans XCBR.Pos inclura l'information de l'émetteur qui a été reçue comme partie du message GOOSE ayant déclenché l'opération.

7.3.7 Directional protection activation information (ACD)

Le Tableau 24 définit la classe de données communes "directional protection activation information".

Tableau 24 – Spécification de la classe de données communes "Directional protection activation information"

Classe ACD					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut					
Généralités	BOOLEAN	ST	dchg		M
dirGeneral	ENUMERATED	ST	dchg	unknown forward backward both	M
phsA	BOOLEAN	ST	dchg		GC_2_1
dirPhsA	ENUMERATED	ST	dchg	unknown forward backward	GC_2_1
phsB	BOOLEAN	ST	dchg		GC_2_2
dirPhsB	ENUMERATED	ST	dchg	unknown forward backward	GC_2_2
phsC	BOOLEAN	ST	dchg		GC_2_3
dirPhsC	ENUMERATED	ST	dchg	unknown forward backward	GC_2_3
neut	BOOLEAN	ST	dchg		GC_2_4
dirNeut	ENUMERATED	ST	dchg	unknown forward backward	GC_2_4
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
configuration, description et extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 18.					

7.3.8 Security violation counting (SEC)

Le Tableau 25 définit la classe de données communes "security violation counting".

**Tableau 25 – Spécification de la classe de données communes
"Security violation counting"**

Classe SEC					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut					
cnt	INT32U	ST	dchg		M
sev	ENUMERATED	ST		unknown critical major minor warning	M
t	TimeStamp	ST			M
addr	OCTET STRING64	ST			O
addInfo	VISIBLE STRING64	ST			O
configuration, description et extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 18.					

7.3.9 Binary counter reading (BCR)

Le Tableau 26 définit la classe de données communes "binary counter reading".

Tableau 26 – Spécification de la classe de données communes "Binary counter reading"

Classe BCR					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut					
actVal	INT64	ST	dchg		M
frVal	INT64	ST	dupd		GC_2_1
frTm	TimeStamp	ST			GC_2_1
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
configuration, description et extension					
units	Unit	CF	dchg	voir Annexe A	O
pulsQty	FLOAT32	CF	dchg		M
frEna	BOOLEAN	CF	dchg		GC_2_1
strTm	TimeStamp	CF	dchg		GC_2_1
frPd	INT32	CF	dchg		GC_2_1
frRs	BOOLEAN	CF	dchg		GC_2_1
d	VISIBLE STRING255	DC			O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 18.					

7.3.10 Histogram (HST)

Le Tableau 27 définit la classe de données communes "Histogram".

Tableau 27 – Spécification de la classe de données communes "Histogram"

Classe HST					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataSource	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut					
hstVal	ARRAY 0..maxPts-1 OF INT32	ST	dchg, dupd		M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
configuration, description et extension					
numPts	INT16U	CF		0 < numPts ≤ maxPts	M
hstRangeC	ARRAY 0..maxPts-1 OF Cells	CF	dchg		M
xUnits	Unit	CF	dchg		M
yUnits	Unit	CF	dchg		O
units	Unit	CF	dchg		O
maxPts	INT16U	CF			M
xD	VISIBLE STRING255	DC			M
xDU	UNICODE STRING255	DC			O
yD	VISIBLE STRING255	DC			O
yDU	UNICODE STRING255	DC			O
d	VISIBLE STRING255	DC			O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_M
cdcName	VISIBLE STRING255	EX			AC_DLND_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 18.					

7.3.11 Visible string status (VSS)

Le Tableau 28 définit la classe de données communes "visible string status".

Tableau 28 – Définition de la classe de données communes "Visible string status"

Classe VSS					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataSource	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut					
stVal	VISIBLE STRING 255	ST	dchg	Text	M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
configuration, description et extension					
d	VISIBLE STRING255	DC		Text	O

Classe VSS					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_M
cdcName	VISIBLE STRING255	EX			AC_DLND_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 18.					

7.4 Spécifications de classe de données communes pour les informations relatives au mesurande

7.4.1 Application de services

Le Tableau 29 définit le modèle d'informations de mesurande de base. En particulier, il définit les relations d'héritage et la spécialisation de services définis dans la CEI 61850-7-2.

NOTE Des valeurs mesurées telles qu'utilisées dans les articles suivants peuvent aussi être appliquées à des valeurs calculées.

Tableau 29 – Modèle d'informations de mesurande de base

Modèle d'informations de mesurande de base					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
Donnée					
DataAttribute					
attributs mesurés					
substitution					
configuration, description et extension					
Services (voir la CEI 61850-7-2)					
Les services suivants sont hérités de la CEI 61850-7-2. Ils sont spécialisés en limitant le service aux attributs ayant une contrainte fonctionnelle comme spécifié ci-dessous.					
Modèle de services selon la CEI 61850-7-2	Service	Le service s'applique à Attr avec FC		Remarque	
GenCommonDataClass model (modèle de GenCommonDataClass)	SetDataValues GetDataValues GetDataDefinition GetDataDirectory	DC, CF, SV, BL ALL ALL ALL			
Data set model (Modèle de jeux de données)	GetDataSetValues SetDataSetValues	ALL DC, CF, SV, BL			
Reporting model GSE model Sampled values model	Report SendGOOSEMessage SendMSVMessage SendUSVMessage	ALL MX MX MX		comme spécifié dans le jeu de données qui est utilisé pour définir le contenu du message.	

7.4.2 Measured value (MV)

Le Tableau 30 définit la classe de données communes “measured value”.

Tableau 30 – Measured value

Classe MV					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
attributs mesurés					
instMag	AnalogueValue	MX			O
mag	AnalogueValue	MX	dchg, dupd		M
range	ENUMERATED	MX	dchg	normal high low high-high low-low	O
q	Quality	MX	qchg		M
t	TimeStamp	MX			M
substitution et bloqué					
subEna	BOOLEAN	SV			PICS_SUBST
subMag	AnalogueValue	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description et extension					
units	Unit	CF	dchg	voir Annexe A	O
db	INT32U	CF	dchg	0 ... 100 000	O
zeroDb	INT32U	CF	dchg	0 ... 100 000	O
sVC	ScaledValueConfig	CF	dchg		AC_SCAV
rangeC	RangeConfig	CF	dchg		GC_CON_range
smpRate	INT32U	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 29.					

7.4.3 Complex measured value (CMV)

Le Tableau 31 définit la classe de données communes “complex measured value”.

Tableau 31 – Complex measured value

Classe CMV					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
attributs mesurés					
instCVal	Vector	MX			O
cVal	Vector	MX	dchg, dupd		M
range	ENUMERATED	MX	dchg	normal high low high-high low-low	O
rangeAng	ENUMERATED	MX	dchg	normal high low high-high low-low	O
q	Quality	MX	qchg		M
t	TimeStamp	MX			M
substitution et bloqué					
subEna	BOOLEAN	SV			PICS_SUBST
subCVal	Vector	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description et extension					
units	Unit	CF	dchg	voir Annexe A	O
db	INT32U	CF	dchg	0 ... 100 000	O
dbAng	INT32U	CF	dchg	0 ... 100 000	O
zeroDb	INT32U	CF	dchg	0 ... 100 000	O
rangeC	RangeConfig	CF	dchg		GC_CON_range
rangeAngC	RangeConfig	CF	dchg		GC_CON_range Ang
magSVC	ScaledValueConfig	CF	dchg		AC_SCAV
angSVC	ScaledValueConfig	CF	dchg		AC_SCAV
angRef	ENUMERATED	CF	dchg	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother Synchrophasor	O
smpRate	INT32U	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 29.					

7.4.4 Sampled value (SAV)

Le Tableau 32 définit la classe de données communes "sampled value". Cette classe de données communes est utilisée pour représenter des échantillons de valeurs analogiques instantanées. Les valeurs sont en général émises en utilisant le modèle "transmission of sampled value model" (c'est-à-dire modèle de transmission de valeurs échantillonnées) tel que défini dans la CEI 61850-7-2.

Tableau 32 – Sampled value

Classe SAV					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
attributs mesurés					
instMag	AnalogueValue	MX			M
q	Quality	MX	qchg		M
t	TimeStamp	MX			O
configuration, description et extension					
units	Unit	CF	dchg	voir Annexe A	O
sVC	ScaledValueConfig	CF	dchg		AC_SCAV
min	AnalogueValue	CF	dchg		O
max	AnalogueValue	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 29.					

7.4.5 Valeurs mesurées liées à phase-terre/neutre pour un système triphasé (WYE)

Le Tableau 33 définit la classe de données communes "WYE". Cette classe est un ensemble de mesures simultanées dans un système triphasé qui représentent les valeurs phase-terre.

Tableau 33 – WYE

Classe WYE					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
SubDataObject					
phsA	CMV				GC_1
phsB	CMV				GC_1
phsC	CMV				GC_1
neut	CMV				GC_1
net	CMV				GC_1
res	CMV				GC_1
DataAttribute					
configuration, description et extension					
angRef	ENUMERATED	CF	dchg	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother Synchrophasor	O
phsToNeut	BOOLEAN	CF	dchg	DEFAULT = FALSE	O

d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 29.					

Concernant les attributs de données de la CDC CMV, les spécifications complémentaires suivantes s'appliquent.

- L'attribut de donnée angRef de phsA, phsB, phsC, neut, net et res ne doit pas être utilisé. En revanche, l'attribut angRef défini dans la CDC WYE doit être utilisé.
- Les valeurs de phsA.t, phsB.t, phsC.t, neut.t, net.t et res.t sont identiques. Elles spécifient l'heure à laquelle les valeurs de phsA, phsB, phsC et neut ont été acquises ou déterminées simultanément.

7.4.6 Valeurs mesurées liées à phase-phase pour un système triphasé (DEL)

Le Tableau 34 définit la classe de données communes “delta”. Cette classe est un ensemble de mesures dans un système triphasé qui représentent les valeurs phase-phase.

Tableau 34 – Delta

Classe DEL					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
SubDataObject					
phsAB	CMV				GC_1
phsBC	CMV				GC_1
phsCA	CMV				GC_1
DataAttribute					
configuration, description et extension					
angRef	ENUMERATED	CF	dchg	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother Synchrophasor	O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 29.					

Concernant les attributs de données de la CDC CMV, les spécifications complémentaires suivantes s'appliquent.

- L'attribut de donnée angRef of phsAB, phsBC et phsCA ne doit pas être utilisé. En revanche, l'attribut angRef défini dans la CDC DEL doit être utilisé.
- Les valeurs de phsAB.t, phsBC.t et phsCA.t sont identiques. Elles spécifient l'heure à laquelle les valeurs de phsAB, phsBC, phsCA ont été acquises ou déterminées simultanément.

7.4.7 Sequence (SEQ)

Le Tableau 35 définit la classe de données communes “sequence”. Cette classe est un ensemble de composantes séquentielles d'une valeur.

Tableau 35 – Sequence

Classe SEQ					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
SubDataObject					
c1	CMV				M
c2	CMV				M
c3	CMV				M
DataAttribute					
attributs mesurés					
seqT	ENUMERATED	MX		pos-neg-zero dir-quad-zero	M
configuration, description et extension					
phsRef	ENUMERATED	CF	dchg	A B C	O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 29.					

Concernant les attributs de données de la CDC CMV, les spécifications complémentaires suivantes s'appliquent.

- Les valeurs de c1.t, c2.t et c3.t sont identiques. Elles spécifient l'heure à laquelle les valeurs de c1, c2 et c3 ont été calculées.

7.4.8 Harmonic value (HMV)

Le Tableau 36 définit la classe de données communes pour des valeurs harmoniques non liées à la phase. Cette classe est un ensemble de valeurs qui représentent le contenu harmonique ou interharmonique d'une valeur de processus.

Tableau 36 – Harmonic value

Classe HMV					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
SubDataObject					
har	ARRAY 0..numHar OF CMV				M
DataAttribute					
configuration, description et extension					
numHar	INT16U	CF	dchg	>0	M
numCyc	INT16U	CF	dchg	>0	M
evalTm	INT16U	CF	dchg		M
smpRate	INT32U	CF	dchg		O
Fréquence	FLOAT32	CF	dchg	nominal frequency	M

hvRef	ENUMERATED	CF	dchg	fundamental rms absolute	O
rmsCyc	INT16U	CF	dchg		AC_RMS_M
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_M
cdcName	VISIBLE STRING255	EX			AC_DLND_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 29.					

NOTE Les harmoniques pour un circuit individuel ont des angles de phase (facultatifs) mais n'ont pas besoin de référence pour l'angle (angRef) car, par convention, la référence est toujours la fréquence fondamentale (indice 1).

7.4.9 Harmonic value for WYE (HWYE)

Le Tableau 37 définit la classe de données communes “harmonic value for WYE” (c'est-à-dire valeur harmonique pour WYE). Cette classe est un ensemble de mesures (ou évaluations) simultanées de valeurs qui représentent le contenu harmonique ou interharmonique d'une valeur de processus dans un système triphasé avec des valeurs phase terre.

Tableau 37 – Harmonic values for WYE

Classe HWYE					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
SubDataObject					
phsAHar	ARRAY 0..numHar OF CMV				M
phsBHar	ARRAY 0..numHar OF CMV				O
phsCHar	ARRAY 0..numHar OF CMV				O
neutHar	ARRAY 0..numHar OF CMV				O
netHar	ARRAY 0..numHar OF CMV				O
resHar	ARRAY 0..numHar OF CMV				O
DataAttribute					
configuration, description et extension					
numHar	INT16U	CF	dchg	>0	M
numCyc	INT16U	CF	dchg	>0	M
evalTm	INT16U	CF	dchg		M
angRef	ENUMERATED	CF	dchg	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother Synchrophasor	O
smpRate	INT32U	CF	dchg		O
Fréquence	FLOAT32	CF	dchg	fundamental frequency	M
hvRef	ENUMERATED	CF	dchg	fundamental rms absolute	O
rmsCyc	INT16U	CF	dchg		AC_RMS_M
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 29.					

7.4.10 Harmonic value for DEL (HDEL)

Le Tableau 38 définit la classe de données communes “harmonic value for delta” (c'est-à-dire valeur harmonique pour montage triangle). Cette classe est un ensemble de mesures (ou évaluations) simultanées de valeurs qui représentent le contenu harmonique ou interharmonique d'une valeur de processus dans un système triphasé avec des valeurs phase-phase.

Tableau 38 – Harmonic values for delta

Classe HDEL					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
SubDataObject					
phsABHar	ARRAY 0..numHar OF CMV				M
phsBCHar	ARRAY 0..numHar OF CMV				O
phsCAHar	ARRAY 0..numHar OF CMV				O
DataAttribute					
configuration, description et extension					
numHar	INT16U	CF	dchg	>0	M
numCyc	INT16U	CF	dchg	>0	M
evalTm	INT16U	CF	dchg		M
angRef	ENUMERATED	CF	dchg	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother Synchrophasor	O
smpRate	INT32U	CF	dchg		O
Fréquence	FLOAT32	CF	dchg	nominal frequency	M
hvRef	ENUMERATED	CF	dchg	fundamental rms absolute	O
rmsCyc	INT16U	CF	dchg		AC_RMS_M
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 29.					

7.5 Spécifications de classe de données communes pour les commandes

7.5.1 Application de services

Le Tableau 39 définit le modèle d'informations de statut contrôlables de base. En particulier, il définit les relations d'héritage et la spécialisation de services définis dans la CEI 61850-7-2.

Tableau 39 – Modèle d'informations de statut contrôlable de base

Modèle d'informations de statut contrôlable de base					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
état/ attributs mesurés et miroir de contrôle					
substitution et bloqué					
configuration, description et extension					
paramètres pour services de contrôle					
Services (voir la CEI 61850-7-2)					
Les services suivants sont hérités de la CEI 61850-7-2. Ils sont spécialisés en limitant le service aux attributs ayant une contrainte fonctionnelle comme spécifié ci-dessous.					
Modèle de services selon la CEI 61850-7-2	Service	Le service s'applique à Attr avec FC		Remarque	
GenCommonDataClass model	SetDataValues GetDataValues GetDataDefinition GetDataDirectory	DC, CF, SV, BL ALL ALL ALL			
Data set model (Modèle de jeux de données)	GetDataSetValues SetDataSetValues	ALL DC, CF, SV, BL			
Reporting model GSE model	Report SendGOOSEMessage SendGSSEMessage	ALL ST, MX ST		comme spécifié dans le jeu de données qui est utilisé pour définir le contenu du message	
Sampled values model	SendMSVMessage SendUSVMessage	ST, MX ST, MX			
Modèle de contrôle	Select SelectWithValue Cancel Operate CommandTermination TimeActivatedOperate				

Toutes les classes de données communes pour les informations de statut contrôlables comprennent aussi bien la commande que les informations de statut connexes.

NOTE Le paramètre de service du contrôle, qui appartient au modèle de contrôle défini dans la CEI 61850-7-2, est inclus ici, comme ce type est défini par le CDC.

7.5.2 Controllable single point (SPC)

Le Tableau 40 définit la classe de données communes “controllable single point” (c'est-à-dire simple position contrôlable).

Tableau 40 – Controllable single point

Classe SPC					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut et miroir de contrôle					
origin	Originator	ST			AC_CO_O
ctlNum	INT8U	ST		0..255	AC_CO_O
stVal	BOOLEAN	ST	dchg	FALSE TRUE	AC_ST
q	Quality	ST	qchg		AC_ST
t	TimeStamp	ST			AC_ST
stSeld	BOOLEAN	ST	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution et bloqué					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	BOOLEAN	SV		FALSE TRUE	PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description et extension					
pulseConfig	PulseConfig	CF	dchg		AC_CO_O
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 39.					
paramètres pour services de contrôle					
Nom du paramètre de service		Type du paramètre de service		Valeur/Plage de valeurs	
ctlVal		BOOLEAN		off (FALSE) on (TRUE)	

7.5.3 Controllable double point (DPC)

Le Tableau 41 définit la classe de données communes “controllable double point”.

Tableau 41 – Controllable double point

Classe DPC					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut et miroir de contrôle					
origin	Originator	ST			AC_CO_O
ctlNum	INT8U	ST		0..255	AC_CO_O
stVal	CODED ENUM	ST	dchg	intermediate-state off on bad-state	M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
stSeld	BOOLEAN	ST	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution et bloqué					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	CODED ENUM	SV		intermediate-state off on bad-state	PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description et extension					
pulseConfig	PulseConfig	CF	dchg		AC_CO_O
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 39.					
paramètres pour services de contrôle					
Nom du paramètre de service		Type du paramètre de service		Valeur/Plage de valeurs	
ctlVal		BOOLEAN		off (FALSE) on (TRUE)	

La valeur bad-state signifie que le serveur ne peut pas détecter si la position est ouverte, fermée ou dans un état intermédiaire.

7.5.4 Controllable integer status (INC)

Le Tableau 42 définit la classe de données communes “controllable integer status” (c'est-à-dire statut entier contrôlable).

Tableau 42 – Controllable integer status

Classe INC					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut et miroir de contrôle					
origin	Originator	ST			AC_CO_O
ctlNum	INT8U	ST		0..255	AC_CO_O
stVal	INT32	ST	dchg		M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
stSeld	BOOLEAN	ST	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution et bloqué					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	INT32	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description et extension					
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
minVal	INT32	CF	dchg		O
maxVal	INT32	CF	dchg		O
stepSize	INT32U	CF	dchg	1 ... (maxVal – minVal)	O
operTimeout	INT32U	CF	dchg		AC_CO_O
units	Unit	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 39.					
paramètres pour services de contrôle					
Nom du paramètre de service		Type du paramètre de service		Valeur/Plage de valeurs	
ctlVal		INT32			

7.5.5 Controllable enumerated status (ENC)

Le Tableau 43 définit la classe de données communes “controllable enumerated status” (c'est-à-dire statut énuméré contrôlable).

Tableau 43 – Controllable enumerated status

Classe ENC					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut et miroir de contrôle					
origin	Originator	ST			AC_CO_O
ctlNum	INT8U	ST		0..255	AC_CO_O
stVal	ENUMERATED	ST	dchg		M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
stSeld	BOOLEAN	ST	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution et bloqué					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	ENUMERATED	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description et extension					
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 39.					
paramètres pour services de contrôle					
Nom du paramètre de service		Type du paramètre de service		Valeur/Plage de valeurs	
ctlVal		ENUMERATED			

7.5.6 Binary controlled step position information (BSC)

Le Tableau 44 définit la classe de données communes “binary controlled step position information” (informations binaires de position de phase contrôlée).

Tableau 44 – Binary controlled step position information

Classe BSC					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut et miroir de contrôle					
origin	Originator	ST			AC_CO_O
ctlNum	INT8U	ST		0..255	AC_CO_O
valWTr	ValWithTrans	ST	dchg		AC_ST
q	Quality	ST	qchg		AC_ST
t	TimeStamp	ST			AC_ST
stSeld	BOOLEAN	ST	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution et bloqué					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	ValWithTrans	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description et extension					
persistent	BOOLEAN	CF	dchg		M
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
minVal	INT8	CF	dchg		O
maxVal	INT8	CF	dchg		O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 39.					
paramètres pour services de contrôle					
Nom du paramètre de service		Type du paramètre de service		Valeur/Plage de valeurs	
ctlVal		CODED ENUM		stop lower higher reserved	

7.5.7 Integer controlled step position information (ISC)

Le Tableau 45 définit la classe de données communes "integer controlled step position information".

Tableau 45 – Integer controlled step position information

Classe ISC					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
statut et miroir de contrôle					
origin	Originator	ST			AC_CO_O
ctlNum	INT8U	ST		0..255	AC_CO_O
valWTr	ValWithTrans	ST	dchg		AC_ST
q	Quality	ST	qchg		AC_ST
t	TimeStamp	ST			AC_ST
stSeld	BOOLEAN	ST	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution et bloqué					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	ValWithTrans	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description et extension					
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
minVal	INT8	CF	dchg		O
maxVal	INT8	CF	dchg		O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 39.					
paramètres pour services de contrôle					
Nom du paramètre de service		Type du paramètre de service		Valeur/Plage de valeurs	
ctlVal		INT8		-64 ... 63	

7.5.8 Controllable analogue process value (APC)

Le Tableau 46 définit la classe de données communes “controllable analogue process value” (c'est-à-dire valeur de processus analogique contrôlable).

Tableau 46 – Controllable analogue process value

Classe APC					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
attributs mesurés et miroir de contrôle					
origin	Originator	MX			AC_CO_O
ctlNum	INT8U	MX		0..255	AC_CO_O
mxVal	AnalogueValue	MX	dchg		AC_ST
q	Quality	MX	qchg		AC_ST
t	TimeStamp	MX			AC_ST
stSeld	BOOLEAN	MX	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution et bloqué					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	AnalogueValue	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description et extension					
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
units	Unit	CF	dchg	voir Annexe A	O
db	INT32U	CF	dchg	0 ... 100 000	O
sVC	ScaledValueConfig	CF	dchg		AC_SCAV
minVal	AnalogueValue	CF	dchg		O
maxVal	AnalogueValue	CF	dchg		O
stepSize	AnalogueValue	CF	dchg	0 ... (maxVal – minVal)	O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLND_A_M
Services					
Comme défini dans le Tableau 39.					
paramètres pour services de contrôle					
Nom du paramètre de service		Type du paramètre de service		Valeur/Plage de valeurs	
ctlVal		AnalogueValue			

7.5.9 Binary controlled analog process value (BAC)

Le Tableau 47 définit la classe de données communes “binary controlled analog process value” (c'est-à-dire valeur binaire de processus analogique contrôlée).

Tableau 47 – Binary controlled analog process value

Classe BAC					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
Statut et miroir de contrôle					
origin	Originator	MX			AC_CO_O
ctlNum	INT8U	MX		0..255	AC_CO_O
mxVal	AnalogueValue	MX	dchg		AC_ST
q	Quality	MX	qchg		AC_ST
t	TimeStamp	MX			AC_ST
stSeld	BOOLEAN	MX	dchg		O
opRcvd	BOOLEAN	OR	dchg		O
opOk	BOOLEAN	OR	dchg		O
tOpOk	TimeStamp	OR			O
substitution et bloqué					
subEna	BOOLEAN	SV			PICS_SUBST
subVal	AnalogueValue	SV			PICS_SUBST
subQ	Quality	SV			PICS_SUBST
subID	VISIBLE STRING64	SV			PICS_SUBST
blkEna	BOOLEAN	BL			O
configuration, description et extension					
persistent	BOOLEAN	CF	dchg		M
ctlModel	CtlModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
units	Unit	CF	dchg	voir Annexe A	O
dB	INT32U	CF	dchg	0 ... 100 000	O
sVC	ScaledValueConfig	CF	dchg		AC_SCAV
minVal	AnalogueValue	CF	dchg		O
maxVal	AnalogueValue	CF	dchg		O
stepSize	AnalogueValue	CF	dchg	1 ... (maxVal – minVal)	O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLND_M
Services					
Comme défini dans le Tableau 39.					
paramètres pour services de contrôle					
Nom du paramètre de service		Type du paramètre de service		Valeur/Plage de valeurs	
ctlVal		CODED ENUM		stop lower higher reserved	

7.6 Spécifications de classe de données communes pour "status settings"

7.6.1 Application de services

Le Tableau 48 définit le modèle de réglages de statut contrôlables de base. En particulier, il définit les relations d'héritage et la spécialisation de services définis dans la CEI 61850-7-2.

Tableau 48 – Modèle de réglages de statut de base

Modèle d'informations de statut contrôlables de base					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
réglage					
configuration, description et extension					
Services (voir la CEI 61850-7-2)					
Les services suivants sont hérités de la CEI 61850-7-2. Ils sont spécialisés en limitant le service aux attributs ayant une contrainte fonctionnelle comme spécifié ci-dessous.					
Modèle de services selon la CEI 61850-7-2	Service	Le service s'applique à Attr avec FC		Remarque	
GenCommonDataClass model	SetDataValues GetDataValues GetDataDefinition GetDataDirectory	DC, CF, SP ALL exceptés SE ALL ALL			
Data set model (Modèle de jeux de données)	GetDataSetValues SetDataSetValues	ALL excepté SE DC, CF			
Reporting model GSE model	Report SendGOOSEMessage	ALL excepté SE SP		comme spécifié dans le jeu de données qui est utilisé pour définir le contenu du message.	
Setting group control model	SetEditSGValues GetEditSGValues	SE SE, SG			

7.6.2 Single point setting (SPG)

Le Tableau 49 définit la classe de données communes "single point setting".

Tableau 49 – Single point setting

Classe SPG					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
réglage					
setVal	BOOLEAN	SP	dchg	off (FALSE) on (TRUE)	AC_NSG_M
setVal	BOOLEAN	SG, SE		off (FALSE) on (TRUE)	AC_SG_M
configuration, description et extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 48.					

7.6.3 Integer status setting (ING)

Le Tableau 50 définit la classe de données communes “integer status setting”.

Tableau 50 – Integer status setting

Classe ING					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
réglage					
setVal	INT32	SP	dchg		AC_NSNG_M
setVal	INT32	SG, SE			AC_SG_M
configuration, description et extension					
minVal	INT32	CF	dchg		O
maxVal	INT32	CF	dchg		O
stepSize	INT32U	CF	dchg	1 ... (maxVal – minVal)	O
units	Unit	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 48.					

7.6.4 Enumerated status setting (ENG)

Le Tableau 51 définit la classe de données communes “enumerated status setting”.

Tableau 51 – Enumerated status setting

Classe ENG					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
réglage					
setVal	ENUMERATED	SP	dchg		AC_NSNG_M
setVal	ENUMERATED	SG, SE			AC_SG_M
configuration, description et extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 48.					

7.6.5 Object reference setting (ORG)

Le Tableau 52 définit la classe de données communes "object reference setting".

Tableau 52 – Spécification de la classe de données communes "Object reference setting"

Classe ORG					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
réglage					
setSrcRef	ObjectReference	SP	dchg	Object Reference	M
setTstRef	ObjectReference	SP	dchg	Object Reference	GC_2_1
setSrcCB	ObjectReference	SP	dchg	Object Reference	O
setTstCB	ObjectReference	SP	dchg	Object Reference	GC_CON_setTstRef
intAddr	VISIBLE STRING255	SP	dchg		O
tstEna	BOOLEAN	SP	dchg		GC_2_1
configuration, description et extension					
purpose	VISIBLE STRING255	DC			O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 48.					

7.6.6 Time setting group (TSG)

Le Tableau 53 définit la classe de données communes "Time setting group" (groupe de réglages de l'heure).

Tableau 53 – Spécification de la classe de données communes "Time setting group"

Classe TSG					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
réglage					
setTm	TimeStamp	SP	dchg		AC_NSG_C1
setCal	CalendarTime	SP	dchg		AC_NSG_C1
setTm	TimeStamp	SG, SE			AC_SG_C1
setCal	CalendarTime	SG, SE			AC_SG_C1
configuration, description et extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC DLNDA

Classe TSG					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
cdcName	VISIBLE STRING255	EX			M AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 48.					

7.6.7 Currency setting group (CUG)

Le Tableau 54 définit la classe de données communes "Currency setting group" (c'est-à-dire groupe de réglages des monnaies).

Tableau 54 – Spécification de la classe de données communes "Currency setting group"

Classe CUG					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
Réglage					
cur	Currency	SP	dchg	Code de monnaies à trois caractères selon l'ISO 4217	AC_NSG_M
cur	Currency	SG, SE		Code de monnaies à trois caractères selon l'ISO 4217	AC_SG_M
configuration, description et extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 48.					

7.6.8 Visible String Setting (VSG)

Le Tableau 55 définit la classe de données communes "visible string setting group" (groupe de réglages des chaînes visibles).

Tableau 55 – Spécification de la classe de données communes "Visible string setting group"

Classe VSG					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
réglage					
setVal	VISIBLE STRING255	SP	dchg		AC NSG M

Classe VSG					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
setVal	VISIBLE STRING255	SG, SE			AC_SG_M
<i>configuration, description et extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDL_M
cdcName	VISIBLE STRING255	EX			AC_DLNDL_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 48.					

7.7 Spécifications de classe de données communes pour "analogue settings" (c'est-à-dire réglages analogiques)

7.7.1 Application de services

Le Tableau 56 définit le modèle d'informations analogiques contrôlables de base. En particulier, il définit les relations d'héritage et la spécialisation de services définis dans la CEI 61850-7-2.

Tableau 56 – Modèle de réglages analogiques de base

Modèle d'informations analogiques contrôlables de base					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
réglage					
configuration, description et extension					
Services (voir la CEI 61850-7-2)					
Les services suivants sont hérités de la CEI 61850-7-2. Ils sont spécialisés en limitant le service aux attributs ayant une contrainte fonctionnelle comme spécifié ci-dessous.					
Modèle de services selon la CEI 61850-7-2	Service		Le service s'applique à Attr avec FC		Remarque
GenCommonDataClass model	SetDataValues GetDataValues GetDataDefinition GetDataDirectory		DC, CF, SP ALL exceptés SE ALL ALL		
Data set model (Modèle de jeux de données)	GetDataSetValues SetDataSetValues		ALL excepté SE DC, CF		
Reporting model GSE model	Report SendGOOSEMessage		ALL excepté SE SP		comme spécifié dans le jeu de données qui est utilisé pour définir le contenu du message.
Setting group control model	SetEditSGValues GetEditSGValues		SE SE, SG		

7.7.2 Analogue setting (ASG)

Le Tableau 57 définit la classe de données communes “analogue setting”.

Tableau 57 – Analogue setting

Classe ASG					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
réglage					
setMag	AnalogueValue	SP	dchg		AC_NSg_M
setMag	AnalogueValue	SG, SE			AC_Sg_M
configuration, description et extension					
units	Unit	CF	dchg	voir Annexe A	O
sVC	ScaledValueConfig	CF	dchg		AC_SCAV
minVal	AnalogueValue	CF	dchg		O
maxVal	AnalogueValue	CF	dchg		O
stepSize	AnalogueValue	CF	dchg	0 ... (maxVal – minVal)	O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDa_M
cdcName	VISIBLE STRING255	EX			AC_DLNDa_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 56.					

7.7.3 Setting curve (CURVE)

Le Tableau 58 définit la classe de données communes “setting curve” (c'est-à-dire courbe de réglages).

Tableau 58 – Setting curve

Classe CURVE					
Nom d'attribut de donnée	Type	FC	TrgOp	Valeur/Plage de valeurs	M/O/C
DataName	Hérité de GenDataObject Class ou de GenSubDataObject Class (voir la CEI 61850-7-2)				
DataAttribute					
réglage					
setCharact	ENUMERATED	SP	dchg		AC_NSG_M
setParA	FLOAT32	SP	dchg		AC_NSG_O
setParB	FLOAT32	SP	dchg		AC_NSG_O
setParC	FLOAT32	SP	dchg		AC_NSG_O
setParD	FLOAT32	SP	dchg		AC_NSG_O
setParE	FLOAT32	SP	dchg		AC_NSG_O
setParF	FLOAT32	SP	dchg		AC_NSG_O
setCharact	ENUMERATED	SG, SE			AC_SG_M
setParA	FLOAT32	SG, SE			AC_SG_O
setParB	FLOAT32	SG, SE			AC_SG_O
setParC	FLOAT32	SG, SE			AC_SG_O
setParD	FLOAT32	SG, SE			AC_SG_O
setParE	FLOAT32	SG, SE			AC_SG_O
setParF	FLOAT32	SG, SE			AC_SG_O
configuration, description et extension					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
Comme défini dans le Tableau 56					

Les DataObjects de cette classe de données communes doivent être utilisés pour décrire les courbes de réglages utilisés dans l'équipement de protection. La CDC CURVE est utilisée pour sélectionner avec l'attribut setChar 1 à 48 formes de courbe prédéfinies. Dans un certain nombre de cas, il est en plus permis de changer les paramètres pour les courbes. Les formes de courbe sont typiquement définies avec des formules utilisant jusqu'à 6 paramètres. Certaines de ces formules sont normalisées (valeur de setCharact entre 1 et 16), d'autres formules peuvent être définies par l'utilisateur (valeur de setCharact entre 17 et 32; la spécification de la formule est une question locale). Dans certains cas, la courbe peut être spécifiée comme étant une matrice de n paires (x,y) (valeur de setChar entre 33 et 48; la spécification de la matrice de n paires (x,y) est une question locale; une donnée de la CDC CSG peut être utilisée pour spécifier chacune des caractéristiques 33 à 48). La courbe obtenue peut être lue du dispositif en utilisant une donnée dédiée de la CDC CSD telle que définie en 7.8.4.