



ISO/IEC 29341-6-10

Edition 1.0 2008-11

INTERNATIONAL STANDARD

**Information technology – UPnP Device Architecture –
Part 6-10: Heating, Ventilation and Air Conditioning Device Control Protocol –
Control Valve Service**

IECNORM.COM : Click to view the full PDF of ISO/IEC 29341-6-10:2008



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2008 ISO/IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about ISO/IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

IECNORM.COM : Click to view the full PDF of ISO/IEC 29341-6-10:2008



ISO/IEC 29341-6-10

Edition 1.0 2008-11

INTERNATIONAL STANDARD

**Information technology – UPnP Device Architecture –
Part 6-10: Heating, Ventilation and Air Conditioning Device Control Protocol –
Control Valve Service**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE

F

ICS 35.200

ISBN 2-8318-1007-5

CONTENTS

FOREWORD	3
ORIGINAL UPNP DOCUMENTS (informative)	5
1. Overview and Scope	7
2. Service Modeling Definitions	7
2.1. Service Type	7
2.2. State Variables	7
2.2.1. ControlMode	8
2.2.2. PositionTarget	8
2.2.3. PositionStatus	8
2.2.4. MinPosition	8
2.2.5. MaxPosition	8
2.2.6. Relationships Between State Variables	8
2.3. Eventing and Moderation	9
2.4. Actions	9
2.4.1. GetMode	9
2.4.2. SetMode	10
2.4.3. GetPosition	10
2.4.4. GetPositionTarget	11
2.4.5. SetPosition	11
2.4.6. GetMinMax	12
2.4.7. SetMinMax	12
2.4.8. Non-Standard Actions Implemented by an UPnP Vendor	13
2.4.9. Relationships Between Actions	13
2.4.10. Common Action Error Codes	13
2.5. Theory of Operation	14
3. XML Service Description	15
4. Test	18

LIST OF TABLES

Table 1: State Variables	7
Table 2: Relationship Between State Variables	8
Table 3: Event Moderation	9
Table 4: Actions	9
Table 5: Arguments for GetMode	9
Table 6: Arguments for SetMode	10
Table 7: Arguments for GetPosition	10
Table 8: Arguments for GetPositionTarget	11
Table 9: Arguments for SetPosition	11
Table 10: Arguments for GetMinMax	12
Table 11: Arguments for SetMinMax	13

INFORMATION TECHNOLOGY – UPNP DEVICE ARCHITECTURE –

Part 6-10: Heating, Ventilation and Air Conditioning Device Control Protocol – Control Valve Service

FOREWORD

- 1) ISO (International Organization for Standardization) and IEC (International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards. Their preparation is entrusted to technical committees; any ISO and IEC member body interested in the subject dealt with may participate in this preparatory work. International governmental and non-governmental organizations liaising with ISO and IEC also participate in this preparation.
- 2) In the field of information technology, ISO and IEC have established a joint technical committee, ISO/IEC JTC 1. Draft International Standards adopted by the joint technical committee are circulated to national bodies for voting. Publication as an International Standard requires approval by at least 75 % of the national bodies casting a vote.
- 3) The formal decisions or agreements of IEC and ISO on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC and ISO member bodies.
- 4) IEC, ISO and ISO/IEC publications have the form of recommendations for international use and are accepted by IEC and ISO member bodies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC, ISO and ISO/IEC publications is accurate, IEC or ISO cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 5) In order to promote international uniformity, IEC and ISO member bodies undertake to apply IEC, ISO and ISO/IEC publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any ISO/IEC publication and the corresponding national or regional publication should be clearly indicated in the latter.
- 6) ISO and IEC provide no marking procedure to indicate their approval and cannot be rendered responsible for any equipment declared to be in conformity with an ISO/IEC publication.
- 7) All users should ensure that they have the latest edition of this publication.
- 8) No liability shall attach to IEC or ISO or its directors, employees, servants or agents including individual experts and members of their technical committees and IEC or ISO member bodies for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication of, use of, or reliance upon, this ISO/IEC publication or any other IEC, ISO or ISO/IEC publications.
- 9) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

IEC and ISO draw attention to the fact that it is claimed that compliance with this document may involve the use of patents as indicated below.

ISO and IEC take no position concerning the evidence, validity and scope of the putative patent rights. The holders of the putative patent rights have assured IEC and ISO that they are willing to negotiate free licences or licences under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statements of the holders of the putative patent rights are registered with IEC and ISO.

Intel Corporation has informed IEC and ISO that it has patent applications or granted patents.

Information may be obtained from:

Intel Corporation
Standards Licensing Department
5200 NE Elam Young Parkway
MS: JFS-98
USA – Hillsboro, Oregon 97124

Microsoft Corporation has informed IEC and ISO that it has patent applications or granted patents as listed below:

6101499 / US; 6687755 / US; 6910068 / US; 7130895 / US; 6725281 / US; 7089307 / US; 7069312 / US;
10/783 524 / US

Information may be obtained from:

Microsoft Corporation
One Microsoft Way
USA – Redmond WA 98052

Philips International B.V. has informed IEC and ISO that it has patent applications or granted patents.

Information may be obtained from:

Philips International B.V. – IP&S
High Tech campus, building 44 3A21
NL – 5656 Eindhoven

NXP B.V. (NL) has informed IEC and ISO that it has patent applications or granted patents.

Information may be obtained from:

NXP B.V. (NL)
High Tech campus 60
NL – 5656 AG Eindhoven

Matsushita Electric Industrial Co. Ltd. has informed IEC and ISO that it has patent applications or granted patents.

Information may be obtained from:

Matsushita Electric Industrial Co. Ltd.
1-3-7 Shiromi, Chuoh-ku
JP – Osaka 540-6139

Hewlett Packard Company has informed IEC and ISO that it has patent applications or granted patents as listed below:

5 956 487 / US; 6 170 007 / US; 6 139 177 / US; 6 529 936 / US; 6 470 339 / US; 6 571 388 / US; 6 205 466 / US

Information may be obtained from:

Hewlett Packard Company
1501 Page Mill Road
USA – Palo Alto, CA 94304

Samsung Electronics Co. Ltd. has informed IEC and ISO that it has patent applications or granted patents.

Information may be obtained from:

Digital Media Business, Samsung Electronics Co. Ltd.
416 Maetan-3 Dong, Yeongtang-Gu,
KR – Suwon City 443-742

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC and ISO shall not be held responsible for identifying any or all such patent rights.

ISO/IEC 29341-6-10 was prepared by UPnP Implementers Corporation and adopted, under the PAS procedure, by joint technical committee ISO/IEC JTC 1, *Information technology*, in parallel with its approval by national bodies of ISO and IEC.

The list of all currently available parts of the ISO/IEC 29341 series, under the general title *Universal plug and play (UPnP) architecture*, can be found on the IEC web site.

This International Standard has been approved by vote of the member bodies, and the voting results may be obtained from the address given on the second title page.

ORIGINAL UPnP DOCUMENTS (informative)

Reference may be made in this document to original UPnP documents. These references are retained in order to maintain consistency between the specifications as published by ISO/IEC and by UPnP Implementers Corporation. The following table indicates the original UPnP document titles and the corresponding part of ISO/IEC 29341:

UPnP Document Title	ISO/IEC 29341 Part
UPnP Device Architecture 1.0	ISO/IEC 29341-1
UPnP Basic:1 Device	ISO/IEC 29341-2
UPnP AV Architecture:1	ISO/IEC 29341-3-1
UPnP MediaRenderer:1 Device	ISO/IEC 29341-3-2
UPnP MediaServer:1 Device	ISO/IEC 29341-3-3
UPnP AVTransport:1 Service	ISO/IEC 29341-3-10
UPnP ConnectionManager:1 Service	ISO/IEC 29341-3-11
UPnP ContentDirectory:1 Service	ISO/IEC 29341-3-12
UPnP RenderingControl:1 Service	ISO/IEC 29341-3-13
UPnP MediaRenderer:2 Device	ISO/IEC 29341-4-2
UPnP MediaServer:2 Device	ISO/IEC 29341-4-3
UPnP AV Datastructure Template:1	ISO/IEC 29341-4-4
UPnP AVTransport:2 Service	ISO/IEC 29341-4-10
UPnP ConnectionManager:2 Service	ISO/IEC 29341-4-11
UPnP ContentDirectory:2 Service	ISO/IEC 29341-4-12
UPnP RenderingControl:2 Service	ISO/IEC 29341-4-13
UPnP ScheduledRecording:1	ISO/IEC 29341-4-14
UPnP DigitalSecurityCamera:1 Device	ISO/IEC 29341-5-1
UPnP DigitalSecurityCameraMotionImage:1 Service	ISO/IEC 29341-5-10
UPnP DigitalSecurityCameraSettings:1 Service	ISO/IEC 29341-5-11
UPnP DigitalSecurityCameraStillImage:1 Service	ISO/IEC 29341-5-12
UPnP HVAC_System:1 Device	ISO/IEC 29341-6-1
UPnP HVAC_ZoneThermostat:1 Device	ISO/IEC 29341-6-2
UPnP ControlValve:1 Service	ISO/IEC 29341-6-10
UPnP HVAC_FanOperatingMode:1 Service	ISO/IEC 29341-6-11
UPnP FanSpeed:1 Service	ISO/IEC 29341-6-12
UPnP HouseStatus:1 Service	ISO/IEC 29341-6-13
UPnP HVAC_SetpointSchedule:1 Service	ISO/IEC 29341-6-14
UPnP TemperatureSensor:1 Service	ISO/IEC 29341-6-15
UPnP TemperatureSetpoint:1 Service	ISO/IEC 29341-6-16
UPnP HVAC_UserOperatingMode:1 Service	ISO/IEC 29341-6-17
UPnP BinaryLight:1 Device	ISO/IEC 29341-7-1
UPnP DimmableLight:1 Device	ISO/IEC 29341-7-2
UPnP Dimming:1 Service	ISO/IEC 29341-7-10
UPnP SwitchPower:1 Service	ISO/IEC 29341-7-11
UPnP InternetGatewayDevice:1 Device	ISO/IEC 29341-8-1
UPnP LANDevice:1 Device	ISO/IEC 29341-8-2
UPnP WANDevice:1 Device	ISO/IEC 29341-8-3
UPnP WANConnectionDevice:1 Device	ISO/IEC 29341-8-4
UPnP WLANAccessPointDevice:1 Device	ISO/IEC 29341-8-5
UPnP LANHostConfigManagement:1 Service	ISO/IEC 29341-8-10
UPnP Layer3Forwarding:1 Service	ISO/IEC 29341-8-11
UPnP LinkAuthentication:1 Service	ISO/IEC 29341-8-12
UPnP RadiusClient:1 Service	ISO/IEC 29341-8-13
UPnP WANCableLinkConfig:1 Service	ISO/IEC 29341-8-14
UPnP WANCommonInterfaceConfig:1 Service	ISO/IEC 29341-8-15
UPnP WANDSLLinkConfig:1 Service	ISO/IEC 29341-8-16
UPnP WANEthernetLinkConfig:1 Service	ISO/IEC 29341-8-17
UPnP WANIPConnection:1 Service	ISO/IEC 29341-8-18
UPnP WANPOTSLinkConfig:1 Service	ISO/IEC 29341-8-19
UPnP WANPPPoEConnection:1 Service	ISO/IEC 29341-8-20
UPnP WLANConfiguration:1 Service	ISO/IEC 29341-8-21
UPnP Printer:1 Device	ISO/IEC 29341-9-1
UPnP Scanner:1.0 Device	ISO/IEC 29341-9-2
UPnP ExternalActivity:1 Service	ISO/IEC 29341-9-10
UPnP Feeder:1.0 Service	ISO/IEC 29341-9-11
UPnP PrintBasic:1 Service	ISO/IEC 29341-9-12
UPnP Scan:1 Service	ISO/IEC 29341-9-13
UPnP QoS Architecture:1.0	ISO/IEC 29341-10-1
UPnP QoSDevice:1 Service	ISO/IEC 29341-10-10
UPnP QoSManager:1 Service	ISO/IEC 29341-10-11
UPnP QoSPolicyHolder:1 Service	ISO/IEC 29341-10-12
UPnP QoS Architecture:2	ISO/IEC 29341-11-1
UPnP QOS v2 Schema Files	ISO/IEC 29341-11-2

UPnP Document Title	ISO/IEC 29341 Part
UPnP QosDevice:2 Service	ISO/IEC 29341-11-10
UPnP QosManager:2 Service	ISO/IEC 29341-11-11
UPnP QosPolicyHolder:2 Service	ISO/IEC 29341-11-12
UPnP RemoteUIClientDevice:1 Device	ISO/IEC 29341-12-1
UPnP RemoteUIServerDevice:1 Device	ISO/IEC 29341-12-2
UPnP RemoteUIClient:1 Service	ISO/IEC 29341-12-10
UPnP RemoteUIServer:1 Service	ISO/IEC 29341-12-11
UPnP DeviceSecurity:1 Service	ISO/IEC 29341-13-10
UPnP SecurityConsole:1 Service	ISO/IEC 29341-13-11

IECNORM.COM : Click to view the full PDF of ISO/IEC 29341-6-10:2008

1. Overview and Scope

This service definition is compliant with the UPnP Device Architecture version 1.0. It defines a service type referred to herein as ControlValve:1.

ControlValve:1 provides programmatic control and status information for modulating water control valves or modulating air dampers used in Heating Ventilation and Air-Conditioning (HVAC) applications.

ControlValve:1 enables the following functions:

- Analog (modulating) control of Control Valves and Air Dampers

ControlValve:1 does not address:

- On/Off control valves or dampers
- Fire or Smoke dampers

2. Service Modeling Definitions

2.1. Service Type

The following service type identifies a service that is compliant with this template:

urn:schemas-upnp-org:service:ControlValve:1

The shorthand ControlValve:1 is used herein to refer to this service type.

2.2. State Variables

Defines the state variables for the operating mode of the control valve / air damper, its target position, and its actual position. Additionally defines optional state variables for “soft” minimum and maximum positions.

NOTE: (Explanation of the meaning of positions): Table 1 below describes Allowed Value ranges of 0 to 100, which signify a control valve / air damper position in the range of 0% to 100%. In all such cases, a value of 0% corresponds to the FULLY CLOSED control valve position (minimum mechanical limit of the actuator), and a value of 100% corresponds to the FULLY OPEN control valve position (maximum mechanical limit of the actuator).

Table 1: State Variables

Variable Name	Req. or Opt. ¹	Data Type	Allowed Value ²	Default Value ²	Eng. Units
ControlMode	R	string	OPEN, CLOSED, AUTO	CLOSED	n/a
PositionTarget	R	ui1	>= 0, <= 100, += 1	0	Percent
PositionStatus	R	ui1	>= 0, <= 100, += 1	0	Percent
MinPosition	O	ui1	>= 0, <= 100, += 1	0	Percent
MaxPosition	O	ui1	>= 0, <= 100, += 1	100	Percent
<i>Non-standard state variables implemented by an UPnP vendor go here.</i>	<i>X</i>	<i>TBD</i>	<i>TBD</i>	<i>TBD</i>	<i>TBD</i>

¹ R = Required, O = Optional, X = Non-standard.

² Values listed in this column are (all) required.

2.2.1. ControlMode

Determines the control mode. When ControlMode is OPEN, the device should motor to the 100% (fully open) position; when ControlMode is CLOSED, it should motor to the 0% (fully closed) position; and when ControlMode is AUTO the device position will be dependent on the value of the PositionTarget and the MinPosition and MaxPosition variables – described below.

2.2.2. PositionTarget

Determines the desired position of the device when ControlMode is AUTO. (See above Note “Explanation of the meaning of positions”)

2.2.3. PositionStatus

Measures the actual physical position of the device. (See above Note “Explanation of the meaning of positions”)

2.2.4. MinPosition

Determines the minimum position that the device may take when ControlMode is AUTO. (See above Note “Explanation of the meaning of positions”). MinPosition is the “soft” minimum position, which is typically > 0% - where 0% is the “hard” minimum position.

MinPosition is an optional state variable; if MinPosition is not implemented in the device, then the device must behave as if the value of MinPosition were to be 0%

2.2.5. MaxPosition

Determines the maximum position of that the device may take when ControlMode is AUTO. (See above Note “Explanation of the meaning of positions”). MaxPosition is the “soft” maximum position, which is typically < 100% - where 100% is the “hard” maximum position.

MaxPosition is an optional state variable; if MaxPosition is not implemented in the device, then the device must behave as if the value of MaxPosition were to be 100%

2.2.6. Relationships Between State Variables

The actual position (PositionStatus) of the device must follow the table below:

Table 2: Relationship Between State Variables

ControlMode	PositionTarget	PositionStatus
CLOSED	any	0% (i.e. “hard” minimum)
OPEN	any	100% (i.e. “hard” maximum)
AUTO	PositionTarget < MinPosition	MinPosition (i.e. “soft” minimum)
AUTO	MinPosition < PositionTarget < MaxPosition	PositionTarget
AUTO	PositionTarget > MaxPosition	MaxPosition (i.e. “soft” maximum)

If the values of ControlMode, PositionTarget, MinPosition or MaxPosition change, then the device should start to change its physical position towards the new value determined by the above table. Due to the physical running time of the motor /actuator, this process will take a certain period of time that depends on the vendor’s implementation. The value of the PositionStatus state variable should correspond to the actual physical device position.

NOTE: Vendors that implement control point strategies should bear in mind that due to friction, inertia, hysteresis and numerical rounding it is quite possible that the PositionStatus variable will take an indeterminate

time to reach the value of the corresponding PositionTarget variable. Indeed it is quite likely that PositionStatus variable might *never* achieve exactly the same value as the PositionTarget variable.

Relationships between standard state variable(s) defined herein and any non-standard state variable(s) is TBD.

2.3. Eventing and Moderation

Table 3: Event Moderation

Variable Name	Evented	Moderated Event	Max Event Rate ¹	Logical Combination	Min Delta per Event ²
PositionTarget	no				
PositionStatus	yes	yes	30	OR	10 * (Step)
ControlMode	yes	no			
MinPosition	no				
MaxPosition	no				
<i>Non-standard state variables implemented by an UPnP vendor go here.</i>	<i>TBD</i>	<i>TBD</i>	<i>TBD</i>	<i>TBD</i>	<i>TBD</i>

¹ Determined by N, where Rate = (Event)/(N secs).

² (N) * (allowedValueRange Step).

2.4. Actions

Table 4: Actions

Name	Req. or Opt. ¹
GetMode	R
SetMode	R
GetPosition	R
GetPositionTarget	R
SetPosition	R
GetMinMax	O
SetMinMax	O
<i>Non-standard actions implemented by an UPnP vendor go here.</i>	<i>X</i>

¹ R = Required, O = Optional, X = Non-standard.

2.4.1. GetMode

Returns the current value of ControlMode

2.4.1.1. Arguments

Table 5: Arguments for GetMode

Argument	Direction	relatedStateVariable
CurrentControlMode	OUT ^R	ControlMode

^R = Return Value (RETVAL)

2.4.1.2. Dependency on State

Returns the current value of ControlMode.

2.4.1.3. Effect on State

None.

2.4.1.4. Errors

errorCode	errorDescription	Description
402	Invalid Args	See UPnP Device Architecture section on Control.
501	Action Failed	See UPnP Device Architecture section on Control.
800-899	TBD	(Specified by UPnP vendor.)

2.4.2. SetMode

Sets the new value of ControlMode.

2.4.2.1. Arguments

Table 6: Arguments for SetMode

Argument	Direction	relatedStateVariable
NewControlMode	IN	ControlMode

2.4.2.2. Dependency on State

None.

2.4.2.3. Effect on State

Sets the new value of ControlMode. This may influence PositionStatus according to Table 2.

2.4.2.4. Errors

errorCode	ErrorDescription	Description
402	Invalid Args	See UPnP Device Architecture section on Control.
501	Action Failed	See UPnP Device Architecture section on Control.
800-899	TBD	(Specified by UPnP vendor.)

2.4.3. GetPosition

Returns the current value of value of PositionStatus

2.4.3.1. Arguments

Table 7: Arguments for GetPosition

Argument	Direction	relatedStateVariable
CurrentPositionStatus	OUT ^R	PositionStatus

^R = Return Value (RETVAl)

2.4.3.2. Dependency on State

Returns the current value of PositionStatus.

2.4.3.3. Effect on State

None.

2.4.3.4. Errors

errorCode	ErrorDescription	Description
402	Invalid Args	See UPnP Device Architecture section on Control.
501	Action Failed	See UPnP Device Architecture section on Control.
800-899	TBD	(Specified by UPnP vendor.)

2.4.4. GetPositionTarget

Returns the current value of value of PositionTarget

2.4.4.1. Arguments

Table 8: Arguments for GetPositionTarget

Argument	Direction	relatedStateVariable
CurrentPositionTarget	OUT ^R	PositionTarget

^R = Return Value (RETVAl)

2.4.4.2. Dependency on State

Returns the current value of PositionTarget.

2.4.4.3. Effect on State

None.

2.4.4.4. Errors

errorCode	ErrorDescription	Description
402	Invalid Args	See UPnP Device Architecture section on Control.
501	Action Failed	See UPnP Device Architecture section on Control.
800-899	TBD	(Specified by UPnP vendor.)

2.4.5. SetPosition

Sets the new value of PositionTarget.

2.4.5.1. Arguments

Table 9: Arguments for SetPosition

Argument	Direction	relatedStateVariable
NewPositionTarget	IN	PositionTarget

2.4.5.2. Dependency on State

None.

2.4.5.3. Effect on State

Sets the new value of PositionTarget. After a certain period of time, which depends on the physical speed of the vendor's actuator, the value of PositionStatus should (normally) become the same as PositionTarget according to Table 2.

2.4.5.4. Errors

errorCode	ErrorDescription	Description
402	Invalid Args	See UPnP Device Architecture section on Control.
501	Action Failed	See UPnP Device Architecture section on Control.
800-899	TBD	(Specified by UPnP vendor.)

2.4.6. GetMinMax

Gets the current values of MinPosition and MaxPosition.

2.4.6.1. Arguments

Table 10: Arguments for GetMinMax

Argument	Direction	relatedStateVariable
CurrentMinPosition	OUT	MinPosition
CurrentMaxPosition	OUT	MaxPosition

2.4.6.2. Dependency on State

Returns the current values of MinPosition and MaxPosition.

2.4.6.3. Effect on State

None.

2.4.6.4. Errors

errorCode	ErrorDescription	Description
402	Invalid Args	See UPnP Device Architecture section on Control.
501	Action Failed	See UPnP Device Architecture section on Control.
800-899	TBD	(Specified by UPnP vendor.)

2.4.7. SetMinMax

Sets new values of MinPosition and MaxPosition.

2.4.7.1. Arguments

Table 11: Arguments for SetMinMax

Argument	Direction	relatedStateVariable
NewMinPosition	IN	MinPosition
NewMaxPosition	IN	MaxPosition

2.4.7.2. Dependency on State

None.

2.4.7.3. Effect on State

Sets new values of MinPosition and MaxPosition. This may influence PositionStatus according to Table 2.

2.4.7.4. Errors

In addition to the individual range constraints on newMinPosition and newMaxPosition (valid range 0 to 100), there is a further combination range constraint: The value of newMinPosition must be less than the value of newMaxPosition. In case that SetMinMax is called with newMinPosition $\geq$ newMaxPosition, the action must fail with an error code 701

errorCode	errorDescription	Description
402	Invalid Args	See UPnP Device Architecture section on Control.
501	Action Failed	See UPnP Device Architecture section on Control.
701	Min Exceeds Max	Requested value for MinPosition is greater than (or equal to) the requested value for MaxPosition
800-899	TBD	(Specified by UPnP vendor.)

2.4.8. Non-Standard Actions Implemented by an UPnP Vendor

To facilitate certification, non-standard actions implemented by an UPnP vendor should be included in this service template. The UPnP Device Architecture lists naming requirements for non-standard actions (cf. section on Description).

2.4.9. Relationships Between Actions

The actions defined herein may be called in any order.

Relationships between standard action(s) defined herein and any non-standard action(s) is TBD.

2.4.10. Common Action Error Codes

The following table lists error codes common to actions for this service type. If an action results in multiple errors, the most-specific error should be returned.

errorCode	errorDescription	Description
401	Invalid Action	See UPnP Device Architecture section on Control.
402	Invalid Args	See UPnP Device Architecture section on Control.
404	Invalid Var	See UPnP Device Architecture section on Control.
501	Action Failed	See UPnP Device Architecture section on Control.
600-699	TBD	Common action errors. Defined by UPnP Forum Technical Committee.
800-899	TBD	(Specified by UPnP vendor.)

2.5. Theory of Operation

A Control Valve or Air Damper is used to control the amount of heating or cooling energy being provided into a building space.

Under normal operation, ControlMode will be AUTO. A control point, (e.g. a temperature controller), will modulate the position of the Control Valve or Air Damper by using SetPosition to change the value of PositionTarget. Under normal operation the value of PositionStatus will track PositionTarget.

A control point can call GetPosition to read the current position of the Control Valve or Air Damper.

Under special override conditions, a control point may use SetMode to change the value of ControlMode, for example as follows:

- i) ControlMode can be set to CLOSED when the air-conditioning or heating plant is shut down – this forces the device to a “hard” closed position.
- ii) ControlMode can be set to OPEN to provide a forced override to a “hard” open position – e.g. for emergency (smoke) ventilation.

A control point can call GetMode to read the current value of ControlMode.

The MinPosition and MaxPosition are optional parameters, provided to set “soft” limits on the range (stroke) of PositionStatus. A control point can call SetMinMax to set MinPosition and MaxPosition to new values. For example in the case of Air Dampers:

- i) MinPosition may be set to provide minimum fresh air requirements, and
- ii) MaxPosition may be set to prevent drafts.

It is not likely that SetMinMax would be called very frequently – e.g. in the above example, the minimum fresh air setting might be adjusted on a day /night basis.

A control point can call GetMinMax to read the current values of MinPosition and MaxPosition.

3. XML Service Description

```

<?xml version="1.0"?>
<scpd xmlns="urn:schemas-upnp-org:service-1-0">
  <specVersion>
    <major>1</major>
    <minor>0</minor>
  </specVersion>
  <actionList>
    <action>
      <name>GetMode</name>
      <argumentList>
        <argument>
          <name>CurrentControlMode</name>
          <direction>out</direction>
          <retval />
          <relatedStateVariable>ControlMode</relatedStateVariable>
        </argument>
      </argumentList>
    </action>
    <action>
      <name>SetMode</name>
      <argumentList>
        <argument>
          <name>NewControlMode</name>
          <direction>in</direction>
          <relatedStateVariable>ControlMode</relatedStateVariable>
        </argument>
      </argumentList>
    </action>
    <action>
      <name>GetPosition</name>
      <argumentList>
        <argument>
          <name>CurrentPositionStatus</name>
          <direction>out</direction>
          <retval />
          <relatedStateVariable>PositionStatus</relatedStateVariable>
        </argument>
      </argumentList>
    </action>
    <action>
      <name>GetPositionTarget</name>
      <argumentList>
        <argument>
          <name>CurrentPositionTarget</name>
          <direction>out</direction>
          <retval />
          <relatedStateVariable>PositionTarget</relatedStateVariable>
        </argument>
      </argumentList>
    </action>
    <action>
      <name>SetPosition</name>
      <argumentList>
        <argument>
          <name>NewPositionTarget</name>
          <direction>in</direction>
          <relatedStateVariable>PositionTarget</relatedStateVariable>
        </argument>
      </argumentList>
    </action>
  </actionList>
</scpd>

```