
INTERNATIONAL STANDARD



3745

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION • МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ • ORGANISATION INTERNATIONALE DE NORMALISATION

Acoustics — Determination of sound power levels of noise sources — Precision methods for anechoic and semi-anechoic rooms

Acoustique — Détermination des niveaux de puissance acoustique émis par les sources de bruit — Méthodes de laboratoire pour les salles anéchoïque et semi-anéchoïque

First edition — 1977-05-15

Corrected and reprinted — 1983-02-01

UDC 543.6

Ref. No. ISO 3745-1977 (E)

Descriptors : acoustics, acoustic measurement, noise (sound), sound sources, sound power, laboratory tests, enclosures.

Price based on 21 pages

FOREWORD

ISO (the International Organization for Standardization) is a worldwide federation of national standards institutes (ISO member bodies). The work of developing International Standards is carried out through ISO technical committees. Every member body interested in a subject for which a technical committee has been set up has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work.

Draft International Standards adopted by the technical committees are circulated to the member bodies for approval before their acceptance as International Standards by the ISO Council.

International Standard ISO 3745 was developed by Technical Committee ISO/TC 43, *Acoustics*, and was circulated to the member bodies in May 1975.

It has been approved by the member bodies of the following countries :

Austria	Ireland	South Africa, Rep. of
Belgium	Israel	Sweden
Canada	Italy	Switzerland
Czechoslovakia	Japan	Turkey
Denmark	Netherlands	United Kingdom
Finland	New Zealand	U.S.A.
France	Norway	U.S.S.R.
Germany	Poland	
Hungary	Romania	

No member body expressed disapproval of the document.

This International Standard cancels and replaces ISO Recommendation R 495-1966, of which it constitutes a technical revision.

CONTENTS		Page
0.1	Related International Standards	1
0.2	Synopsis of ISO 3745	2
0.3	Introduction	2
1	Scope and field of application	2
2	References	3
3	Definitions	3
4	Test room requirements	4
5	Instrumentation	5
6	Installation and operation of source	5
7	Determination of mean-square pressure	6
8	Calculation of sound power level	9
9	Information to be recorded	10
10	Information to be reported	10
Annexes		
A	Test room qualification procedures	11
B	Recommended array of microphone positions in a free field	13
C	Basic array of microphone positions in a free field over a reflecting plane	15
D	Coaxial circular paths in parallel planes for microphone traverses in a free field over a reflecting plane	16
E	Calculation of directivity index and directivity factor	17
F	System for microphone traverses along meridional paths in a free field	18
G	Guidelines for the design of test rooms	19
H	Examples of suitable instrumentation systems	20
I	Guidelines for the detection of impulsive noise	21

This page intentionally left blank

STANDARDSISO.COM : Click to view the full PDF of ISO 3745:1977

Acoustics — Determination of sound power levels of noise sources — Precision methods for anechoic and semi-anechoic rooms

0.1 RELATED INTERNATIONAL STANDARDS

This International Standard is one of a series specifying various methods for determining the sound power levels of machines and equipment. These basic documents specify only the acoustical requirements for measurements appropriate for different test environments as shown in table 1.

When applying these basic documents, it is necessary to decide which one is most appropriate for the conditions and

purposes of the test. The operating and mounting conditions of the machine or equipment to be tested must be in accordance with the general principles stated in the basic documents.

Guidelines for making these decisions are provided in ISO 3740. If no sound test code is specified for a particular machine, the mounting and operating conditions shall be fully described in the test report.

TABLE 1 — International Standards specifying various methods for determining the sound power levels of machines and equipment

International Standard No.*	Classification of method	Test environment	Volume of source	Character of noise	Sound power levels obtainable	Optional information available
3741	Precision	Reverberation room meeting specified requirements	Preferably less than 1 % of test room volume	Steady, broad-band	In one-third octave or octave bands	A-weighted sound power level
3742				Steady, discrete-frequency or narrow-band		
3743	Engineering	Special reverberant test room		Steady, broad-band narrow-band, discrete-frequency	A-weighted and in octave bands	Other weighted sound power levels
3744	Engineering	Outdoors or in large room	Largest dimension less than 15,0 m	Any	A-weighted and in one-third octave or octave bands	Directivity information and sound pressure levels as a function of time; other weighted sound power levels
3745	Precision	Anechoic or semi-anechoic room	Preferably less than 0,5 % of test room volume	Any		
3746	Survey	No special test environment	No restrictions : limited only by available test environment	Steady, broad-band, narrow-band, discrete-frequency	A-weighted	Sound pressure levels as a function of time; other weighted sound power levels

* See clause 2.

0.2 SYNOPSIS OF ISO 3745

Applicability

Test environment

Free field (anechoic room) or free field over a reflecting plane (semi-anechoic room).

Type of source

Device, machine, component, subassembly.

Size of noise source

Volume of the source preferably less than 0,5 % of test room volume.

Character of noise radiated by the source

All types.

Accuracy

Precision (standard deviation for determining sound power levels for 1 kHz octave band is less than or equal to 0,5 dB for anechoic rooms and less than or equal to 1,0 dB for semi-anechoic rooms).

Quantities to be measured

Sound pressure levels (weighted and in frequency bands) over a prescribed surface.

Quantities to be calculated

Weighted sound power level (A is required; other weightings are optional).

Sound power levels in frequency bands.

Directivity characteristics of the source (optional).

0.3 INTRODUCTION

This International Standard specifies in detail two laboratory methods for determining the sound power radiated by a device, machine, component or subassembly using a laboratory anechoic room having prescribed acoustical characteristics. While other methods could be used to measure the noise emitted by machinery and equipment, the methods specified in this International Standard are particularly useful for rating the sound output of sources which produce steady noise and for which directivity information on the source may be desired.

The methods specified in this International Standard yield physical data that may be used for the following purposes :

- 1) rating apparatus according to its sound power output;
- 2) establishing sound control measures;
- 3) predicting the sound pressure levels produced by a device in a given enclosure or environment.

Techniques for utilizing the physical data for these special purposes are not included in this International Standard.

The determination of the sound power radiated by a sound source in a completely free field or in a free field above a reflecting plane is based on the premise that the reverberant field produced by the source is negligible and that the total radiated power is obtained from the mean-square sound pressure averaged in time and in space over a hypothetical sphere or hemisphere surrounding the source. The radius of the sphere or hemisphere is chosen so that its surface is in the far radiation field of the source.

This International Standard, together with the others in this series (see table 1), supersedes ISO/R 495.

1 SCOPE AND FIELD OF APPLICATION

1.1 General

This International Standard specifies two laboratory methods for determining the sound power level of a source. It gives requirements for the test room, as well as the source location, operating conditions and instrumentation. Techniques are specified for obtaining an estimate of the surface sound pressure level from which the weighted sound power level of the source as well as the sound power level in octave or one-third octave bands may be calculated. It is intended to prescribe techniques for acoustical measurements that may be used in test codes for particular types of equipment.

1.2 Field of application

1.2.1 Types of noise

This International Standard applies to sources which produce sound that is uniformly distributed in frequency over the frequency range of interest and is relatively steady for at least 30 s. The spectrum of the sound may also include prominent discrete-frequency components or narrow bands of noise. The procedures specified in this International Standard may also be applied to sources that emit non-steady noise as defined in ISO 2204, with the exception of an isolated burst of sound energy, or a burst train with a repetition rate less than 10 per second. (See annex I for guidelines on the detection of impulsive noise.)

1.2.2 Size of source

This International Standard applies primarily to small sound sources, i.e. sources whose volumes are preferably less than 0,5 % of the volume of the test room used for the measurements. This restriction is necessary to ensure that the hypothetical sphere or hemisphere surrounding the sources lies in the far radiation field of the source.

1.3 Measurement uncertainty

Measurements made in conformity with this International Standard tend to result in standard deviations which are equal to or less than those given in tables 2 and 3. The standard deviations of tables 2 and 3 reflect the cumulative effects of all causes of measurement uncertainty, excluding variations in the sound power of the source from test to test.

The major cause of uncertainty in determining sound power in an anechoic room is the spatial irregularity of the sound field due to the directivity of the source. In a semi-anechoic room, the spatial irregularity may be increased due to the superposition of the sound field of the actual source and that of the image source. The directivity pattern of a source located above a reflecting plane is generally more complicated than that of the same source in a free field. Moreover, the near field extends to greater distance, and the radius of the test hemispheres is usually larger than the radius of the test sphere that would be required in a free field. The smallest uncertainty in determining sound power levels occurs when measurements are made in a free field. For this reason, if no other constraints are present, the free-field environment is preferred for laboratory measurements. However, it is difficult to make measurements on some classes of equipment under truly free-field conditions. Some sound sources are too large to fit into existing anechoic rooms, some are too heavy to be suspended in the centre of these rooms and others are normally supported by or associated with a hard, reflecting surface. For these reasons, the free field above a reflecting plane is a laboratory environment that is useful for measurements on many different types of equipment.

An anechoic room provides the preferred environment for measurements with the smallest uncertainty. However, reasonable accuracy can be obtained in a semi-anechoic room provided the precautions specified in this International Standard are observed.

TABLE 2 – Uncertainty in determining sound power levels of sound sources in anechoic rooms

Octave band centre frequencies	One-third octave band centre frequencies	Standard deviation of mean value
Hz	Hz	dB
125 to 500	100 to 630	1,0
1 000 to 4 000	800 to 5 000	0,5
8 000	6 300 to 10 000	1,0

TABLE 3 – Uncertainty in determining sound power levels of sound sources in semi-anechoic rooms

Octave band centre frequencies	One-third octave band centre frequencies	Standard deviation of mean value
Hz	Hz	dB
125 to 500	100 to 630	1,5
1 000 to 4 000	800 to 5 000	1,0
8 000	6 300 to 10 000	1,5

2 REFERENCES

ISO 266, *Acoustics – Preferred frequencies for measurement*.

ISO/R 354, *Measurement of absorption coefficients in a reverberation room*.

ISO 2204, *Acoustics – Guide to the measurement of airborne acoustical noise and evaluation of its effects on man*.

ISO 3740, *Acoustics – Determination of sound power levels of noise sources – Guidelines for the use of basic International Standards and for the preparation of noise test codes*.

ISO 3741, *Acoustics – Determination of sound power levels of noise sources – Precision methods for broad-band sources in reverberation rooms*.

ISO 3742, *Acoustics – Determination of sound power levels of noise sources – Precision methods for discrete-frequency and narrow-band sources in reverberation rooms*.

ISO 3743, *Acoustics – Determination of sound power levels of noise sources – Engineering methods for special reverberation test rooms*.

ISO 3744, *Acoustics – Determination of sound power levels of noise sources – Engineering methods for free-field conditions over a reflecting plane*.

ISO 3746, *Acoustics – Determination of sound power levels of noise sources – Survey method*.

IEC Publication 50(08), *International electrotechnical vocabulary – Electro-acoustics*.

IEC Publication 179, *Precision sound level meters*.

IEC Publication 179A, *First supplement to Publication 179, Additional characteristics for the measurement of impulsive sounds*.

IEC Publication 225, *Octave, half-octave and third-octave band filters intended for the analysis of sound and vibrations*.

3 DEFINITIONS

For the purposes of this International Standard, the following definitions apply :

3.1 free sound field : A field in a homogeneous, isotropic medium free of boundaries.

3.2 free field over a reflecting plane : A field in a homogeneous, isotropic medium in the half-space above an infinite, rigid plane surface.

3.3 anechoic room : A test room whose surfaces absorb essentially all of the incident sound energy over the frequency range of interest, thereby affording free-field conditions over the measurement surface.

3.4 semi-anechoic room : A test room with a hard, reflecting floor whose other surfaces absorb essentially all the incident sound energy over the frequency range of interest, thereby affording free-field conditions above a reflecting plane.

3.5 surface sound pressure : The sound pressure averaged in time on a mean-square basis and also averaged over the measurement surface using the averaging procedures specified in clause 7.

3.6 surface sound pressure level, $\overline{L}_p$, in decibels : Ten times the logarithm to the base 10 of the ratio of the square of the surface sound pressure to the square of the reference sound pressure. The weighting network or the width of the frequency band used shall be indicated; for example, A-weighted sound pressure level, octave band sound pressure level, one-third octave band sound pressure level, etc. The reference sound pressure is 20 μ Pa.

3.7 sound power level, L_W , in decibels : Ten times the logarithm to the base 10 of the ratio of a given sound power to the reference sound power. The weighting network or the width of the frequency band used shall be indicated; for example, A-weighted sound power level, octave band power level, one-third octave band power level, etc. The reference sound power is 1 pW ($= 10^{-12}$ W).

NOTE — The mean sound pressure level at some reference radius is numerically different from the sound power level and its use in lieu of the sound power level is not recommended.

3.8 frequency range of interest : For general purposes, the frequency range of interest includes the octave bands with centre frequencies between 125 and 8 000 Hz and the one-third octave bands with centre frequencies between 100 and 10 000 Hz. Any band may be excluded in which the level is more than 40 dB below the highest band pressure level. For special purposes, the frequency range of interest may be extended at either end, provided the test environment and instrument accuracy are satisfactory for use over the extended frequency range. For sources which radiate predominantly high (or low) frequency sound, the frequency range of interest may be limited in order to optimize the test facility and procedures.

3.9 measurement surface : A hypothetical surface of area S enveloping the source on which the measuring points are located. For the purposes of this International Standard, the measurement surface is usually a sphere or hemisphere of radius r .

3.10 far field : That portion of the radiation field of a noise source in which the sound pressure level decreases by 3 dB for each doubling of the area of the measurement surface. This is equivalent to a decrease of 6 dB for each doubling of the distance from a point source.

In the far field, the mean-square pressure is proportional to the total acoustic power radiated by the source.

NOTE — For most practical sources, the far field begins at a distance from the source which may be significantly less than $2a$, where a is the largest dimension of the source.

3.11 near field : That portion of the radiation field of a noise source which lies between the source and the far field.

3.12 volume of source under test : The volume of the whole object under test.

4 TEST ROOM REQUIREMENTS

4.1 General

The test room shall be large enough and shall have a sufficiently high value of the total sound absorption to provide an adequate free field for all frequency bands within the frequency range of interest and for each measurement surface selected. For guidance on the design of anechoic rooms, refer to annex G.

4.1.1 Criterion for room adequacy

The adequacy of the test room for measurements according to this International Standard shall be established using the procedures of annex A.

4.1.2 Criterion for background noise

At the microphone positions, the background sound pressure level including any noise due to the motion of the microphone shall be at least 6 dB and preferably more than 12 dB below the sound pressure level to be measured in each frequency band within the frequency range of interest.

4.2 Room volume

In order to make measurements in the far radiation field of the source, it is recommended that the volume of the test room be at least 200 times greater than the volume of the source whose sound power level is to be determined.

4.3 Criteria for temperature and humidity

The air absorption in the test room varies with temperature and humidity, particularly at frequencies above 1 000 Hz. For measurements according to this International Standard the temperature and the relative humidity shall be controlled during the sound pressure level measurements and held to as nearly constant values as practicable.

4.4 Criteria for the reflecting plane

The reflecting plane on which the source is located shall extend at least to the measurement surface. The sound absorption coefficient of the reflecting plane shall not exceed 0,06.

5 INSTRUMENTATION

5.1 General

The instrumentation shall be designed to measure the level of the mean-square sound pressure with A-weighting or in octave or one-third octave bands, averaged over time and over the measurement surface. Surface averaging is usually carried out by measuring the time-averaged sound pressure levels with a prescribed time constant for a fixed number of microphone positions (see 7.3) and computing the average value according to 7.7.

NOTE — For establishing the presence of impulsive noise, the "impulse" meter characteristics according to IEC Publication 179A shall be used in addition.

The instrumentation used can perform the required time averaging in two different ways :

- a) By continuous averaging of the squared signal using RC-smoothing with a time constant τ_A . Such continuous averaging provides only an approximation of the true time average, and it places restrictions on the "settling" time and observation time.

NOTE — An example of an instrument employing such averaging is a sound level meter that meets the requirements of IEC Publication 179 with a "slow" meter characteristic.

- b) By integrating the squared signal over a fixed time interval τ_D . This integration may be performed by either digital or analogue means.

Examples of suitable instrumentation systems are given in annexes H and I.

5.2 The microphone and its associated cable

A condenser microphone, or the equivalent in accuracy, stability and frequency response, shall be used. The microphone shall have a flat frequency response, over the frequency range of interest, for the angle of incidence specified by the manufacturer. A 13 mm (1/2 in) microphone is recommended.

The microphone and its associated cable shall be chosen so that their sensitivity does not change over the temperature range encountered in the measurement. If the microphone is moved, care shall be exercised to avoid introducing acoustical noise (for example, wind noise) or electrical noise (for example, from gears, flexing cables, or sliding contacts) that could interfere with the measurements.

5.3 Frequency response of the instrumentation system

The frequency response of the instrumentation system, for the angle of incidence specified by the manufacturer, shall be flat over the frequency range of interest within the tolerances given in table 4.

TABLE 4 — Relative tolerances for the instrumentation system

Frequency	Tolerance limits
Hz	dB
80	$\pm 1,5$
100 to 4 000	$\pm 1,0$
5 000 to 8 000	$\pm 1,5$
10 000	$\pm 2,0$
12 500	$\pm 3,0$

5.4 Weighting network, frequency analyser

An A-weighting network meeting the tolerances of IEC Publication 179 and an octave band or one-third octave band filter set meeting the requirements of IEC Publication 225 shall be used. The centre frequencies of the frequency bands shall correspond to those of ISO 266.

NOTE — If other weighting networks are used in addition to A-weighting, the characteristics of such networks shall be reported.

5.5 Calibration

Before each series of measurements, an acoustical calibrator with an accuracy of $\pm 0,2$ dB shall be applied to the microphone for calibration of the entire measuring system at one or more frequencies over the frequency range of interest. The calibrator shall be checked annually to verify that its output has not changed. In addition, an electrical calibration of the instrumentation system over the entire frequency range of interest shall be performed periodically, at least at intervals of 2 years.

6 INSTALLATION AND OPERATION OF SOURCE

6.1 General

In many cases, the sound power emitted by a source depends upon its support or mounting conditions as well as the manner in which the source is operated. This clause gives general recommendations concerning the installation and operation of sources. Reference should be made to specific test codes for more detailed information concerning installation and operation of specific types of sources (for example, rotating electrical machines).

6.2 Installation of source

Whenever a typical condition of mounting exists for the source, that condition shall be used or simulated, if practicable. Sources which are normally supported by or associated with a hard surface shall be installed in a semi-anechoic room (free field above a reflecting plane).

6.2.1 Method of mounting

Many small sound sources (for example, ballasts for fluorescent lamps, electric clocks, etc.), although themselves poor radiators of low-frequency sound, may, as a result of the method of mounting, produce marked increases in low-frequency sound when their vibrational energy is transmitted to surfaces large enough to be efficient radiators. Resilient mounting should be interposed if possible between the device to be measured and the supporting surfaces so that the transmission of vibration to the support and the reaction on the source are both minimized. However, such resilient mounts shall not be used if the device under test is not resiliently mounted in typical field installations. In this case, the mounting base shall have a sufficiently high impedance to prevent it from vibrating and radiating sound excessively.

6.3 Choice of method

The following considerations dictate the method that shall be used for determinations of sound power according to the requirements of this International Standard.

6.3.1 Plane reflecting surfaces

When a source is mounted near a reflecting plane, the power it radiates may differ appreciably from the power it radiates into free space. If such a mounting is typical of field installations, the device under test shall be installed in a semi-anechoic room (free field above a reflecting plane) located with respect to the hard floor as in typical field installations. The reflecting plane is considered to be a part of the source.

6.3.2 Free-field environment

If the source under test is not usually mounted over a reflecting plane, or if no typical condition of mounting exists, the source shall be placed near the centre of an anechoic room.

NOTE — Equipment normally operated on a table or stand shall be so mounted during the tests. Either an anechoic or a semi-anechoic room may be used.

6.4 Auxiliary equipment

Care shall be taken to ensure that any electrical conduits, piping or air ducts connected to the equipment do not radiate significant amounts of sound energy into the test room. If practicable, all auxiliary equipment necessary for the operation of the device under test shall be located outside the test room and the test room shall be cleared of all objects which may interfere with the measurements.

6.5 Operation of source during test

During the acoustical measurements, the source shall be operated in a specified manner typical of normal use. One or more of the following operational conditions may be appropriate:

- 1) device under normal load operating at normal speed;

- 2) device under full load (if different from 1));

- 3) device under no load (idling);

- 4) device under operating condition corresponding to maximum sound generation.

The sound power levels of sources may be determined for any desired set of operating conditions (i.e. temperature, humidity, device speed, etc.). These test conditions shall be selected beforehand and shall be held constant during the test. The source shall be in a stable operating condition before any noise measurements are made.

7 DETERMINATION OF MEAN-SQUARE PRESSURE

7.1 General

An anechoic room provides the preferred environment for measurements with the smallest uncertainty (see table 2). However, reasonable accuracy can be obtained in a semi-anechoic room provided the precautions specified in this International Standard are observed (see table 3).

7.2 Measurement surface

7.2.1 Radius of test sphere

For measurements in an anechoic room, the hypothetical sphere which is used to determine the space average of the mean-square sound pressure should preferably be centered on the acoustic centre of the sound source. As the location of the acoustic centre is frequently unknown, the centre chosen (for example, the geometric centre of the source) shall be clearly stated in the test report. The radius of the test sphere shall be equal to or greater than twice the major source dimension, and not less than 1 m. No microphone position shall be used which lies outside the region qualified for measurements according to annex A.

7.2.2 Radius of test hemisphere

For measurements in a semi-anechoic room, the hypothetical hemisphere shall be centered on the projection on the floor of the centre selected according to 7.2.1. The radius of the test hemisphere shall be equal to or greater than twice the major source dimension, or four times the average distance of the source from the reflecting plane, whichever is the larger, and not less than 1 m. No microphone position shall be used which lies outside the region qualified for measurements according to annex A.

NOTE — If a test hemisphere cannot be used, a measurement surface defined by a constant distance, d (i.e. the measurement distance) from the radiating surface of the source may be used. The measurement distance, d , should not be less than 1 m.

7.3 Microphone positions

7.3.1 General

To obtain the average value of the mean-square pressure on the surface of the test sphere (or hemisphere), one of the three following methods shall be used :

- 1) An array of fixed microphone positions is used, the positions being distributed over the surface of the test sphere (or hemisphere).

NOTE — Either a single microphone may be moved from one position to the next sequentially or a number of fixed microphones may be used and their outputs sampled sequentially.

- 2) The microphone is moved along multiple parallel circular paths regularly spaced on the test sphere (or hemisphere).

- 3) The single microphone is moved along multiple meridional arcs regularly spaced on the test sphere (or hemisphere).

7.3.2 Fixed microphone positions

7.3.2.1 TEST SPHERE (FOR MEASUREMENTS IN A FREE FIELD)

The array of 20 microphone positions shown in annex B shall be used. In general, the number of measurement points is sufficient if the difference, in decibels, between the highest and lowest sound pressure levels measured in any frequency band of interest is numerically less than half the number of measurement points. If this requirement is not satisfied using the 20-point array of annex B, an additional 20-point array may be defined by rotating the original array of annex B by 180° about the z-axis. (The top and bottom points on the z-axis of the new array are coincident with the top and bottom points of the original array.) The 40 points on the two arrays are associated with equal areas on the surface of the test sphere of annex B.

NOTES

1 If the requirement on the sufficiency of the number of measurement points is not satisfied by the 40 points on the two arrays, a detailed investigation may be necessary of the sound pressure levels over a restricted area of the sphere where "beaming" from a highly directional source may be observed. This detailed investigation is necessary to determine the highest and lowest values of the sound pressure level in the frequency band of interest. If this procedure is followed, the microphone positions will usually not be associated with equal areas on the surface of the test sphere and proper allowance must be made (see 7.7.1.2).

2 For sources which are essentially non-directional, the use of fewer microphone positions (for example, 8 or 12) may not result in higher uncertainties than those given in table 2.

7.3.2.2 TEST HEMISPHERE (FOR MEASUREMENTS IN A FREE FIELD OVER A REFLECTING PLANE)

The array of 10 microphone positions shown in annex C shall be used. In general, the number of measurement points is sufficient if the difference in decibels between the highest and lowest sound pressure levels measured in any frequency band of interest is numerically less than half

the number of measurement points. If this requirement is not satisfied using the 10-point array of annex C, an additional 10-point array may be defined by rotating the original array of annex C by 180° about the z-axis. (The top point on the z-axis of the new array is coincident with the top point of the original array.) The 20 points on the two arrays are associated with equal areas on the surface of the test hemisphere of annex C.

NOTES

1 If the requirement on the sufficiency of the number of measurement points is not satisfied by the 20 points on the two arrays, a detailed investigation may be necessary of the sound pressure levels over a restricted area of the hemisphere where "beaming" from a highly directional source may be observed. This detailed investigation is necessary to determine the highest and lowest values of the sound pressure level in the frequency bands of interest. If this procedure is followed, the microphone positions will usually not be associated with equal areas on the surface of the test hemisphere and proper allowance must be made (see 7.7.1.2).

2 To reduce errors due to interference effects caused by reflections from the plane, no fewer than the 10 microphone positions prescribed in annex C shall be used even if the source is essentially non-directional and broad-band in character.

7.3.3 Coaxial circular paths in parallel planes

For measurements in a free field over a reflecting plane, the sound pressure level is averaged in space and time by moving a single microphone successively along at least five circular paths as shown in annex D. The annular areas of the hemisphere associated with each circular path are equal. The microphone is traversed at constant speed using a turntable.

For measurements in a completely free field, five additional circular paths are used which are the mirror images of those shown in annex D.

NOTE — To avoid errors due to interference effects caused by reflections from the plane, no fewer than the five circular paths prescribed in annex D shall be used in a free field above a reflecting plane even if the source is essentially non-directional and broad-band in character.

7.3.4 Meridional arc traverses

A third alternative method for averaging the mean-square pressure over the surface of the test sphere or hemisphere uses a single microphone, traversed along a semi-circular arc about a horizontal axis through the centre of the source. The microphone output is squared and averaged by electronic means, giving suitable weight to the surface areas of the sphere. For measurements in a free field over a reflecting plane, the arc is only a quarter-circle in length; the axis about which the microphone rotates lies in the reflecting plane as shown in annex F. At least eight such microphone traverses at equal increments of azimuth angle around the source shall be used. This may be accomplished by rotating the source.

7.4 Conditions of measurement

7.4.1 General

Environmental conditions may have an adverse effect on the microphone used for the measurements. Such conditions (for example, strong electric or magnetic fields, wind impingement of air discharge (if any) from the equipment being tested, high or low temperatures), must be avoided by proper selection or placement of the microphone. The microphone shall always be oriented in such a way that the angle of incidence of the sound waves is that for which the microphone is calibrated.

7.4.2 Measurement with sound level meter

If the indicating meter of a sound level meter is used, the "slow" characteristic shall be used. When the fluctuations of the indicating pointer on the sound level meter are less than ± 3 dB using the "slow" meter characteristic, the noise is considered to be steady for the purposes of this International Standard, and the level is taken to be the average of the maximum and minimum levels during the period of observation. If the meter fluctuations during the period of observation are greater than ± 3 dB, the noise is considered non-steady and the procedures of annex H shall be used.

NOTE — For establishing the presence of impulsive noise, additional measurements with the "impulsive" meter characteristic shall be performed. The procedure of annex I shall be used.

7.4.3 Measurement with RC-smoothing or integrating systems

If RC-smoothing is used, the time constant τ_A shall be long enough to obtain an estimate of the rms level during the period of observation with a precision of $\pm 0,5$ dB.

If true integration is used, it is recommended that the integration time be equal to the period of observation.

For time-varying noise, it is important to specify carefully the period of observation, and this will usually depend on the purposes of the measurements. For example, if the noise level of the machine has two particular modes of operation having different noise levels, it may be necessary to select a period of observation for each mode.

7.5 Observations to be obtained

The sound pressure level shall be observed over a typical period of operation of the source. Readings of the sound pressure level (corresponding to the level of the mean-square sound pressure) shall be taken at each measuring point with A-weighting and for each frequency band within the frequency range of interest. The instrumentation used must comply with the requirements of clause 5.

The following data shall be obtained :

- 1) A-weighted sound pressure levels and band pressure levels during operation of the source under test;

- 2) A-weighted sound pressure levels and band pressure levels produced by the background noise.

For the frequency bands centered on or below 160 Hz, the period of observation shall be at least 30 s. For A-weighted sound levels and for the frequency bands centered on or above 200 Hz, the period of observation shall be at least 10 s.

7.6 Correction for background sound pressure levels

The background sound pressure levels shall be obtained using one of the methods specified in 7.3 with the source not in operation. When the background noise is less than 6 dB below the sound pressure level at each measurement point and in each frequency band with the source in operation, the accuracy of the measurements will be reduced and no data shall be reported. The measured band pressure levels shall be corrected for the influence of background noise according to table 5.

TABLE 5 — Corrections for background sound pressure levels

Difference between sound pressure level measured with sound source operating and background sound pressure level alone	Correction to be subtracted from sound pressure level measured with sound source operating to obtain sound pressure level due to sound source alone
dB	dB
6	1,3
7	1,0
8	0,8
9	0,6
10	0,4
11	0,3
12	0,3
13	0,2
14	0,2
15	0,1

7.7 Calculation of surface sound pressure level

The sound power level of a source, L_W , is calculated from the surface sound pressure level averaged over the surface of the test sphere (or hemisphere), $\overline{L_p}$. This surface sound pressure level, $\overline{L_p}$, is calculated from the space average of the mean-square sound pressures over the test sphere (or hemisphere). To obtain the surface sound pressure level, $\overline{L_p}$, from the sound pressure level readings, the following procedures are appropriate.

7.7.1 Fixed microphone positions

When fixed microphone positions are used, one of the following two procedures is appropriate.

7.7.1.1 EQUAL AREAS

When the microphone positions are associated with equal areas of the test sphere (or hemisphere) the following equation shall be used to obtain the surface sound pressure level, $\overline{L}_p$:

$$\overline{L}_p = 10 \log_{10} \frac{1}{N} \left[\sum_{i=1}^N 10^{0.1 L_{pi}} \right] \quad \dots (1)$$

where

$\overline{L}_p$ is the surface sound pressure level, in decibels.
Reference : 20 μ Pa;

L_{pi} is the band pressure level resulting from the i^{th} measurement, in decibels. Reference : 20 μ Pa;

N is the number of measurements.

7.7.1.2 UNEQUAL AREAS

When the microphone positions are associated with unequal partial areas of the measurement surface, the following equation shall be used to obtain the surface sound pressure level, $\overline{L}_p$:

$$\overline{L}_p = 10 \log_{10} \frac{1}{S} \left[\sum_{i=1}^N S_i 10^{0.1 L_{pi}} \right] \quad \dots (2)$$

where

$\overline{L}_p$ is the surface sound pressure level, in decibels.
Reference : 20 μ Pa;

L_{pi} is the band pressure level resulting from the i^{th} measurement, in decibels. Reference : 20 μ Pa;

S_i is the partial area of the sphere (or hemisphere) associated with the i^{th} measurement;

S is the total area of the measurement sphere (or hemisphere);

N is the number of measurements.

7.7.2 Circular microphone traverses

When the microphone is caused to traverse along ten or five circular paths (see 7.3.3), the surface sound pressure level, $\overline{L}_p$, is obtained from equation (1) in 7.7.1.1, where L_{pi} = average band pressure level for the i^{th} traverse.

7.7.3 Traverses along circular arcs

If the method specified in 7.3.4 is used, the surface sound pressure level, $\overline{L}_p$, is obtained by squaring and averaging the output of the microphone and giving suitable weight to the surface areas of the sphere. One method of accomplishing this is shown in annex F.

8 CALCULATION OF SOUND POWER LEVEL

8.1 Free field

In a free field, the sound power level L_W of a source is calculated from the following equation :

$$L_W = \overline{L}_p + 10 \log_{10} (S_1/S_0) + C \quad \dots (3)$$

where

$\overline{L}_p$ is the surface sound pressure level over the test sphere, in decibels. Reference : 20 μ Pa;

$S_1 = 4 \pi r^2$ is the area of test sphere (of radius r);

$S_0 = 1 \text{ m}^2$;

C is the correction term, in decibels, for the influence of temperature θ (in degrees Celsius) and atmospheric pressure p (in millibars).

$$C = -10 \log_{10} \frac{Z_c}{400}$$

$$= -10 \log_{10} \left[\left(\frac{293}{273 + \theta} \right)^{0.5} \times \frac{p}{1\,000} \right]$$

NOTE — The correction term C is necessary only if atmospheric conditions differ significantly from $\theta = 20^\circ \text{C}$ and $p = 1\,000 \text{ mbar}$ (10^5 Pa). Use of the correction C ensures that the correct value of Z_c ; the characteristic impedance of air, appropriate to the temperature and atmospheric pressure existing during the sound pressure level measurements, is utilized in the computation. It does not provide a means whereby measurements may be corrected to temperatures or atmospheric pressures other than those existing during the measurements.

8.2 Free field over a reflecting plane

For a free field over a reflecting plane, the sound power level L_W of a source is calculated from the following equation :

$$L_W = \overline{L}_p + 10 \log_{10} (S_2/S_0) + C \quad \dots (4)$$

where

$S_2 = 2 \pi r^2$ is the area of test hemisphere (of radius r);

$S_0 = 1 \text{ m}^2$.

NOTE — Other symbols are the same as those used in equation (3).

8.3 Weighted sound power level and band sound power levels

The values of the surface sound pressure level, $\overline{L}_p$, used in equations (3) and (4) above may be obtained using a weighting network in the instrumentation system (for example, A-weighting) or by means of an octave or one-third octave band filter. If a weighted sound power level is to be obtained, the calculations using equation (3) [or equation (4)] need be done only once. To obtain band power levels, the calculation procedure must be repeated for each frequency band within the frequency range of interest.

9 INFORMATION TO BE RECORDED

The following information, when applicable, shall be compiled and recorded for all measurements made according to the requirements of this International Standard.

9.1 Sound source under test

- Description of the sound source under test (including dimensions).
- Operating conditions.
- Mounting conditions.
- Location of sound source in test room.
- If test object has multiple noise sources, description of source(s) in operation during measurements.

9.2 Acoustic environment

- Dimensions of test room; description of physical treatment of the walls, ceiling and floor; sketch showing the location of source and room contents.
- Acoustical qualification of test room according to annex A.
- Air temperature in degrees Celsius, relative humidity in per cent and barometric pressure in millibars.

9.3 Instrumentation

- Equipment used for the measurements, including name, type, serial number and manufacturer.
- Bandwidth of frequency analyser.
- Frequency response of instrumentation system.
- Method used to calibrate the microphone(s) and the date and place of calibration.

9.4 Acoustical data

- The locations and orientation of the microphone path or array (a sketch shall be included if necessary).
- The corrections in decibels, if any, applied in each frequency band for the frequency response of the microphone, frequency response of the filter in the pass band, background noise, etc.
- The surface sound pressure level, $\overline{L_p}$, in decibels, calculated for the A-weighted sound pressure level (other weightings are optional) and the level in each frequency band of interest, with reference to 20 μPa .
- The sound power levels, in decibels, calculated for all frequency bands used, in decibels, with reference to 1 pW ($= 10^{-12}$ W), and the A-weighted sound power level with reference to 1 pW.
- The corrected sound power levels tabulated or plotted to the nearest half decibel.
- The date and time when the measurements were performed.
- If required, the difference between "slow" and "impulse" readings, according to annex I.
- Remarks on subjective impression of noise (audible discrete tones, impulsive character, spectral content, temporal characteristics, etc.).
- If required, the directivity index and the directivity factor (see annex E).

10 INFORMATION TO BE REPORTED

The report shall contain the statement that the sound power level has been obtained in full conformity with the procedures of this International Standard. The report shall state that these sound power levels are in decibels re 1 pW.

Only those data (see clause 9) shall be reported which are required for the purposes of the measurements.

ANNEX A

TEST ROOM QUALIFICATION PROCEDURES

A.1 GENERAL

A laboratory room providing a free field (anechoic room) or a free field over a reflecting plane (semi-anechoic room) shall be used for measurements made in accordance with the requirements of this International Standard.

The test room shall be large enough and free from reflecting objects with the exception of the reflecting plane in a semi-anechoic room. The test room shall provide a measurement surface which lies :

- a) in a sound field which is free of undesired sound reflections from the room boundaries ("free-field condition");
- b) outside the near field of the sound source under test.

A procedure is described in this annex to determine the undesired environmental influences (if any) and to check the free-field conditions. For measurements in semi-anechoic rooms, the reflecting plane shall satisfy the requirements given in clause A.2.

A.2 PROPERTIES OF REFLECTING PLANE

Measurements may be made over a reflecting plane in a test room in which one of the surfaces is reflecting, or in a test room with sound-absorbing surfaces in which a reflecting plane is established.

NOTE — Particularly when the reflecting surface is not a ground plane, or is not an integral part of a test room surface, care shall be exercised to ensure that the plane does not radiate any appreciable sound due to vibrations.

A.2.1 Shape and size

The reflecting plane shall not be smaller than the projection of the measuring surface on the plane.

A.2.2 Absorption coefficient

The absorption coefficient of the plane shall be less than 0,06 over the frequency range of interest.

A.3 SOUND PRESSURE DECREASE TEST

A.3.1 Instrumentation

A.3.1.1 Test sound source

An electro-acoustic system with loudspeakers shall be used. The sound radiation shall be omnidirectional with deviations less than ± 1 dB.

NOTE — It is recommended that different sources be used for different frequency ranges, for example :

< 400 Hz : Electrodynamic loudspeaker 25 cm in diameter in closed, damped 0,020 m³ box.

400 to 2 000 Hz : Two electrodynamic speakers 10 cm in diameter bolted together so that their mounting rings lie in the same plane and electrically connected as a pulsating "sphere".

2 kHz to 10 kHz : Baffled loudspeaker system with a narrow cylindrical tube (< 1,5 cm diameter) the end section of which only radiates the sound.

A.3.1.2 Microphone

The use of a 13 mm (1/2 in) microphone is recommended.

A.3.2 Installation of test source and microphone

A.3.2.1 Source location

A.3.2.1.1 ANECHOIC ROOMS

The test sound sources shall be located in essentially the same positions as that of the source under test, preferably in the centre of the room.

A.3.2.1.2 SEMI-ANECHOIC ROOMS

The test sound sources shall be located immediately above the plane of the reflecting floor. The maximum distance between the radiating surface of the test source and the reflecting plane shall be small enough so that the resulting radiation is omnidirectional in the hemisphere over the plane with deviations as specified in A.3.1.1.

A.3.2.2 Microphone locations

Microphone traverses shall be made for at least eight straight paths away from the centre of the test sound source in different directions. Key microphone paths are the lines from the source to the room corners. Four or more paths shall be chosen at random. However, paths very close to the reflecting floor are not recommended.

A.3.3 Test procedure

The electro-acoustic system described in A.3.1 and A.3.2 shall be operated at discrete frequencies which cover in discrete steps the entire frequency range of interest for the sound source under test. The one-third octave frequencies of ISO 266 shall be used as centre frequencies below 125 Hz and above 4 000 Hz in one-third octave steps. Octave steps shall be used between 125 and 4 000 Hz.

NOTE — If the machine under test radiates only broad-band noise the procedure may be carried out for one-third octave band noise or octave band noise instead of discrete frequencies.

The microphone shall be moved continuously along the paths described in A.3.2 for each test frequency and the sound pressure levels recorded. These levels are to be compared with the decay predicted by the inverse square law and the differences between the measured and the theoretical levels are to be calculated for each path and each test frequency.

A.3.4 Qualification requirements

The differences shall not exceed the values given in table 6.

TABLE 6 — Maximum allowable differences between the measured and theoretical levels

Type of test room	One-third octave band centre frequency	Allowable differences
	Hz	dB
Anechoic	≤ 630	± 1,5
	800 to 5 000	± 1,0
	≥ 6 300	± 1,5
Semi-anechoic	≤ 630	± 2,5
	800 to 5 000	± 2,0
	≥ 6 300	± 3,0

The differences in table 6 determine the allowable measurement radii and the largest space surrounding the source within which an allowable measurement surface may be chosen. If the measurement surface lies outside the near field of the actual sound sources under test, this measurement surface is suitable for measurements according to this International Standard.

If these requirements cannot be satisfied, measurements cannot be performed according to this International Standard as the test room fails to qualify.

ANNEX B

RECOMMENDED ARRAY OF MICROPHONE POSITIONS IN A FREE FIELD

The locations of 20 points associated with equal areas on the surface of a sphere of a radius r are shown in figure 1. Table 7 gives the Cartesian coordinates (x, y, z) with origin at the centre of the source. The z -axis is chosen perpendicularly upward from a horizontal plane ($z = 0$).

TABLE 7 – Microphone positions

No.	$\frac{x}{r}$	$\frac{y}{r}$	$\frac{z}{r}$
1	– 0,99	0	0,15
2	0,50	– 0,86	0,15
3	0,50	0,86	0,15
4	– 0,45	0,77	0,45
5	– 0,45	– 0,77	0,45
6	0,89	0	0,45
7	0,33	0,57	0,75
8	– 0,66	0	0,75
9	0,33	– 0,57	0,75
10	0	0	1,0
11	0,99	0	– 0,15
12	– 0,50	0,86	– 0,15
13	– 0,50	– 0,86	– 0,15
14	0,45	– 0,77	– 0,45
15	0,45	0,77	– 0,45
16	– 0,89	0	– 0,45
17	– 0,33	– 0,57	– 0,75
18	0,66	0	– 0,75
19	– 0,33	0,57	– 0,75
20	0	0	– 1,0





FIGURE 1

ANNEX C

BASIC ARRAY OF MICROPHONE POSITIONS IN A FREE FIELD OVER A REFLECTING PLANE

The locations of 10 points associated with equal areas on the surface of a hemisphere of radius r are shown in figure 2.

The Cartesian coordinates (x, y, z) with the origin centered on the projection of the acoustic centre of the source on the reflecting plane are the same as locations 1 through 10 given in table 7 of annex B.




If the source emits predominant pure tones, strong interference effects may occur if several microphone positions are placed at the same height above the reflecting plane. In such cases the use of a microphone array with the coordinates given in table 8 is recommended :

TABLE 8 — Recommended microphone positions when the source emits predominant pure tones

No.	$\frac{x}{r}$	$\frac{y}{r}$	$\frac{z}{r}$
1	0,16	− 0,96	0,22
2	0,78	− 0,60	0,20
3	0,78	0,55	0,31
4	0,16	0,90	0,41
5	− 0,83	0,32	0,45
6	0,83	− 0,40	0,38
7	− 0,26	− 0,65	0,71
8	0,74	− 0,07	0,67
9	− 0,26	0,50	0,83
10	0,10	− 0,10	0,99

ANNEX D

COAXIAL CIRCULAR PATHS IN PARALLEL PLANES FOR MICROPHONE TRAVERSES
IN A FREE FIELD OVER A REFLECTING PLANE



The paths are selected so that the annular area of the hemisphere associated with each path is the same.

FIGURE 3

ANNEX E

CALCULATION OF DIRECTIVITY INDEX AND DIRECTIVITY FACTOR

E.1 FREE FIELD

The directivity index DI, in decibels, of the source may be calculated from measurements in a free field by using the following equation :

$$DI = L_{pi} - \overline{L_p} \quad \dots (5)$$

where

L_{pi} is the sound pressure level, in decibels, measured in the particular direction in which DI is desired, at a distance r from the source. Reference : 20 μ Pa;

$\overline{L_p}$ is the surface sound pressure level, in decibels, over the test sphere of radius r . Reference : 20 μ Pa.

The directivity factor Q of the source, in a given direction, may be determined from the following equation :

$$Q = \text{antilog}_{10} \frac{DI}{10} \quad \dots (6)$$

where DI is the directivity index, in decibels, in the same direction obtained from equation (5).

E.2 FREE FIELD OVER A REFLECTING PLANE

The directivity pattern of a source operating in a free field above a reflecting plane is generally more complex than that for the same source operating in a free field. However, when a source is normally associated with a hard reflecting plane, it may be desirable to obtain the directivity index and directivity factor for the source by considering the reflecting plane to be part of the source.

The directivity index DI, in decibels, of the source may be calculated from measurements in a free field above a reflecting plane by using the following equation :

$$DI = L_{pi} - \overline{L_p} + 3 \quad \dots (7)$$

where

L_{pi} is the sound pressure level, in decibels, measured in the particular direction in which DI is desired, at a distance r from the source. Reference : 20 μ Pa;

$\overline{L_p}$ is the surface sound pressure level, in decibels, over the test hemisphere of radius r . Reference : 20 μ Pa.

NOTE — In the report of the measurements, it may be sufficient to include only the highest value of DI and the direction in which it occurs.

ANNEX F

SYSTEM FOR MICROPHONE TRAVERSES ALONG
MERIDIONAL PATHS IN A FREE FIELD





FIGURE 4