

**NFPA®**

# 1143

---

**Standard for  
Wildland Fire Management**

---

**2018**



## IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

### NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA STANDARDS

NFPA® codes, standards, recommended practices, and guides (“NFPA Standards”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Standards.

The NFPA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Standards. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Standards available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Standards. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

### REVISION SYMBOLS IDENTIFYING CHANGES FROM THE PREVIOUS EDITION

Text revisions are shaded. A **Δ** before a section number indicates that words within that section were deleted and a **Δ** to the left of a table or figure number indicates a revision to an existing table or figure. When a chapter was heavily revised, the entire chapter is marked throughout with the **Δ** symbol. Where one or more sections were deleted, a **•** is placed between the remaining sections. Chapters, annexes, sections, figures, and tables that are new are indicated with an **N**.

Note that these indicators are a guide. Rearrangement of sections may not be captured in the markup, but users can view complete revision details in the First and Second Draft Reports located in the archived revision information section of each code at [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo). Any subsequent changes from the NFPA Technical Meeting, Tentative Interim Amendments, and Errata are also located there.

### REMINDER: UPDATING OF NFPA STANDARDS

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that NFPA Standards may be amended from time to time through the issuance of a Tentative Interim Amendment (TIA) or corrected by Errata. An official NFPA Standard at any point in time consists of the current edition of the document together with any TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of Tentative Interim Amendments or corrected by Errata, go to [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo) to choose from the list of NFPA Standards or use the search feature to select the NFPA Standard number (e.g., NFPA 13). The document information page provides up-to-date document-specific information as well as postings of all existing TIAs and Errata. It also includes the option to register for an “Alert” feature to receive an automatic email notification when new updates and other information are posted regarding the document.

# **IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS**

## **ADDITIONAL NOTICES AND DISCLAIMERS**

### **Updating of NFPA Standards**

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments or corrected by Errata. An official NFPA Standard at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes® Subscription Service, visit the NFPA website at [www.nfpa.org](http://www.nfpa.org), or contact the NFPA at the address listed below.

### **Interpretations of NFPA Standards**

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing the Development of NFPA Standards shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

### **Patents**

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Standard. The users of NFPA Standards bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Standards.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Standard may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

### **Law and Regulations**

Users of NFPA Standards should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

### **Copyrights**

NFPA Standards are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Standards for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Standards, contact NFPA at the address below.

### **For Further Information**

All questions or other communications relating to NFPA Standards and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA standards during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: [stds\\_admin@nfpa.org](mailto:stds_admin@nfpa.org).

For more information about NFPA, visit the NFPA website at [www.nfpa.org](http://www.nfpa.org). All NFPA codes and standards can be viewed at no cost at [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo).

Copyright © 2017 National Fire Protection Association®. All Rights Reserved.

## NFPA® 1143

### Standard for

## Wildland Fire Management

### 2018 Edition

This edition of NFPA 1143, *Standard for Wildland Fire Management*, was prepared by the Technical Committee on Wildland Fire Management. It was issued by the Standards Council on August 1, 2017, with an effective date of August 21, 2017, and supersedes all previous editions.

This edition of NFPA 1143 was approved as an American National Standard on August 21, 2017.

### Origin and Development of NFPA 1143

The first edition of NFPA 295, titled *Community Forest Fire Fighting Equipment*, was adopted by NFPA in 1934. The next edition was issued in 1956 as *Community Equipment and Organization for Fighting Forest, Grass and Brush Fires*. The document was retitled *Recommendations for Forest, Grass and Brush Fire Control* when it was issued in 1965 and retitled again, as *Recommendations for Wildfire Control and Environmental Improvement*, in 1972. In 1973, the document became a standard titled *Standard for Wildfire Control by Volunteer Fire Departments*, and it carried that title in the 1978 edition as well. The document was titled *Standard for Wildfire Control* with the issuance of the 1985 edition. Subsequent editions were issued in 1991 and 1998.

The 2003 edition was a complete rewrite of the document, which was renumbered and renamed NFPA 1143, *Standard for Wildland Fire Management*. In developing the 2003 edition, the technical committee recognized the development of the National Fire Plan in the United States and numerous mitigation efforts to solve the ailing forests and endangered communities in or near forested areas. In addition, the committee incorporated material to help small community and volunteer fire departments prepare for not only fire suppression in forested and wildland areas but also the broader task of wildland fire management, including mitigation, prevention, and community coordination.

The 2009 edition reflected the continued evolution of best practices in wildland fire management at the national level and further emphasized the full cycle of wildland fire management through mitigation, prevention, preparation, and suppression. The committee incorporated information to help make the document more consistent with NFPA standards on emergency services incident management and disaster management programs and to reflect current practices in regard to fire fighter safety.

The 2014 edition of NFPA 1143 was a reconfirmation of updates made in the 2009 edition. The committee updated cross-references throughout the document and updated figures to provide examples of modern equipment being utilized for wildland fire management. These updates provided the user with new examples of equipment such as dozers, helicopters, and airtankers.

In the 2018 edition of NFPA 1143, the technical committee revises the terminology from the document to be more representative of the document's intent. The technical committee aligns training and qualifications with the NFPA or the National Wildfire Coordinating Group (NWCG). The committee also aligns the incident management chapter to the National Incident Management System (NIMS). Clarification of the terminology and redefinitions found in fire suppression subsections include size-up, fire engagement and management, and mop-up and demobilization. The technical committee revises the responsibilities of public information officer (PIO) to complement NIMS and revises the responsibilities of safety officer to participate in tactics and planning meetings that are also outlined in NIMS. The technical committee clarifies the required documentation for finance and administration and updates the NWCG referenced publications.

## Technical Committee on Wildland Fire Management

**Paul Acosta**, Colorado State Fire Fighters Association, CO [L]  
Rep. National Volunteer Fire Council

**Randall K. Bradley**, Tracy Fire Department/South County Fire Authority, CA [E]

**Frederick R. Flores**, CAL FIRE/CA Department of Forestry & Fire Protection, CA [L]  
Rep. International Association of Fire Fighters

**Donald C. Freyer**, Warner Robins, GA [SE]

**Joseph T. Holland**, Hoover Treated Wood Products, FL [M]

**Wesley M. Keller**, Pennsylvania Bureau of Forestry, PA [U]

**Alexander Maranghides**, National Institute of Standards & Technology, MD [RT]

**Steve Oaks**, Santa Barbara County Fire Department, CA [E]

**Stephen S. Pollock**, Texas A&M Forest Service, TX [E]  
Rep. International Association of Fire Chiefs

**Jim Prevette**, Southern Group of State Foresters, NC [U]

**Gene Rogers**, Wildland Fire Technologies Inc., OR [SE]

**Rob Rosovich**, FireIce Inc., FL [M]

**Patrick Shipp**, Webster Fire Department, TX [E]

**Thomas B. Sing**, Quest Fire Analysis, TX [SE]

**Jim Stumpf**, Organizational Quality Associates, ID [SE]

### Alternates

**Nelson P. Bryner**, National Institute of Standards & Technology, MD [RT]  
(Alt. to Alexander Maranghides)

**Craig M. Daugherty**, San Juan County Fire Department, NM [E]  
(Alt. to Stephen S. Pollock)

**James P. Gogolski**, Hoover Treated Wood Products, OH [M]  
(Alt. to Joseph T. Holland)

**Jeanne Pincha-Tulley**, USDA Forest Service, CA [E]  
(Voting Alt.)

**Ron Raley**, Raley's Forestry and Wildfire, CA [M]  
(Voting Alt.)

**Thomas M. Sing**, Quest Fire Analysis, TX [SE]  
(Alt. to Thomas B. Sing)

**Christopher R. Vaughan**, Alabama Fire College, AL [L]  
(Alt. to Paul Acosta)

**Thomas McGowan**, NFPA Staff Liaison

*This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.*

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

**Committee Scope:** This committee shall have the primary responsibility for documents on wildland fire management.

## Contents

<b>Chapter 1 Administration</b> .....	1143- 4	5.2 Financial Planning. ....	1143- 7
1.1 Scope. ....	1143- 4	5.3 Safety Requirements. ....	1143- 7
1.2 Purpose. ....	1143- 4	5.4 Training and Qualifications. ....	1143- 7
1.3 Wildland Fire Management Policies. ....	1143- 4		
<b>Chapter 2 Referenced Publications</b> .....	1143- 4	<b>Chapter 6 Incident Management</b> .....	1143- 8
2.1 General. ....	1143- 4	6.1 Organizational Structure. ....	1143- 8
2.2 NFPA Publications. ....	1143- 4	6.2 Functional Responsibilities. ....	1143- 8
2.3 Other Publications. ....	1143- 4	6.3 Multijurisdictional Incidents. ....	1143- 10
2.4 References for Extracts in Mandatory Sections. ....	1143- 5	6.4 Coordination. ....	1143- 10
<b>Chapter 3 Definitions</b> .....	1143- 5	<b>Chapter 7 Fire Suppression</b> .....	1143- 10
3.1 General. ....	1143- 5	7.1 Size-Up. ....	1143- 10
3.2 NFPA Official Definitions. ....	1143- 5	7.2 Fire Engagement and Management. ....	1143- 10
3.3 General Definitions. ....	1143- 5	7.3 Mop-Up and Demobilization. ....	1143- 10
<b>Chapter 4 Risk/Hazard Assessment and Mitigation</b> .....	1143- 6	<b>Chapter 8 Post-Incident Activities</b> .....	1143- 10
4.1 General. ....	1143- 6	8.1 Reporting. ....	1143- 10
4.2 Values at Risk. ....	1143- 6	8.2 Incident Review and Close Out. ....	1143- 10
4.3 Ignition Risk Assessment. ....	1143- 6	8.3 Finance/Administration. ....	1143- 11
4.4 Fire Hazard Assessment. ....	1143- 6	<b>Annex A Explanatory Material</b> .....	1143- 11
4.5 Mitigation Plan. ....	1143- 6	<b>Annex B Air Operations for Wildland Fire Incidents</b> .....	1143- 29
4.6 Evaluation of Mitigation Plan. ....	1143- 7	<b>Annex C Informational References</b> .....	1143- 33
<b>Chapter 5 Preparedness</b> .....	1143- 7	<b>Index</b> .....	1143- 35
5.1 Wildland Fire Response Planning. ....	1143- 7		

## NFPA 1143

## Standard for

## Wildland Fire Management

2018 Edition

**IMPORTANT NOTE:** This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notices and Disclaimers Concerning NFPA Standards.” They can also be viewed at [www.nfpa.org/disclaimers](http://www.nfpa.org/disclaimers) or obtained on request from NFPA.

**UPDATES, ALERTS, AND FUTURE EDITIONS:** New editions of NFPA codes, standards, recommended practices, and guides (i.e., NFPA Standards) are released on scheduled revision cycles. This edition may be superseded by a later one, or it may be amended outside of its scheduled revision cycle through the issuance of Tentative Interim Amendments (TIAs). An official NFPA Standard at any point in time consists of the current edition of the document, together with all TIAs and Errata in effect. To verify that this document is the current edition or to determine if it has been amended by TIAs or Errata, please consult the National Fire Codes® Subscription Service or the “List of NFPA Codes & Standards” at [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo). In addition to TIAs and Errata, the document information pages also include the option to sign up for alerts for individual documents and to be involved in the development of the next edition.

**NOTICE:** An asterisk (\*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [ ] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, the complete title and edition of the source documents for extracts in mandatory sections of the document are given in Chapter 2 and those for extracts in informational sections are given in Annex C. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced publications can be found in Chapter 2 and Annex C.

## Chapter 1 Administration

**1.1 Scope.** This standard provides minimum requirements to fire protection organizations on the management of wildland fire, including prevention, mitigation, preparation, and suppression.

**1.2\* Purpose.** The purpose of this standard is to specify management practices and policies necessary for a fire protection organization to develop a wildland fire management program.

## 1.3 Wildland Fire Management Policies.

**1.3.1** The authority having jurisdiction (AHJ) shall develop a policy for managing the organization in all aspects of wildland fire, including prevention, mitigation, preparation, and suppression.

**1.3.1.1** As a minimum, the policy shall be established in accordance with legal mandates, organization priorities, planning procedures, incident management, personnel safety and training, and cooperative agreements.

**1.3.1.2** Additional policy items shall be included as determined necessary by the AHJ.

**1.3.2** Where the possibility of wildland fire constitutes a threat, the AHJ shall have a management plan to perform the activities as required by this standard.

**1.3.3** The goal shall be to reduce wildland fire loss through the establishment, maintenance, and coordination of policies and programs addressing fire prevention, risk assessment and mitigation, planning, incident management, personnel, infrastructure, training, communications, fire suppression capabilities, and safety.

## Chapter 2 Referenced Publications

**2.1 General.** The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

**2.2 NFPA Publications.** National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 1002, *Standard for Fire Apparatus Driver/Operator Professional Qualifications*, 2017 edition.

NFPA 1026, *Standard for Incident Management Personnel Professional Qualifications*, 2014 edition.

NFPA 1051, *Standard for Wildland Firefighting Personnel Professional Qualifications*, 2016 edition.

NFPA 1141, *Standard for Fire Protection Infrastructure for Land Development in Wildland, Rural, and Suburban Areas*, 2017 edition.

NFPA 1144, *Standard for Reducing Structure Ignition Hazards from Wildland Fire*, 2018 edition.

NFPA 1451, *Standard for a Fire and Emergency Service Vehicle Operations Training Program*, 2013 edition.

NFPA 1500, *Standard on Fire Department Occupational Safety, Health, and Wellness Program*, 2018 edition.

NFPA 1521, *Standard for Fire Department Safety Officer Professional Qualifications*, 2015 edition.

NFPA 1561, *Standard on Emergency Services Incident Management System and Command Safety*, 2014 edition.

NFPA 1582, *Standard on Comprehensive Occupational Medical Program for Fire Departments*, 2018 edition.

NFPA 1616, *Standard on Mass Evacuation, Sheltering, and Re-entry Programs*, 2017 edition.

NFPA 1977, *Standard on Protective Clothing and Equipment for Wildland Fire Fighting*, 2016 edition.

## 2.3 Other Publications.

**2.3.1 NWCG (National Wildfire Coordinating Group) Publications.** National Interagency Fire Center Publications, Great Basin Cache Supply Office, 3833 So. Development Avenue, Boise, ID 83705.

NWCG I-100, *Introduction to the Incident Command System*, 2015.

NWCG L-180, *Human Factors in the Wildland Fire Service*, 2014.



NWCG S-130, *Firefighter Training*, 2003.

NWCG S-190, *Introduction to Wildland Fire Behavior*, 2008.

## **N 2.3.2 Other Publications.**

*Merriam-Webster's Collegiate Dictionary*, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

## **2.4 References for Extracts in Mandatory Sections.**

NFPA 1, *Fire Code*, 2018 edition.

NFPA 101®, *Life Safety Code*®, 2018 edition.

NFPA 1051, *Standard for Wildland Firefighting Personnel Professional Qualifications*, 2016 edition.

NFPA 1141, *Standard for Fire Protection Infrastructure for Land Development in Wildland, Rural, and Suburban Areas*, 2017 edition.

NFPA 1451, *Standard for a Fire and Emergency Service Vehicle Operations Training Program*, 2013 edition.

## **Chapter 3 Definitions**

**3.1 General.** The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

## **3.2 NFPA Official Definitions.**

**3.2.1\* Approved.** Acceptable to the authority having jurisdiction.

**3.2.2\* Authority Having Jurisdiction (AHJ).** An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

**3.2.3 Labeled.** Equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization that is acceptable to the authority having jurisdiction and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

**3.2.4\* Listed.** Equipment, materials, or services included in a list published by an organization that is acceptable to the authority having jurisdiction and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services, and whose listing states that either the equipment, material, or service meets appropriate designated standards or has been tested and found suitable for a specified purpose.

**3.2.5 Shall.** Indicates a mandatory requirement.

**3.2.6 Should.** Indicates a recommendation or that which is advised but not required.

**3.2.7 Standard.** An NFPA Standard, the main text of which contains only mandatory provisions using the word "shall" to indicate requirements and that is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions are not to be

considered a part of the requirements of a standard and shall be located in an appendix, annex, footnote, informational note, or other means as permitted in the NFPA Manuals of Style. When used in a generic sense, such as in the phrase "standards development process" or "standards development activities," the term "standards" includes all NFPA Standards, including Codes, Standards, Recommended Practices, and Guides.

## **3.3 General Definitions.**

**3.3.1 Agency.** A division of government with a specific function or a nongovernmental organization (e.g., private business) that offers a particular kind of assistance.

**3.3.2\* Apparatus.** A motor-driven vehicle or group of vehicles designed and constructed for the purpose of fighting fires.

**3.3.3 Command.** The act of directing and/or controlling resources by virtue of explicit legal, agency, or delegated authority.

**3.3.4 Finance.** The incident management section responsible for all incident costs and financial considerations.

**3.3.5 Fire Hazard.** A fuel complex, defined by volume, type, condition, arrangement, and location, that determines the degree of ease of ignition and of resistance to control.

**3.3.6 Incident.** An occurrence, either human-caused or a natural phenomenon, that requires action or support by emergency services personnel to prevent or minimize loss of life or damage to property and/or natural resources.

**3.3.7\* Incident Action Plan (IAP).** A plan that contains objectives reflecting the overall incident strategy, specific tactical actions, and supporting information for the next operational period.

**3.3.8 Incident Commander (IC).** The individual responsible for the management of all incident operations at the incident site.

**Δ 3.3.9\* Incident Management System (IMS).** A system that defines the roles and responsibilities to be assumed by responders and the standard operating procedures/standard operating guidelines (SOPs/SOGs) to be used in the management and direction of emergency incidents and other functions.

**Δ 3.3.10 Jurisdiction.** Any governmental unit or political division or a subdivision. [1, 2018]

**3.3.11 Liaison.** The individual responsible for the coordination of activities with assisting agencies.

**3.3.12 Logistics.** The incident management section responsible for providing facilities, services, support, and materials for the incident.

**3.3.13 Mitigation.** Action that moderates the severity of a fire hazard or risk.

**3.3.14 Operations.** The incident management section responsible for all tactical operations at the incident.

**3.3.15 Planning.** The incident management section responsible for the collection, evaluation, and dissemination of tactical information related to the incident and for preparation and documentation of incident management plans.



**3.3.16 Prevention.** Activities, including public education, law enforcement, personal contact, and reduction of fuel hazards, directed at reducing the incidence of fires.

**3.3.17 Risk.** A measure of the probability and severity of adverse effects that result from exposure to a hazard. [1451, 2013]

• **3.3.18 Stakeholder.** An individual, or representative of same, having an interest in the successful completion of a project. [101, 2018]

**3.3.19\* Unified Command.** A standard method to coordinate command of an incident where multiple agencies have jurisdiction.

**3.3.20\* Values at Risk.** Public and private resources, which include, but are not limited to, property, structures, physical improvements, natural and cultural resources, community infrastructure, and economic, environmental, and social values.

• **3.3.21\* Wildland Fire.** An unplanned and uncontrolled fire spreading through vegetative fuels, including any structures or other improvements thereon. [1141, 2017]

**3.3.22\* Wildland/Urban Interface.** Locations in which the AHJ determines that topographical features, vegetation fuel types, local weather conditions, and prevailing winds result in the potential for ignition of the structures within the area from flames and firebrands of a wildland fire.

**3.3.23\* Wildland/Urban Interface Coordinator.** The person responsible for the development of the plan(s) for the reduction of the fire risks and hazards associated in the wildland/urban interface. [1051, 2016]

• **3.3.24 Wildland/Urban Interface Protection Specialist.** The person responsible for the development and/or implementation of a plan to protect people, animals, communities, individual structures, or other improvements from a wildland fire. [1051, 2016]

## Chapter 4 Risk/Hazard Assessment and Mitigation

**4.1\* General.** The AHJ shall develop a written risk and hazard assessment and mitigation plan based on values at risk and consistent with fire fighter and public safety.

### 4.2 Values at Risk.

**4.2.1** The AHJ shall involve the community, landowners, industry, and other stakeholders in the identification of values to be protected within the jurisdiction.

**4.2.2** The values shall include, but not be limited to, health, safety, property, and resource values, as well as the social, economic, environmental, and political concerns of the local jurisdiction.

### 4.3 Ignition Risk Assessment.

**4.3.1** The AHJ shall evaluate the potential and historical sources of ignition.

**4.3.2\*** The evaluation shall include both natural and human sources of ignition.

### 4.4\* Fire Hazard Assessment.

**4.4.1** The AHJ shall assess the severity of wildland fires within or threatening the jurisdiction.

**4.4.2** The assessment shall consider, but not be limited to, the following:

- (1) Vegetation (fuels)
- (2) Topography
- (3) Aspect
- (4) Fire history
- (5) Historical fire weather
- (6) Fire danger rating
- (7) Potential fire behavior
- (8) Fire-fighting capabilities and limitations
- (9) Ingress and egress

Δ **4.4.3** In the assessment of wildland/urban interface hazards to structures, the requirements in NFPA 1144 shall apply.

### 4.5\* Mitigation Plan.

**4.5.1 Plan Development.** Based on the values, ignition risk assessment, and fire hazard assessment, the AHJ shall develop a plan identifying the required mitigation activities, responsible party, priorities, and implementation schedule.

**4.5.1.1\*** This plan shall be developed and implemented in coordination with the stakeholders.

**4.5.2 Activities.** The mitigation activities shall include, but not be limited to, the details outlined in 4.5.3 through 4.5.8.

**4.5.3 Ignitions.** The AHJ shall identify the prevention activities that reduce the occurrence of human-caused ignition.

### 4.5.4 Fuels Treatment.

**4.5.4.1** The AHJ shall identify activities necessary to mitigate fire behavior characteristics through fuel modification.

**4.5.4.2** Acceptable methods of fuel treatment include, but are not limited to, prescribed burning by qualified personnel, mowing, pruning, removing, species substitution, mulching, chemical treatments, converting to compost, and grazing.

**4.5.5\* Public Education.** The AHJ shall appoint a qualified individual(s) whose duties shall include, but not be limited to, the following:

- (1) Scheduling and facilitating public meetings to identify values at risk, wildland fire threats, and potential mitigation strategies
- (2) Disseminating information concerning activities and their status through development and distribution of prevention information
- (3) Familiarizing press and media representatives with the threat of wildland fire and mitigation strategies

### 4.5.6 Structures.

Δ **4.5.6.1** Where a wildland fire ignition risk and fire hazard severity assessment indicates the need, mitigation activities for existing construction shall be consistent with NFPA 1144.

Δ **4.5.6.2** The design criteria for new construction and land development in and near wildland fire threats shall be consistent with NFPA 1141 and NFPA 1144.

**4.5.7 Infrastructure.** The AHJ shall evaluate and consider the need for modification or additions to the infrastructure, including the following:

- (1) Roads — including ingress/egress
- (2) Water supply
- (3) Communications
- (4) Utility corridors
- (5) Transportation corridors
- (6) Airports

▲ **4.5.7.1** All new or modified infrastructure shall comply with the provisions of NFPA 1141.

**4.5.8\* Special Considerations.** The AHJ shall comply with civil and environmental laws in the planning and implementation of mitigation activities, including those pertaining to threatened and endangered species and historical and cultural resources.

▲ **4.6\* Evaluation of Mitigation Plan.** The AHJ shall, on an annual basis, review the mitigation plan to monitor progress of mitigation activities and to determine whether priorities have changed.

## Chapter 5 Preparedness

### 5.1 Wildland Fire Response Planning.

**5.1.1** The AHJ shall evaluate the capabilities and limitations of existing fire-fighting resources.

**5.1.2** When the situation indicates that additional resources are needed, consideration shall be given to the following:

- (1)\* Mutual Aid and Cooperative Fire Protection agreements
- (2) Budget adjustments for additional personnel, apparatus, or other equipment
- (3) Government and private sector grants
- (4) Volunteer recruitment
- (5) Additional training
- (6) Improved tactics
- (7) Use of improved and innovative techniques

**5.1.3 Preparedness Planning.** The AHJ shall develop a written preparedness plan(s) for wildland fire management consistent with fire fighter and public safety.

**5.1.3.1** The plan(s) shall be based on life safety, followed by property and natural resources to be protected, as well as the political, social, economic, environmental, and other concerns of the local jurisdictions.

▲ **5.1.3.2** This plan shall, on an annual basis, be reviewed and, as a minimum, include the following:

- (1) Identification of specific wildland fire hazards, ignition risks, and potential hazard areas within the jurisdiction and other hazards that have a negative effect on wildland fire management efforts
- (2) Identification of fire protection features such as lakes, rivers, water points, natural firebreaks, potential escape routes, and other areas or features that are beneficial to wildland fire management efforts
- (3)\* A list of fire-fighting resources, including personnel, apparatus, and equipment
- (4) A list of all cooperating agencies and other mutual aid resources and the procedures for requesting assistance from those agencies and resources

- (5) A reference to any and all existing mutual aid agreements, contracts, and other protection agreements applicable to wildland fire management efforts
- (6) A list of specific objectives relating to training, safety, response times, and staffing levels
- (7) A list of other resources that provide analyses of fire cause, identification of special fire hazards, identification of ignition risks, assessment of wildland/urban interface fire protection problems, and proposed measures to reduce fire occurrence
- (8) Reference NFPA 1616 for mass evacuation, sheltering, and re-entry guidance

**5.2\* Financial Planning.** The financial element of the preparedness plan shall include, as a minimum, the contractual agreements to provide for the following services:

- (1) Fuel, oil, and lubricants
- (2) Medical services, including injury reports
- (3) Catering services, food, and drinking water
- (4) Incident-specific personnel hiring and compensation
- (5) Outside services, including lodging and communications
- (6) Equipment maintenance
- (7) Specialized fire-fighting equipment
- (8) Purchasing practices, procedures, and agreements
- (9) Other incident support

**5.3\* Safety Requirements.** The AHJ shall develop safety requirements that include 5.3.1 through 5.3.5.

**5.3.1** The AHJ shall develop a safety program that includes all aspects of wildland fire incident operation, personnel welfare, and the use of personal protective clothing and equipment.

▲ **5.3.1.1** The program shall be established in accordance with jurisdictional policies and procedures and reflect the established guidance provided by NFPA 1500.

▲ **5.3.1.2\*** All personal protective clothing and equipment shall meet the requirements of NFPA 1977.

▲ **5.3.2** The safety officer's function shall be to carry out duties in accordance with established wildland fire incident procedures and the criteria outlined in NFPA 1521.

**5.3.3** Protective measures shall be taken for apparatus and equipment used during wildland fire incidents.

▲ **5.3.4** Equipment operators shall meet the requirements of NFPA 1002 and be trained as outlined in NFPA 1451.

▲ **5.3.5** The AHJ shall follow the medical examination standards established in NFPA 1582.

### 5.4\* Training and Qualifications.

▲ **5.4.1** All wildland fire fighters shall have a working knowledge and the skills of wildland fire safety practices and procedures meeting the requirements in National Wildfire Coordinating Group (NWCG) S-130, *Firefighter Training*, S-190, *Introduction to Wildland Fire Behavior*, L-180, *Human Factors in the Wildland Fire Service*, and I-100, *Introduction to the Incident Command System*.

**5.4.2\*** All personnel responding to wildland fire shall meet the job performance requirements of NFPA 1051.

**5.4.3\*** All members of the agencies and organizations involved in wildland fire suppression shall be trained in safety procedures around air operations.

## Chapter 6 Incident Management

**Δ 6.1\* Organizational Structure.** In the management of wildland fire incidents, the AHJ shall utilize an incident management system (IMS) as specified in NFPA 1561.

**6.1.1** At the initial stages of the incident, all command and support functions shall be the direct responsibility of the incident commander (IC).

**6.1.2** As the incident grows in size and complexity, the functions shall be delegated as appropriate to qualified personnel as specified in NFPA 1026.

**N 6.1.3** The organizational structure identified in Section 6.1 shall be compliant with the National Incident Management System (NIMS).

**6.2\* Functional Responsibilities.** Each of the following functions as specified in 6.2.1 through 6.2.3.4 shall be addressed regardless of the size and complexity of the incident:

- (1) Incident command
- (2) Operations
- (3) Planning
- (4) Logistics
- (5) Finance

### 6.2.1\* Incident Command Functions.

**Δ 6.2.1.1\*** The responsibilities of incident command shall be carried out by the IC.

**N 6.2.1.2** These responsibilities shall include, but not be limited to, the following:

- (1)\* Developing the command and support organization for the incident
- (2) Establishing a command post
- (3) Developing, reviewing, revising, evaluating, approving, and distributing an incident action plan (IAP) for each operational period
- (4) Ensuring adequate safety measures are followed, using the following principles:
  - (a) Activities that present a significant risk to the safety of fire fighters shall be limited to situations where there is a potential to save endangered lives.
  - (b) In those situations where improved property is threatened but lives are not at risk, threats to fire fighter safety shall be minimized.
- (5) Maintaining command throughout the duration of the incident, including transfer and termination of command
- (6)\* Acquiring a formal Delegation of Authority from the AHJ
- (7) Controlling access of essential and nonessential individuals to the incident scene
- (8) Maintaining awareness of situation status
- (9) Evaluating progress of the incident
- (10) Maintaining awareness of deployment of all assigned units
- (11) Maintaining personnel accountability
- (12) Requesting additional resources as needed
- (13) Notifying key people, officials, and the AHJ of incident status
- (14) Approving release of information to the public
- (15) Approving the demobilization of resources

### 6.2.2\* Command Staff Functions.

#### 6.2.2.1 Public Information Officer.

**6.2.2.1.1** The public information officer shall develop and release approved information about the incident to the news media, to incident personnel, and to other appropriate agencies and organizations.

**6.2.2.1.2** Only one public information officer shall be assigned for each incident, including incidents operating under unified command and multijurisdictional incidents.

**6.2.2.1.3** The public information officer shall be permitted to have assistants as necessary, and the assistants shall be permitted to also represent assisting agencies or jurisdictions.

**Δ 6.2.2.1.4** The following are the major responsibilities of the public information officer, which shall apply to any incident:

- (1) Determine from the IC if there are any limits on information release
- (2) Develop material for use in media briefings
- (3) Obtain IC's approval of media releases
- (4) Inform media and conduct media briefings
- (5) Arrange for tours and other interviews or briefings as requested
- (6) Obtain media information that can be useful to incident planning
- (7) Maintain current information summaries and displays on the incident and provide information on the status of the incident to assigned personnel
- (8) Maintain unit log
- (9) Participate in planning meeting

#### 6.2.2.2 Liaison Officer.

**6.2.2.2.1** Incidents that are multijurisdictional, or have several agencies involved, shall be permitted to establish the position of liaison officer on the command staff.

**6.2.2.2.2\*** The liaison officer shall be the contact for the personnel assigned to the incident by assisting or cooperating agencies.

**6.2.2.2.3** The following are the major responsibilities of the liaison officer, which shall apply to any incident:

- (1) Be a contact point for agency representatives
- (2) Maintain a list of assisting and cooperating agencies and agency representatives
- (3) Assist in establishing and coordinating interagency contacts
- (4) Keep agencies supporting the incident aware of incident status
- (5) Monitor incident operations to identify current or potential inter-organizational problems
- (6) Participate in planning meetings and provide current resource status, including limitations and capability of assisting agency resources
- (7) Maintain unit log

#### 6.2.2.3 Safety Officer.

**6.2.2.3.1** Standard operating procedures/standard operating guidelines (SOPs/SOGs) shall define criteria for the response or appointment of a safety officer.

**Δ 6.2.2.3.2\*** The safety officer and assistant safety officer(s) shall be specifically identifiable on the incident scene.

**6.2.2.3.3** The safety officer shall monitor conditions, activities, and operations to determine whether they fall within the criteria as defined in the incident's risk management plan. When the perceived risk(s) is not within these criteria, the safety officer shall take action as outlined in 6.2.1.2(4).

• **Δ 6.2.2.3.4** The following are the major responsibilities of the safety officer, which shall apply to any incident:

- (1) Participate in tactics and planning meetings
- (2) Identify hazardous situations associated with the incident
- (3) Review the IAP for safety implications
- (4) Exercise emergency authority to stop and prevent unsafe acts
- (5) Investigate accidents that have occurred within the incident area
- (6) Assign assistants as needed
- (7) Review and approve the medical plan
- (8) Maintain unit log

• **6.2.3 General Staff Functions.**

**Δ 6.2.3.1 Operations Function.** The operations function shall be responsible for carrying out the strategic and tactical plans of the incident and shall include incident and post-incident planning and actions.

**N 6.2.3.1.1** The responsibilities of operations are carried out by the IC until delegated to a qualified operations section chief.

**N 6.2.3.1.2** These responsibilities shall include, but not be limited to, the following:

- (1) Evaluating, organizing, and assigning available resources following SOPs/SOGs based on the scale and complexity of operations
- (2) Evaluating the number of qualified and equipped people available, their physical condition, their experience and skill levels, and their availability
- (3) Evaluating the types and amount of equipment and apparatus available within a specified response time, where the resources are located, how they can be transported to the incident, and the suitability of such equipment for use in wildland fire management, considering terrain and other local conditions
- (4) Carrying out tactical functions to support the IAP
- (5) Ensuring that all safety elements of the IAP are followed
- (6) Maintaining accountability for all tactical resources
- (7) Developing the operations portion of the IAP, including tactical work assignments
- (8) Requesting resources as needed to implement the IAP
- (9) Maintaining close contact with subordinate tactical supervisors
- (10) Directing release of resources from assigned status (not release from the incident)
- (11) Implementing tactical changes to the IAP during the operational period as necessary
- (12) Maintaining close communication with the IC
- (13) Maintaining unit log

**6.2.3.2 Planning Function.** The planning function shall be the responsibility of the IC for the preparation of all plans necessary to carry out the purpose and goals of the fire management agencies and organizations.

**Δ 6.2.3.2.1** The responsibilities of planning are carried out by the IC until delegated to a qualified planning section chief.

**N 6.2.3.2.2** These responsibilities shall include, but not be limited to, the following:

- (1) Organizing a planning section to include the following units as necessary:
  - (a) Resources unit
  - (b) Situation unit
  - (c) Documentation unit
  - (d) Demobilization unit
  - (e) Specialized positions
- (2) Collecting, evaluating, developing, and disseminating information
- (3) Accounting for organizational structure, availability of resources, and deployment of resources
- (4) Maintaining, documenting, and displaying situation and resource status
- (5)\* Developing the proposed IAP in coordination with command and general staff
- (6) Disseminating the IAP for each operational period
- (7) Reassigning personnel already on site to IMS organizational positions as appropriate
- (8) Determining the need for any specialized resources in support of the incident
- (9) Overseeing preparation of incident demobilization plan
- (10) Maintaining unit log

**6.2.3.3 Logistics Function.** The logistics function shall be responsible to the IC for providing support resources that meet the goals and purposes of the wildland fire management effort.

**Δ 6.2.3.3.1** The responsibilities of logistics shall be carried out by the IC until delegated to a qualified logistics section chief.

**N 6.2.3.3.2\*** These responsibilities shall include, but not be limited to, the following:

- (1) Assessing and determining the need for facilities, communications, support services, supplies, and equipment
- (2) Organizing a logistics section to include the following units as necessary:
  - (a) Supply unit
  - (b)\* Facilities unit
  - (c)\* Ground support unit
  - (d)\* Communications unit
  - (e) Food unit
  - (f) Medical unit
- (3) Managing all incident logistics
- (4) Providing logistical input during the tactics meeting and through required documents for preparing the IAP
- (5) Identifying anticipated and known incident service and support requirements
- (6) Requesting or acquiring additional resources as needed
- (7) Preparing and disseminating the communications plan, medical plan, and traffic plan for the IAP
- (8) Supporting demobilization

**6.2.3.4 Finance/Administration Function.** The IC shall be responsible for the finance/administration function for all aspects of financial management in support of the fire protection organization.

**Δ 6.2.3.4.1** The responsibilities of finance/administration shall be carried out by the IC until delegated to a qualified finance section chief.



**N 6.2.3.4.2** These responsibilities shall include, but not be limited to, the following:

- (1) Organizing a finance/administration section to include the following units as necessary:
  - (a) Time unit
  - (b) Procurement unit
  - (c) Compensation/claims unit
  - (d) Cost unit
- (2) Managing all financial aspects of an incident
- (3) Providing financial and cost analysis information to the IC and to others as requested
- (4) Gathering pertinent information from briefings with responsible agencies
- (5) Developing an operating plan for the finance/administration section
- (6) Filling supply and support needs
- (7) Meeting with representatives of assisting and cooperating agencies as needed
- (8) Maintaining daily contact with agency administrator's headquarters on finance/administration matters
- (9) Ensuring that all personnel time records are completed and transmitted to home agencies, according to policy
- (10) Providing financial input to demobilization planning
- (11) Ensuring that all obligation documents (e.g., contracts, purchase orders) initiated at the incident are prepared and completed
- (12) Following a methodology for the disbursement of funds

**6.3 Multijurisdictional Incidents.** AHJs shall implement a unified command system or a single command system to coordinate among responsible agencies or organizations.

**6.4 Coordination.** The IC shall coordinate with all assisting and cooperating agencies or organizations.

## Chapter 7 Fire Suppression

**7.1 Size-Up.** Upon arrival, the IC shall conduct a size-up to determine the extent of the fire and its potential, taking into consideration the following factors:

- (1) Incident type
- (2) Location/jurisdiction
- (3) Incident size
- (4) Incident status
- (5) Incident command and fire name
- (6) Weather conditions
- (7) Radio frequencies
- (8) Best access routes
- (9) Special hazards or concerns
- (10) Additional resource needs

### 7.2\* Fire Engagement and Management.

**7.2.1\*** The IC shall deploy personnel and equipment to the incident according to strategic and tactical plans [the incident action plan (IAP)], within the priorities established for the incident and with consideration for the safety of the public and incident-assigned personnel.

**7.2.2** Once the threat to life and property is evaluated, the IC shall plan for and execute tasks necessary for the overall management of the incident.

**7.2.3** The incident management plan shall address the following issues:

- (1) Fire fighter and public safety
- (2) Available resources
- (3) Overall incident strategy
- (4) Tactical operations

### 7.3 Mop-Up and Demobilization.

**7.3.1** When the IAP requires containment and management of the fire, the IC shall ensure that mop-up operations meet the needs of the local unit and facilitate the return of the incident to the local fire manager.

**7.3.2** The IC shall ensure that the demobilization of resources is carried out in a safe, effective, and efficient manner.

## Chapter 8 Post-Incident Activities

### 8.1\* Reporting.

**8.1.1** The AHJ or designee shall complete and file incident reports as required.

**8.1.2** Such reports, whether hard copy or electronic, shall be filed within the time frame specified by the state, provincial, or federal authority.

### 8.2 Incident Review and Close Out.

**8.2.1** After completion of the incident, the AHJ, in conjunction with the IC, shall conduct a review of the actions taken during the incident.

**8.2.2** Designated personnel from all functional areas of the incident shall be in attendance to provide for a thorough review of the operation.

**Δ 8.2.3** The AHJ shall review all activities related to the incident, including safety practices and provisions; strategy and tactics to accomplish overall objectives; the deployment of personnel, equipment, and apparatus; support functions; and the overall management of the incident.

**8.2.4** The AHJ shall take corrective actions in all areas where deficiencies exist or problems occurred.

**8.2.5** All reviews and evaluations shall be conducted as constructive critiques to determine the facts related to the incident.

**8.2.6** As a minimum, evaluations shall cover the following:

- (1) Examination of accidents, injuries, or fatalities connected to the incident to determine cause(s) and contributing factors and, where applicable, to recommend corrective actions
- (2) Examination of the actions used on the incident and confirmation of effective decisions or corrected deficiencies
- (3) Identification and evaluation of new or improved procedures, techniques, or tactics used on the incident
- (4) Identification of potential alternative procedures, techniques, tactics, or equipment for effective use in future incidents
- (5) Examination of the incident to determine fire cause(s) and contributing factors and, where applicable, to recommend preventive or mitigating measures

### 8.3 Finance/Administration.

**8.3.1** The AHJ shall satisfy all financial commitments related to the incident, including cost-share agreements.

**8.3.2** The AHJ shall review and investigate any known financial claims or potential liabilities related to the incident.

**8.3.3** The AHJ shall prepare and distribute the required documentation that will provide the necessary information to initiate the issuing of reimbursable bills to the appropriate parties.

**8.3.4** The AHJ shall establish a process to ensure all financial obligations are met.

## Annex A Explanatory Material

*Annex A is not a part of the requirements of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.*

**A.1.2** This standard provides wildfire management information and minimum requirements for communities in rural and forested areas. Many of these communities are exposed to the dangers of large fires involving many acres of natural fuels, such as forest, grass, or brush. To prepare for such emergencies, the responsible fire protection organizations and individuals should be aware of the most recent and useful wildland fire management techniques, equipment, training, and operations.

This standard includes a list of mandatory requirements that must be met if fire fighters are to be safe in the prevention and suppression of wildland fires. Additional information on large equipment, heavy power tools, specialized wildland fire-fighting equipment, and techniques for landscape management, prescribed fire, smoke management, community and subdivision planning, and other mitigation measures is available in other publications.

In many rural and wildland areas, forest, grass, crop, and brush fires are a continual problem. These fires, if not controlled, can endanger human life and cause serious damage to property, natural resources, and the environment. Evaluation of wildland fires has shown that fire damage can be prevented or minimized if mitigation efforts are made and when, in the case of such fires, aggressive suppression actions by trained fire fighters are executed in the early stages of fire development.

**A.3.2.1 Approved.** The National Fire Protection Association does not approve, inspect, or certify any installations, procedures, equipment, or materials; nor does it approve or evaluate testing laboratories. In determining the acceptability of installations, procedures, equipment, or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure, or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization that is concerned with product evaluations and is thus in a position to determine compliance with appropriate standards for the current production of listed items.

**A.3.2.2 Authority Having Jurisdiction (AHJ).** The phrase “authority having jurisdiction,” or its acronym AHJ, is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where

public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

**A.3.2.4 Listed.** The means for identifying listed equipment may vary for each organization concerned with product evaluation; some organizations do not recognize equipment as listed unless it is also labeled. The authority having jurisdiction should utilize the system employed by the listing organization to identify a listed product.

**A.3.3.2 Apparatus.** Examples include engines and tenders.

**A.3.3.7 Incident Action Plan (IAP).** The plan might be oral or written. When written, the plan might have a number of attachments, including incident objectives, organization assignment list, assignment list, incident radio communication plan, medical plan, traffic plan, safety plan, weather and fire behavior forecasts, and incident map.

**A.3.3.9 Incident Management System (IMS).** The system is also referred to as an incident command system (ICS). [1561, 2014]

**A.3.3.19 Unified Command.** Unified command is a team effort that allows all agencies with jurisdictional responsibility, either geographical or functional, to manage an incident by establishing a common set of objectives and strategies. This should be accomplished without loss of or abdication of authority, responsibility, or accountability.

**A.3.3.20 Values at Risk.** Such resources include timber, watershed, wildlife, unique scenic and recreation areas, range, air quality, structures, and people.

**A.3.3.21 Wildland Fire.** The terms *wildfire* and *wildland fire* are often used interchangeably by many in and out of the fire protection community. This document prefers the term *wildland fire* as all encompassing when referring to fires in the wildland, wildland/urban interface, and/or wildland/urban intermix areas.

**A.3.3.22 Wildland/Urban Interface.** The term *wildland/urban interface* can distort the perception of the primary issue. It can direct attention to “where” structures are located (e.g., at the edge of communities near the wildland) rather than if they are highly ignitable. And if so, the focus on “where” can result in a concern about things that won’t make a big difference in reducing structure loss (i.e., how fire fighters and equipment get there, what type of fire equipment is needed, and the location of fire hydrants and water sources). How wide the roads are and where the fire hydrants are located become of little value if there are more structures at risk than equipment to protect them, or if it’s too dangerous to safely be there with fire-fighting forces.

The essence of this issue is not where structures and domestic landscapes adjoin wildland, but the location, density, and availability of ignitable structures. Which structures are at the



greatest risk, ignition-resistant homes bordering the wildland or a dense subdivision with wood shingle roofs several miles away from wildland fuels? The wildland/urban interface is not geographic location but rather a set of conditions that can exist in many communities. [1144, 2018]

**A.3.3.23 Wildland/Urban Interface Coordinator.** This person coordinates with local residents, local government, and the responsible fire service agency.

▲ **A.4.1** The wildland/urban interface coordinator should be responsible for developing the risk and hazard assessment with community and stakeholder involvement. For specific information regarding hazard and risk assessment in wildland areas, refer to NFPA 1144, Figure A.4.1.2, which shows a structure assessment guide, and Table A.4.1.2, which illustrates a sample structure assessment rating form.

**A.4.3.2** These sources can include, but are not limited to, the following:

- (1) Natural occurrences (e.g., lightning, volcanic eruptions)
- (2) Utility and transportation corridors
- (3) Industry
- (4) Recreation
- (5) Arson

▲ **A.4.4** The probability of a wildland fire starting is dependent on an ignition source, fuel conditions, and the weather. Accurate determination of fire danger can be made only through specific weather-related observations such as temperature, humidity, wind speed, and fuel moisture. These observations are used by systems such as the National Fire Danger Rating System and the Canadian Forest Fire Danger Rating System.

A seasonal risk analysis is a method of incorporating important information into a fire hazard assessment. A seasonal risk analysis requires fire managers to step back, review current and predicted weather and fuels information, compare this information with historic weather and fuels records, and predict the upcoming fire season's severity and duration for any given area. It is important to incorporate drought indices into this assessment. Information from a seasonal risk analysis can be used to modify step-up and re-attack plans. It provides the basis for actions such as prepositioning critical resources, requesting additional funding, and modifying memoranda of understanding (MOUs) to meet anticipated needs.

Each AHJ selects and compares to normal the current value and seasonal trend of one or more of the following indicators that are most useful in predicting fire season severity and duration:

- (1) National Fire Danger Rating System (NFDRS) [or Canadian Forest Fire Danger Rating System (CFFDRS)] index values [Energy Release Component (ERC), Burning Index (BI)]
- (2) Temperature levels
- (3) Precipitation levels
- (4) Humidity levels
- (5) Palmer Drought or Standardized Precipitation Index
- (6) 1000-hour fuel moisture (timber fuels)
- (7) Vegetation moisture levels, live fuel moisture (brush fuels), and curing rate (grass fuels)
- (8) Episodic wind events (moisture drying days)

▲ **A.4.5** It is important to identify problems or potential problems. Identification of priority wildland fire mitigation should look at a number of variables, including ignition risks, fire hazards, and values.

Once risks, hazards, and values have been evaluated, it is possible to determine when, where, and how to implement fire mitigation programs. By comparing an area's potential to have an ignition (risks) with its potential to burn after ignition (hazards) and identifying the values threatened by a wildland fire, a fire prevention plan can be written. This plan can focus on the highest priority wildland fire problems within a given area. It is not necessary to have an extensive fire mitigation effort in an area where a number of risks exist but the hazard is minimal and no real values are threatened. In contrast, it is important to have a comprehensive effort in an area where there are substantial risks, a high hazard, and a threat to high values.

The wildland fire mitigation plan should address what needs to be done in each area based on the type of activities and uses. It should define what actions will take place and when, and who is responsible. Wildland fire mitigation activities fall into three broad categories:

- (1) *Education.* Education is aimed at changing people's behavior by informing them. People can be informed through printed materials, mass media (radio, television, etc.), one-on-one contacts, or group presentations. Information can also be delivered through signs, displays, fairs, parades, and so forth.
- (2) *Engineering.* Engineering is an activity designed to shield an ignition source (e.g., spark arrester) or remove the fuel that would ignite from a spark (e.g., clearance around a home).
- (3) *Enforcement.* Enforcement is used to gain compliance with fire codes and ordinances. The wildland fire mitigation plan should select the most cost-effective mix of activities to mitigate potential fire problems within each priority area. The wildland fire mitigation plan should be evaluated on an annual basis. If ignitions are occurring in an area where an active fire mitigation program is implemented, the fire mitigation activities should be reviewed. This review could result in a change of activities within the area. If the plan is working, there will be no need to make any changes.

**A.4.5.1.1** Examples of stakeholders include, but are not limited to, the following:

- (1) Neighboring fire organizations
- (2) Police organizations
- (3) Public works agencies
- (4) Service/support organizations
- (5) Public utilities
- (6) Medical/health facilities
- (7) Media and the general public
- (8) Dispatch/communications centers
- (9) Insurance companies
- (10) Local government stakeholders
- (11) Homeowner organizations
- (12) Environmental agencies and organizations
- (13) Planners, builders, and developers
- (14) Other special interest groups

These stakeholders could have plans or activities that should be integrated with the wildfire mitigation plan. Furthermore, the jurisdiction for which the AHJ is developing the mitigation plan might be required to develop a Community Wildfire Protection Plan (CWPP) as mandated by the federal Healthy Forests Restoration Act (P.L. 108-148). The guidelines for CWPPs require stakeholder coordination and should be followed in this case. Guidelines can be found at <http://www.safnet.org/policyandpress/cwpphandbook.pdf>.

▲ **A.4.5.5** Depending on the needs of the AHJ, an individual with qualifications as a public fire and life safety educator or as a public information officer might be suitable. NFPA 1035 provides information on qualifications for these types of positions.

▲ **A.4.5.8** In the pursuit of wildfire safety and mitigation, the AHJ will need to coordinate plans and activities with a wide variety of stakeholders. In this process, care should be taken to avoid conflicts with existing laws or local ordinances and to minimize the possibility of creating new hazards (fire and other) while mitigating identified wildfire hazards.

**A.4.6** Periodic review and revision of the mitigation plan will help to determine if activities are reaching the goals of reducing fire hazards and if priorities need to be shifted to meet changing conditions.

▲ **A.5.1.2(1)** Several model plans exist. Some state and federal agencies have standard elements for inclusion in such plans. *NFPA 1600* provides additional guidance to the AHJ for developing all-hazard preparedness plans and ensuring consistency with state and federal plans.

The AHJ should use the following as the basis for establishing new cooperative agreements and for reviewing existing cooperative agreements:

- (1) Cooperation in prevention, pre-incident, and suppression operations [see Figure A.5.1.2(1)(a) and Figure A.5.1.2(1)(b) for model agreement language]
- (2) Coordination in development and implementation of wildland fire management plans, protection standards, strategies, tactics, and procedures
- (3) Identification of parties responsible for implementing various aspects of the agreement
- (4) Existence of a command structure (see Chapter 6)
- (5) Communications capability
- (6) Minimum qualification requirements of personnel
- (7) Existence of an annual operating plan used to define and update specific operating procedures prior to each fire season

▲ **A.5.1.3.2(3)** *Equipment.*

*Hand Tools.* Tools needed will vary by sections of the country due to differences in fuels, soil, and topography. All equipment selected for fire management work should be maintained and used for the type of work for which it was designed. Many national standards and specifications are available to help fire department organizations purchase the proper equipment. Assistance in selecting appropriate tools can be obtained from federal, state, or provincial wildland fire-fighting agencies.

*Power Saws.* Power saws are an essential tool for fire suppression activities. Information on power saws can be secured from the manufacturers as well as from operators who have used the various makes and types. Because fire suppression can require carrying saws long distances over rough terrain, saw weight is an important consideration. Saws should be equipped with approved spark arresters to minimize the possibility of hot exhaust particles igniting nearby fuels. References for information on approved spark arresters for power saws can be found in Annex C.

*Tractor Plows and Dozers.* Tractor plows and dozers are valuable tools for wildland fire suppression [see Figure A.5.1.3.2(3)(a) and Figure A.5.1.3.2(3)(b)]. Most fire departments will not find it economical to own tractors or bulldozers, but they should evaluate the capabilities under existing conditions of terrain, fuels, and rates of fire spread. Heavy tractor equipment is available from construction and logging operators, whose names and telephone numbers should be included in the fire plan. Qualified supervision should be provided to monitor operation.

Any tractor plows or dozers used for wildland fire suppression should be equipped with protective canopies, winches, and adequate lights for operating at night. Unless turbo-charged, tractor plows or dozers should also be equipped with approved spark arresters. References for information on approved spark arresters for tractor plows and dozers can be found in Annex C.

**A.5.2** *Supplemental Fire Suppression and Cost-Share Agreement.* This agreement provides for a coordinated cooperative fire suppression operation on this fire and describes the cost divisions. This agreement is a supplement to the master agreement/contract among the agencies listed. See [http://www.nwcg.gov/teams/ibpwt/documents/cooprelations/master\\_coop\\_agreement\\_template.pdf](http://www.nwcg.gov/teams/ibpwt/documents/cooprelations/master_coop_agreement_template.pdf) for the full text of the master agreement template. (See Figure A.5.2.)

▲ **A.5.3** Fire fighting requires fast action, sustained effort, and greater energy than most other work. Fire fighting is hazardous. In the United States, fire fighting has one of the highest accident rates of any occupation. Safety procedures and principles must be practiced. Most accidents can be prevented by careful procedures and training before emergencies. The safety and welfare of the entire fire-fighting organization are the responsibility of the IC. All persons in authority are likewise responsible for the safety of the personnel under their direction.

▲ **A.5.3.1.2** During wildland fire management activities, protective clothing should include approved head protection, gloves, protective footwear, and flame-resistant clothing as defined in NFPA 1977.

Hard hats reduce the number of serious injuries and must be worn on the fireline. A safety hard hat with chin strap is preferred, but a standard fire fighter's helmet can be permitted to be worn as an alternative. Lightweight "bump" hats are unacceptable because they do not provide adequate protection in wildland fire management.

### SAMPLE FIRE DEPARTMENT MUTUAL AID AGREEMENT

WHEREAS, the governmental units of \_\_\_\_\_ have rendered mutual aid in fire services in the past and anticipate a continuing demand for such mutual aid and cooperation in the use of their fire personnel and equipment for the safety, health, and welfare of the people of their respective governmental units during times of emergency;

NOW THEREFORE, \_\_\_\_\_ does hereby agree that its fire department will render mutual aid to \_\_\_\_\_ under the following conditions:

- (1) In the event of any serious emergency, the parties to this agreement shall cooperate in an effort to provide fire services subject to the terms and conditions prescribed in this agreement.
- (2) The fire chief, the director of public safety, or commanding officer of the fire department of the parties to this agreement, or such other individual as the governing body of such governmental unit may from time to time designate by resolution, shall have the authority in the event of serious emergency to determine whether men and/or equipment shall be sent beyond the jurisdictional limits of the responding party. It is the intention of this agreement to vest in each party to this agreement the sole right to determine when its needs will permit it to respond to a call by the other unit of government, and it is further agreed by the parties thereto that if the fire department shall refrain from sending any personnel and/or equipment beyond its jurisdiction, that such unit thus failing to respond shall not be liable for damage to the party to this agreement.
- (3) The fire chief, director of public safety, or commanding officer of the department requesting mutual aid shall be in command of all units responding from other governmental units. All personnel and equipment of a responding unit shall be under the immediate command of the highest ranking officer attached to such responding units. All commands and orders for the use of such personnel and equipment shall be made for the commanding officer of the requesting department through the ranking officer of the units responding, whenever possible. The officer in charge of the department sending assistance shall, however, at all times have the power to recall to the responding department any personnel or equipment from an assistance mission.
- (4) Each governmental unit entering this agreement shall continue to provide the same salaries, compensation for death or disability, and retirement and furlough payments to their employees who are assigned to render assistance to another governmental unit in performance of this agreement as that employee would receive if on duty within the corporate limits of the governmental unit by which he or she is employed. (Cost of repairs and maintenance of equipment used or expended while rendering assistance under this agreement will be borne by the governmental unit owning the equipment.)
- (5) When a governmental unit responds with mutual aid, it should be understood that the responsibility of providing and/or requesting aid to protect the unprotected area is that of the responding unit.
- (6) Either party to this agreement shall be permitted at any time to withdraw from further participating in this agreement by giving 30 days prior written notice of termination to the other parties of this agreement.

In witness whereof, the parties sign and execute this agreement as of this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_\_.

NFPA 1143

**FIGURE A.5.1.2(1)(a) Sample Fire Department Aid Agreement.** (Source: Michigan Townships Association, [www.michigantownships.org](http://www.michigantownships.org))

## MODEL COOPERATIVE FIRE PROTECTION AGREEMENT

### Suggested Items for Consideration During Development

#### I. Title

#### II. Authorities

Reference applicable laws or higher level agreements.

#### III. Purpose/Recitals

Describe why agreement is necessary.

Describe who is involved.

Describe mutual benefit.

#### IV. Definitions

The key definitions in this section will standardize usage in the context of the agreement, thereby simplifying and improving communications. Include as appropriate key definitions such as the following:

**Reciprocal (Mutual Aid) Fire Protection:** Reciprocal initial attack zones for lands of intermingled or adjoining protection responsibility can be established. Within such zones a supporting party will, upon request or voluntarily, take initial attack action in support of the protecting party as they are in a position to provide. The protecting party will not be required to reimburse the supporting party for costs incurred. The reciprocal assistance period, defined in Annual Operating Plans, does not usually exceed 24 hours.

**Reimbursable (Cooperative) Fire Protection:** The protecting party can request fire suppression resources from supporting parties, per conditions set in the agreement, (and Annual Operating Plans). Such resources are to be paid for by the protecting party.

**Offset (Exchange) Fire Protection:** The parties are permitted to exchange responsibility for fire protection for lands under their jurisdiction. The rate of exchange will be based upon comparable cost, acreage involved, complexity, and other factors as might be appropriate and mutually agreed to by the parties. The exchange zones are often documented in Annual Operating Plans. The goal is to gain an equal exchange that provides greater overall fire protection.

**Fee Basis (Contract) Fire Protection:** For an agreed upon fee, one party is permitted to assume fire protection responsibilities on lands under the jurisdiction of another. The terms and conditions of such arrangements are generally outlined in a contract agreement.

**Annual Operating Plan:** An annually updated document that outlines operational procedures in support of a multi-year Cooperative Fire Protection Agreement. Annual Operating Plans are normally developed locally, and must be authorized by appropriate officials.

#### V. Interagency Cooperation

Identify sources of oversight and direction as needed to cover specific actions. Require local Annual Operating Plans. Enable and direct cooperative efforts, such as the following:

- (1) Area coordinating group
- (2) Local cooperative initiatives
- (3) Joint projects and local agreements
- (4) Incident command system
- (5) Interagency dispatch centers/service centers
- (6) Multi-agency coordination (MAC) groups
- (7) Fire prevention
- (8) Prescribed fire and fuels management
- (9) Licensing training
- (10) Communication systems
- (11) Weather data processing system
- (12) Automatic weather stations
- (13) Aviation operations
- (14) Joint facilities
- (15) Inmate use
- (16) Military resources

#### VI. Fire Protection

Define jurisdictional responsibilities and limitations. Include protection area and boundaries. Methods of fire protection assistance pursuant to agreement, as follows:

- (1) Reciprocal
- (2) Reimbursable
- (3) Offset
- (4) Fee basis or contract

#### VII. Fire Suppression

- (1) Closest forces concept
- (2) Shared resources
- (3) Joint resources
- (4) Fire notifications
- (5) Protection priorities

NFPA 1143 (p. 1 of 2)

FIGURE A.5.1.2(1)(b) Model Cooperative Fire Protection Agreement. (Source: National Wildland/Urban Interface Fire Program)



## MODEL COOPERATIVE FIRE PROTECTION AGREEMENT (*continued*)

- (6) Boundary fires
- (7) Independent action on lands protected by another agency
- (8) Applicable suppression response policies
- (9) Escaped fire situation analysis (EFSA)
- (10) Determination of cause and preservation of evidence
- (11) Fire reports and documentation
- (12) Post-fire analysis
- (13) Law enforcement actions
- (14) Fire disasters and relief

### VIII. Reimbursements

Appropriated fund limitation: "Nothing herein shall be interpreted as obligating the parties to this agreement to expend funds, or as involving them in any contract or other obligation for the future payment of money in excess of appropriations authorized by law and administratively allocated for the work contemplated in this Agreement."

- (1) Specific reimbursable services and procedures
- (2) Cost sharing (for incidents affecting more than one agency)
- (3) Procurement
- (4) Billing procedures

### IX. General Provisions

- (1) Duration of emergency assignments
- (2) Loaned equipment
- (3) Mutual sharing of information
- (4) Local cooperation (levels in terms of geographical authority)
- (5) Accident investigations
- (6) Nonwildland fire and medical aid responses
- (7) Previous agreements (replacement intentions)
- (8) Employment policy
- (9) Suppression and damage collection
- (10) Waiver of claims (liability responsibility to remain with employing party)
- (11) Third-party claims (liability to third parties)
- (12) Officials not to benefit ("No member of, or delegate to Congress or Resident Commissioner shall be admitted to any share or part of this Agreement or to any benefit to arise therefrom, unless it is made with a corporation for its general benefit.")
- (13) Amendments procedures
- (14) Examination and audit (specific auditable agreement provisions)
- (15) Civil rights
- (16) Duration of agreement (number of years or indefinite; describe termination progress)

NFPA 1143 (p. 2 of 2)

FIGURE A.5.1.2(1)(b) *Continued*

Footwear should be leather lace-up boots. It is recommended that boots be without steel toes except for those used by chain saw operators as required by the AHJ. The boots should have slip-resistant soles, such as a hard rubber lug-type or tractor tread, which allows for maximum traction and prevents melting when exposed to normal fireline conditions. Soles should not be made of composition rubber or plastic, which have low melting points. This does not preclude the use of boots with smooth, hard rubber soles or those with a well-defined tread. However, the disadvantage of those soles is their tendency to slip on smooth rocks, logs, dry grass, and pine needles, surfaces that are often encountered in wildland fires. The height of the boot tops should be a minimum of 8 in. (20.32 cm). Low-quarter boots or shoes should not be worn because they do not provide ankle support, keep out sparks and dirt, or protect from stubs and other foreign objects. Pull on-type boots, such as structural fire-fighting rubber boots, cowboy boots, or engineering boots, are not recommended because they do not provide adequate ankle support and protection, do not keep out sparks and dirt, and are loose-fitting and can cause blisters.



FIGURE A.5.1.3.2(3)(a) A Dozer Equipped with Protective Canopy, Lights, Brush Guards, and a Winch.



**FIGURE A.5.1.3.2(3)(b) Tractor Plows Being Used in Suitable Terrain to Build Firelines.** (Source: Florida Division of Forestry)

Fire shelters should be worn only by individuals trained in their use but should be available for use by all fire fighters during suppression activities. Flame-resistant clothing designed for wildland fire fighting should be worn. Loose-fitting clothing reduces chafing and affords more protection. Collars and cuffs should be buttoned to protect the arms and neck from heat, burns, scratches, and insects. Gloves should be worn to protect hands. Fire fighters should wear goggles for eye protection in smoky or dusty environments.

▲ **A.5.4** All personnel should receive initial and refresher training in first aid, fireline safety, fire behavior, and techniques and methods of wildland fire suppression. Hands-on training with hand tools and equipment, as well as crew and fireline organization, should be included. Crew leaders and company officers need specialized training in fire management tactics to ensure their competence when directing fire suppression operations. It is recommended that cooperative training with other wildland fire management agencies and organizations be conducted. Federal, state, and provincial forest fire officers have technical training materials and are available to assist.

Many agencies and organizations have established programs to provide training in structural fire fighting. Training in wildland fire tactics and techniques can be obtained from state, provincial, or federal wildland fire protection agencies, which conduct special fire schools, seminars, and other forms of instruction. A number of publications dealing with wildland fire management are available from state forestry offices or from the National Wildfire Coordinating Group (NWCG). (See Annex C.)

▲ **A.5.4.2** The safety and welfare of personnel are the first and foremost considerations in all incident operations and decisions. The following references provide basic knowledge of fire suppression safety standards and procedures:

- (1) Fire behavior: NWCG S-190, *Introduction to Fire Behavior*.
- (2) Ten standard fire orders: NWCG-NFES 001077, *Incident Response Pocket Guide*. These fire orders are as follows:
  - (a) Keep informed on fire weather conditions and forecasts.

- (b) Know what your fire is doing at all times.
  - (c) Base all actions on current and expected behavior of the fire.
  - (d) Identify escape routes and make them known.
  - (e) Post lookouts when there is possible danger.
  - (f) Be alert. Keep calm. Think clearly. Act decisively.
  - (g) Maintain prompt communications with your forces, your supervisor, and adjoining forces.
  - (h) Give clear instructions and ensure they are understood.
  - (i) Maintain control of your forces at all times.
  - (j) Fight the fire aggressively, having provided for safety first.
- (3) Eighteen “watch out” situations: NWCG-NFES 001077, *Incident Response Pocket Guide*. These situations are as follows:
  - (a) Fire not scouted and sized up
  - (b) In country not seen in daylight
  - (c) Safety zones and escape routes not identified
  - (d) Unfamiliar with weather and local factors influencing fire behavior
  - (e) Uninformed on strategy, tactics, and hazards
  - (f) Instructions and assignments not clear
  - (g) No communication link between crew members and supervisor
  - (h) Constructing line without safe anchor point
  - (i) Building line downhill with fire below
  - (j) Attempting frontal assault on fire
  - (k) Unburned fuel between you and the fire
  - (l) Cannot see main fire and not in contact with anyone who can
  - (m) On a hillside where rolling material can ignite fuel below
  - (n) Weather becoming hotter and drier
  - (o) Wind increasing and/or changing direction
  - (p) Getting frequent spot fires across line
  - (q) Terrain or fuels making escape to safety zones difficult
  - (r) Feeling like taking a nap near the fireline
- (4) Four major common denominators of fire behavior on fatal and near-fatal fires, as outlined in NWCG-NFES 2225, *Common Denominators of Fire Behavior on Tragedy and Near-Miss Forest Fires*, are as follows:
  - (a) On relatively small fires or deceptively quiet areas of large fires
  - (b) In relatively light fuels, such as grass, herbs, and light brush
  - (c) When there is an unexpected shift in wind direction or in wind speed
  - (d) When fire responds to topographic conditions and runs uphill

Alignment of topography and wind during the burning period should always be considered a trigger point to re-evaluate strategy and tactics.
- (5) Downhill indirect line construction guidelines: NWCG-NFES 001077, *Incident Response Pocket Guide*.



## SUPPLEMENTAL FIRE SUPPRESSION AND COST-SHARE AGREEMENT

### Exhibit F

The purpose of this agreement is to provide for a coordinated cooperative fire suppression operation on this fire and to describe the cost divisions. This agreement is a supplement to the Master Cooperative Wildland Fire Management Agreement or \_\_\_\_\_ (list other agreement and number) between the agencies listed.

(1) Fire name \_\_\_\_\_ Origin date \_\_\_\_\_ Time \_\_\_\_\_

(2) Origin: Township \_\_\_\_\_ Range \_\_\_\_\_ Section \_\_\_\_\_

(3) Estimated size \_\_\_\_\_ acres at the time of this agreement.

(4) Agency \_\_\_\_\_ Fire # \_\_\_\_\_ Accounting code \_\_\_\_\_

Agency \_\_\_\_\_ Fire # \_\_\_\_\_ Accounting code \_\_\_\_\_

Agency \_\_\_\_\_ Fire # \_\_\_\_\_ Accounting code \_\_\_\_\_

Agency \_\_\_\_\_ Fire # \_\_\_\_\_ Accounting code \_\_\_\_\_

Agency \_\_\_\_\_ Fire # \_\_\_\_\_ Accounting code \_\_\_\_\_

(5) This agreement becomes effective on: \_\_\_\_\_

at \_\_\_\_\_ and remains in effect until amended or terminated.

(6) Overall direction of this incident will be by ( ) Unified Command, or by ( ) Single Command structure. Identify below personnel filling the following positions:

Position	Name(s)	Agency
Incident Commander	_____	_____
Agency Administrator	_____	_____
Representative	_____	_____
Liaison	_____	_____
Finance	_____	_____
Operations	_____	_____

(7) Suppression action will be subject to the following special conditions and land management considerations:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

(8) Geographic responsibility (if appropriate) by agency is defined as follows:

Agency \_\_\_\_\_ Geographic responsibility \_\_\_\_\_

Agency \_\_\_\_\_ Geographic responsibility \_\_\_\_\_

Agency \_\_\_\_\_ Geographic responsibility \_\_\_\_\_

Agency \_\_\_\_\_ Geographic responsibility \_\_\_\_\_

NFPA 1143 (p. 1 of 2)

**FIGURE A.5.2 Sample Supplemental Fire Suppression and Cost-Share Agreement.** (Source: Master Cooperative Wildland Fire Management and Stafford Act Response Agreement, National Wildfire Coordinating Group, 2007)

### SUPPLEMENTAL FIRE SUPPRESSION AND COST-SHARE AGREEMENT *(continued)*

(9) The agency responsible for structural protection will be \_\_\_\_\_

(10) Special operational conditions agreed to (include as appropriate air operations, base camp, food service, fire investigation, security, etc.). List cost share information in Item #11.

(11) Fire suppression COSTS will be divided between agencies as described:

Cost Centers	Agency	Agency	Agency
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

(12) Other conditions relative to this agreement (notifications, incident information, etc.) \_\_\_\_\_

(13)

_____	_____	_____	_____
Agency	Agency	Agency	Agency
_____	_____	_____	_____
Signature	Signature	Signature	Signature
_____	_____	_____	_____
Title/Date	Title/Date	Title/Date	Title/Date

List of attachments (if any): \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

NFPA 1143 (p. 2 of 2)

**FIGURE A.5.2** *Continued*

- (6) LCES (lookouts, communications, escape routes, and safety zones): LCES Course, NWCG-S-134, *Lookouts, Communications, Escape Routes and Safety Zones (LCES)*. LCES include the following:
  - (a) Adequate lookouts posted to observe potential changes in fuel, weather, topography, and fire behavior
  - (b) Communication provided for and maintained with the supervisor at all times
  - (c) Escape routes for emergency evacuation identified and clearly understood by all fire fighters
  - (d) Safety zones in cleared or natural areas devoid of flammable material reconnoitered and/or provided for and known to all crew members
- (7) The ten Wildland/Urban Interface Fire “Watch Out Situations”: NWCG-NFES 001077, *Incident Response Pocket Guide*. These situations are as follows:
  - (a) Poor access and narrow congested one-way roads
  - (b) Bridge load limits
  - (c) Wooden construction and wood shake roofs
  - (d) Power lines, propane tanks, and HazMat threats
  - (e) Inadequate water supply
  - (f) Natural fuels closer than 30 ft (9 m) to structures
  - (g) Structures in chimneys, box or narrow canyons, or on steep slopes (30 percent or greater)
  - (h) Extreme fire behavior
  - (i) Strong winds
  - (j) Evacuation of public (panic)

▲ **A.5.4.3 Fixed-Wing Aircraft.** The use of fire retardants dropped from aircraft is a modern, sophisticated attack tool in wildland fire management [see Figure A.5.4.3(a)]. It is probable that members of fire departments will become involved in the use of airtankers; therefore, they should be cognizant of the safety rules regarding airtanker operations.

Ground forces should be warned when drops will be made in their area. Often the airtanker pilot will make a dry run or high pass over the portion of the fire where the drop will be made. This indicates that the drop will be made within 1 to 3 minutes. If drops have already been made in the area, there usually will be no dry runs.

A fire fighter who is unable to retreat to a safe place when an airdrop is imminent should observe the following safety procedures:

- (1) Lie face down with head toward oncoming aircraft and hard hat in place. If possible, grab something solid and get behind it to prevent being carried or rolled about by the drop. Spread feet apart for better body stability and to assist digging in.
- (2) Hold tools out to the side and away from the body. Flying tools or equipment can cause injury.
- (3) Do not run unless escape is assured. Never stand up in the path of an airdrop.
- (4) Stay away from large old trees and snags. Tops, limbs, or entire trees could break and fall, causing injury.

After the retardant drop has been made, there is a follow-up advantage on the fire. However, the following factors should be considered after the drop:

- (1) Most retardants are slippery; therefore, be careful of footing and wipe off all hand tools, in particular the handles.
- (2) Heavy application of retardant on surfaced roads can be hazardous and should be washed down as soon as possible.
- (3) Retardant should be washed from equipment and structures as soon as possible to prevent damage to finishes.
- (4) Retardant could also damage agricultural or ornamental vegetation; actions should be taken to minimize such damage.

*Rotary Wing Aircraft (Helicopters).* The use of helicopters has become a key part of wildland fire protection [see Figure A.5.4.3(b) and Figure A.5.4.3(c)]. As with any other piece of fire-fighting equipment, definitive safety rules should be followed when using or operating equipment near a helicopter. The following safety procedures apply to helicopter operations:

- (1) Approach and departure
  - (a) Get the pilot's attention and permission before approaching the helicopter.
  - (b) Always approach in full view of the pilot. Never approach from the rear of the helicopter.
  - (c) Always approach or depart in a crouched position. Gusts of wind can cause the rotor blades to drop low to the ground.
  - (d) Safety helmets should be held to prevent their being blown away or blown up into the rotors by the rotor blast.
  - (e) Never approach or depart from a helicopter from or to ground that is upslope from the main rotor. Rotors are almost invisible when turning at high speed or under poor lighting conditions.
  - (f) Keep clear of the main and tail rotors at all times. Do not walk to the rear of the helicopter when entering or exiting the helicopter.
  - (g) Carry all long-handled tools in such a manner that the handles will not be raised into the rotor path.
- (2) Working around heliports
  - (a) Stay at least 100 ft (30 m) from helicopters at all times unless you have a specific job that requires otherwise. Your presence can cause confusion and disrupt the pilot's concentration.
  - (b) Do not face a landing helicopter unless you are wearing goggles.
  - (c) Do not remain in an area that is under the flight path of any helicopter.
  - (d) Do not smoke within 50 ft (15 m) of any helicopter or fueling area.
- (3) In-flight safety
  - (a) Do not smoke in the helicopter.
  - (b) Use the seat belt and keep it secured until the pilot instructs you to leave the helicopter.

- (c) Ensure that all loose gear and helmets, maps, papers, and so forth, are held to prevent their being blown about the helicopter or out the windows.
- (d) Do not let any gear get in the way of the pilot or the pilot's controls.
- (e) Never throw anything out of a helicopter.
- (f) Do not talk to the pilot, unless necessary, during takeoff and landing.
- (g) Be alert for hazards such as other aircraft and telephone and power lines.
- (h) Never slam the doors of a helicopter. The doors do not have spring-loaded locks, so the handles must be physically turned to close the door.

**Δ A.6.1** To provide fire prevention and control and to protect life and property from wildland fire, a community should establish the following:

- (1) **A** designated formal organization headed by a fire chief or fire warden charged with the responsibility of prevention and suppression of wildland fires. The chief would be in charge of the entire departmental operation. The chief should be appointed by the governing body, if one exists, or elected by the membership on the basis of merit and ability. The chief can be a paid professional, a part-time paid employee, or a volunteer.
- (2) A well-organized, equipped, and trained fire company or crew who will operate under the authority of the chief, fire warden, or subordinate officer. If attacked at once, most small wildland fires can be handled by a well-trained squad or company of two to five fire fighters. Large or fast moving fires require more fire fighters, more equipment, expert supervision, and extensive radio and telephone communications.
- (3) Three or four small companies or squads of five or six fire fighters, with leaders, can be grouped together under the command of a crew leader or company officer. The leader can be one of several crew leaders commanding similar groups. All personnel under the leader's command, as well as others concerned with incident management, should know who the crew leader is and the scope of the leader's authority. The crews or companies can be assigned to action only on a designated portion of the main fire. This designated portion of the fire is called a *sector* or *division*.



**FIGURE A.5.4.3(a)** An Airtanker Making a Drop of Fire Retardant on a Wildland Fire.



**FIGURE A.5.4.3(b)** A Helicopter Using a Bucket to Make a Water Drop on a Wildland Fire.



**FIGURE A.5.4.3(c)** Heavy-Lift Helicopter Making a Water Drop on a Wildland Fire. (Source: Erickson Air-Crane)

**A.6.2** On a small incident, one person can handle all of the functions in Section 6.2.

▲ **A.6.2.1** The first responsible authority (ranger, warden, company officer, crew leader, or other officer) who arrives at the emergency is the incident commander (IC) until someone with higher authority assumes command. Whenever a new IC assumes command, all officers, crew leaders, and others involved in the incident should be notified. The IC is responsible for planning and directing the fire management efforts; assembling crews of fire companies and telling them where and how to work; making the best use of personnel; arranging for communications, rest periods, and relief crews; making the best use of equipment and tools; obtaining supplies; and ensuring that the fire is extinguished before the last crews are released from the scene. In other words, the IC is responsible for all activities and operations at an emergency incident. The IC delegates more and more responsibility to assistants as the needed organizational effort grows, but the IC is always the final authority and bears total operational responsibility.

**A.6.2.1.1** The responsibilities listed might not be necessary at all incidents. This listing of responsibilities is not in any particular order.

**A.6.2.1.2(1)** The IC should provide for public information, safety, and liaison functions in which each function should be filled as needed depending on the size and complexity of the incident. Command staff functions should include those elements of the IMS that operate in direct support of the IC and contribute to the overall management of the incident.

**A.6.2.1.2(6)** A Delegation of Authority is the formal process authorizing the IC to act on behalf of the AHJ. See Figure A.6.2.1.2(6).

▲ **A.6.2.2** The IMS should include command staff functions that are activated upon escalation of an incident or with multiple alarms. Specific individuals should be designated to respond and assume command staff duties.

• **A.6.2.2.2.2** These are personnel other than those on direct tactical assignments or those involved in a unified command.

**A.6.2.2.3.2** This can be accomplished by wearing a reflective vest, helmet, or other indicator.

**A.6.2.3.2.2(5)** The planning function should include the development of alternative strategies. The IAP should include, as appropriate, a safety plan (from the safety officer), an incident traffic plan (from ground support), a communications plan (from the communications unit), and other supporting plans.

**A.6.2.3.3.2** Logistics should provide services and support systems to all the organizational components involved in the incident, including facilities, transportation, supplies, equipment maintenance, fueling, feeding, communications, and medical services for incident-assigned personnel. The logistics function is vital to the proper management of organizations involved in wildland fire management. Resource determinations need to be made before, during, and following wildland fire incidents. For many fire protection organizations, existing resources need to be reappplied only to meet wildland fire management requirements.

**A.6.2.3.3.2(2)(b)** If the IC or logistics section chief determines the need for facilities, the following items should be considered:

- (1) Location for appropriate facilities
- (2) Evaluation of the physical facilities and usable space required to meet pre-incident planning objectives
- (3) Identification of locations for apparatus storage, equipment and personnel staging, base camp operations, lodging of personnel, and support services sites

The establishment of appropriate facilities and usable space locations is an important aspect of the logistics function. Elements that should be considered when determining strategic locations include probable wildland fire locations, other emergency services available, adequacy of public roads and utilities, scope of communications networks, and extent of outside assistance required. A general checklist for facilities includes the following items:

- (1) Keep incident facilities at a manageable size.
- (2) Enforce rules of conduct at facilities.
- (3) Provide a bulletin board at an assembly area.
- (4) Maintain proper accountability of all property.
- (5) With safety in mind, locate a sleeping area.
- (6) Participate in the development of a demobilization plan.
- (7) Control dust when needed.
- (8) Consider environmental protection when locating incident facilities.
- (9) Keep first aid facilities accessible and well marked.
- (10) Inspect facilities for safety and fire hazards and take corrective action when needed.
- (11) Consider and supply computer support when needed.
- (12) Have well-marked parking areas.
- (13) Keep facilities clean.
- (14) Locate shaded eating areas.

▲ **A.6.2.3.3.2(2)(c)** The IC or logistics section chief determines the need for various kinds of ground support. The logistics pre-incident plan should identify necessary support services, including personnel, equipment, and supplies, that facilitate continual operations throughout the incident. These can include the following:

*General Ground Support.* The ground support checklist should include the following:

- (1) Provide direction signs on roads to facilities and drop points that are included in the traffic plan.
- (2) Place signs at incident facilities and drop points.
- (3) Plan adequate rest for drivers.
- (4) Isolate and place signs at fuel storage area.
- (5) Develop and enforce vehicle control plan.
- (6) Plan for transportation for both personnel and equipment to and from incident camp to actual incident.
- (7) Provide maintenance and fueling according to schedule.
- (8) Inspect equipment condition.
- (9) Maintain all equipment records.
- (10) Provide transportation and support vehicles.

*Emergency Medical Support.* The logistics function should determine the required level of emergency medical support and identify available resources. During incidents, appropriate emergency medical support, including transportation capabilities, should be made at the incident locations.



## DELEGATION OF AUTHORITY

### Colorado State Office Montrose Field Office

As of 1800, May 20, 2005, I have delegated authority to manage the Crystal River Fire, Number E353, San Juan Resource Area, to Incident Commander Bill Jones and his Incident Management Team.

The fire, which originated as four separate lightning strikes occurring on May 17, 2005, is burning in the Crystal River Drainage. My considerations for management of this fire are the following:

- (1) Provide for fire fighter and public safety.
- (2) Manage the fire with as little environmental damage as possible. The guide to minimum impact suppression tactics (MIST) is attached.
- (3) Key cultural features requiring priority protection are Escalante Cabin, and overlook boardwalks along the south rim.
- (4) Key resources considerations are protecting endangered species by avoiding retardant and foams from entering the stream; if the ponderosa pine timber sale is threatened, conduct a low intensity under burn and clear fuels along road 312.
- (5) Restrictions for suppression actions include no tracked vehicles on slopes greater than 20 percent on meadow soils, except where roads exist and are identified for use. No retardant will be used within 100 ft of water.
- (6) Minimum tools for use are Type 2/3 helicopters, chainsaws, hand tools, and portable pumps.
- (7) My agency Resource Advisor will be Eric Johnson (wildlife biologist).
- (8) The NE flank of the fire borders private property and must be protected if threatened. John Dennison of the Big Pine Fire Department will be the local representative.
- (9) Manage the fire cost-effectively for the values at risk.
- (10) Provide training opportunities for the resources area personnel to strengthen our organizational capabilities.
- (11) Minimum disruption of residential access to private property, and visitor use consistent with public safety.

\_\_\_\_\_  
(Signature and Title of Agency Administrator)

\_\_\_\_\_  
(Date)

#### Amendment to Delegation of Authority

The Delegation of Authority dated May 20, 2005, issued to Incident Commander Bill Jones for the management of the Crystal River Fire, number E353, is hereby amended as follows. This will be effective at 1800, May 22, 2005.

- (3) Key cultural features requiring priority protection are: Escalante Cabin, overlook boardwalks along the south rim, and the Ute Mountain study site.
- (12) Use of tracked vehicles authorized to protect Escalante Cabin.

\_\_\_\_\_  
(Signature and Title of Agency Administrator)

\_\_\_\_\_  
(Date)

NFPA 1143

**FIGURE A.6.2.1.2(6) Sample Delegation of Authority.** (Source: USDA Forest Service)



*Food Services Support.* The logistics function should determine the required level of food services support and identify available resources. Applicable health standards should be reviewed and placed in perspective with the size and complexity of anticipated incident activity. Pre-incident plans should include identification of providers and probable location sites and include available utilities, tentative operation schedules, and contract prices. The food service checklist should include the following:

- (1) Sanitation requirements (i.e., state, local, and OSHA) should be met.
- (2) Food service sanitation requirements should be met.
- (3) Food handlers should keep hands clean and should avoid handling food without wearing proper clothing and gloves.
- (4) Food handlers should be free of communicable disease.
- (5) Perishable foods should be stored under refrigeration at 40°F (4°C) or lower until served.
- (6) Hot foods should be kept at 150°F (66°C) or higher until served.
- (7) Reusable food utensils should be cleaned and immersed for 2 minutes in at least 170°F (77°C) water.
- (8) First aid material and first aid treatment should not be in kitchen or serving areas.
- (9) Recycling should be considered.

*Sanitation Services Support.* The logistics function should determine the required level of sanitation services, including resources for ample toilets, with cleaning, inspection, and maintenance schedules; trash and garbage collection and removal to approved sites; and ample replacement of consumable supplies. The sanitation checklist should include the following:

- (1) Provide adequate toilet facilities and establish a regular inspection and maintenance schedule to keep them clean.
- (2) Provide trash and garbage collection points and daily removal.
- (3) Locate garbage or trash collection points downwind of sleeping or eating areas.

*Water Supply.* The logistics function should determine the requirements for potable water and identify sources and a system of water distribution. The water supply checklist should include the following:

- (1) Use a safe local water supply or haul it from a domestic water supply in trucks approved for potable water only.
- (2) Have the water tested and protect it from contamination.

*Security.* The logistics function should determine and provide for security for personnel and equipment.

- Δ **A.6.2.3.3.2(2)(d)** The IC or logistics section chief determines the need for a communications function, which can include resources such as various radio networks (fixed and portable); landline and cellular telephones; pagers, scanners, and other audible alert equipment; and computer, data, and fax capabilities.

Communications needs can also include radio system needs, including frequency allocation, availability, and compatibility of equipment between responding agencies, transmission and security priorities and procedures, and equipment assignment and accountability.

The communications element of the logistics function is vital to personnel safety and organizational effectiveness when wildland fires occur. A functional communications network provides rapid notification of wildland fire emergencies, alerting of organizational units, notification of the general public of incident status and/or evacuation needs, and uninhibited communication with key cooperators and other outside agencies.

A communications system by which fires and emergencies can be reported to the fire organization is essential. There must be telephone communications to some central location that serves as a dispatch center. An emergency telephone number, publicized in the response area and published in the local telephone company directory (e.g., 9-1-1), must be established.

- **A.7.2** The threat to the lives of fire fighters and the public is always the highest priority, and the IC's fire attack decision should be based on safety as the top priority. For low-intensity fires, consideration should be given to direct tactics. For high-intensity fires with unpredictable fire behavior or difficult terrain, considerations should be given to initiating established protective actions and indirect tactics.

- Δ **A.7.2.1\*** Several types of wildland fire-fighting chemicals are used in wildland fire management. Each chemical product has specific requirements for mixing, handling, and applying. Most suppliers are willing to provide the necessary expertise and/or training for working with their product. Wildland fire chemicals can be applied to a fire by fixed-wing airtankers, including single-engine airtankers (SEATS), helicopters with buckets or fixed tanks, fire engines, portable pumps, or back pumps.

The types of wildland fire-fighting chemicals are as follows:

*Long-Term Retardants.* Long-term retardants contain salts (phosphate fertilizers) that alter the way the fire burns, decreasing the fire intensity and slowing the advance of the fire, even after the water has evaporated. The water aids in uniform dispersal of the chemical over the target area. Long-term retardants continue to work until they are removed by water application, rain, or erosion.

Long-term retardants are used with direct or indirect tactics. They can also be used to protect structures and forest fuels adjacent to a fireline, to aid in prescribed burning and backfiring, and to aid in mop-up.

*Class A Foams.* The foam solution is a homogeneous mixture of water and a foam concentrate. An aerated solution is created by forcing or entraining air into a foam solution by means of specialized equipment or by cascading it through the air at a high velocity.

Foam fire suppressants contain foaming and wetting agents. The foaming agents affect the accuracy of an aerial drop, how fast the water drains from the foam, and how well the products cling to the fuel surfaces. The wetting agents increase the ability of the drained water to penetrate fuels. The selection of concentrate dilution (between 0.1 and 1.0 percent by volume) and application equipment will yield a range of products with different uses, as shown in the following:

- (1) Foam solutions and very sloppy foam with little bubble structure for mop-up where the wetting agent increases penetration of the water into the fuel and char

- (2) Fluid foam for wet line and reducing the runoff of the applied water
- (3) Dry foam for insulating blankets and exposure protection

The fire suppression and protection effectiveness of Class A foams depends on their capability to retain moisture. As the water evaporates, so does the fire suppression capability of suppressing fire. Under optimum conditions, suppressants remain effective from a few minutes to 1 hour.

Foams can be used as part of direct tactics in support of on-the-line fire crews or for short-term protection of structures (e.g., decks, outbuildings) and forest fuels adjacent to a fire-line, as well as in prescribed burning, backfiring, and mop-up. For more information on Class A foams and their application in structure fire fighting, refer to NFPA 1150 and NFPA 1145.

*Water Enhancers (Gels).* Water enhancers, often referred to as gels, alter the physical characteristics of water in increased effectiveness, accuracy of aerial drops, and adhesion to fuels (by clinging to vertical and smooth surfaces). The fire suppression or protection effectiveness for water enhancers depends on the amount and characteristics of the water they contain.

Water enhancers are mixed with water at low concentrations (less than 3 percent). When mixing most of the water enhancers, the amount of concentrate required to obtain a desired consistency is dependent on the hardness of the water used. Specialized mixing and blending equipment might be required, and cleanup is more difficult than with foams. Gel products are not compatible with each other. Gels contain thickeners but might not contain wetting agents. Because of the incompatibility of the products with salts, including those in retardants, thorough cleanup is necessary when first changing to gels. Always follow the manufacturer's recommendations for preparation, mixing, application, and cleanup.

Water enhancers can be used in direct tactics.

**A.8.1** The reporting of fires is an important function of the AHJ. Fire reports provide a realistic and factual basis for fire prevention planning, support for funding requests, and aid in organizational development. The reports can be significant documents during investigations and in insurance claims adjustment cases. A report must be completed on every fire or false alarm responded to by the fire department. It is important that information be compiled while it is fresh in the reporting officer's mind. The U.S. Fire Administration (USFA), in conjunction with the National Fire Information Council (NFIC), has developed the National Fire Incident Reporting System (NFIRS), which includes several modules that provide information specific to wildland fire incidents. At the state level, NFIRS provides for the collection of reports on incidents to which local communities responded. NFIRS uses the local databases from individual states to form the national database. The USFA analyzes this database and publishes the analysis. Current forms are available from the following web site: [www.nfirs.fema.gov](http://www.nfirs.fema.gov). The basic form, NFIRS-1 [see Figure A.8.1(a)], captures data relevant to fire location (B), incident type (C), dates and times (E1), actions taken (F), resources (G1), estimated dollar losses and values (G2), and completed modules (e.g., NFIRS-8, Wildland Fire). NFIRS-8 [see Figure A.8.1(b)] focuses on wildland fire and provides in-depth information about, among other things, the cause of the fire (D1), human factors contributing to ignition (D2), the weather (H), and National Fire Danger Rating System (NFDRS) fuel model at origin (K). Although field forms can assist in information gathering, the NFIRS system is a computer-based program developed to reduce recordkeeping time and improve output reporting capability. The AHJ should complete and file incident reports as required.

<b>A</b> FDID <input type="text"/> State <input type="text"/> Incident Date <input type="text"/> Station <input type="text"/> Incident Number <input type="text"/> Exposure <input type="text"/> <div style="float: right;"> <input type="checkbox"/> Delete  <input type="checkbox"/> Change  <input type="checkbox"/> No Activity         </div>		<b>NFIRS-1 Basic</b>	
<b>B Location Type</b> <input type="checkbox"/> Check this box to indicate that the address for this incident is provided on the Wildland Fire Module in Section B, "Alternative Location Specification." Use only for wildland fires. <div style="display: flex; justify-content: space-between;"> <div style="width: 60%;"> <input type="checkbox"/> Street address  <input type="checkbox"/> Intersection  <input type="checkbox"/> In front of  <input type="checkbox"/> Rear of  <input type="checkbox"/> Adjacent to  <input type="checkbox"/> Directions  <input type="checkbox"/> US National Grid         </div> <div style="width: 35%;">           Census Tract <input type="text"/> - <input type="text"/>            Number/Milepost <input type="text"/> Prefix <input type="text"/> Street or Highway <input type="text"/>            Street Type <input type="text"/> Suffix <input type="text"/>            Apt./Suite/Room <input type="text"/> City <input type="text"/> State <input type="text"/> ZIP Code <input type="text"/>            Cross Street, Directions or National Grid, as applicable         </div> </div>			
<b>C Incident Type</b> <input type="text"/> Incident Type <input type="text"/>		<b>E1 Dates and Times</b> Midnight is 0000 Month <input type="text"/> Day <input type="text"/> Year <input type="text"/> Hour <input type="text"/> Min <input type="text"/> <input type="checkbox"/> Check boxes if dates are the same as Alarm Date. <b>Alarm</b> <input type="checkbox"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> ARRIVAL required, unless canceled or did not arrive <b>Arrival</b> <input type="checkbox"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> CONTROLLED optional, except for wildland fires <b>Controlled</b> <input type="checkbox"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> LAST UNIT CLEARED, required except for wildland fires <b>Last Unit Cleared</b> <input type="checkbox"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/>	
<b>D Aid Given or Received</b> <input type="checkbox"/> None 1 <input type="checkbox"/> Mutual aid received 2 <input type="checkbox"/> Auto. aid received 3 <input type="checkbox"/> Mutual aid given 4 <input type="checkbox"/> Auto. aid given 5 <input type="checkbox"/> Other aid given <div style="border: 1px solid black; padding: 5px; margin-top: 10px;">             Their FDID <input type="text"/> Their State <input type="text"/>              Their Incident Number <input type="text"/> </div>		<b>E2 Shifts and Alarms</b> Local Option Shift or Platoon <input type="text"/> Alarms <input type="text"/> District <input type="text"/> <b>E3 Special Studies</b> Local Option Special Study ID# <input type="text"/> Special Study Value <input type="text"/>	
<b>F Actions Taken</b> <input type="text"/> Primary Action Taken (1) <input type="text"/> Additional Action Taken (2) <input type="text"/> Additional Action Taken (3) <input type="text"/>		<b>G1 Resources</b> <input type="checkbox"/> Check this box and skip this block if an Apparatus or Personnel Module is used. <div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <b>Suppression</b> Apparatus <input type="text"/> Personnel <input type="text"/>  <b>EMS</b> <input type="text"/> <input type="text"/>  <b>Other</b> <input type="text"/> <input type="text"/> </div> <div style="width: 50%;"> <b>G2 Estimated Dollar Losses and Values</b>            Required for all fires if known. Optional for non-fires.           <div style="display: flex; justify-content: space-between;"> <div> <b>LOSSES:</b>  <b>Property</b> \$ <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/>  <b>Contents</b> \$ <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/>  <b>PRE-INCIDENT VALUE:</b> Optional  <b>Property</b> \$ <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/>  <b>Contents</b> \$ <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> </div> <div style="text-align: right;"> <b>None</b> <input type="checkbox"/>  <input type="checkbox"/>  <input type="checkbox"/>  <input type="checkbox"/> </div> </div> </div> </div>	
<b>Completed Modules</b> <input type="checkbox"/> Fire-2 <input type="checkbox"/> Structure Fire-3 <input type="checkbox"/> Civilian Fire Cas.-4 <input type="checkbox"/> Fire Service Cas.-5 <input type="checkbox"/> EMS-6 <input type="checkbox"/> HazMat-7 <input type="checkbox"/> Wildland Fire-8 <input type="checkbox"/> Apparatus-9 <input type="checkbox"/> Personnel-10 <input type="checkbox"/> Arson-11		<b>H1 Casualties</b> <input type="checkbox"/> None <div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <b>Deaths</b> <input type="text"/> <input type="text"/>  <b>Injuries</b> <input type="text"/> <input type="text"/>  <b>Fire Service</b> <input type="text"/> <input type="text"/>  <b>Civilian</b> <input type="text"/> <input type="text"/> </div> <div style="width: 50%;"> <b>H2 Detector</b> Required for confined fires.            1 <input type="checkbox"/> Detector alerted occupants            2 <input type="checkbox"/> Detector did not alert them            U <input type="checkbox"/> Unknown         </div> </div>	
<b>H3 Hazardous Materials Release</b> <input type="checkbox"/> None 1 <input type="checkbox"/> Natural gas: slow leak, no evacuation or HazMat actions 2 <input type="checkbox"/> Propane gas: <21-lb tank (as in home BBQ grill) 3 <input type="checkbox"/> Gasoline: vehicle fuel tank or portable container 4 <input type="checkbox"/> Kerosene: fuel burning equipment or portable storage 5 <input type="checkbox"/> Diesel fuel/fuel oil: vehicle fuel tank or portable storage 6 <input type="checkbox"/> Household solvents: home/office spill, cleanup only 7 <input type="checkbox"/> Motor oil: from engine or portable container 8 <input type="checkbox"/> Paint: from paint cans totaling <55 gallons 0 <input type="checkbox"/> Other: special HazMat actions required or spill > 55 gal (Please complete the HazMat form.)		<b>I Mixed Use</b> <input type="checkbox"/> Not mixed <b>Property</b> 10 <input type="checkbox"/> Assembly use 20 <input type="checkbox"/> Education use 33 <input type="checkbox"/> Medical use 40 <input type="checkbox"/> Residential use 51 <input type="checkbox"/> Row of stores 53 <input type="checkbox"/> Enclosed mall 58 <input type="checkbox"/> Business & residential 59 <input type="checkbox"/> Office use 60 <input type="checkbox"/> Industrial use 63 <input type="checkbox"/> Military use 65 <input type="checkbox"/> Farm use 00 <input type="checkbox"/> Other mixed use	
<b>J Property Use</b> <input type="checkbox"/> None <b>Structures</b> 131 <input type="checkbox"/> Church, place of worship 161 <input type="checkbox"/> Restaurant or cafeteria 162 <input type="checkbox"/> Bar/tavern or nightclub 213 <input type="checkbox"/> Elementary school, kindergarten 215 <input type="checkbox"/> High school, junior high 241 <input type="checkbox"/> College, adult education 311 <input type="checkbox"/> Nursing home 331 <input type="checkbox"/> Hospital <b>Outside</b> 124 <input type="checkbox"/> Playground or park 655 <input type="checkbox"/> Crops or orchard 669 <input type="checkbox"/> Forest (timberland) 807 <input type="checkbox"/> Outdoor storage area 919 <input type="checkbox"/> Dump or sanitary landfill 931 <input type="checkbox"/> Open land or field		341 <input type="checkbox"/> Clinic, clinic-type infirmary 342 <input type="checkbox"/> Doctor/dentist office 361 <input type="checkbox"/> Prison or jail, not juvenile 419 <input type="checkbox"/> 1- or 2-family dwelling 429 <input type="checkbox"/> Multifamily dwelling 439 <input type="checkbox"/> Rooming/boarded house 449 <input type="checkbox"/> Commercial hotel or motel 459 <input type="checkbox"/> Residential, board and care 464 <input type="checkbox"/> Dormitory/barracks 519 <input type="checkbox"/> Food and beverage sales 936 <input type="checkbox"/> Vacant lot 938 <input type="checkbox"/> Graded/cared for plot of land 946 <input type="checkbox"/> Lake, river, stream 951 <input type="checkbox"/> Railroad right-of-way 960 <input type="checkbox"/> Other street 961 <input type="checkbox"/> Highway/divided highway 962 <input type="checkbox"/> Residential street/driveway 539 <input type="checkbox"/> Household goods, sales, repairs 571 <input type="checkbox"/> Gas or service station 579 <input type="checkbox"/> Motor vehicle/boat sales/repairs 599 <input type="checkbox"/> Business office 615 <input type="checkbox"/> Electric-generating plant 629 <input type="checkbox"/> Laboratory/science laboratory 700 <input type="checkbox"/> Manufacturing plant 819 <input type="checkbox"/> Livestock/poultry storage (barn) 882 <input type="checkbox"/> Non-residential parking garage 891 <input type="checkbox"/> Warehouse 981 <input type="checkbox"/> Construction site 984 <input type="checkbox"/> Industrial plant yard <div style="margin-top: 10px;">           Look up and enter a Property Use code and description only if you have NOT checked a Property Use box.  <div style="display: flex; align-items: center;"> <div style="flex: 1;"> <b>Property Use</b> <input type="text"/> </div> <div style="flex: 1; text-align: right;"> <b>Code</b> <input type="text"/> </div> </div> </div>	

FIGURE A.8.1(a) NFIRS-1, Basic Reporting Form.

<b>K1 Person/Entity Involved</b>		<div style="display: flex; justify-content: space-between;"> <span>Local Option</span> <span>Business Name (if applicable)</span> <span>Area Code</span> <span>Phone Number</span> </div>	
<input type="checkbox"/> Check this box if same address as incident Location (Section B). Then skip the three duplicate address lines.	<div style="display: flex; justify-content: space-between;"> <span>Mr., Ms., Mrs.</span> <span>First Name</span> <span>MI</span> <span>Last Name</span> <span>Suffix</span> </div> <div style="display: flex; justify-content: space-between; margin-top: 5px;"> <span>Number</span> <span>Prefix</span> <span>Street or Highway</span> <span>Street Type</span> <span>Suffix</span> </div> <div style="display: flex; justify-content: space-between; margin-top: 5px;"> <span>Post Office Box</span> <span>Apt./Suite/Room</span> <span>City</span> </div> <div style="display: flex; justify-content: space-between; margin-top: 5px;"> <span>State</span> <span>ZIP Code</span> </div>		
<input type="checkbox"/> More people involved? Check this box and attach Supplemental Forms (NFIRS-1S) as necessary.			

  

<b>K2 Owner</b>		<div style="display: flex; justify-content: space-between;"> <span>Local Option</span> <span>Business Name (if applicable)</span> <span>Area Code</span> <span>Phone Number</span> </div>	
<input type="checkbox"/> Same as person involved? Then check this box and skip the rest of this block.	<div style="display: flex; justify-content: space-between;"> <span>Mr., Ms., Mrs.</span> <span>First Name</span> <span>MI</span> <span>Last Name</span> <span>Suffix</span> </div> <div style="display: flex; justify-content: space-between; margin-top: 5px;"> <span>Number</span> <span>Prefix</span> <span>Street or Highway</span> <span>Street Type</span> <span>Suffix</span> </div> <div style="display: flex; justify-content: space-between; margin-top: 5px;"> <span>Post Office Box</span> <span>Apt./Suite/Room</span> <span>City</span> </div> <div style="display: flex; justify-content: space-between; margin-top: 5px;"> <span>State</span> <span>ZIP Code</span> </div>		

  

<div style="border: 1px solid black; padding: 2px; width: 20px; margin: 0 auto;">L</div>	<div style="border: 1px solid black; padding: 2px;"> <b>Remarks:</b>          Local Option       </div>	<div style="border: 1px solid black; padding: 5px; margin-top: 20px;"> <b>Fire Module Required?</b>          Check the box that applies and then complete the Fire Module based on Incident Type, as follows:         <table style="width: 100%; border-collapse: collapse; margin-top: 5px;"> <tr> <td style="width: 50%; vertical-align: top;"> <input type="checkbox"/> Buildings 111  <input type="checkbox"/> Special structure 112  <input type="checkbox"/> Confined 113-118  <input type="checkbox"/> Mobile property 120-123  <input type="checkbox"/> Vehicle 130-138  <input type="checkbox"/> Vegetation 140-143  <input type="checkbox"/> Outside rubbish fire 150-155  <input type="checkbox"/> Special outside fire 160  <input type="checkbox"/> Special outside fire 161-163  <input type="checkbox"/> Crop fire 170-173           </td> <td style="width: 50%; vertical-align: top;">             Complete Fire &amp; Structure Modules              Complete Fire Module &amp; Section I, Structure Module              Basic Module Only              Complete Fire Module              Complete Fire Module              Complete Fire or Wildland Module              Basic Module Only              Complete Fire or Wildland Module              Complete Fire Module              Complete Fire or Wildland Module           </td> </tr> </table> </div>	<input type="checkbox"/> Buildings 111 <input type="checkbox"/> Special structure 112 <input type="checkbox"/> Confined 113-118 <input type="checkbox"/> Mobile property 120-123 <input type="checkbox"/> Vehicle 130-138 <input type="checkbox"/> Vegetation 140-143 <input type="checkbox"/> Outside rubbish fire 150-155 <input type="checkbox"/> Special outside fire 160 <input type="checkbox"/> Special outside fire 161-163 <input type="checkbox"/> Crop fire 170-173	Complete Fire & Structure Modules Complete Fire Module & Section I, Structure Module Basic Module Only Complete Fire Module Complete Fire Module Complete Fire or Wildland Module Basic Module Only Complete Fire or Wildland Module Complete Fire Module Complete Fire or Wildland Module
<input type="checkbox"/> Buildings 111 <input type="checkbox"/> Special structure 112 <input type="checkbox"/> Confined 113-118 <input type="checkbox"/> Mobile property 120-123 <input type="checkbox"/> Vehicle 130-138 <input type="checkbox"/> Vegetation 140-143 <input type="checkbox"/> Outside rubbish fire 150-155 <input type="checkbox"/> Special outside fire 160 <input type="checkbox"/> Special outside fire 161-163 <input type="checkbox"/> Crop fire 170-173	Complete Fire & Structure Modules Complete Fire Module & Section I, Structure Module Basic Module Only Complete Fire Module Complete Fire Module Complete Fire or Wildland Module Basic Module Only Complete Fire or Wildland Module Complete Fire Module Complete Fire or Wildland Module			
<div style="display: flex; align-items: center;"> <div>             ITEMS WITH A ★ MUST ALWAYS BE COMPLETED!           </div> </div>		<input type="checkbox"/> More remarks? Check this box and attach Supplemental Forms (NFIRS-1S) as necessary.		

  

<b>M Authorization</b>	
Check box if same as Officer in charge. <input type="checkbox"/>	<div style="display: flex; justify-content: space-between;"> <div>             Officer in charge ID              Member making report ID           </div> <div>             Signature              Signature           </div> <div>             Position or rank              Position or rank           </div> <div>             Assignment              Assignment           </div> <div>             Month              Month           </div> <div>             Day              Day           </div> <div>             Year              Year           </div> </div>

FIGURE A.8.1(a) Continued

**FIGURE A.8.1(b) NFIRS-8, Wildland Fire Reporting Form.**



## Annex B Air Operations for Wildland Fire Incidents

*This annex is not a part of the requirements of this NFPA document but is included for informational purposes only.*

**B.1 General.** This annex presents fundamental information for agencies and organizations desiring to use aircraft for any and all aspects of wildland fire prevention, detection, and suppression. It presents necessary and useful information on procedures, practices, organization, and management, as well as suggested policy.

**B.1.1 Aircraft Uses.** Many agencies and organizations in different countries use aircraft for reconnaissance, fire detection, fire suppression, fuel management, and coordination of ground control forces.

**B.1.2 Definitions of Aeronautical and Air Operations Terminology.**

**B.1.2.1 Abort.** An order to terminate a preplanned aircraft maneuver (e.g., abort takeoff, abort retardant drop run).

**N B.1.2.2 Aerial Supervision Module (ASM).** A module that serves as a lead plane with an ATGS

**B.1.2.3 AGL.** Above ground level.

**B.1.2.4 Air Attack.** An operation involving the use of aircraft as part of the fire suppression action.

**Δ B.1.2.5 Air Tactical Group Supervisor (ATGS).** The officer in tactical command of all aircraft operating at an incident and who could be in charge from the air.

**B.1.2.6 Air Traffic.** Aircraft operating in the air or on an airport surface, exclusive of loading ramps and parking areas.

**B.1.2.7 Airtanker.** A fixed-wing aircraft equipped to drop fire retardants or fire suppressants.

**B.1.2.8 Airtanker Coordinator/Birddog Pilot/Lead Plane Pilot.** The pilot of the control aircraft, working under supervision of the air tactical group supervisor (ATGS), who designates targets of retardant drops and coordinates the movement of airtankers.

**B.1.2.9 Autorotation.** A nonpowered flight condition, with the rotor system maintaining the required flight rpm at a given forward airspeed. Autorotation is due to the relative wind upward through the rotors, caused by the weight, forward speed, and descent of the helicopter.

**Δ B.1.2.10 Birddog/Air Tactical Group Supervisor (ATGS).** The individual in charge of air operations over a fire.

**B.1.2.11 Break.** Weak or missed area in retardant or suppressant drop.

**B.1.2.12 Bucket.** A specialized container carried by the helicopter like a sling load and used to drop retardants or suppressants.

**B.1.2.13 Candling.** See B.1.2.69, Torching.

**B.1.2.14 Canopy.** The uppermost layer of tree foliage.

**B.1.2.15 Chicot (French).** See B.1.2.64, Snag.

**B.1.2.16 Crown Fire.** Fire traveling in the upper foliage of standing timber.

**B.1.2.17 Density Altitude.** Pressure altitude for ambient temperature. In standard International Civil Aviation Organization (ICAO) atmosphere, density and pressure altitude are equal. For a given pressure altitude, the higher the temperature, the higher the density altitude.

**B.1.2.18 Direct Attack.** A drop with the main portion of retardant or suppressant falling on the flame front.

**B.1.2.19 Down Loading.** The reduction in aircraft gross weight made to compensate for loss of performance due to increase in density altitude.

**B.1.2.20 Dozer Line.** A physical fire break made by dozers or tractor plows.

**B.1.2.21 Drift.** The effect of wind or smoke on retardant/suppressant drop.

**B.1.2.22 Drop Accuracy.** The assessment of a drop (i.e., where a load lands in relation to the target) made by the air tactical group supervisor or a fireline supervisor.

**N B.1.2.23 Drop Height.** The vertical distance between the aircraft and the canopy. The appropriate drop height is the height at which the forward motion of the agent ceases when it reaches the canopy.

**B.1.2.24 Drop Sequence.** The order and method in which the tanks are released.

**B.1.2.25 Drop Zone.** Drop target area.

**B.1.2.26 Dry Run.** A simulated retardant or suppressant run made on a target by the birddog, lead plane, or airtanker. Used to indicate approach and target to airtanker and to check for flight hazards.

**B.1.2.27 Early.** Landing before the target. Retardant/suppressant dropped before the target is reached. Sometimes referred to as *short*.

**B.1.2.28 Elevation.** The elevation of the lead plane or the birddog when it is over the target on a dry run.

**B.1.2.29 ETA.** Estimated time of arrival.

**B.1.2.30 ETD.** Estimated time of departure.

**B.1.2.31 Final.** That portion of the flight path that is aligned with the retardant/suppressant drop line.

**B.1.2.32 Flank.** Side of a fire joining base or rear to head.

**B.1.2.33 Ground Effect.** Reaction of the wing or rotor downwash against ground surface, forming a "ground cushion" that increases lifting capability of that section of air.

**B.1.2.34 Ground Fire.** Fire in duff, ground debris, or low-growing vegetation.

**B.1.2.35 Head.** The side of the fire having the fastest rate of spread.

**B.1.2.36 Heading.** The compass direction in which the longitudinal axis of an aircraft points.

**B.1.2.37 Helibase.** Location for parking, fueling, and maintenance of helicopters within the general area of an incident.

**B.1.2.38 Helibase Manager.** The officer responsible for managing resources/supplies at a helibase, heliport, or heli-spot.



**B.1.2.39 Helibucket.** See B.1.2.12, Bucket.

**B.1.2.40 Helicopter Coordinator.** With instructions from the air tactical group supervisor (ATGS), the person responsible for coordinating tactical or logistical mission(s) by helicopters assigned to an incident.

**B.1.2.41 Heliport.** A designated landing area that is accessible by road and large enough to accommodate, at a minimum, two helicopters. It should have fueling facilities, a wind indicator, fire extinguishers, surfaced pads, tie-downs, parking areas, a water source, telephone and radio communications, officers for base personnel, pilots' rest areas, and lights.

**B.1.2.42 Helispot.** Location where a helicopter can land and take off.

**B.1.2.43 Helitack.** The initial attack phase of fire suppression using helicopters and trained airborne teams to achieve immediate control of wildland fire in a safe and economical manner.

**B.1.2.44 Helitack Crew Member.** A fire fighter trained in the use of helicopter accessories and in techniques to attack and suppress wildland fire.

△ **B.1.2.45 Helitack Supervisor.** The person in charge of a helitack crew.

**B.1.2.46 Helitank.** A tank that is attached to a helicopter and used to carry liquids such as suppressants or retardants.

**B.1.2.47 Hot Spot.** An active part of a fire within or along the fire boundary.

**B.1.2.48 Incident Commander (IC).** The chief of an incident management team under the ICS.

**B.1.2.49 Incident Command System (ICS).** Qualifying and organizing personnel to manage wildland fires or other incidents.

**B.1.2.50 Initial Attack.** The first action taken to suppress a fire, whether it be ground or air attack.

**B.1.2.51 Knot.** Nautical mile per hour.

**B.1.2.52 Late Drop.** Retardant or suppressant landing beyond the target.

**B.1.2.53 Line.** A stretch of retardant or suppressant laid by aircraft to support constructed line or to retard fire spread.

△ **B.1.2.54 Line Length.** The distance covered on the ground by a single retardant or suppressant drop at a given coverage level.

**B.1.2.55 "Load and Return."** An order to a pilot to return to airtanker base, reload, and return to the drop area.

**B.1.2.56 Low Drop.** A drop lower than recommended minimum drop height.

**B.1.2.57 Orbit.** The circular holding pattern an aircraft makes over one specific spot or area.

**B.1.2.58 Paracargo.** Cargo and equipment that is attached to parachutes for dropping from aircraft for support of ground crews.

△ **B.1.2.59 Parallel Attack.** An outside (indirect) attack parallel to and removed from the fire's edge. A parallel attack is used only with long-term retardants in an air attack operation.

**B.1.2.60 Restricted Air Space.** See B.1.2.68, Temporary Flight Restriction.

**B.1.2.61 Retardant, Long-Term.** Solution having a chemical retarding action on fire even after water content has evaporated.

**B.1.2.62 "Return and Hold."** An order to a pilot to return to base and wait for further instructions; denotes mission completed and further loads not required.

**B.1.2.63 Salvo.** The dropping of the entire retardant or suppressant load at one time.

**B.1.2.64 Snag.** Any dead or living tree rising above the forest canopy.

**B.1.2.65 Split Load.** A drop sequence wherein the load is dropped in increments.

**B.1.2.66 Spot Fire.** A fire outside or ahead of the main fire boundary.

**B.1.2.67 Suppressants.** Agents (i.e., water or foam) used to extinguish the flaming and glowing phases of combustion by direct application to burning fuels.

**B.1.2.68 Temporary Flight Restriction (TFR).** Special use airspace obtained under U.S. Federal Aviation Regulations, Part 91.137, for the use of air attack or other incident aircraft.

**B.1.2.69 Torching.** The burning of the foliage of a single tree, or a small group of trees, from the bottom up.

**B.1.2.70 Traffic Pattern.** The traffic flow that is prescribed for aircraft landing at, taxiing on, and taking off from an airport. The usual components of a traffic pattern are upwind leg, crosswind leg, base leg, and final approach.

△ **B.1.2.71 Trail Drop.** To drop retardant to give an extended pattern on the ground.

**B.1.2.72 Weather Advisory.** In aviation forecast practice, an expression of hazardous weather conditions not predicted in the area forecast, as they affect the operation of air traffic and as prepared by the National Weather Service.

**B.1.2.73 Wetting Agent.** Chemical added to water to reduce surface tension.

## **B.2 Aircraft and Equipment Suitability and Selection.**

### **B.2.1 Fixed-Wing Aircraft.**

△ **B.2.1.1 Detection, Reconnaissance, and Survey.** Small airplanes (single- and multi-engine) are used for detection, reconnaissance, and surveys. Airplanes for fire reconnaissance are used in combination with ground detection systems in areas of high fire occurrence. The use of aircraft for checking areas not visible from ground detection units is an accepted practice. Reconnaissance flights are scheduled following lightning storms. Flights to check "going" fires and controlled fires from previous days provide the latest information on conditions and progress.

Heat-sensing systems, known as forward-looking infrared (FLIR) systems, have been developed for use with small aircraft. These systems are feasible, and simplicity of operation warrants their consideration for detection and reconnaissance activities. With further development, the detection could be computerized.

Surveys of an area before and after a burn can provide a detailed review and study of an area that could otherwise be expensive and time consuming. Many times the measurement of burn areas can be accomplished with a minimal amount of flying time.

Small airplanes can be made available for other jobs in connection with wildland fire protection. It is standard practice for agencies and organizations that do not own their own aircraft to contract with a local fixed base operator (FBO) to provide the aircraft and pilot.

**Δ B.2.1.2 Paracargo and Freight.** Numerous types of small, medium, and large airplanes are used for transporting freight and dropping paracargo to fire camps or isolated crews. Not all airplanes are suitable for freight activities, and few can be modified into good paracargo aircraft. Most civilian airplanes now being used were designed and built for carrying passengers and require special modifications to be suitable for freight or paracargo work.

Desirable features for airfreight and paracargo airplanes are as follows: sufficient capacity, smooth floors, inherent stability, moderate or low stalling and landing speeds, suitable paracargo discharge aperture, ample reserve power at near gross weight (multi-engine), easy control under marginal flying conditions, good visibility, stripped utility interior, cargo tie-down facilities, and approved seats, seat belts, and shoulder harnesses.

**Δ B.2.1.3 Amphibious Operations.** Amphibious aircraft or float-equipped aircraft can be more versatile and serve more functions than land-based aircraft. This type of aircraft is used in Alaska and some parts of Canada and the contiguous United States where suitable lakes and rivers are numerous and in coastal areas.

As long as adequate water depth and an unobstructed water surface area are maintained, little or no preparation other than suitable docking or ramp facilities is required for a water-based operation. If no safe natural docking or beaching site is available, temporary docks can be constructed to facilitate loading and unloading and to avoid damage to the aircraft.

Many amphibious aircraft are equipped to drop suppressants such as foam.

**B.2.1.4 Airtankers.** Aircraft selection for wildland fire suppression and related uses presents certain problems. The performance characteristics of the aircraft should be such that safe and efficient operations can be conducted over typical terrain and at necessary elevations. The aircraft integrity should be such that atmospheric conditions will not present a structural problem.

Light airtankers can be operated in a cost-effective manner as initial attack aircraft on wildland fires where the fires are within 30 mi (48 km) of the air attack base. These aircraft are also capable of support action and accurate low-volume drops in confined areas.

Medium, large, and very large airtankers with 2000 gal or more (7600 L or more) capacities, like the one shown in Figure B.2.1.4, are more cost-effective for long-range, high-volume cascading on fires and retardant fireline construction. This should not preclude the use of large airtankers at short range, because many times fires are contained or controlled by several high-volume cascading actions.



**FIGURE B.2.1.4 P2V-5F Airtanker.**

**B.2.2 Rotary-Wing Aircraft.** The helicopter has become a familiar multi-use fire-fighting aircraft in wildland fire suppression. This aircraft has become as necessary in today's fire suppression as hand tools, crews, tractors, smoke jumpers, engines, and airtankers.

**Δ B.2.2.1 Retardant and Suppressant Dropping.** The versatility and maneuvering capabilities of the helicopter make this aircraft an important initial attack tool. Helicopters with capacities for dropping 80 gal to 3000 gal (303 L to 11,356 L) of suppressants or retardants are principal weapons in the helitack phase of wildland fire suppression. Helicopters utilize two methods of dropping: a bucket slung underneath the helicopter or a fixed external tank.

**Δ B.2.2.2 Initial Attack Transport.** Helitack functions are designed to transport trained personnel to a fire in short time periods. Small crews, trained and equipped, can gain control of most incipient wildland fire situations if they can make fast initial attack. This can be accomplished by landing or rappelling near the fire.

**Δ B.2.2.3 Reconnaissance and Scouting.** Performance characteristics of the helicopter make it an excellent reconnaissance and scouting aircraft. Slow speed and the ability to operate in areas that could not be observed from fixed-wing aircraft, plus its usefulness in providing terrain and fire intelligence that otherwise could not be obtainable, are obvious benefits. Helicopters provide an ideal platform for using heat-sensing and mapping systems. The systems range from handheld units to mounted units.

**B.2.2.4 Shuttling Equipment and Personnel.** Equipment can be moved to other fire areas by heliport to heliport or, where landings cannot be accomplished in a safe manner, by paracargo or sling load methods. Personnel (fire crews, helitack personnel, and others) can be airlifted as conditions warrant. Food and water can be delivered to line crews, and spike camps can be supported in this manner.

**B.2.2.5 Rescue.** Helicopters are an essential part of many rescue operations. The following are some uses:

- (1) Airlifting medical personnel to care for and move injured persons to medical aid sites or hospitals
- (2) Scouting and directing rescue crews
- (3) Servicing isolated parties until rescue can be accomplished